

CONSUMER NOTICE OF TAP WATER RESULTS

Contact us at 609-893-8141 to obtain a translated copy of the public education materials or to request assistance in the appropriate language.

05/08/2026

Dear Consumers,

As you may know, Early Childhood Center is also a public water system because we are responsible for providing you with water at this location and ensuring that the drinking water we provide meets state and federal standards. We collected a drinking water sample for lead in our building(s) at 20 locations on 04/23/2026. Below please find a chart illustrating the sampling locations and their results.

| Sample Location | Result in mg/l |
|----------------------|----------------|
| Main office sink | <0.00100 mg/l |
| Main office bathroom | <0.00100 mg/l |
| Nurse Bathroom sink | 0.00138 mg/l |
| Kitchen 3 bowl sink | <0.00100 mg/l |
| Kitchen 2 bowl sink | <0.00100 mg/l |
| Cafeteria fountain | <0.00100 mg/l |
| Room A1 sink | <0.00100 mg/l |
| Room A4 sink | <0.00100 mg/l |
| Room B8 sink | <0.00100 mg/l |
| Room B1 sink | <0.00100 mg/l |
| Library sink | 0.00371 mg/l |
| Room C2 sink | <0.00100 mg/l |
| Room C10 sink | 0.00102 mg/l |
| Room C13 sink | <0.00100 mg/l |
| Room D6 sink | <0.00100 mg/l |
| Roo D1 sink | <0.00100 mg/l |
| Room D12 sink | <0.00100 mg/l |
| Room D10 sink | <0.00100 mg/l |
| Room A7 sink | <0.00100 mg/l |
| Nurse sink | <0.00100 mg/l |

We are happy to report that the 90th percentile value for our water system is below the lead action level of 0.015 mg/l. *[EPA recommends that the 90th percentile level be included, if known prior to the delivery deadline.]*