CONSUMER NOTICE OF TAP WATER RESULTS

Contact us at 609-893-8141 to obtain a translated copy of the public education materials or to request assistance in the appropriate language.

05/08/2026

Dear Consumers,

As you may know, Marcus Newcomb Middle School is also a public water system because we are responsible for providing you with water at this location and ensuring that the drinking water we provide meets state and federal standards. We collected a drinking water sample for lead in our building(s) at 10 locations on 04/23/2026. Below please find a chart illustrating the sampling locations and their results.

Sample Location	Result in mg/l
Main office bathroom	0.00111 mg/l
Fountain room 212	<0.00100 mg/l
Fountain boiler room	<0.00100 mg/l
Kitchen mop sink	0.00801 mg/l
Kitchen 2 bowl sink	0.00127 mg/l
Kitchen bathroom sink	<0.00100 mg/l
200 boys' bathroom left	0.00105 mg/l
200 girls' bathroom left	<0.00100 mg/l
300 wing fountain	0.00139 mg/l

We are happy to report that the 90th percentile value for our water system is below the lead action level of 0.015 mg/l. *[EPA recommends that the 90th percentile level be included, if known prior to the delivery deadline.]*