



POCATELLO/CHUBBUCK SCHOOL DISTRICT 25
LEARNING TODAY FOR THE POSSIBILITIES OF TOMORROW

**Administration Offices
3115 Pole Line Road
Pocatello, Idaho 83201**

Addendum No. 1

May 11, 2026

RE: 2026 Security Camera Replacement at Various District Sites (REBID)
FROM: Business Services
(208) 235-3270

This Addendum becomes a part of the Contract Documents and modifies the original Bidding Specifications, as noted below. This addendum consists of one (1) page. You must acknowledge the Addendum on the Bid Proposal sheet. **Failure to acknowledge Addendum(s) on the bid sheet may subject the bidder to disqualification.**

REQUIREMENTS FOR REPLACEMENT OF SECURITY EQUIPMENT AT VARIOUS BUILDINGS

- 1. On page 3 of the specification, the following clarification refers to item number two (2), Low Light/Night Vision: IR with at least 100 ft range:

All cameras are to have IR range of 10M except for fish eye cameras as they do not need IR.

- 2. On page 10 of the specification under **BID OPTIONS**, the following changes need to be made:
To be deleted:

Install OpenEye only.

To replace with:

Any ONVIF camera is allowed as long as it works with our current OpenEye NVR.
OpenEye servers to be configured for thirty (30) days of onboard storage.

Please see page 3 of the specification for further clarification regarding ONVIF.

NO OTHER CHANGES
END OF ADDENDUM No. 1 – May 11, 2026, js