

May 13, 2026


HMC Architects Project No. 3431010000

DSA File and Application No. 39-50 / 02-123780

PTN: 6858-296

ADDENDUM NO. 3

LUSD - District Office Server Room Modifications
1305 East Vine Street, Lodi, CA 95240



HMC Architects

1. ALL WORKMANSHIP, MATERIALS, APPLIANCES AND EQUIPMENT which may be included in the following items shall be the same relative quantity as described for similar work set forth in the original or main specifications of which these Addendum items shall be considered a part.
2. ADDENDUM SECTIONS (included with this Addendum)
The following modify or supplement the issued bid documents. NONE
3. ADDENDUM DRAWINGS (included with this Addendum)
The following modify or supplement the issued bid documents. NONE
4. PROJECT MANUAL
NONE
5. DRAWINGS
NONE

6. BID QUESTIONS

- A. Fire Sprinkler System - Field Installation: What are the working days and hours for the fire sprinkler system field installation?

Response: Regular working days and hours for most work. If any work has excessive noise, it should be coordinated with the District for outside of these hours.

- B. Fire Sprinkler System - Working Days/Hrs: What are the working days and hours for the fire sprinkler system survey above the ceilings throughout the first floor?

Response: Regular working days and hours for most work. If any work has excessive noise, it should be coordinated with the District for outside of these hours.

- C. Fire Sprinkler System - Plans: Is the as-built fire sprinkler system overhead and underground plans available to the successful general contractor?

Response: Yes, these will be made available.

- D. Fire Sprinkler System - Location: Is the intent of the scope of work at the end of the project that no fire sprinkler system piping and fire sprinklers heads are to be located above and/or below the ceiling in Server Room 1-17?

Response: At the end of the job there will be no fire sprinkler that would be able to put water on the server rack.

- E. Fire Sprinkler System - Elect Rm 1-15: This question was asked regarding Addendum 1 Section 5 Item 1c...What completed spaces are being referred to? Fire sprinkler head wise it should only be Electrical Room 1-15, correct?

Response: Completed spaces refer to the entire area of work.

- F. Fire Sprinkler System - Contractor Responsibility: The fire sprinkler contractor is responsible for submitting plans and obtaining a permit for the fire sprinkler work as shown on the bid documents, correct?

Response: It will be the responsibility of the selected contractor to prepare and submit shop drawings and other information to the city to obtain the permit.

* * * END OF ADDENDUM * * *