



Environmental Control Systems, Inc.

Environmental Engineers and Management Consultants

May 14, 2026

Mr. Jake Gallagher
Director of Operations
Marple Newtown School District
38 Media Line Road
Newtown Square, Pennsylvania 19073

Re: Lead in Drinking Water Sampling Results

Dear Mr. Gallagher:

Various drinking water outlets in the Marple Newtown School District were tested for Lead in Drinking Water on April 21, 2026. Samples were collected from outlets in accordance with EPA protocol listed in the 3T's for Reducing Lead in Drinking Water in Schools, revised October 2018.

The analysis was performed by EMSL Analytical, Cinnaminson, NJ, an EPA accredited laboratory. Results are based on EPA recommended action level which is 15 ppb for lead in schools based on a 250 ml sample analysis method for Metals by ICP-MS-EPA 200.8.

The results from various outlets tested are Non-Detect which is under the PA Act 39, EPA action limit of 15 ppb. Lead in Drinking Water Testing fulfills your 2025-2026 obligation Under PA Act 39 of 2018, to test for or discuss lead levels annually in the drinking water of any facility where children attend school.

Please let us know if you have any questions.

Cordially,

Barbara Lippmann
President