NOTIFICATION APPLIANCE SUPPLEMENTARY RECORD OF INSPECTION AND TESTING

This form is a supplement to the System Record of Inspection and Testing.
It includes a notification appliance test record.
This form is to be completed by the system inspection and testing contractor at the time of the inspection and/or test.
It shall be permitted to modify this form as needed to provide a more complete and/or clear record.
Insert N/A in all unused lines.

Inspection/Test Start Date/Time: 1/30/25 2:30PM Inspection/Test Completion Date/Time: 1/31/25 8:00 PM

Number of Supplemental Pages Attached: _____

1. PROPERTY INFORMATION

Name of property: [redacted]

Address: [redacted]

2. NOTIFICATION APPLIANCE TEST RESULTS

Appliance Type	Location/Identifier	Test Results
SPEAKER STROBE	ROOM B1	Pass
SPEAKER STROBE	ROOM B2	Pass
SPEAKER STROBE	ROOM B3	Pass
SPEAKER STROBE	BLDG B GIRL R.R	Pass
SPEAKER STROBE	ROOM B4	Pass
SPEAKER STROBE	ROOM B5	Pass
SPEAKER STROBE	BLDG B BOY RR	Pass
SPEAKER STROBE	RM B6	Pass
SPEAKER STROBE	RM B7	Pass
SPEAKER STROBE	RM B8	Pass
SPEAKER STROBE	RM B9	Pass
SPEAKER STROBE	LIBRARY	Pass
SPEAKER STROBE	WOMENS R.R.	Pass
SPEAKER STROBE	MENS R.R.	Pass
SPEAKER STROBE	PORTABLE P.1	Pass
SPEAKER STROBE	PORTABLE P.2	Pass
SPEAKER STROBE	PORTABLE P.3	Pass
SPEAKER STROBE	PORTABLE P.4	Pass
SPEAKER STROBE	PORTABLE P.5	Pass
SPEAKER STROBE	PORTABLE P.6	Pass

© 2015 National Fire Protection Association

FIGURE 7.8.2(h) Notification Appliance Supplementary Record of Inspection and Testing. (SIG-TMS)

NOTIFICATION APPLIANCE SUPPLEMENTARY RECORD OF INSPECTION AND TESTING *(continued)*

2. NOTIFICATION APPLIANCE TEST RESULTS *(continued)*

Appliance Type	Location/Identifier	Test Results
SPEAKER STROBE	PORTABLE P.7	Pass
SPEAKER STROBE	ADMIN CONFERENCE RM.	Pass
SPEAKER STROBE	ADMIN WORKROOM	Pass
STROBE ONLY	STAFF RESTROOM	Pass
SPEAKER STROBE	ADMIN LOBBY	Pass
STROBE ONLY	NURSE RESTROOM	Pass
SPEAKER STROBE	K1	Pass
SPEAKER STROBE	KINDER WORKROOM	Pass
STROBE ONLY	K1 BOYS RESTROOM	Pass
STROBE ONLY	K2 GIRLS RESTROOM	Pass
SPEAKER STROBE	K2	Pass
STROBE ONLY	WOMENS RESTROOM MPR	Pass
STROBE ONLY	MENS RESTROOM MPR	Pass
SPEAKER STROBE	EAST_FOYER MPR	Pass
SPEAKER STROBE	KITCHEN	Pass
SPEAKER STROBE	CLASSROOM A5	Pass
SPEAKER STROBE	CLASSROOM A4	Pass
SPEAKER STROBE	BOYS RESTROOM	Pass
SPEAKER STROBE	GIRLS RESTROOM	Pass
SPEAKER STROBE	CLASSROOM A3	Pass
SPEAKER STROBE	CLASSROOM A2	Pass
SPEAKER STROBE	STAFF LOUNGE	Pass
SPEAKER STROBE	CLASSROOM A6	Pass
SPEAKER STROBE	CLASSROOM A7	Pass
SPEAKER STROBE	CLASSROOM A8	Pass
SPEAKER STROBE	A3 WORKROOM	Pass
SPEAKER STROBE	K3	Pass

See main System Record of Inspection and Testing for additional information, certifications, and approvals.

© 2015 National Fire Protection Association NFPA 72 (p. 2 of 2)

FIGURE 7.8.2(h) *Continued*

NOTIFICATION APPLIANCE SUPPLEMENTARY RECORD OF INSPECTION AND TESTING *(continued)*

2. NOTIFICATION APPLIANCE TEST RESULTS *(continued)*

Appliance Type	Location/Identifier	Test Results
STROBE ONLY	K3 GIRLS RESTROOM	Pass
STROBE ONLY	K3 BOYS RESTROOM	Pass
SPEAKER STROBE	K5	Pass
SPEAKER STROBE	K4	Pass
STROBE ONLY	K4 RESTROOM	Pass
SPEAKER STROBE	PORTABLE R1	Pass
STROBE ONLY	GIRLS RESTROOM R1	Pass
STROBE ONLY	BOYS RESTROOM R1	Pass
SPEAKER STROBE	PORTABLE R1 OFFICE	Pass
STROBE ONLY	R2 RESTROOM	Pass
SPEAKER STROBE	R2	Pass
SPEAKER STROBE	R3	Pass
SPEAKER STROBE	R4	Pass
SPEAKER STROBE	R5	Pass
SPEAKER STROBE	R6	Pass
SPEAKER STROBE	R7	Pass
		Pass
		Pass
		Pass
		Pass
		Pass
		Pass
		Pass
		Pass
		Pass
		Pass
		Pass

See main System Record of Inspection and Testing for additional information, certifications, and approvals.

© 2015 National Fire Protection Association NFPA 72 (p. 2 of 2)

FIGURE 7.8.2(h) *Continued*