



Hayward Unified School District
Purchasing Department
24411 Amador Street, Hayward, CA 94544

BID # 26.006
Tennyson High School Locker Rooms/Gym Floor Upgrades

Addendum #4 - May 18, 2026

(Total of #1 pages including attachments)

A. REQUEST FOR INFORMATION/OTHER

1	Question:	Who is to be providing the WAPs? If contractor, please specify what make and model
	Response:	OMM: Provide data outlet with 2 drops. WAP device is by the District.
2	Question:	Specs state technical requirements for Fiber Optics. We do not see any fiber optic cable described on drawings or other contract documents. Please advise.
	Response:	OMM: There is no new fiber optic run required
3	Question:	For low-voltage lighting and control, do low-voltage cables need to be in conduit surface mounted to devices?
	Response:	All low voltage lighting and control wire shall be installed in raceway except where wire is installed in an accessible space above the ceiling. Where walls or ceiling are opened, conduit and wire shall be concealed in wall or ceiling. Where raceway must be mounted on the wall or ceiling surface, low voltage lighting and control wire shall be installed in Wiremold surface raceway