



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 15, 2026

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: Eagle Rock Elem Lead Testing

Order No.: 26050145

Dear John Harding:

Neilson Research Corporation received 67 sample(s) on 5/5/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26050145
Date: 5/15/2026

CLIENT: Eagle Point School District #9
Project: Eagle Rock Elem Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-01 Client Sample ID: 057KF
 Collection Date: 5/5/2026 6:43:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 057KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.96		0.500	ppb	1	5/7/2026	15.0	A

Lab ID: 26050145-02 Client Sample ID: 058KF
 Collection Date: 5/5/2026 6:43:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 058KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.510		0.500	ppb	1	5/7/2026	15.0	A

Lab ID: 26050145-03 Client Sample ID: 059KF
 Collection Date: 5/5/2026 6:44:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 059KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.12		0.500	ppb	1	5/7/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-04 Client Sample ID: 060KF
 Collection Date: 5/5/2026 6:45:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 060KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.59		0.500	ppb	1	5/7/2026	15.0	A

Lab ID: 26050145-05 Client Sample ID: 061KF
 Collection Date: 5/5/2026 6:46:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 061KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.68	1	0.500	ppb	1	5/7/2026	15.0	A

Lab ID: 26050145-06 Client Sample ID: 046CF
 Collection Date: 5/5/2026 6:50:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 046CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/7/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-07 Client Sample ID: 047DW
 Collection Date: 5/5/2026 6:51:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 047DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.74		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-08 Client Sample ID: 068DW
 Collection Date: 5/5/2026 6:55:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 068DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-09 Client Sample ID: 036CF
 Collection Date: 5/5/2026 6:55:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 036CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-10 Client Sample ID: 037DW
 Collection Date: 5/5/2026 6:56:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 037DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.516		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-11 Client Sample ID: 001CF
 Collection Date: 5/5/2026 5:36:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 001CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-12 Client Sample ID: 002DW
 Collection Date: 5/5/2026 5:37:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 002DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.19	1	0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-13 Client Sample ID: 049CF
 Collection Date: 5/5/2026 5:41:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 049CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.902		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-14 Client Sample ID: 003CF
 Collection Date: 5/5/2026 5:43:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 003CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.44		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-15 Client Sample ID: 004DW
 Collection Date: 5/5/2026 5:43:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 004DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.25		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-16 Client Sample ID: 005CF
 Collection Date: 5/5/2026 5:47:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 005CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-17 Client Sample ID: 006DW
 Collection Date: 5/5/2026 5:47:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 006DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-18 Client Sample ID: 007CF
 Collection Date: 5/5/2026 5:49:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 007CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-19 Client Sample ID: 008DW
 Collection Date: 5/5/2026 5:45:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 008DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-20 Client Sample ID: 009CF
 Collection Date: 5/5/2026 5:52:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 009CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-21 Client Sample ID: 010DW
 Collection Date: 5/5/2026 5:53:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 010DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-22 Client Sample ID: 011CF
 Collection Date: 5/5/2026 5:54:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 011CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-23 Client Sample ID: 012DW
 Collection Date: 5/5/2026 5:56:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 012DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.57		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-24 Client Sample ID: 013BF
 Collection Date: 5/5/2026 5:56:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 013BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-25 Client Sample ID: 014BF
 Collection Date: 5/5/2026 5:57:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 014BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.20		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-26 Client Sample ID: 015BF
 Collection Date: 5/5/2026 5:58:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 015BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-27 Client Sample ID: 016BF
 Collection Date: 5/5/2026 5:59:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 016BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.521		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-28 Client Sample ID: 017WB
 Collection Date: 5/5/2026 6:01:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 017WB

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-29 Client Sample ID: 018DW
 Collection Date: 5/5/2026 6:02:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 018DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-30 Client Sample ID: 019BF
 Collection Date: 5/5/2026 6:03:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 019BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.659		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-31 Client Sample ID: 020BF
 Collection Date: 5/5/2026 6:06:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 020BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.33		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-32 Client Sample ID: 021BF
 Collection Date: 5/5/2026 6:06:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 021BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-33 Client Sample ID: 022CF
 Collection Date: 5/5/2026 6:09:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 022CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-34 Client Sample ID: 023DW
 Collection Date: 5/5/2026 6:10:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 023DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-35 Client Sample ID: 024CF
 Collection Date: 5/5/2026 6:12:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 024CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.50		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-36 Client Sample ID: 025DW
 Collection Date: 5/5/2026 6:12:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 025DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.747		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-37 Client Sample ID: 026CF
 Collection Date: 5/5/2026 6:14:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 026CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-38 Client Sample ID: 027DW
 Collection Date: 5/5/2026 6:15:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 027DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-39 Client Sample ID: 028CF
 Collection Date: 5/5/2026 6:15:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 028CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-40 Client Sample ID: 050CF
 Collection Date: 5/5/2026 6:19:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 050CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.00		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-41 Client Sample ID: 034CF
 Collection Date: 5/5/2026 6:58:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 034CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.531		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-42 Client Sample ID: 035DW
 Collection Date: 5/5/2026 6:59:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 035DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-43 Client Sample ID: 032CF
 Collection Date: 5/5/2026 7:00:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 032CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-44 Client Sample ID: 033DW
 Collection Date: 5/5/2026 7:04:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 033DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-45 Client Sample ID: 030CF
 Collection Date: 5/5/2026 7:01:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 030CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.66		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-46 Client Sample ID: 031DW
 Collection Date: 5/5/2026 7:01:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 031DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.51		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-47 Client Sample ID: 042DW
 Collection Date: 5/5/2026 7:02:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 042DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.614		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-48 Client Sample ID: 041DW
 Collection Date: 5/5/2026 7:02:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 041DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.986		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-49 Client Sample ID: 038BF
 Collection Date: 5/5/2026 7:05:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 038BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-50 Client Sample ID: 039BF
 Collection Date: 5/5/2026 7:06:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 039BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.24		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-51 Client Sample ID: 051DW
 Collection Date: 5/5/2026 6:20:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 051DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.79		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-52 Client Sample ID: 065BF
 Collection Date: 5/5/2026 6:21:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 065BF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.763		0.500	ppb	1	5/13/2026	15.0	A	

Lab ID: 26050145-53 Client Sample ID: 052CF
 Collection Date: 5/5/2026 6:23:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 052CF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.512		0.500	ppb	1	5/13/2026	15.0	A	

Lab ID: 26050145-54 Client Sample ID: 053CF
 Collection Date: 5/5/2026 6:29:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 053CF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.839		0.500	ppb	1	5/13/2026	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-55 Client Sample ID: 054DW
 Collection Date: 5/5/2026 6:29:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 054DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.750		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-56 Client Sample ID: 064BF
 Collection Date: 5/5/2026 6:32:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 064BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.73		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-57 Client Sample ID: 055WB
 Collection Date: 5/5/2026 6:37:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 055WB

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-58 Client Sample ID: 056DW
 Collection Date: 5/5/2026 6:37:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 056DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-59 Client Sample ID: 063BF
 Collection Date: 5/5/2026 6:40:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 063BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-60 Client Sample ID: 062KF
 Collection Date: 5/5/2026 6:41:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 062KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.01		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-61 Client Sample ID: 040BF
 Collection Date: 5/5/2026 7:09:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 040BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-62 Client Sample ID: 043BF
 Collection Date: 5/5/2026 7:10:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 043BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.519		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-63 Client Sample ID: 044BF
 Collection Date: 5/5/2026 7:11:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 044BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.04		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-64 Client Sample ID: 045BF
 Collection Date: 5/5/2026 7:12:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 045BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-65 Client Sample ID: 048BF
 Collection Date: 5/5/2026 7:15:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 048BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.69		0.500	ppb	1	5/13/2026	15.0	A

Lab ID: 26050145-66 Client Sample ID: 029DW
 Collection Date: 5/5/2026 6:15:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 029DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050145
 Date Reported: 5/15/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050145
Received Date: 5/5/2026 9:45:00 AM
Reported Date: 5/15/2026 2:00:49 PM

Sample Information:

Lab ID: 26050145-67 Client Sample ID: 066BF
 Collection Date: 5/5/2026 6:24:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 066BF

Trace Metals by EPA 200.8 ICP-MS						Analyst: PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.500	ppb	1	5/13/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050145

15-May-26

Client: Eagle Point School District #9
Project: Eagle Rock Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36690	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/6/2026	RunNo: 69483						
Client ID: PBW	Batch ID: 36690	TestNo: E200.8	E200.8	Analysis Date: 5/7/2026	SeqNo: 1143437						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.500

Sample ID: LCS-36690	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/6/2026	RunNo: 69483						
Client ID: LCSW	Batch ID: 36690	TestNo: E200.8	E200.8	Analysis Date: 5/7/2026	SeqNo: 1143438						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 107 0.500 100 0 107 85 115

Sample ID: 26050089-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/6/2026	RunNo: 69483						
Client ID: BatchQC	Batch ID: 36690	TestNo: E200.8	E200.8	Analysis Date: 5/7/2026	SeqNo: 1143443						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.500 100 0.831 102 70 130

Sample ID: 26050089-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/6/2026	RunNo: 69483						
Client ID: BatchQC	Batch ID: 36690	TestNo: E200.8	E200.8	Analysis Date: 5/7/2026	SeqNo: 1143444						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 104 0.500 100 0.831 103 70 130 103 0.785 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050145

15-May-26

Client: Eagle Point School District #9
Project: Eagle Rock Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36765	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: PBW	Batch ID: 36765	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147030						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.500

Sample ID: LCS-36765	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: LCSW	Batch ID: 36765	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147031						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 100 0.505 100 0 100 85 115

Sample ID: 26050145-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: 010DW	Batch ID: 36765	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147033						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.6 0.505 100 0.220 98.4 70 130

Sample ID: 26050145-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: 010DW	Batch ID: 36765	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147034						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.505 100 0.220 100 70 130 98.6 2.08 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050145

15-May-26

Client: Eagle Point School District #9
Project: Eagle Rock Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36764	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: PBW	Batch ID: 36764	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147058						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.500

Sample ID: LCS-36764	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: LCSW	Batch ID: 36764	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147059						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.9 0.505 100 0 99.9 85 115

Sample ID: 26050145-07AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: 047DW	Batch ID: 36764	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147061						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.8 0.505 100 1.74 98.0 70 130

Sample ID: 26050145-07AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: 047DW	Batch ID: 36764	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147062						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.9 0.505 100 1.74 98.2 70 130 99.8 0.143 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050145

15-May-26

Client: Eagle Point School District #9
Project: Eagle Rock Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36766	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: PBW	Batch ID: 36766	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147086						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.500

Sample ID: LCS-36766	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: LCSW	Batch ID: 36766	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147087						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.3 0.505 100 0 99.3 85 115

Sample ID: 26050145-41AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: 034CF	Batch ID: 36766	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147089						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 100 0.505 100 0.531 99.5 70 130

Sample ID: 26050145-41AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2026	RunNo: 69658						
Client ID: 034CF	Batch ID: 36766	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147090						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 96.8 0.505 100 0.531 96.3 70 130 100 3.31 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050145

15-May-26

Client: Eagle Point School District #9
Project: Eagle Rock Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36776	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2026	RunNo: 69658						
Client ID: PBW	Batch ID: 36776	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147114						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.500

Sample ID: LCS-36776	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2026	RunNo: 69658						
Client ID: LCSW	Batch ID: 36776	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147115						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 102 0.500 100 0 102 85 115

Sample ID: 26050145-67AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2026	RunNo: 69658						
Client ID: 066BF	Batch ID: 36776	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147119						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.500 100 1.06 99.8 70 130

Sample ID: 26050145-67AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2026	RunNo: 69658						
Client ID: 066BF	Batch ID: 36776	TestNo: E200.8	E200.8	Analysis Date: 5/13/2026	SeqNo: 1147120						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 102 0.500 100 1.06 101 70 130 101 0.750 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Sample Log-In Check List

Client Name: **EAGLEPTSCHOOL**

Work Order Number: **26050145**

RcptNo: **1**

Logged by:	Ahlia Brown	5/5/2026 9:45:00 AM	<i>Ahlia Brown</i>
Completed By:	Kyler Woolsey	5/6/2026 12:11:19 PM	<i>Kyler Woolsey</i>
Reviewed By:	Tamra Schmedemann	5/15/2026 1:54:50 PM	<i>Tamra Schmedemann</i>

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
 2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
 4. Shipping container/cooler in good condition? Yes No
 Custody seals intact on shipping container/cooler? Yes No Not Present NA
 No. Seal Date: Signed By:
 5. Was an attempt made to cool the samples? Yes No NA
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
 7. Sample(s) in proper container(s)? Yes No
 8. Sufficient sample volume for indicated test(s)? Yes No
 9. Are samples (except VOA and ONG) properly preserved? Yes No
 10. Was preservative added to bottles? Yes No NA
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
 12. Were any sample containers received broken? Yes No
 13. Does paperwork match bottle labels? Yes No
 (Note discrepancies on chain of custody)
 14. Are matrices correctly identified on Chain of Custody? Yes No
 15. Is it clear what analyses were requested? Yes No
 16. Were all holding times able to be met? Yes No
 (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: JCS09
 Address: P.O. Box 548
Eagle Pt DR 97524
 Email: _____
 Phone: _____ Fax: _____
 Collected By (Print): Loni Connor
 Collected By (Sign): [Signature]
 Email Report Mail Report Fax Report

Section B

Required Project Information

Project Name: Eagle Peak Elem.
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: John Harding
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard: 10 Business Days
 Priority: 5 Business Days (List x 1.50)
 Express: 3 Business Days (List x 1.75)
 Rush: 2 Business Days (List x 2.00)
 Rush: 1 Business Day (List x 2.50)
 Rush: Same Day (List x 3.00)

Authorized Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # Use Only	(Lab)
057 KF			5/5	6:43	1				01	
058 KF				6:43	1				02	
059 KF				6:44	1				03	
060 KE				6:45	1				04	
061 KF				6:46	1				05	
046 CF				6:50	1				06	
047 DW				6:51	1				07	
065 DW				6:55	1				08	
036 CF				6:55	1				09	
037 DW				6:57	1				10	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OY - Other

Section F

Relinquish/Receive

Relinquished By:	Print	Date	Time
<u>[Signature]</u>	<u>Loni Connor</u>	<u>5/5/26</u>	<u>9:45</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<u>Abilia Brown</u>	<u>5/5/26</u>	<u>9:45</u>

Section G

Lab Use Only

Temp: ambient IR Therm ID: _____
 ≤6°C: Yes No _____
 Received on Ice: Yes No _____
 Number of Bottles Received: _____
 pH Checked: _____
 COC Seals Intact: Yes No NA _____
 Field Blank Included: Yes No _____

Received Via UPS FedEX Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: <u>JCSDA</u> Address: Email: Phone: _____ Fax: _____ Collected By (Print): <u>Lois Oconnor</u> Collected By (Sign): <u>[Signature]</u> Email Report <input type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>	Section B Required Project Information Project Name: <u>Eagle Rock Elem.</u> Project Number: Report To: Copy To:	Section C Invoice Information Attention: <u>John Harding</u> Company Name: Address: P.O. #	Section D Rush Status (Subject to Scheduling) <input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00) Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
---	--	--	--

Analysis Requested	
No. of Containers	
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers
001CF 8432			5/5/26	5:36	1 <u>Lead</u>
002DW 8430				5:37	
049CF 8394				5:41	
003CF 8452				5:43	
004DW 8439				5:43	
005CF 8452				5:47	
006DW 8457				5:47	
007CF 8396				5:49	
008DW 8442				5:49	
009CF 8445				5:52	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

NRC Workorder # (Lab Use Only) 26050145

Remarks / Field Data	NRC Sample # (Use Only)	(Lab)
	11	
	12	
	13	
	14	
	15	
	16	
	17	
	18	
	19	
	20	

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		Lois Oconnor	5/5/26	9:45
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>AB</u>		allia Brown	5/5/26	9:45

Section G

Lab Use Only

Temp: amb IR Therm ID: _____

≤6°C: Yes No _____

Received on Ice: Yes No _____

Number of Bottles Received:

pH Checked:

COC Seals Intact: Yes No NA _____

Field Blank Included: Yes No _____

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: <u>JCSM</u> Address: _____ Email: _____ Phone: _____ Fax: _____ Collected By (Print): <u>Loni Connor</u> Collected By (Sign): <u>[Signature]</u> Email Report ___ Mail Report ___ Fax Report ___	Section B Required Project Information Project Name: <u>Eagle Rock Elem.</u> Project Number: _____ Report To: _____ Copy To: _____	Section C Invoice Information Attention: <u>John Harding</u> Company Name: _____ Address: _____ P.O. # _____	Section D Rush Status (Subject to Scheduling) ___ Standard: 10 Business Days ___ Priority: 5 Business Days (List x 1.50) ___ Express: 3 Business Days (List x 1.75) ___ Rush: 2 Business Days (List x 2.00) ___ Rush: 1 Business Day (List x 2.50) ___ Rush: Same Day (List x 3.00) Authorized ___ Yes ___ No
--	--	--	--

Analysis Requested											
No. of Containers											
Lead											

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Remarks / Field Data	NRC Sample # (Lab Use Only)	(Lab)
<u>010 DW</u> <i>Taken from Bottles</i>								
<u>011 CF</u>			<u>5/5</u>	<u>5:53</u>				
<u>012 DW</u>				<u>5:54</u>				
<u>013 BF</u>				<u>5:56</u>				<u>21</u>
<u>014 BF</u>				<u>5:56</u>				<u>22</u>
<u>015 BF</u>				<u>5:57</u>				<u>23</u>
<u>016 BF</u>				<u>5:58</u>				<u>24</u>
<u>017 WB</u>				<u>5:59</u>				<u>25</u>
<u>018 DW</u>				<u>6:01</u>				<u>26</u>
<u>019 BF</u>				<u>6:02</u>				<u>27</u>
				<u>6:03</u>				<u>28</u>
								<u>29</u>
								<u>30</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By: <u>[Signature]</u>	Sign	Print	Date	Time
Received By:		<u>Loni Connor</u>	<u>5/5/26</u>	<u>9:45</u>
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>Anita Brown</u>	<u>5/5/26</u>	<u>9:45</u>

Section G
Lab Use Only

Temp: <u>100.8</u>	IR Therm ID: _____
±0.5°C: ___ Yes ___ No	
Received on Ice: ___ Yes ___ No	
Number of Bottles Received: _____	
pH Checked: _____	
COC Seals Intact: ___ Yes ___ No ___ NA	
Field Blank Included: ___ Yes ___ No	
Received Via ___ UPS ___ FedEX ___ Other ___ Hand	
Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # _____	Amount _____

** Per Loni over phone DE 5/5/26*

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>JCSPO</u>		Project Name: <u>Eagle Rock Edm.</u>		Attention: <u>John Harding</u>		<input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00)	
Address:		Project Number:		Company Name:		<input type="checkbox"/> Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Email:		Report To:		Address:			
Phone: _____ Fax: _____		Copy To:		P.O. #			
Collected By (Print): <u>Loni Connor</u>							
Collected By (Sign): <u>[Signature]</u>							
Email Report <input type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>							

Analysis Requested										
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers					
020 BF	8377		6/5	6:06	Lead					
021 BF	8375			6:06						
022 CF	84162			6:09						
023 DW	8431			6:10						
024 CF	8384			6:12						
025 DW	8467			6:12						
026 CF	8440			6:14						
027 DW	8450			6:15						
028 CF	8415			6:15						
050 CF	84764			6:19						

NRC Workorder # (Lab Use Only) <u>26050145</u>		
Remarks / Field Data	NRC Sample # (Use Only)	(Lab)
	<u>31</u>	
	<u>32</u>	
	<u>33</u>	
	<u>34</u>	
	<u>35</u>	
	<u>36</u>	
	<u>37</u>	
	<u>38</u>	
	<u>39</u>	
	<u>40</u>	

Section E
Sample Information

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By: <u>[Signature]</u>	Print: <u>Loni Connor</u>	Date: <u>5/26/15</u>	Time: <u>9:45</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: <u>AB</u>	<u>ahira Brown</u>	<u>5/26/15</u>	<u>9:45</u>

Section G
Lab Use Only

Temp: amb IR Therm ID: _____

≤6°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: _____

pH Checked: _____

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Received Via UPS FedEX Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company:		Project Name: <u>Eagle Rock Elem.</u>		Attention:		<input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00)	
Address:		Project Number:		Company Name:		<input type="checkbox"/> Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Email:		Report To:		Address:			
Phone: Fax:		Copy To:		P.O. #			
Collected By (Print):							
Collected By (Sign):							
Email Report ___ Mail Report ___ Fax Report ___							

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>2605043</u>		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers												
034 CF			5/5	6:58	Head												
035 DW				10:59													
032 CF				7:00													
033 DW				7:01													
030 CF				7:01													
031 DW				7:01													
042 DW				7:02													
041 DW				7:02													
038 BF				7:05													
039 BF				7:06													

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:					
Received By:					
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:	<u>AB</u>	<u>Antia Brown</u>	<u>5/5/2018</u>	<u>9:45</u>	

Section G Lab Use Only	
Temp: <u>amj</u>	IR Therm ID: ___
±6°C: ___ Yes ___ No	
Received on Ice: ___ Yes ___ No	
Number of Bottles Received: ___	
pH Checked: ___	
COC Seals Intact: ___ Yes ___ No ___ NA	
Field Blank Included: ___ Yes ___ No	
Received Via ___ UPS ___ FedEX ___ Other ___ Hand	
Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # ___ Amount ___	

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: JCS09
 Address: _____
 Email: _____
 Phone: _____ Fax: _____
 Collected By (Print): Lori Oconnor
 Collected By (Sign): [Signature]
 Email Report Mail Report Fax Report

Section B

Required Project Information

Project Name: Eagle Rock Elem.
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: John Harding
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard: 10 Business Days
 Priority: 5 Business Days (List x 1.50)
 Express: 3 Business Days (List x 1.75)
 Rush: 2 Business Days (List x 2.00)
 Rush: 1 Business Day (List x 2.50)
 Rush: Same Day (List x 3.00)
 Authorized Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # (Use Only)	(Lab)
051 DW	8475		5/5	6:20	1		26050145		51	
015 BF	8463			6:21	1			52		
052 CF	8461			6:23	1			53		
053 CF	8489			6:28	1			54		
054 DW	8476			6:29	1			55		
064 BF	8443			6:32	1			56		
055 WW	8491			6:37	1			57		
056 DW	8484			6:35	1			58		
063 BF	8488			6:40	1			59		
062 KF	8492			6:40	1			60		

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Print	Date	Time
<u>[Signature]</u>	Lori Oconnor	5/5/16	9:45
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	Ahna Brown	5/5/20	9:45

Section G

Lab Use Only

Temp: any IR Therm ID: _____
 ≤6°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: _____
 pH Checked: _____
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: JCSDA
 Address: PO Box 548
Eagle Mt OR 97524
 Email: _____
 Phone: _____ Fax: _____
 Collected By (Print): Loni O'Connor
 Collected By (Sign): [Signature]
 Email Report Mail Report Fax Report

Section B

Required Project Information

Project Name: Eagle Rock Elem
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: John Harding
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard: 10 Business Days
 Priority: 5 Business Days (List x 1.50)
 Express: 3 Business Days (List x 1.75)
 Rush: 2 Business Days (List x 2.00)
 Rush: 1 Business Day (List x 2.50)
 Rush: Same Day (List x 3.00)
 Authorized Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
040 BF			5/5	7:09	1	Lead
043 BF				7:10	1	
044 BF				7:11	1	
045 BF				7:12	1	
048 BF				7:15	1	
029 DW				6:15		
066 BF				6:24		

NRC Workorder # (Lab Use Only) 26050145
 Remarks / Field Data
 NRC Sample # (Lab Use Only)
61
62
63
64
65
66
67

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By: [Signature] Sign
 Received By: Loni O'Connor Print Date: 5/5/26 Time: 9:45
 Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By Laboratory: AB Anita Brown Date: 5/5/26 Time: 9:45

Section G

Lab Use Only

Temp: AMB IR Therm ID: _____
 ≤6°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: _____
 pH Checked: _____
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No
 Received Via UPS FedEx Other Hand
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Per Loni over phone