Lead in Water Test Results Summary: Meridian Creek Middle School

Notes:

- **The lead in water Action Level is 15 parts per billion (ppb).**
  Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "**ND**" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
C114 - Health Room Faucet Nurses Station	19221600-001NS	2/27/2026	ND	Non-Detect	*[enter date]*	*[enter result]*	*[autofill]*
C115- Health Room Bathroom Faucet	19221600-002BF	2/27/2026	ND	Non-Detect			
C113 - Staff Bathroom Faucet	19221600-003BF	2/27/2026	ND	Non-Detect			
C108 - Staff Bathroom Faucet	19221600-004BF	2/27/2026	ND	Non-Detect			
C107- Staff Room Faucet	19221600-005SF	2/27/2026	ND	Non-Detect			
C107- Staff Room Water Bottle Filler	19221600-006WB	2/27/2026	ND	Non-Detect			
C120-Art Classroom Faucet Left	19221600-007CF	2/27/2026	2.10	Low			
C120-Art Classroom Faucet Center	19221600-008CF	2/27/2026	ND	Non-Detect			
C120-Art Classroom Faucet Right	19221600-009CF	2/27/2026	1.40	Low			
C130 - Kitchen Dishwashing sink Faucet Left	19221600-010KF	2/27/2026	0.67	Low			
C130 - Kitchen Dishwashing sink Faucet Right	19221600-011KF	2/27/2026	ND	Non-Detect			
C130 - Kitchen Dishwashing Sink Sprayer	19221600-151KF	2/27/2026	4.40	Low			
C130- Kitchen Handwashing sink by dishwasher	19221600-012KF	2/27/2026	ND	Non-Detect			
C130- Kitchen North East Prep Sink Left	19221600-013KF	2/27/2026	ND	Non-Detect			
C130- Kitchen North East Prep Sink Right	19221600-014KF	2/27/2026	ND	Non-Detect			
C130- Kitchen South West Prep Sink	19221600-015KF	2/27/2026	ND	Non-Detect			
C130- Kitchen South West Prep Sink Sprayer	19221600-152KF	2/27/2026	ND	Non-Detect			
C130- Kitchen Sink South Wall	19221600-016KF	2/27/2026	ND	Non-Detect			
C138 - Staff Bathroom Faucet	19221600-017BF	2/27/2026	ND	Non-Detect			
D101 - Commons sink Faucet	19221600-018CF	2/27/2026	ND	Non-Detect			
C101- Commons Drinking Fountain	19221600-019DW	2/27/2026	ND	Non-Detect			
C101 - Commons Bottle Filler	19221600-020WB	2/27/2026	ND	Non-Detect			
E132- Girl's Bathroom Faucet Far Left #1	19221600-021BF	2/27/2026	ND	Non-Detect			
E132- Girl's Bathroom Faucet Center Left #2	19221600-022BF	2/27/2026	ND	Non-Detect			
E132- Girl's Bathroom Faucet Center Left #3	19221600-023BF	2/27/2026	ND	Non-Detect			
E132- Girl's Bathroom Faucet Center Right #4	19221600-024BF	2/27/2026	ND	Non-Detect			
E132- Girl's Bathroom Faucet Center Right #5	19221600-025BF	2/27/2026	ND	Non-Detect			
E132- Girl's Bathroom Faucet Far Right #6	19221600-026BF	2/27/2026	ND	Non-Detect			
E131- Boy's Bathroom Faucet Far Left #1	19221600-027BF	2/27/2026	ND	Non-Detect			
E131 - Boy's Bathroom Faucet Center Left #2	19221600-028BF	2/27/2026	ND	Non-Detect			
E131 - Boy's Bathroom Faucet Center Left #3	19221600-029BF	2/27/2026	ND	Non-Detect			
E131 - Boy's Bathroom Faucet Center Right #4	19221600-030BF	2/27/2026	ND	Non-Detect			
E131 - Boy's Bathroom Faucet Center Right #5	19221600-031BF	2/27/2026	ND	Non-Detect			
E131 - Boy's Bathroom Faucet Far Right #6	19221600-032BF	2/27/2026	ND	Non-Detect			
E135 - Single User Bathroom Faucet	19221600-033BF	2/27/2026	ND	Non-Detect			
Hallway across E129- Drinking Fountain Left	19221600-034DW	2/27/2026	ND	Non-Detect			
Hallway across E129- Drinking Fountain Right	19221600-035DW	2/27/2026	ND	Non-Detect			
Hallway across E129- Water Bottle Filler	19221600-036WB	2/27/2026	ND	Non-Detect			
E126 - Girl's PE Office Bathroom Faucet	19221600-038BF	2/27/2026	ND	Non-Detect			
E128- Girl's Locker Bathroom Faucet Far Left #1	19221600-039BF	2/27/2026	ND	Non-Detect			
E128- Girl's Locker Bathroom Faucet Center Left #2	19221600-040BF	2/27/2026	ND	Non-Detect			
E128- Girl's Locker Bathroom Faucet Center Right #3	19221600-041BF	2/27/2026	ND	Non-Detect			

E128- Girl's Locker Bathroom Faucet Far Right #4	19221600-042BF	2/27/2026	ND	Non-Detect			
E120- Boy's PE Office Bathroom Faucet	19221600-044BF	2/27/2026	ND	Non-Detect			
E122- Boys Locker Bathroom Faucet Far Left #1	19221600-045BF	2/27/2026	ND	Non-Detect			
E122- Boys Locker Bathroom Faucet Center Left #2	19221600-046BF	2/27/2026	ND	Non-Detect			
E122- Boys Locker Bathroom Faucet Center Right #3	19221600-047BF	2/27/2026	ND	Non-Detect			
E122- Boys Locker Bathroom Faucet Far Right #4	19221600-048BF	2/27/2026	ND	Non-Detect			
E114 - Main Gym South Wall Drinking Fountain Left	19221600-049DW	2/27/2026	ND	Non-Detect			
E114 - Main Gym South Wall Drinking Fountain Right	19221600-050DW	2/27/2026	ND	Non-Detect			
E114 - Main Gym South Wall Bottle Filler	19221600-153WB	2/27/2026	ND	Non-Detect			
E114 - Main Gym North Wall Drinking Fountain Left	19221600-051DW	2/27/2026	ND	Non-Detect			
E114 - Main Gym North Wall Drinking Fountain Right	19221600-052DW	2/27/2026	ND	Non-Detect			
E114 - Main Gym North Wall Bottle Filler	19221600-053WB	2/27/2026	ND	Non-Detect			
E109 - Band Classroom Faucet	19221600-054CF	2/27/2026	ND	Non-Detect			
E109 - Band Classroom Drinking Fountain	19221600-055DW	2/27/2026	ND	Non-Detect			
E107 - Choir Classroom Faucet	19221600-056CF	2/27/2026	ND	Non-Detect			
E107 - Choir Classroom Drinking Fountain	19221600-057DW	2/27/2026	ND	Non-Detect			
A113- Staff Bathroom Faucet	19221600-058BF	2/27/2026	ND	Non-Detect			
A114 - Boy's Bathroom Faucet Far Left #1	19221600-059BF	2/27/2026	ND	Non-Detect			
A114 - Boy's Bathroom Faucet Left #2	19221600-060BF	2/27/2026	ND	Non-Detect			
A114 - Boy's Bathroom Faucet Center Left #3	19221600-061BF	2/27/2026	ND	Non-Detect			
A114 - Boy's Bathroom Faucet Center #4	19221600-062BF	2/27/2026	3.00	Low			
A114 - Boy's Bathroom Faucet Center Right #5	19221600-063BF	2/27/2026	ND	Non-Detect			
A114 - Boy's Bathroom Faucet Right #6	19221600-064BF	2/27/2026	ND	Non-Detect			
A114 - Boy's Bathroom Faucet Far Right #7	19221600-065BF	2/27/2026	ND	Non-Detect			
A115 - Girl's Bathroom Faucet Far Left #1	19221600-066BF	2/27/2026	ND	Non-Detect			
A115- Girl's Bathroom Faucet Left #2	19221600-067BF	2/27/2026	ND	Non-Detect			
A115- Girl's Bathroom Faucet Center Left #3	19221600-068BF	2/27/2026	ND	Non-Detect			
A115- Girl's Bathroom Faucet Center #4	19221600-069BF	2/27/2026	ND	Non-Detect			
A115- Girl's Bathroom Faucet Center Right #5	19221600-070BF	2/27/2026	ND	Non-Detect			
A115- Girl's Bathroom Faucet Right #6	19221600-071BF	2/27/2026	ND	Non-Detect			
A115 - Girl's Bathroom Faucet Far Right #7	19221600-072BF	2/27/2026	ND	Non-Detect			
B127 - Porch Drinking Fountain Left	19221600-073DW	2/27/2026	ND	Non-Detect			
B127 - Porch Drinking Fountain Right	19221600-074DW	2/27/2026	ND	Non-Detect			
B127 - Porch Drinking Bottle Filler	19221600-075WB	2/27/2026	ND	Non-Detect			
B107- Space Maker Classroom Faucet Left	19221600-076CF	2/27/2026	ND	Non-Detect			
B107- Space Maker Classroom Faucet Right	19221600-077CF	2/27/2026	ND	Non-Detect			
B107- Space Maker Classroom Drinking Fountain	19221600-078DW	2/27/2026	ND	Non-Detect			
B109- Tech Classroom Faucet	19221600-079CF	2/27/2026	ND	Non-Detect			
B109- Tech Classroom Drinking Fountain	19221600-080DW	2/27/2026	ND	Non-Detect			
B113- Workroom Sink Faucet	19221600-081SF	2/27/2026	ND	Non-Detect			
B113- Workroom Bottle Filler	19221600-082WB	2/27/2026	ND	Non-Detect			
A102- Classroom Faucet	19221600-083CF	2/27/2026	ND	Non-Detect			
A102- Classroom Drinking Fountain	19221600-084DW	2/27/2026	ND	Non-Detect			
A104 - Classroom Faucet	19221600-085CF	2/27/2026	ND	Non-Detect			
A104- Classroom Drinking Fountain	19221600-086DW	2/27/2026	ND	Non-Detect			
A105 - Science Classroom Middle Faucet	19221600-087CF	2/27/2026	ND	Non-Detect			
A105 - Science Classroom South Facing Left Faucet	19221600-088CF	2/27/2026	ND	Non-Detect			
A105 - Science Classroom South Facing Drinking Fountain	19221600-089DW	2/27/2026	ND	Non-Detect			
A105 - Science Classroom South Facing Right Faucet	19221600-090CF	2/27/2026	ND	Non-Detect			
A105 - Science Classroom West Facing Left Faucet	19221600-091CF	2/27/2026	ND	Non-Detect			
A105 - Science Classroom West Facing Right Faucet	19221600-092CF	2/27/2026	ND	Non-Detect			

A105 - Science Classroom North Facing Left Faucet	19221600-093CF	2/27/2026	ND	Non-Detect			
A105 - Science Classroom North Facing Right Faucet	19221600-094CF	2/27/2026	ND	Non-Detect			
Science Prep Room Between A105-A108 Staff Sink	19221600-095SF	2/27/2026	ND	Non-Detect			
A108 - Science Classroom Middle Faucet	19221600-096CF	2/27/2026	ND	Non-Detect			
A108 - Science Classroom North Facing Left Faucet	19221600-097CF	2/27/2026	ND	Non-Detect			
A108 - Science Classroom North Facing Right Faucet	19221600-098CF	2/27/2026	ND	Non-Detect			
A108 - Science Classroom East Facing Left Faucet	19221600-099CF	2/27/2026	ND	Non-Detect			
A108 - Science Classroom East Facing Right Faucet	19221600-100CF	2/27/2026	0.88	Low			
A108 - Science Classroom South Facing Left Faucet	19221600-101CF	2/27/2026	ND	Non-Detect			
A108 - Science Classroom South Facing Right Faucet	19221600-102CF	2/27/2026	0.59	Low			
A108 - Science Classroom South Facing Drinking Fountain	19221600-103DW	2/27/2026	ND	Non-Detect			
A109 - Classroom Faucet	19221600-104CF	2/27/2026	ND	Non-Detect			
A109 - Classroom Drinking Fountain	19221600-105DW	2/27/2026	ND	Non-Detect			
A110 - Classroom Faucet	19221600-106CF	2/27/2026	ND	Non-Detect			
A110 - Classroom Drinking Fountain	19221600-107DW	2/27/2026	ND	Non-Detect			
B213 - Science Prep Sink	19221600-108SF	2/27/2026	ND	Non-Detect			
B214 - Science Classroom Middle Faucet	19221600-109CF	2/27/2026	5.70	Moderate			
B214 - Science Classroom West Facing Left Faucet	19221600-110CF	2/27/2026	**18.00**	**Action Req.**	4/7/2026	1.90	Low
B214 - Science Classroom West Facing Drinking Fountain	19221600-111DW	2/27/2026	ND	Non-Detect			
B214 - Science Classroom West Facing Right Faucet	19221600-112CF	2/27/2026	1.40	Low			
B214 - Science Classroom North Facing Left Faucet	19221600-113CF	2/27/2026	2.50	Low			
B214 - Science Classroom North Facing Right Faucet	19221600-114CF	2/27/2026	0.74	Low			
B214 - Science Classroom East Facing Left Faucet	19221600-115CF	2/27/2026	ND	Non-Detect			
B214 - Science Classroom East Facing Right Faucet	19221600-116CF	2/27/2026	ND	Non-Detect			
B215 - Classroom Faucet	19221600-117CF	2/27/2026	ND	Non-Detect			
B215 - Classroom Drinking Fountain	19221600-118DW	2/27/2026	ND	Non-Detect			
A202- Classroom Faucet	19221600-119CF	2/27/2026	ND	Non-Detect			
A202- Classroom Drinking Fountain	19221600-120DW	2/27/2026	ND	Non-Detect			
A204 - Classroom Faucet	19221600-121CF	2/27/2026	ND	Non-Detect			
A204 - Classroom Drinking Fountain	19221600-122DW	2/27/2026	ND	Non-Detect			
A205 - Classroom Faucet	19221600-123CF	2/27/2026	ND	Non-Detect			
A205 - Classroom Drinking Fountain	19221600-124DW	2/27/2026	ND	Non-Detect			
A206 - Classroom Faucet	19221600-125CF	2/27/2026	ND	Non-Detect			
A206 - Classroom Drinking Fountain	19221600-126DW	2/27/2026	ND	Non-Detect			
A208 - Classroom Faucet	19221600-127CF	2/27/2026	ND	Non-Detect			
A208 - Classroom Drinking Fountain	19221600-128DW	2/27/2026	ND	Non-Detect			
A209 - Classroom Faucet	19221600-129CF	2/27/2026	ND	Non-Detect			
A209 - Classroom Drinking Fountain	19221600-130DW	2/27/2026	ND	Non-Detect			
A210 - Classroom Faucet	19221600-131CF	2/27/2026	ND	Non-Detect			
A210 - Classroom Drinking Fountain	19221600-132DW	2/27/2026	ND	Non-Detect			
A213 - Staff Bathroom Faucet	19221600-133BF	2/27/2026	ND	Non-Detect			
B227 - Left Drinking Fountain	19221600-134DW	2/27/2026	ND	Non-Detect			
B227 - Right Drinking Fountain	19221600-135DW	2/27/2026	ND	Non-Detect			
B227 - Bottle Filler	19221600-136WB	2/27/2026	ND	Non-Detect			
A214 - Boy's Bathroom Far Left Faucet #1	19221600-137BF	2/27/2026	ND	Non-Detect			
A214 - Boy's Bathroom Left Faucet #2	19221600-138BF	2/27/2026	ND	Non-Detect			
A214 - Boy's Bathroom Center Left Faucet #3	19221600-139BF	2/27/2026	ND	Non-Detect			
A214 - Boy's Bathroom Center Faucet #4	19221600-140BF	2/27/2026	0.98	Low			
A214 - Boy's Bathroom Center Right Faucet #5	19221600-141BF	2/27/2026	ND	Non-Detect			
A214 - Boy's Bathroom Right Faucet #6	19221600-142BF	2/27/2026	0.56	Low			
A214 - Boy's Bathroom Far Right Faucet #7	19221600-143BF	2/27/2026	ND	Non-Detect			

A215 - Girl's Bathroom Far Left Faucet #1	19221600-144BF	**2/27/2026**	ND	Non-Detect			
A215 - Girl's Bathroom Left Faucet #2	19221600-145BF	**2/27/2026**	ND	Non-Detect			
A215 - Girl's Bathroom Center Left Faucet #3	19221600-146BF	**2/27/2026**	0.73	Low			
A215 - Girl's Bathroom Center Faucet #4	19221600-147BF	**2/27/2026**	ND	Non-Detect			
A215 - Girl's Bathroom Center Right Faucet #5	19221600-148BF	**2/27/2026**	0.55	Low			
A215 - Girl's Bathroom Right Faucet #6	19221600-149BF	**2/27/2026**	ND	Non-Detect			
A215 - Girl's Bathroom Far Right Faucet #7	19221600-150BF	**2/27/2026**	ND	Non-Detect			