

Lead in Water Test Results Summary: Lowrie Primary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
A106- Work room faucet	19221400-001SF	2/24/2026	0.6	Low	[enter date]	[enter result]	[autofill]
A106- Work room drinking fountain	19221400-002DW	2/24/2026	ND	Non-Detect			
A110- Staff bathroom faucet	19221400-003BF	2/24/2026	ND	Non-Detect			
A117- Staff room faucet Left	19221400-004SF	2/24/2026	0.99	Low			
A117- Staff room faucet Right	19221400-005SF	2/24/2026	ND	Non-Detect			
A112- Health room faucet	19221400-006NS	2/24/2026	ND	Non-Detect			
A111- Health room bathroom faucet	19221400-007BF	2/24/2026	ND	Non-Detect			
A120A- Alcove water bottle filler Left	19221400-008WB	2/24/2026	ND	Non-Detect			
A120A- Alcove drinking fountain Right	19221400-009DW	2/24/2026	ND	Non-Detect			
A120- Bathroom faucet far left #1	19221400-010BF	2/24/2026	ND	Non-Detect			
A120- Bathroom faucet center left #2	19221400-011BF	2/24/2026	0.88	Low			
A120- Bathroom faucet center right #3	19221400-012BF	2/24/2026	4.3	Low			
A120- Bathroom faucet far right #4	19221400-013BF	2/24/2026	2.4	Low			
A121- Bathroom faucet far left #1	19221400-014BF	2/24/2026	0.74	Low			
A121- Bathroom faucet center left #2	19221400-015BF	2/24/2026	3.4	Low			
A121- Bathroom faucet center right #3	19221400-016BF	2/24/2026	0.78	Low			
A121- Bathroom faucet far right #4	19221400-017BF	2/24/2026	ND	Non-Detect			
A122- Staff bathroom faucet	19221400-018BF	2/24/2026	ND	Non-Detect			
A119- Gym Classroom faucet	19221400-019CF	2/24/2026	2.9	Low			
A133- Classroom faucet right	19221400-020CF	2/24/2026	3	Low			
A133- Drinking fountain	19221400-021DW	2/24/2026	2.8	Low			
B101- Program classroom faucet left	19221400-022CF	2/24/2026	ND	Non-Detect			
B101- Program classroom faucet right	19221400-023CF	2/24/2026	ND	Non-Detect			
B102- Classroom faucet left	19221400-024CF	2/24/2026	0.63	Low			
B102- Classroom faucet right	19221400-025CF	2/24/2026	0.78	Low			
B103- Classroom faucet	19221400-026CF	2/24/2026	ND	Non-Detect			
B103- Classroom drinking faucet	19221400-027DW	2/24/2026	0.93	Low			
B104- Classroom faucet	19221400-028CF	2/24/2026	ND	Non-Detect			
B104- Classroom drinking faucet	19221400-029DW	2/24/2026	ND	Non-Detect			
B105- Classroom faucet	19221400-030CF	2/24/2026	ND	Non-Detect			
B105- Classroom drinking faucet	19221400-031DW	2/24/2026	ND	Non-Detect			
B111- Porch Classroom faucet	19221400-032CF	2/24/2026	ND	Non-Detect			
B122- Girls Bathroom faucet far left #1	19221400-033BF	2/24/2026	0.62	Low			
B122- Girls Bathroom faucet left center #2	19221400-034BF	2/24/2026	ND	Non-Detect			
B122- Girls Bathroom faucet right center #3	19221400-035BF	2/24/2026	1.1	Low			
B122- Girls Bathroom faucet far right #4	19221400-036BF	2/24/2026	ND	Non-Detect			
Hallway outside B122- Drinking fountain	19221400-037DW	2/24/2026	ND	Non-Detect			
Hallway outside B121- Bottle Filler	19221400-038WB	2/24/2026	ND	Non-Detect			
B121- Boys Bathroom faucet far left #1	19221400-039BF	2/24/2026	ND	Non-Detect			
B121- Boys Bathroom faucet center left #2	19221400-040BF	2/24/2026	ND	Non-Detect			
B121- Boys Bathroom faucet center right #3	19221400-041BF	2/24/2026	0.62	Low			
B121- Boys Bathroom faucet far right #4	19221400-042BF	2/24/2026	ND	Non-Detect			
B120- Staff Bathroom faucet	19221400-043BF	2/24/2026	ND	Non-Detect			
B106- Classroom faucet	19221400-044CF	2/24/2026	0.57	Low			
B106- Classroom drinking faucet	19221400-045DW	2/24/2026	ND	Non-Detect			
B107- Classroom faucet	19221400-046CF	2/24/2026	ND	Non-Detect			
B107- Classroom drinking faucet	19221400-047DW	2/24/2026	ND	Non-Detect			
B108- Classroom faucet	19221400-048CF	2/24/2026	2.3	Low			
B108- Classroom drinking faucet	19221400-049DW	2/24/2026	0.55	Low			
B109- Classroom faucet	19221400-050CF	2/24/2026	ND	Non-Detect			

B109- Classroom drinking faucet	19221400-051DW	2/24/2026	ND	Non-Detect			
B110- Classroom faucet	19221400-052CF	2/24/2026	ND	Non-Detect			
B110- Classroom drinking faucet	19221400-053DW	2/24/2026	ND	Non-Detect			
B112- Porch Classroom faucet	19221400-054CF	2/24/2026	ND	Non-Detect			
B127- Kitchen faucet south facing handwashing	19221400-055KF	2/24/2026	17	Action Req.	5/6/2026	1.00	Low
B127- Kitchen faucet south facing pot washing sink	19221400-056KF	2/24/2026	ND	Non-Detect			
B127- Kitchen faucet south facing service line	19221400-057KF	2/24/2026	1.6	Low			
B127- Kitchen faucet north facing left handwashing	19221400-058KF	2/24/2026	3	Low			
B127- Kitchen faucet north facing center pot washer	19221400-059KF	2/24/2026	ND	Non-Detect			
B127- Kitchen faucet north facing pot washer spray	19221400-114KF	2/24/2026	0.55	Low			
B127- Kitchen faucet north facing right handwashing	19221400-060KF	2/24/2026	5.3	Moderate			
C101- Classroom faucet	19221400-061CF	2/24/2026	0.69	Low			
C101- Classroom drinking faucet	19221400-062DW	2/24/2026	1	Low			
C102- Classroom faucet	19221400-063CF	2/24/2026	1.1	Low			
C102- Classroom drinking faucet	19221400-064DW	2/24/2026	0.71	Low			
C103- Classroom faucet	19221400-065CF	2/24/2026	0.82	Low			
C103- Classroom drinking faucet	19221400-066DW	2/24/2026	0.94	Low			
C104- Classroom faucet	19221400-067CF	2/24/2026	ND	Non-Detect			
C104- Classroom drinking faucet	19221400-068DW	2/24/2026	9.9	Moderate	5/6/2026	ND	Non-Detect
C105- Classroom faucet	19221400-069CF	2/24/2026	ND	Non-Detect			
C105- Classroom drinking faucet	19221400-070DW	2/24/2026	ND	Non-Detect			
C106- Classroom faucet	19221400-071CF	2/24/2026	ND	Non-Detect			
C106- Classroom drinking faucet	19221400-072DW	2/24/2026	ND	Non-Detect			
C106- Classroom bottle filler	19221400-073WB	2/24/2026	ND	Non-Detect			
C106- Alcove bathroom faucet	19221400-074BF	2/24/2026	ND	Non-Detect			
C109- Prep Kitchen left faucet	19221400-075KF	2/24/2026	3.3	Low			
C109- Prep Kitchen left faucet sprayer	19221400-115KF	2/24/2026	2.6	Low			
C109- Prep Kitchen right faucet	19221400-076KF	2/24/2026	13	High	5/6/2026	2.60	Low
C111- Staff Bathroom faucet	19221400-077BF	2/24/2026	ND	Non-Detect			
B201- Classroom faucet	19221400-078CF	2/24/2026	ND	Non-Detect			
B201- Classroom drinking faucet	19221400-079DW	2/24/2026	ND	Non-Detect			
B202- Classroom faucet	19221400-080CF	2/24/2026	0.71	Low			
B202- Classroom drinking faucet	19221400-081DW	2/24/2026	0.75	Low			
B203- Classroom faucet	19221400-082CF	2/24/2026	ND	Non-Detect			
B203- Classroom drinking faucet	19221400-083DW	2/24/2026	ND	Non-Detect			
B204- Classroom faucet	19221400-084CF	2/24/2026	ND	Non-Detect			
B204- Classroom drinking faucet	19221400-085DW	2/24/2026	0.76	Low			
B205- Classroom faucet	19221400-086CF	2/24/2026	0.95	Low			
B205- Classroom drinking faucet	19221400-087DW	2/24/2026	0.57	Low			
B211- Classroom faucet	19221400-088CF	2/24/2026	0.64	Low			
B222- Girls Bathroom faucet far left #1	19221400-089BF	2/24/2026	1.2	Low			
B222- Girls Bathroom faucet left center #2	19221400-090BF	2/24/2026	0.68	Low			
B222- Girls Bathroom faucet right center #3	19221400-091BF	2/24/2026	0.57	Low			
B222- Girls Bathroom faucet far right #4	19221400-092BF	2/24/2026	350	Action Req.	5/6/2026	ND	Non-Detect
B218- Library alcove drinking faucet	19221400-093DW	2/24/2026	ND	Non-Detect			
B218- Library alcove bottle filler	19221400-094WB	2/24/2026	ND	Non-Detect			
B221- Boys Bathroom faucet far left #1	19221400-095BF	2/24/2026	0.52	Low			
B221- Boys Bathroom faucet center left #2	19221400-096BF	2/24/2026	0.64	Low			
B221- Boys Bathroom faucet center right #3	19221400-097BF	2/24/2026	0.95	Low			
B221- Boys Bathroom faucet far right #4	19221400-098BF	2/24/2026	0.84	Low			
B220- Staff Bathroom faucet	19221400-099BF	2/24/2026	ND	Non-Detect			
B227- Kitchen faucet south facing service line	19221400-100KF	2/24/2026	2.4	Low			
B227- Kitchen faucet west facing left	19221400-101KF	2/24/2026	3.5	Low			
B227-Kitchen faucet west facing left sprayer	19221400-116KF	2/24/2026	2.1	Low			
B227- Kitchen faucet west facing right	19221400-102KF	2/24/2026	5.5	Moderate			
B206- Classroom faucet	19221400-103CF	2/24/2026	0.62	Low			
B206- Classroom drinking faucet	19221400-104DW	2/24/2026	0.67	Low			
B207- Classroom faucet	19221400-105CF	2/24/2026	ND	Non-Detect			
B207- Classroom drinking faucet	19221400-106DW	2/24/2026	ND	Non-Detect			
B208- Classroom faucet	19221400-107CF	2/24/2026	ND	Non-Detect			
B208- Classroom drinking faucet	19221400-108DW	2/24/2026	0.54	Low			
B209- Classroom faucet	19221400-109CF	2/24/2026	ND	Non-Detect			
B209- Classroom drinking faucet	19221400-110DW	2/24/2026	ND	Non-Detect			
B210- Classroom faucet	19221400-111CF	2/24/2026	ND	Non-Detect			
B210- Classroom drinking faucet	19221400-112DW	2/24/2026	ND	Non-Detect			
B212- Porch Classroom faucet	19221400-113CF	2/24/2026	ND	Non-Detect			
C106-Outdoor drinking fountain by entry door	19221400-117DW	2/24/2026	ND	Non-Detect			