SAN BENITO CONSOLIDATED INDPENDENT SCHOOL DISTRICT
CSP-0626-FDW
FENCING DISTRICTWIDE
MAY 18, 2026

ADDENDUM NO. 3

1. Please see revised technical specifications for La Paloma Elementary, updated District Fencing Project specifications, and Fence and Gate Bid Quotation Form. See attachments.

2. Please confirm core drilling at the mini gyms double gate posts & egress gate and fence posts. 8" diameter x 24" deep. Or post on plates? All locations should be post on plate.

3. Please confirm number of doors to be replaced at Sonny Brazil. Is it one new door with frame cut into the building PLUS one replacement door? the bid proposal form shows 24 doors & 1 door with frame for a total of 25. 25 total doors with hardware including one with a frame cut into the building? or is it 24 doors plus 1 door with frame? It is 24 doors replaced with reinforcements and hardware at gyms and Sonny Brazil AND 1 new door with frame cut into the building at Sonny Brazil.

4. Please confirm 4" x sch 40 gate posts for the 12' & 16' double swing gates. Install the standard for that size of gate to prevent sagging.

5. Rim cylinders should be Primus

6. Which egress gates take a borg punch coded lock (similar to what is existing) and which take a schlage lever handle? or are they all lever handle? All borg punch coded locks should have been eliminated by the addendum. Key access only with night latch. All lever handle.

7. Maybe the CTE area gates on the outside take the borg punch coded lock and the mini gym gates/doors have the schlage lever handles? All borg punch coded locks should have been removed by the addendum at all locations, CTE, gyms, Sonny Brazil. Key access only with night latch. All lever handles.


Fencing Project (CSP-0626-FDW) Districtwide
Gyms (Covered Pavilions) Fencing and Gates

Galvanized Fence Panels with Emergency Egress Gates.	
Schedule 48	12'L x 6'H -Double gated (6', 6'gate)
Schedule 20	12'L x 6'H with 4' emergency egress gate. 4' Gates should have preferred hardware below.
Schedule 18	16' L x 6' H -Double gate (8', 8')
Schedule 2	Short Fence Panels (chain-link) connecting gym to existing fence (La Paloma Elementary)
Schedule 1	Short Fence Panels (chain-link) connecting gym to school building (Dr. Cash Elementary)

1. All material used shall be new galvanized material where necessary. Reusing existing or used fencing materials is not allowed.
2. Included measurements are estimates.
3. The contractor/installer is responsible for field-verifying existing conditions and linear measurements.
4. The contractor/installer shall be responsible for all required permits by the governing authority.

6. **HARDWARE AND MATERIAL PREFERED/REQUESTED**

   Door Closers **Model 1261 LCN** or *owner approved equal*
   Emergency egress push bar **Model VD 99EO-3-626-OUT-WH with Night latch Function, Rim Cylinder** or *owner approved equal*
   996L-NLR/V-06 Night Latch Lever Trim for 98/99 Series Exit Device
   or *owner approved equal*
   Residential Grade – Galvanized or *owner approved equal*
   Contractor is responsible for all preparatory work, acquiring permits if necessary, collecting and disposal of all related construction debris.
   Changes to the scope of work will need to be pre-approved by SBCISD before proceeding. Issues or obstacles should be address as soon as possible.
   Dimensions on panels and gates may require adjusting to fit each opening.
   Protective sheet metal (panic device)
   Support Header


La Paloma

FENCING DISTRICTWIDE
CSP-0626-FDW
FENCE AND GATE BID QUOTATION FORM

NO.	CAMPUS	QTY	UNIT COST	TOTAL COST
1	12' x 6' Double gated (6',6')	48	_____	_____
2	12' x 6' Fence Panel with 4' Gate	20	_____	_____
3	16' x 6' Double gated (8',8')	18	_____	_____
4	Short Fence Panel	3	_____	_____

Grand Total for all locations: _____

Days to Complete Installation: _____

Bidder's Name: _____

WE THE UNDERSIGNED, SUBMIT THE ABOVE BID FOR THE ABOVE-MENTIONED ITEMS.

I/We have read the bid requirements, conditions and specifications which are an integral part of the terms of this contract.

My signature also certifies that the accompanying proposal is not the result of, or affected by any unlawful act of collusion with another person or company engaged in the same line of business or commerce, or any act of fraud punishable under current Texas codes. Furthermore, I understand that fraud and unlawful collusion are crimes under the Statue Law, and can result in fines, prison sentences and civil damage awards.

I hereby certify that I am authorized to sign as a Representative for the Firm.

Name of Firm:_____ Signature:_____

Address: _____ Name (Type/Print): _____

_____ Title: _____

Telephone: _____ Date: _____

Fax No:_____ E-Mail: _____

FENCING DISTRICTWIDE
CSP-0626-FDW
CAMPUS LISTING

CAMPUS	16' Double Swing Gate (8',8')	12' Double Swing Gates (6',6')	12' Fence Panel with 4' Gate	Metal Door	Install New Door and Frame	Short Fence Chain-Link Panel	Overhead Door
Fred Booth Global Leadership Academy	2	5	3	1			
Dr. CM Cash	1	6	1	3		1	
Ed Downs Fine Arts Academy	2	6	0	7			
Dr. Raul Garza STEAM Academy	2	5	2	2			
Judge Oscar De La Fuente Elementary	2	4	2	2			
La Encantada Elementary	2	4	2	2			
La Paloma Elementary	1	4	2	2		2	
Rangerville Elementary	2	5	3	1			
Frank Roberts Elementary	2	4	3	1			
Sullivan Environmental Science Academy	1	5	2	2			
Sonny Brazil	1	0	0	1	1		
Multi-Purpose Facility	0	0	0	0			9
TOTALS:	**18**	**48**	**20**	**24**	**1**	**3**	**9**