



AHERA 6-Month Surveillance Inspection Form

(As Required by AHERA – 40 CFR Part 763 Subpart E)

I. Facility Information

School/Building Name: Kyrene Altadena Middle School

LEA (Local Education Agency): Kyrene Elementary School District No. 28

Building Address: 14620 South Desert Foothills Parkway

City/State/Zip: Tempe, AZ 85084

Last Reinspection Date (3-Year): July 3, 2025

II. Surveillance Information

Date of Surveillance: March 9, 2026

Inspector Name: Tracey Carpenter

Inspector Accreditation # / Expiration: ON-188748-14588-082525 Exp. 8.25.26

Management Planner Accreditation # / Expiration: ON-4651-14588-070625 exp 7.6.26

Inspector Company: Dominion Environmental Consultants, Inc.

Phone: (602) 516-1415

III. Review of Asbestos Management Plan

- ✓ Asbestos Management Plan reviewed prior to inspection
- ✓ Most recent inspection/reinspection report available
- ✓ Previous response actions reviewed
- ✓ O&M; program documentation reviewed
- ✓ Training records reviewed by LEA

Comments:

Asbestos Awareness Training held August 18, 2026

IV. O&M Areas with ACM in need of repair

Based on the findings of the inspection, appropriate response actions must be selected in accordance with AHERA guidelines. If ACM is in good condition and unlikely to be disturbed, it may be managed in place through an operations and maintenance (O&M) program, including periodic surveillance and worker training. However, if the material is damaged or poses a risk of fiber release, response actions such as repair (e.g., encapsulation or enclosure) or removal may be required. Repairs are typically used when damage is limited, and the material can be stabilized, while removal is often necessary when ACM is significantly damaged, cannot be effectively repaired, or will be impacted by renovation or demolition activities. All such actions must be performed using accredited personnel and appropriate work practices to prevent asbestos fiber release and protect building occupants. Under 40 CFR 61 Subpart M, projects involving regulated asbestos-containing material (RACM) above threshold amounts (160 sq ft, 260 linear ft, or 35 cubic ft) must follow full NESHAP requirements, regardless of how the waste is packaged.

In the event of a fiber release episode, 40 CFR 763.90 requires prompt action to control the hazard. The affected area must be immediately isolated, appropriate personnel notified, and cleanup performed by trained professionals using HEPA vacuums and wet methods. The damaged ACM must then be repaired, encapsulated, or removed, followed by a visual inspection and, if necessary, air clearance testing before the space can be safely reoccupied.

Room/ Area	HM #	Material Description	Friable? (Y/N)	Damage Observed	Action Needed
Building 2 – Custodial Room (near Room 216)	12/13	Blue Cove Base & Mastic	No	Missing	Replace
Building 2 – Room 315 & Water Fountain (near Room 108)	16/17	Blue/Gray 2' x 2' Carpet Square & Mastic	No	Torn/Missing	Remove/Replace or Encapsulate
Building 2 – Room 52 Entry & Room 304	30/31 32/33	Blue & White 12" x 12" VCT & Mastic	No	Broken/Cracking	Remove/Replace or Enclose/Encapsulate
Building 2 – Women's RR (near Room 307)	62/63	Navy Blue 4" x 4" Ceramic Wall Tile & Mastic	No	Crippled	Remove/Replace or Encapsulate
Building 3 – Lobby	52/53	White 12" x 12" VCT & Mastic	No	Cracking	Remove/Replace or Encapsulate
Building 3 – Kitchen Serving Area	57/58	Tan 4" x 4" Ceramic Wall Tile & Mastic	No	Broken	Remove/Replace or Enclose/Encapsulate
Building 3 – Kitchen	79/80	Gray 12" x 12" Ceramic Floor Tiles	No	Broken	Remove/Replace or Enclose/Encapsulate
Building 3 – Kitchen	82/83	Gray 6" x 4" Ceramic Cove Base Tiles	No	Broken	Remove/Replace or Enclose/Encapsulate
Building 3 – Gym	109/110	Black L-Shaped Cove Base	No	Missing/Broken	Remove/Replace or Enclose/Encapsulate
Building 3 – Locker Rooms	131/132	Navy Blue 4" x 4" Ceramic Tiles	No	Broken	Remove/Replace or Enclose/Encapsulate
Building 3 – Locker Rooms	134/135	Gray 12" x 4" Ceramic Cove Base Tiles	No	Broken/Missing	Remove/Replace or Enclose/Encapsulate

IV. Classification, Condition, Response Action of All Remaining ACBM

BUILDING 2: Main Building

Material Description	Assessment Classification	Material Condition	Changes Since Last Inspection		Response Action Recommendations	Accessibility & Potential for Disturbance	
9" x 9" Clear Block Grout	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Blue 4" Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Blue 4" Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black 2" x 2" Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for 2" x 2" Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Blue/Gray 2" x 2" Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Blue/Gray 2" x 2" Carpet Square	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Interior Frame Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Door/Window Sealant	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Counter Cabinet Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray Sink Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Fixture Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Concrete Pad	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mop Sink Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
White Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
White with Black Specs VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for White with Black Specs VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Concrete Foundation	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Blue 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
White 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Tac Board Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Tac Board Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black Floor Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray Floor Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Floor Expansion Joint	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Beige Wallpaper System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated

Gray with White Specs 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Gray 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Thinset for Gray 2" x 2" Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Brown 16" x 3" Block	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Brown 16" x 3" Block	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 16" x 8" Block	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Brown 16" x 8" Block	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 4" Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Gray 4" Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 18" x 18" Circle Pattern Vinyl	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Gray 18" x 18" Circle Pattern Vinyl	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 36" x 8" Circle Pattern Vinyl	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Gray 36" x 8" Circle Pattern Vinyl	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Skip Trowel Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black Chalk Board	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray Epoxy Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Tan 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Tan 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Tan 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Gray 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Gray 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Black 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Black 4" x 4" Ceramic Wall tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Tan 1"x1" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Tan 1"x1" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Thinset for Tan 1"x1" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Gray 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Thinset for Gray 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated

Beige Fiberglass Reinforced Plastic	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for FRP	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Multicolored Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	G MD SD DA R E	
Grout for Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	G MD SD DA R E	
Mastic for Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Multicolored Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Insulation for Black Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Insulation for Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Untextured Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
White Duct Seam Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
White Duct Mastic	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Red Fire Stop Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Ceiling Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Insulation for Ceiling Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Silver Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Insulation for Silver Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated

BUILDING 3: Multipurpose Room

Material Description	Assessment Classification	Material Condition	Changes Since Last Inspection		Response Action Recommendations	Accessibility & Potential for Disturbance		
Frame Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Blue 12"x12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for Blue 12"2	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
White 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for White 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Tac Board Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for Tac Board Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Floor Expansion Joint	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Tan 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Grout for Tan 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Thinset for Tan 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Gray 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Grout for Gray 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Thinset for Gray 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Black 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Grout for Black 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Thinset for Black 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Gray Epoxy Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Fixture Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Blue 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Grout for Blue 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Thinset for Blue 4" x 4" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
White Fiberglass Reinforced Plastic (FRP)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for White FRP	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
White Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Insulation for Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
White Mop Sink Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Beige Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Black Foam Insulation for Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated

Concrete Foundation	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 12" x 12" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Gray 12" x 12" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Thinset for Gray 12" x 12" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 6" x 4" Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Gray 6" x 4" Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Gray 6" x 4" Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Counter Caulking (Silver)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 16" x 8" CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mortar for Gray 16" x 8" CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Brown Decorative 16" x 8" CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mortar for Decorative CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 60" x 12" Stair Tread	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Stair Tread	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray Sink Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Beige 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Beige Fiberglass Reinforced Plastic (FRP)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Beige FRP	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black 2" x 2" Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Black 2" x 2" Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Blue Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Blue Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray Multicolored Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Gray Multicolored Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black Window Sealant	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black 4" Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black Vinyl Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Black Vinyl Flooring	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
L Shaped Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated

Mastic for L Shaped Cove Base	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Interior Expansion Joint	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black Sink Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray with Specs 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for 2" x 2" Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Thinset for 2" x 2" Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray 2" x 2" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for 2" x 2" Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Thinset for 2" x 2" Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Tan 1" x 1" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Tan 1" x 1" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Thinset for Tan 1" x 1" Ceramic Floor Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Pink 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Yellow 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Yellow 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Yellow 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
White 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for White 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for White 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Navy Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for Navy Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Navy Blue 4" x 4" Ceramic Wall Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Gray Textured 12" x 4" Ceramic Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Grout for 12" x 4" Ceramic Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for 12" x 4" Ceramic Cove Base Tile	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
White Seam Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Mastic for Seam Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Untextured Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated
Black Flex Duct	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D	Accessible Renovated

Insulation for Flex Duct	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D Renovated	Accessible
Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D Renovated	Accessible
Insulation for Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D Renovated	Accessible
Red Fire Stop Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D Renovated	Accessible
Ceiling Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D Renovated	Accessible
Insulation for Ceiling Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D Renovated	Accessible
White Duct Mastic	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible V/D W/D Renovated	Accessible

BUILDING 4: Media Center

Material Description	Assessment Classification	Material Condition	Changes Since Last Inspection		Response Action Recommendations	Accessibility & Potential for Disturbance		
Glass 9" x 9" Block Mortar	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Blue Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for Blue Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Tac Board Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for Tac Board Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Frame Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Black Window Sealant	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Black Chalk Board	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Beige with Tan 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for Beige with Tan 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
White 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for 12" x 12" VCT	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
White Fiberglass Reinforced Plastic (FRP)	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for FRP	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Black 2"x 2" Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for Black 2"x 2" Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Gray Sink Coating	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Counter/Cabinet Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Fixture Caulking	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Gray Multicolored Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mastic for Gray Multicolored Carpet	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Skip Trowel Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Gray 16" x 8" CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mortar for Gray 16" x 8" CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Brown CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mortar for Brown CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Brown Decorative CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Mortar for Brown Decorative CMU	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated
Concrete Pad	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible	Accessible	V/D W/D Renovated

Material Description	Assessment Classification	Material Condition	Changes Since Last Inspection		Response Action Recommendations	Accessibility & Potential for Disturbance
Beige Door Frame Sealant	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Concrete Foundation	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Unfinished Drywall System	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Black Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Insulation for Flex Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Insulation for Silver Duct Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White Seam Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Mastic for Seam Tape	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White Duct Mastic	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Ceiling Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Insulation for Ceiling Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
White Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated
Insulation for Pipe Wrap	1 2 3 4 5 6 7	G MD SD DA R E	Y	N	O&M Repair Enclose/Encaps Remove	Inaccessible Accessible V/D W/D Renovated

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM

***ACBM Condition:**

G Good
MD Minor Damage
SD Significant Damage
DA Damaged & Accessible
R Removed
E Enclosed or Encapsulated

V. Notifications

- ☐ Custodial/Maintenance staff informed by _____ on Date: _____
- ☐ Response action timeline established by _____ on Date: _____
-

VI. Photographic Documentation of Damaged Areas

- ☒ Photo Log of Damaged ACBM Attached
- ☐ No Damages Observed
-

VII. Inspector Certification

I certify that this surveillance was conducted in accordance with 40 CFR §763.92 and applicable state regulations.

Inspector Signature: Gracey Carpenter

Date: 3/9/26

VIII. LEA Acknowledgment

LEA Representative Name: _____

Title: _____

Signature: _____

Date: _____



Kyrene Altadena Middle School – 6 Month Surveillance March 9, 2026

Main Building (Building 2)

Cove Base Missing Custodial Room



Carpet Missing Water Fountain (Rm 108)




Carpet Missing Room 315




Carpet Torn Room 315




Restroom Cove Base Tiles Missing/Broken/Cracking



VCT Tiles Missing/Broken/Cracking



MPR Building (Building 3)		
Lobby	Kitchen	
		
Kitchen Serving Area		Gym/Court
		
Gym/Court	Locker Rooms	
		
Locker Rooms		
		