2024 Water Testing Remediation Plan-last updated 5/4/26

Building	Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	Date Sample Collected	Date Results Received	Date Taken Out of Service	Planned Remediation Measure	Date Remediation Taken	Actual Remediation Taken	Date 2nd Sample Collected	Date Results Received	Second Sample Laboratory Analysis (in ppb)	Date Put Back in Service	Date 3rd Sample Collected	Date Results Received	Third Sample Laboratory Analysis (in ppb)	Date Put Back in Service	Date 4th Sample Collected	Date Results Received	Fourth Sample Laboratory Analysis (in ppb)	Date Put Back in Service
LHS	104.1-2	Kitchen Single Bay Sink	Sink	17.9	6/4/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	10/28/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-4	Kitchen Dishwash 3-Bay Sink, Right	Sink	11	6/4/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	10/28/24	removed	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-5	Kitchen Single Middle Island Sink	Sink	13.2	6/4/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	10/28/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-12	Dish Room Single Sink	Sink	17.3	6/4/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	10/28/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-13A	Faculty Dining Room South Wall	Drinking Fountain	15.4	6/4/24	8/15/24	8/26/24	Replace	12/9/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-36	Boys Pool Locker Room East Wall	Sink	33.5	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-38	Boys Vestibule Lav	Sink	6.4	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-40	Technology Room 167 Center	Sink	15.3	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-41	Technology Room 167 Right	Sink	11.5	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-43	Technology Room 166 Center	Sink	7.2	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-52	Boys Field House Locker Room 1 Left	Sink	6.5	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-101	Across From Room 147	Drinking Fountain	6	6/4/24	8/15/24	8/26/24	Replace	11/6/24	installed new bottle filler	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-102	Room 147 Left Single Sink	Sink	20.5	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-103	Room 147 Right Double Sink	Sink	7.4	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-108	Women's Faculty Lav by Room 143 Left Sink	Sink	7.1	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-110	Men's Faculty Lav by Room 143 Left Sink	Sink	6.3	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-111	Credit Union Room 140	Sink	27.6	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-114	Girls G7 Lav Left	Sink	5.1	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-117	Room 141 Left	Sink	8.6	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-119	Room 138A	Sink	20.4	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-120	Room 136A	Sink	7.5	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-123	Fitness Center/Pool Hallway	Drinking Fountain	17	6/4/24	8/15/24	8/26/24	Replace	10/7/24	installed new bottle filler	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-124	Girls Pool Locker Room	Bubbler	20.7	6/4/24	8/15/24	8/26/24	Replace	2/17/24	removed	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-125	Girls Pool Locker Room	Sink	10.8	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-136	Principal's Office Lav	Sink	9	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-144	G3 Lav Left Sink	Sink	5.5	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-149	B3 Lav Right Sink	Sink	5.3	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-150	Room 111A (Office Area)	Sink	6	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-155	Prep Room Between S11/S12	Sink	21.1	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-156	Outside Room 113	Drinking Fountain	15.1	6/4/24	8/15/24	8/26/24	Replace Filter	12/9/24	installed new bottle filler	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-161	Room 128A	Sink	9.2	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-164	G5 Lav Left Sink	Sink	17.7	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-167	Room 128 Left	Sink	14.7	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-168	Room 128 Right	Sink	12.4	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-169	Room 130A	Sink	6.9	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-171	Room 129	Sink	29.8	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-172	Room 131A Sink by Window	Sink	12.2	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-173	Room 130 Left Wall Left Sink	Sink	73	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-174	Room 130 Left Wall Center Sink	Sink	14.7	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-175	Room 130 Left Wall Right Sink	Sink	11.3	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-176	Room 130 Back Wall Left Sink	Sink	56	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-177	Room 130 Back Wall Middle Sink	Sink	20.3	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-178	Room 130 Back Wall Right Sink	Sink	16.2	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-188	Women's Lav by 200.10 Sink by Window	Sink	44.7	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-189	Women's Lav by 200.10 2nd Sink From Left	Sink	15.1	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-190	Women's Lav by 200.10 3rd Sink From Left	Sink	5.2	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-225	Room 216	Sink	11.3	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-228	Across From Rifle Range in Basement	Sink	11.7	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-229	Across From Rifle Range in Basement	Drinking Fountain	9.2	6/4/24	8/15/24	8/26/24	Replace	12/17/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-230	Basement Laundry Room	Sink	9.4	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LHS	104.1-231	Basement Staff Lav	Sink	5.7	6/4/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-10	Girls Lav by Room 200 Center Sink	Sink	5.5	6/5/24	8/15/24	n/a	Hand Wash Only	8/24/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-16	Room 206/204 Science Office Right Sink	Sink	15.1	6/5/24	8/15/24	n/a	Hand Wash Only	8/24/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-17	Room 206/204 Science Office Left Sink	Sink	11.3	6/5/24	8/15/24	n/a	Hand Wash Only	8/24/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-56	Room 108A	Sink	11.3	6/5/24	8/15/24	n/a	Hand Wash Only	8/24/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-70	Girls Lav by Room 100 Right Sink	Sink	5.3	6/5/24	8/15/24	n/a	Hand Wash Only	8/24/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-104	Kitchen Dish Sprayer South Wall Right	Sink	72.2	6/5/24	8/15/24	n/a	Hand/Dish Wash Only	8/24/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-105	Kitchen Dish Spray by 3 Bay	Sink	645	6/5/24	8/15/24	n/a	Hand/Dish Wash Only	8/24/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-106	Kitchen Faucet Next to 3 Bay	Sink	138	6/5/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	12/9/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LMS	104.2-107	Kitchen 3 Bay Left	Sink	16.2	6/5/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	12/9/24	installed filter	4/5/25	6/2/25	15.3	n/a	6/27/25	10/21/25	2.6 - Cleared	10/22/25	n/a	n/a	n/a	n/a
LMS	104.2-108	Kitchen 3 Bay Right	Sink	7.9	6/5/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	12/9/24	installed filter	4/5/25	6/2/25	8.5	n/a	6/27/25	10/21/25	<1 - Cleared	10/22/25	n/a	n/a	n/a	n/a
WSS	104.3-6	Kitchen Handwash in Corner	Sink	7.5	6/5/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
WSS	104.3-11	Kitchen Single Sink by Coffee	sink	10.1	6/5/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/27/24	installed filter	4/5/25	6/2/25	4.7 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
WSS	104.3-16	Serving Area Handwash	Sink	5.8	6/5/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
WSS	104.3-18	Kitchen Handwash by Stove	Sink	29.1	6/5/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
WSS	104.3-40	Room B103	Sink	11.1	6/5/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
WSS	104.3-130	Room B203	Sink	6.6	6/5/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
WSS	104.3-180	Room C219	Sink	10.9	6/5/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

2024 Water Testing Remediation Plan-last updated 5/4/26

WSS	104.3-211	Room D220	Sink	6.9	6/5/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-6	Room 107	Sink	7.7	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-9	Room 108 Bathroom Sink	Sink	13.6	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-12	Bathroom outside of Room 109	Sink	15.4	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-15	Room 114 Lav	Sink	17.1	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-18	Room 109 Lav	Sink	14.6	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-21	Room 113 - Lav	Sink	15.6	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-24	Room 110 Art Room Lav	Sink	26.3	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-27	Room 112 - Lav	Sink	15.6	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-33	Room 207 - Lav	Sink	10.6	6/5/24	8/15/24	n/a	Hand Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-36	Room 208 - Lav	Sink	11.8	6/5/24	8/15/24	n/a	Hand Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-39	Room 206 - Lav	Sink	14.2	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-42	Room 209 - Lav	Sink	7.7	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-45	Room 205 - Lav	Sink	8.9	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-46	All Gender. Bathroom	Sink	13.8	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-49	Room 204 - Lav	Sink	9.3	6/5/24	8/15/24	n/a	Hand Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-52	Room 203 - Lav	Sink	13.2	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-55	All Gender Bathroom	Sink	20.7	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-63	Room 120	Sink	6.1	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-68	127 Library Media Center	Sink	11.8	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-69	Room 126 Main	Sink	13.2	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-70	Room 126 Lav	Sink	6.3	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-71	Room 125 Main	Sink	11.5	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-72	Room 125 Lav	Sink	12.5	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-74	Rom 106 Nurse Lav	Sink	12.2	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-73	Room 106 Nurse Main	Sink	12.4	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-75	Outside of Room 106	Drinking Fountain	5.1	6/5/24	8/15/24	8/26/24	Replace	10/31/24	installed new bottle filler	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-76	Outside of Room 227	Drinking Fountain	8.5	6/5/24	8/15/24	8/26/24	Replace	10/1/24	installed new bottle filler	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-81	Room 223	Sink	23.9	6/5/24	8/15/24	n/a	Hand Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CP	104.4-86	Girls Lav 220 Far Left	Sink	8	6/5/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-1	Gym Office Lav	Sink	9.1	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-2	Gym Classroom	Sink	6.1	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-3	Kitchen Sprayer	Sink	18.7	6/6/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	10/31/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-10	Gym Passage Left Lav	Sink	12.9	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-23	Girls Lav Rlght	Sink	8.2	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-27	Room 105	Sink	21	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-30	Room 109	Sink	9.1	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-32	Room 108	Sink	9.7	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-35	Principal Office Lav	Sink	8	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-38	Nurse Office Lav	Sink	8.2	6/6/24	8/15/24	n/a	Hand Wash Only, Filter to be installed.	10/31/24	installed filter	4/5/25	6/2/25	2.0 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-45	Room 132	Bubbler	5.4	6/6/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-61	Room 129	sink	5.9	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-64	Room 126	Sink	6.5	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-67	Room 128	Sink	6.1	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-69	Room 127	Bubbler	5.3	6/6/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-74	Room 118B	Sink	28.6	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-1	Kitchen 3 Bay Left	Sink	7.2	6/7/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	12/12/24	installed filter	4/5/25	6/2/25	6.5	n/a	6/27/25	10/21/25	2.8 - Cleared	10/22/25	n/a	n/a	n/a	n/a
HV	104.6-5	Cafeteria Fountain	Drinking Fountain	6.6	6/7/24	8/15/24	8/27/24	Replace	10/1/24	installed new bottle filler	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-11	Principal's Office Lavatory	Sink	17.6	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-14	Room 1 Lavatory	Sink	29.4	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-26	Room 5 Lavatory	Sink	18.8	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-29	Room 4 Lavatory	Sink	5.4	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-33	Room 9 Main	Bubbler	6.3	6/7/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-36	Nurse Exam	Sink	7.5	6/7/24	8/15/24	n/a	Hand Wash Only	NO	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-43	Room 32 Art Office Right	Sink	5.3	6/7/24	8/15/24	n/a	Hand Wash Only	NO	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-52	Room 11	Sink	7.7	6/7/24	8/15/24	n/a	Hand Wash Only	NO	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-53	Room 11	Bubbler	6	6/7/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-63	Girls Locker Coach Office	Sink	7.3	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-64	Girls Locker Room	Sink	24.2	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-67	Boys Gym Office	Sink	5.3	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-74	Room 17	Sink	5.6	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-98	Basement	Sink	10.4	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-3	Kitchen Staff Lav	Sink	5.5	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-4	Room 3	Sink	10.8	6/14/24	6/28/24	n/a	New faucet in construction updates, Summer 2024	8/27/24	New Faucet Installed	4/5/25	6/2/25	3.7 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-5	Room 6	Sink	11.7	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Summer 2025.	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-6	Room 5	Sink	5.9	6/14/24	6/28/24	n/a	New faucet in construction updates, Summer 2024	8/27/24	New Faucet Installed	4/5/25	6/2/25	3.4 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-7	Room 8	Sink	5.7	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Summer 2025.	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-2	Room 1	Sink	20.1	6/14/24	6/28/24	n/a	New faucet in construction updates, Summer 2024	8/27/24	New Faucet Installed	4/5/25	6/2/25	4.3 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-8	Room 7	Sink	10	6/14/24	6/28/24	n/a	New faucet in construction updates, Summer 2024	8/27/24	New Faucet Installed	4/5/25	6/2/25	3.4 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-9	Room 10	Sink	7.3	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Summer 2025.	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

2024 Water Testing Remediation Plan-last updated 5/4/26

JAS	104.7-3	Room 4	Sink	7.3	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Summer 2025.	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-10	Room 9	Sink	7.7	6/14/24	6/28/24	n/a	New faucet in construction updates, Summer 2024	8/27/24	New Faucet Installed	4/5/25	6/2/25	16.4	n/a	6/27/25	10/21/25	12.4	n/a	4/8/26	4/30/26	<1 - Cleared	5/4/26
JAS	104.7-12	Room 11	Sink	6.5	6/14/24	6/28/24	n/a	New faucet in construction updates, Summer 2024	8/27/24	New Faucet Installed	4/5/25	6/2/25	1.9 - Cleared	6/6/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-24	Library Media Center	Sink	6.9	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-30	Room 13	Sink	6.2	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-39	Room 24	Sink	7.6	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-40	Room 23	Sink	8.7	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-41	Art Room West Side Left Single Handle Fixture	Sink	9	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-46	Art Room East Side Right Single Handle Fixture	Sink	35.1	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-55	Kitchen Handwash	Sink	6.6	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	3.7 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-56	Kitchen Prep Table Single Bay	Sink	5.2	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	7.5	n/a	6/27/25	10/21/25	<1 - Cleared	10/22/25	n/a	n/a	n/a	n/a
JAS	104.7-57	Kitchen Pan Fill	Sink	107	6/14/24	8/15/24	n/a	Hand/Dish Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-58	Kitchen 3 Bay Left Sink	Sink	9.9	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	5.3	n/a	6/27/25	10/21/25	<1 - Cleared	10/22/25	n/a	n/a	n/a	n/a
JAS	104.7-59	Kitchen 3 Bay Right Sink	Sink	11.1	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	1.9 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
DO	104.8-1	Basement Men's Lav	Sink	7.2	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
DO	104.8-3	Basement Kitchen	Sink	7.9	6/7/24	8/15/24	n/a	Hand Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
DO	104.8-5	Superintendent's Office Lav	Sink	6.2	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-5	Men's Lav Right	Sink	23.6	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-6	Women's Lav Left	Sink	29.8	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-7	Women's Lav Middle	Sink	20.1	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-8	Women's Lav Right	Sink	12.6	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-10	Locker Room Middle	Sink	19.4	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-11	Locker Room Back	Sink	7.7	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-13	Back Break Room Front	Sink	11.4	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-15	Back Break Room Left	Sink	13.3	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-16	Back Break Room Right	Sink	15.5	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-1	Kitchen Sink	Sink	8.7	6/7/24	8/15/24	n/a	Hand Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-4	Board Room Lav	Sink	5.5	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-16	Room 108	Sink	8.7	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-20	Room 119 Lav	Sink	14.8	6/7/24	8/15/24	n/a	Hand Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-22	Boys Locker Room	Sink	8.8	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-23	Girls Locker Room	Sink	6.1	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-24	Room 125	Sink	13.8	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-28	Lav Near Room 127	Sink	6	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-29	Women's Lav Across From Room 131 Close to I	Sink	46.7	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-30	Women's Lav Across From Room 131 Center Ri	Sink	23.5	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-33	Men's Lav Next to Room 136 Close to Door	Sink	9.3	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-34	Men's Lav Next to Room 136 Center Right	Sink	8.6	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-35	Men's Lav Next to Room 136 Center Left	Sink	12.1	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-36	Men's Lav Next to Room 136 Close to Window	Sink	6.4	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-37	Room 135	Sink	49.9	6/7/24	8/15/24	n/a	Hand Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-42	Room 131	Sink	40.2	6/7/24	8/15/24	n/a	Hand Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a