Stohl BUFFALO ROCHESTER ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

April 30, 2026

Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, New York 14086

Re: Lead Testing in School Drinking Water Additional Initial Sampling

Dear Mr. Bryniarski:

Stohl Environmental was retained by the Lancaster Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building on April 8, 2026:

- **John A. Sciole Elementary – 86 Alys Drive, Lancaster, New York**

Based upon the sampling and analysis performed, no new sources of potable water at John A. Sciole Elementary have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. A summary of the results is as follows:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
104.7-100	Room 2	Bottle Fill	<1.00
104-7-101	Room 4	Bottle Fill	<1.00
104-7-102	Room 6	Bottle Fill	4.90
104-7-103	Room 8	Bottle Fill	N/A
104-7-104	Room 10	Bottle Fill	<1.00
104-7-105	Room 10	Sink	2.96
104-7-106	Room 12	Bottle Fill	<1.00
104-7-107	Room 12	Sink	1.91

If after reviewing this letter you have any questions, or if we can be of assistance in any other way, please do not hesitate to call. Thank you for the opportunity to be of service to the Lancaster Central School District.

Sincerely,
Stohl Environmental, LLC.

Michael Scinta
EPA Lead Risk Assessor

Enc.

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 26-04-03366

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Received Date: 04/17/2026
Reported Date: 04/21/2026
Sampled By: Paul Maier
Tech Certification #:

Project/Test Address: 2023-104.7; John A Sciole Elementary; 86 Alys Dr; Depew, NY 14043

Client Number: 33-5980

Laboratory Results

Fax Number: 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
26-04-03366-001	104.7-100	04/08/2026	ROOM 2	<1.00	04/21/2026	
26-04-03366-002	104.7-101	04/08/2026	ROOM 4	<1.00	04/21/2026	
26-04-03366-003	104.7-102	04/08/2026	ROOM 6	4.90	04/21/2026	
26-04-03366-004	104.7-104	04/08/2026	ROOM 10	<1.00	04/21/2026	
26-04-03366-005	104.7-105	04/08/2026	ROOM 10	2.96	04/21/2026	
26-04-03366-006	104.7-106	04/08/2026	ROOM 12	<1.00	04/21/2026	
26-04-03366-007	104.7-107	04/08/2026	ROOM 12	1.91	04/21/2026	

Environmental Hazards Services, L.L.C

Client Number: 33-5980 Report Number: 26-04-03366

Project/Test Address: 2023-104.7; John A Sciole Elementary; 86 Alys Dr; Depew, NY 14043

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NY 11714

Reviewed By Authorized Signatory: Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023-104.7

Client: Lancaster CSD Contact: Michael Bryniarski

Building: John A Sciole Elementary Location: 86 Alys Dr Depew, NY 14043

LEAD		Turnaround
Water by 200.8	X	72 Hours

Sample #	Location	Outlet Type	Time
104.7-100	Room 2	Bottle Fill	14:35
104.7-101	Room 4	Bottle Fill	14:37
104.7-102	Room 6	Bottle Fill	14:39
104.7-103	Room 8 * Sample bottle received empty JO 4/17/26	Bottle Fill	14:41
104.7-104	Room 10	Bottle Fill	14:43
104.7-105	Room 10	Sink	14:43
104.7-106	Room 12	Bottle Fill	14:45
104.7-107	Room 12	Sink	14:45

26-04-03366

Due Date:
04/22/2026
(Wednesday)
AE

Notes:
Please e-mail lab results to labs@stohlenv.com ☑ If checked, also e-mail results to: Rfranjoine@stohlenvironmental.com

Sampled By: P. Maier Print Name Stohl Env: P. Maier Date: 4/8/2026

Relinquished By: M. Scinta Print Name Stohl Env: M. Scinta Date: 4/15/2026

Received (Name / Lab): J Dannaf EHS Date: 4/17/26 Time: 12:57pm

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2027
Issued April 01, 2026

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Metals I

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

Serial No.: 72235

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.