Stohl ENVIRONMENTAL BUFFALO ROCHESTER

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

April 30, 2026

Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, New York 14086

Re: Lead Testing in School Drinking Water Additional Initial Sampling

Dear Mr. Bryniarski:

Stohl Environmental was retained by the Lancaster Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building on April 8, 2026:

• John A. Sciole Elementary – 86 Alys Drive, Lancaster, New York

Based upon the sampling and analysis performed, no new sources of potable water at John A. Sciole Elementary have been identified as having lead concentrations in water above the N Y S Action Level of 5 parts per billion. A summary of the results is as follows:

Sample Number: 104.7-100
Location: Room 2
Fixture/Outlet Type: Bottle Fill
Laboratory Analysis (in ppb): <1.00

Sample Number: 104.7-101
Location: Room 4
Fixture/Outlet Type: Bottle Fill
Laboratory Analysis (in ppb): <1.00

Sample Number: 104.7-102
Location: Room 6
Fixture/Outlet Type: Bottle Fill
Laboratory Analysis (in ppb): 4.90

Sample Number: 104.7-103
Location: Room 8
Fixture/Outlet Type: Bottle Fill
Laboratory Analysis (in ppb): N/A

Sample Number: 104.7-104
Location: Room 10
Fixture/Outlet Type: Bottle Fill
Laboratory Analysis (in ppb): <1.00


Sample Number: 104.7-105
Location: Room 10
Fixture/Outlet Type: Sink
Laboratory Analysis (in ppb): 2.96

Sample Number: 104.7-106
Location: Room 12
Fixture/Outlet Type: Bottle Fill
Laboratory Analysis (in ppb): <1.00

Sample Number: 104.7-107
Location: Room 12
Fixture/Outlet Type: Sink
Laboratory Analysis (in ppb): 1.91

If after reviewing this letter you have any questions, or if we can be of assistance in any other way, please do not hesitate to call. Thank you for the opportunity to be of service to the Lancaster Central School District.

Sincerely,
Stohl Environmental, L L C.



Michael Scinta
E P A Lead Risk Assessor