



February 2026

Joshua Collop
Pasco School District
1215 West Lewis Street
Pasco, WA 99301

Via email: jcollop@PSD1.org

Regarding: Post-Remediation Drinking Water Sampling for Lead
Pasco Senior High School
1108 N 10th Avenue
Pasco, WA 99301
Project 26003455

Dear Mr. Collop:

On January 28, 2026, Apex Companies, LLC (Apex), performed limited drinking water sampling at Pasco Senior High School for the Pasco School District (Client). Sampling was conducted in response to the replacement of drinking water fixtures within the structures. Sampling was limited to the faucets identified by Client for post-remediation testing. Drinking water in Washington State is regulated by the State of Washington Engrossed Second Substitute House Bill 1139. The testing process followed the protocols described in the Environmental Protection Agency (EPA) document, "*3Ts for Reducing Lead in Drinking Water in Schools*."

BACKGROUND AND SAMPLING PROCEDURE

The sampling methodology followed the protocol described in Section 4 of the Environmental Protection Agency (EPA) document *3Ts for Reducing Lead in Drinking Water in Schools and Childcare Facilities, October 2018* (3Ts) and guidelines established by OHA and ODE. Following these guidelines, Apex assigned an identification number to the fixture and collected a first draw sample. The first draw sample consisted of the first 250 milliliters (mL) of water drawn from the fixture after the water had been sitting stagnant for 8 to 18 hours. The 3Ts' sampling protocol is designed to maximize the likelihood that the highest concentrations of lead in water used for consumption are identified. Because 250 mL samples are relatively small and thus undiluted, the action level set by the EPA for lead is 15 parts per billion (ppb).

The samples were delivered under chain of custody to Apex Laboratories of Tigard, Oregon, for lead analysis.

FINDINGS

This sampling event included 14 water outlets. Post remediation sampling results showed one faucet with elevated lead levels. Washington State Department of Health guidance requires the creation of an action plan and remediation of any outlets testing above 5 ppb in accordance with Chapter 28A.210.410 RCW. No Faucets tested above the 15 ppb immediate action level.

Sample Number	Sample Location	Sample Date	Lead Concentration (ppb)
PHS-R-01	Room 137B Bubbler	1/28/2026	1.61 pbb
PHS-R-02	Room 135 Bubbler	1/28/2026	1.19 pbb
PHS-R-03	Room 199F Faucet	1/28/2026	2.23 pbb
PHS-R-04	Room 191 Faucet	1/28/2026	1.86 pbb
PHS-R-05	Room 256C Left Sink	1/28/2026	3.94 pbb
PHS-R-06	Room 256C Center Sink	1/28/2026	2.76 pbb
PHS-R-07	Room 256C Center Sprayer	1/28/2026	1.11 pbb
PHS-R-08	Room 256C Right Sink	1/28/2026	1.72 pbb
PHS-R-09	Room 223 Faucet	1/28/2026	0.418 pbb
PHS-R-10	Room 179C Faucet	1/28/2026	2.37 pbb
PHS-R-11	Room 133 Faucet	1/28/2026	0.847 pbb
PHS-R-12	Room 136A Sink	1/28/2026	1.73 pbb
PHS-R-13	Room 137 B Faucet	1/28/2026	1.43 pbb
PHS-R-14	Room 133 Bubbler	1/28/2026	14.7 pbb

Table 1. Laboratory results are reported in $\mu\text{g/L}$, a measurement equivalent to ppb. ppb = parts per billion

For additional sample detail, please refer to the attached laboratory report and chain of custody form. The laboratory analytical results are reported in micrograms per liter ($\mu\text{g/L}$), a unit of measure that is equivalent to ppb.

The EPA protocol recommends that follow-up flush sampling be conducted at fixture locations where first draw sample contain lead concentrations of greater than 15 ppb. Apex does not recommend the collection of any follow-up flush samples from this site.

Please feel free to contact me at 509.778.0641 or Tayvin.Trujillo@apexcos.com with any questions or comments.

Sincerely,

Tayvin Trujillo

Tayvin Trujillo
Industrial Hygiene Technician
Apex Companies, LLC

Attachments: Laboratory Results
Chain-of-Custody Form



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

Thursday, February 5, 2026

Justin Ware

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106

Richland, WA 99352

RE: A6A1834 - WWPS - Pasco Senior High / 26003455

Thank you for using Apex Laboratories. We greatly appreciate your business and strive to provide the highest quality services to the environmental industry.

Enclosed are the results of analyses for work order A6A1834, which was received by the laboratory on 1/29/2026 at 2:00:00PM.

If you have any questions concerning this report or the services we offer, please feel free to contact me by email at: jwoodcock@apex-labs.com, or by phone at 503-718-2323.

Please note: All samples will be disposed of within 30 days of sample receipt, unless prior arrangements have been made.

Cooler Receipt Information

Acceptable Receipt Temperature is less than, or equal to, 6 degC (not frozen), or received on ice the same day as sampling.

(See Cooler Receipt Form for details)

Default Cooler 11.3 degC

This Final Report is the official version of the data results for this sample submission, unless superseded by a subsequent, labeled amended report.

All other deliverables derived from this data, including Electronic Data Deliverables (EDDs), CLP-like forms, client requested summary sheets, and all other products are considered secondary to this report.



Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106
Richland, WA 99352

Project: **WWPS**

Project Number: **Pasco Senior High / 260034**

Project Manager: **Justin Ware**

Report ID:

A6A1834 - 02 05 26 1349

ANALYTICAL REPORT FOR SAMPLES

SAMPLE INFORMATION

Client Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
PHS-R-01	A6A1834-01	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-02	A6A1834-02	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-03	A6A1834-03	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-04	A6A1834-04	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-05	A6A1834-05	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-06	A6A1834-06	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-07	A6A1834-07	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-08	A6A1834-08	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-09	A6A1834-09	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-10	A6A1834-10	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-11	A6A1834-11	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-12	A6A1834-12	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-13	A6A1834-13	Drinking Water	01/21/26 00:00	01/29/26 14:00
PHS-R-14	A6A1834-14	Drinking Water	01/21/26 00:00	01/29/26 14:00

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager

**ANALYTICAL REPORT****Apex Laboratories, LLC**6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Apex Companies, LLC - Richland400 Bradley Blvd, Ste 106
Richland, WA 99352Project: **WWPS**Project Number: **Pasco Senior High / 2600345**Project Manager: **Justin Ware****Report ID:****A6A1834 - 02 05 26 1349****ANALYTICAL SAMPLE RESULTS****Total Metals in Drinking Water by EPA 200.8 (ICPMS)**

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
PHS-R-01 (A6A1834-01) Matrix: Drinking Water								
Batch: 26A0944								
Copper	512	---	2.00	ug/L	1	01/31/26 15:55	EPA 200.8	
Lead	1.61	---	0.200	ug/L	1	01/31/26 15:55	EPA 200.8	
PHS-R-02 (A6A1834-02) Matrix: Drinking Water								
Batch: 26A0944								
Copper	341	---	2.00	ug/L	1	01/31/26 16:01	EPA 200.8	
Lead	1.19	---	0.200	ug/L	1	01/31/26 16:01	EPA 200.8	
PHS-R-03 (A6A1834-03) Matrix: Drinking Water								
Batch: 26A0944								
Copper	422	---	2.00	ug/L	1	01/31/26 16:03	EPA 200.8	
Lead	2.23	---	0.200	ug/L	1	01/31/26 16:03	EPA 200.8	
PHS-R-04 (A6A1834-04) Matrix: Drinking Water								
Batch: 26A0944								
Copper	357	---	2.00	ug/L	1	01/31/26 16:04	EPA 200.8	
Lead	1.86	---	0.200	ug/L	1	01/31/26 16:04	EPA 200.8	
PHS-R-05 (A6A1834-05) Matrix: Drinking Water								
Batch: 26A0944								
Copper	521	---	2.00	ug/L	1	01/31/26 16:06	EPA 200.8	
Lead	3.94	---	0.200	ug/L	1	01/31/26 16:06	EPA 200.8	
PHS-R-06 (A6A1834-06) Matrix: Drinking Water								
Batch: 26A0944								
Copper	571	---	2.00	ug/L	1	01/31/26 16:08	EPA 200.8	
Lead	2.76	---	0.200	ug/L	1	01/31/26 16:08	EPA 200.8	
PHS-R-07 (A6A1834-07) Matrix: Drinking Water								
Batch: 26A0944								
Copper	524	---	2.00	ug/L	1	01/31/26 16:10	EPA 200.8	
Lead	1.11	---	0.200	ug/L	1	01/31/26 16:10	EPA 200.8	
PHS-R-08 (A6A1834-08) Matrix: Drinking Water								
Batch: 26A0944								

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

**ANALYTICAL REPORT****Apex Laboratories, LLC**6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062**Apex Companies, LLC - Richland**400 Bradley Blvd, Ste 106
Richland, WA 99352Project: **WWPS**Project Number: **Pasco Senior High / 2600345**Project Manager: **Justin Ware****Report ID:****A6A1834 - 02 05 26 1349****ANALYTICAL SAMPLE RESULTS****Total Metals in Drinking Water by EPA 200.8 (ICPMS)**

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
PHS-R-08 (A6A1834-08)				Matrix: Drinking Water				
Copper	451	---	2.00	ug/L	1	01/31/26 16:12	EPA 200.8	
Lead	1.72	---	0.200	ug/L	1	01/31/26 16:12	EPA 200.8	
PHS-R-09 (A6A1834-09)				Matrix: Drinking Water				
Batch: 26A0944								
Copper	283	---	2.00	ug/L	1	01/31/26 16:19	EPA 200.8	
Lead	0.418	---	0.200	ug/L	1	01/31/26 16:19	EPA 200.8	
PHS-R-10 (A6A1834-10)				Matrix: Drinking Water				
Batch: 26A0944								
Copper	343	---	2.00	ug/L	1	01/31/26 16:21	EPA 200.8	
Lead	2.37	---	0.200	ug/L	1	01/31/26 16:21	EPA 200.8	
PHS-R-11 (A6A1834-11)				Matrix: Drinking Water				
Batch: 26A0944								
Copper	386	---	2.00	ug/L	1	01/31/26 16:23	EPA 200.8	
Lead	0.847	---	0.200	ug/L	1	01/31/26 16:23	EPA 200.8	
PHS-R-12 (A6A1834-12)				Matrix: Drinking Water				
Batch: 26A0944								
Copper	225	---	2.00	ug/L	1	01/31/26 16:25	EPA 200.8	
Lead	1.73	---	0.200	ug/L	1	01/31/26 16:25	EPA 200.8	
PHS-R-13 (A6A1834-13)				Matrix: Drinking Water				
Batch: 26A0944								
Copper	440	---	2.00	ug/L	1	01/31/26 16:27	EPA 200.8	
Lead	1.43	---	0.200	ug/L	1	01/31/26 16:27	EPA 200.8	
PHS-R-14 (A6A1834-14)				Matrix: Drinking Water				
Batch: 26A0944								
Copper	456	---	2.00	ug/L	1	01/31/26 16:29	EPA 200.8	
Lead	14.7	---	0.200	ug/L	1	01/31/26 16:29	EPA 200.8	

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106
Richland, WA 99352Project: WWPS

Project Number: Pasco Senior High / 260034

Project Manager: Justin Ware

Report ID:

A6A1834 - 02 05 26 1349

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 26A0944 - EPA 200.8 Direct Analysis							Drinking Water					
Blank (26A0944-BLK1)		Prepared: 01/30/26 07:04		Analyzed: 01/31/26 15:40								
EPA 200.8												
Copper	ND	---	2.00	ug/L	1	---	---	---	---	---	---	
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	
LCS (26A0944-BS1)		Prepared: 01/30/26 07:04		Analyzed: 01/31/26 15:42								
EPA 200.8												
Copper	96.2	---	2.01	ug/L	1	100	---	96	85 - 115%	---	---	
Lead	14.6	---	0.201	ug/L	1	15.0	---	98	85 - 115%	---	---	
Duplicate (26A0944-DUP1)		Prepared: 01/30/26 07:04		Analyzed: 01/31/26 15:57								
QC Source Sample: PHS-R-01 (A6A1834-01)												
EPA 200.8												
Copper	526	---	2.00	ug/L	1	---	512	---	---	3	20%	
Lead	1.61	---	0.200	ug/L	1	---	1.61	---	---	0.2	20%	
Matrix Spike (26A0944-MS1)		Prepared: 01/30/26 07:04		Analyzed: 01/31/26 15:59								
QC Source Sample: PHS-R-01 (A6A1834-01)												
EPA 200.8												
Copper	625	---	2.01	ug/L	1	100	512	112	70 - 130%	---	---	
Lead	16.2	---	0.201	ug/L	1	15.0	1.61	97	70 - 130%	---	---	
Matrix Spike (26A0944-MS2)		Prepared: 01/30/26 07:04		Analyzed: 01/31/26 16:30								
QC Source Sample: PHS-R-14 (A6A1834-14)												
EPA 200.8												
Copper	536	---	2.01	ug/L	1	100	456	80	70 - 130%	---	---	
Lead	28.0	---	0.201	ug/L	1	15.0	14.7	89	70 - 130%	---	---	

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

**ANALYTICAL REPORT****Apex Laboratories, LLC****6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062****Apex Companies, LLC - Richland****400 Bradley Blvd, Ste 106
Richland, WA 99352**Project: **WWPS**Project Number: **Pasco Senior High / 260034**Project Manager: **Justin Ware****Report ID:****A6A1834 - 02 05 26 1349****SAMPLE PREPARATION INFORMATION****Total Metals in Drinking Water by EPA 200.8 (ICPMS)****Prep: EPA 200.8 Direct Analysis**

Lab Number	Matrix	Method	Sampled	Prepared	Sample Initial/Final	Default Initial/Final	RL Prep Factor
Batch: 26A0944							
A6A1834-01	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-02	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-03	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-04	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-05	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-06	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-07	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-08	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-09	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-10	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-11	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-12	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-13	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00
A6A1834-14	Drinking Water	EPA 200.8	01/21/26 00:00	01/30/26 07:04	10mL/10mL	10mL/10mL	1.00

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106
Richland, WA 99352

Project: WWPS

Project Number: Pasco Senior High / 260034

Project Manager: Justin Ware

Report ID:

A6A1834 - 02 05 26 1349

QUALIFIER DEFINITIONS

Client Sample and Quality Control (QC) Sample Qualifier Definitions:

There are No Qualifiers on Sample or QC Data for this report

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106
Richland, WA 99352

Project: **WWPS**

Project Number: **Pasco Senior High / 260034**

Project Manager: **Justin Ware**

Report ID:

A6A1834 - 02 05 26 1349

REPORTING NOTES AND CONVENTIONS:

Abbreviations:

DET Analyte DETECTED at or above the detection or reporting limit.
ND Analyte NOT DETECTED at or above the detection or reporting limit.
NR Result Not Reported.
RPD Relative Percent Difference. RPDs for Matrix Spikes and Matrix Spike Duplicates are based on concentration, not recovery.

Detection Limits: Limit of Detection (LOD)

Limits of Detection (LODs) are normally set at a level of one half the validated Limit of Quantitation (LOQ).
If no value is listed ('-----'), then the data has not been evaluated below the Reporting Limit.

Reporting Limits: Limit of Quantitation (LOQ)

Validated Limits of Quantitation (LOQs) are reported as the Reporting Limits for all analyses where the LOQ, MRL, PQL or CRL are requested. The LOQ represents a level at or above the low point of the calibration curve, that has been validated according to Apex Laboratories' comprehensive LOQ policies and procedures.

Reporting and Detection Limits: Default Limits

Default Reporting and Detection Limits are based on 100% dry weight with the minimum dilution for the analysis. Reporting and Detection Limits are raised due to moisture content, additional dilutions required for analysis, matrix interferences and in other cases, as necessary.

Reporting Conventions:

Basis: Results for soil samples are generally reported on a 100% dry weight basis.
The Result Basis is listed following the units as "dry", "wet", or "" (blank) designation.

"dry" Sample results and Reporting Limits are reported on a dry weight basis. (i.e. "ug/kg dry")
See Percent Solids section for details of dry weight analysis.

"wet" Sample results and Reporting Limits for this analysis are normally dry weight corrected, but have not been modified in this case.

" " Results without 'wet' or 'dry' designation are not normally dry weight corrected. These results are considered 'As Received'.

QC Source:

In cases where there is insufficient sample provided for Sample Duplicates and/or Matrix Spikes, a Lab Control Sample Duplicate (LCS Dup) may be analyzed to demonstrate accuracy and precision of the extraction batch.

Non-Client Batch QC Samples (Duplicates and Matrix Spike/Duplicates) are not included in this report. Please request a Full QC report if this data is required.

Miscellaneous Notes:

" --- " QC results are not applicable. For example, % Recoveries for Blanks and Duplicates, % RPD for Blanks, Blank Spikes and Matrix Spikes, etc.

" *** " Used to indicate a possible discrepancy with the Sample and Sample Duplicate results when the %RPD is not available. In this case, either the Sample or the Sample Duplicate has a reportable result for this analyte, while the other is Non Detect (ND).

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106
Richland, WA 99352

Project: **WWPS**

Project Number: **Pasco Senior High / 260034**

Project Manager: **Justin Ware**

Report ID:

A6A1834 - 02 05 26 1349

REPORTING NOTES AND CONVENTIONS (Cont.):

Blanks:

Standard practice is to evaluate the results from Blank QC Samples down to a level equal to one half of the Reporting Limit (RL).

Blank results for gravimetric analyses are evaluated to the Reporting Level, not to half of the Reporting Level.

-For Blank hits falling between ½ the RL and the RL (J flagged hits), the associated sample and QC data will receive a 'B-02' qualifier.

-For Blank hits above the RL, the associated sample and QC data will receive a 'B' qualifier, per Apex Laboratories' Blank Policy.

For further details, please request a copy of this document.

Sample results flagged with a 'B' or 'B-02' qualifier are potentially biased high if the sample results are less than ten times the level found in the blank for inorganic analyses, or less than five times the level found in the blank for organic analyses.

'B' and 'B-02' qualifications are only applied to sample results detected above the Reporting Level.

Preparation Notes:

Mixed Matrix Samples:

Water Samples:

Water samples containing significant amounts of sediment are decanted or separated prior to extraction, and only the water portion analyzed, unless otherwise directed by the client.

Soil and Sediment Samples:

Soil and Sediment samples containing significant amounts of water are decanted prior to extraction, and only the solid portion analyzed, unless otherwise directed by the client.

Sampling and Preservation Notes:

Certain regulatory programs, such as National Pollutant Discharge Elimination System (NPDES), require that activities such as sample filtration (for dissolved metals, orthophosphate, hexavalent chromium, etc.) and testing of short hold analytes (pH, Dissolved Oxygen, etc.) be performed in the field (on-site) within a short time window. In addition, sample matrix spikes are required for some analyses, and sufficient volume must be provided, and billable site specific QC requested, if this is required. All regulatory permits should be reviewed to ensure that these requirements are being met.

Data users should be aware of which regulations pertain to the samples they submit for testing. If related sample collection activities are not approved for a particular regulatory program, results should be considered estimates. Apex Laboratories will qualify these analytes according to the most stringent requirements, however results for samples that are for non-regulatory purposes may be acceptable.

Benzofluoranthene Isomer Reporting:

Due to coelutions present on the analytical column, the results reported for Benzo(b+j)fluoranthene(s) represent the concentration of both the Benzo(b)fluoranthene and Benzo(j)fluoranthene isomers. Calibration, validation and accreditation are based on the Benzo(b)fluoranthene isomer.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106
Richland, WA 99352

Project: **WWPS**

Project Number: **Pasco Senior High / 260034**

Project Manager: **Justin Ware**

Report ID:

A6A1834 - 02 05 26 1349

Decanted Samples:

Soils/Sediments:

Unless TCLP analysis is required or there is notification otherwise for a specific project, all Soil and Sediments containing excess water are decanted prior to analysis in order to provide the most representative sample for analysis.

Water Samples:

Water samples containing solids and sediment may need to be decanted in order to eliminate these particulates from the water extractions. In the case of organics extractions, a solvent rinse of the container will not be performed.

Volatiles Soils (5035s)

Samples that are field preserved by 5035 for volatiles are dry weight corrected using the same dry weight correction as for normal analyses.

In the case of decanted samples, the dry weight may be performed on a decanted sample, while the aliquot for 5035 may not have been treated the same way. If this is a concern, please submit separate containers for dry weight analysis for volatiles can be provided.

All samples decanted in the laboratory are noted in this report with the DCNT qualifier indicating the sample was decanted.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106
Richland, WA 99352

Project: WWPS

Project Number: Pasco Senior High / 260034

Project Manager: Justin Ware

Report ID:

A6A1834 - 02 05 26 1349

LABORATORY ACCREDITATION INFORMATION

ORELAP Certification ID: OR100062 (Primary Accreditation)

EPA ID: OR01039

All methods and analytes reported from work performed at Apex Laboratories are included on Apex Laboratories' ORELAP Scope of Certification, with the exception of any analyte(s) listed below:

Apex Laboratories

Matrix	Analysis	TNI_ID	Analyte	TNI_ID	Accreditation
--------	----------	--------	---------	--------	---------------

All reported analytes are included in Apex Laboratories' current ORELAP scope.

Secondary Accreditations

Apex Laboratories also maintains reciprocal accreditation with non-TNI states (Washington DOE), as well as other state specific accreditations not listed here.

Subcontract Laboratory Accreditations

Subcontracted data falls outside of Apex Laboratories' Scope of Accreditation.

Please see the Subcontract Laboratory report for full details, or contact your Project Manager for more information.

Field Testing Parameters

Results for Field Tested data are provided by the client or sampler, and fall outside of Apex Laboratories' Scope of Accreditation.

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106

Richland, WA 99352

Project: WWPSProject Number: Pasco Senior High / 2600345Project Manager: Justin Ware

Report ID:

A6A1834 - 02 05 26 1349

APEX LABS		CHAIN OF CUSTODY		Lab # <u>A6A1834</u> - COC <u>1</u> of <u>2</u>	
6700 SW Sandburg St., Tigard, OR 97223 Ph: 503-718-2323		Project Name: <u>Pasco Senior High</u>		Project # <u>2600 3455</u>	
Company: <u>APEX</u>		Project Mgr: <u>Justin Ware</u>		PO #	
Address:		Phone:		Email: <u>Justin.Ware@Pasco.edu</u>	
Sampled by: <u>Justin Ware</u>		ANALYSIS REQUEST			
Site Location:					
State _____					
County _____					
SAMPLE ID					
DATE					
TIME					
MATRIX					
# OF CONTAINERS					
NWTPH-HCID					
NWTPH-GX					
8260 BTEX					
8260 RBDM VOCs					
8260 Halo VOCs					
8260 VOCs Full List					
8270 SIM PAHs					
8270 Semi-Vols Full List					
8082 PCBs					
8081 Pesticides					
RCRA Metals (8)					
Priority Metals (13)					
Al, Sb, As, Ba, Be, Cd, Ca, Cr, Cu, Fe, Pb, Hg, Mg, Mn, Mo, Ni, K, Se, Ag, Na, TL, V, Zn					
TOTAL DISS. TCLP					
TCLP Metals (8)					
Lead & Copper					
describing water					
Hold Sample					
Frozen Archive					
1	PHS-R-01				
2	PHS-R-02				
3	PHS-R-03				
4	PHS-R-04				
5	PHS-R-05				
6	PHS-R-06				
7	PHS-R-07				
8	PHS-R-08				
9	PHS-R-09				
10	PHS-R-10				

TAT Requested (circle)		1 Day	2 Day	3 Day	Other:
5 Day					

Standard Turn Around Time (TAT) = 10 Business Days

RECEIVED BY:		RECEIVED BY:		RECEIVED BY:	
Signature:	Date:	Signature:	Date:	Signature:	Date:
<u>[Signature]</u>	<u>1/24/16</u>	<u>[Signature]</u>	<u>1/24/16</u>	<u>[Signature]</u>	<u>1/24/16</u>
Printed Name:	Time:	Printed Name:	Time:	Printed Name:	Time:
<u>Justin Ware</u>	<u>9:00 AM</u>	<u>Justin Ware</u>	<u>1:00</u>	<u>Justin Ware</u>	<u>1:00</u>
Company:		Company:		Company:	
<u>APEX</u>		<u>APEX</u>		<u>APEX</u>	

SAMPLES ARE HELD FOR 30 DAYS

SPECIAL INSTRUCTIONS:

Form Y-002 R-01

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106

Richland, WA 99352

Project: **WWPS**

Project Number: **Pasco Senior High / 2600345**

Project Manager: **Justin Ware**

Report ID:

A6A1834 - 02 05 26 1349

Apex Labs 6700 SW Sandburg St., Tigard, OR 97223 Ph: 503-718-2323		CHAIN OF CUSTODY Lab # <u>461324</u> COC <u>2 of 2</u>	
Company:	Project Mgr:	Project Name:	Project #:
Address:	Phone:	Email:	PO #:
Sampled by:			
Site Location:			
State _____ County _____			
SAMPLE ID			
1	PHS-R-11	DATE	TIME
2	PHS-R-12		
3	PHS-R-13		
4	PHS-R-14		
5			
6			
7			
8			
9			
10			
ANALYSIS REQUEST			
# OF CONTAINERS			
MATRIX			
NWTPH-HCID			
NWTPH-GX			
8260 BTEX			
8260 RBDM VOCs			
8260 Halo VOCs			
8260 VOCs Full List			
8270 SIM PAHs			
8270 Semi-Vols Full List			
8082 PCBs			
8081 Pesticides			
RCRA Metals (8)			
Priority Metals (13)			
Al, Sb, As, Ba, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Hg, Mg, Mn, Mo, Ni, K, Se, Ag, Na, TL, V, Zn			
TOTAL DISS. TCLP			
TCLP Metals (8)			
Hold Sample			
Frozen Archive			
SPECIAL INSTRUCTIONS:			
Standard Turn Around Time (TAT) = 10 Business Days			
TAT Requested (circle)			
1 Day 2 Day 3 Day			
Standard Other:			
SAMPLES ARE HELD FOR 30 DAYS			
RELINQUISHED BY:		RECEIVED BY:	
Signature: _____	Date: <u>1/14/16</u>	Signature: <u>[Signature]</u>	Date: <u>1/29/16</u>
Printed Name: _____	Time: _____	Printed Name: <u>[Signature]</u>	Time: <u>1400</u>
Company: _____	Company: <u>Apex Labs</u>	Company: _____	Company: _____

Form Y-002 R-01

Apex Laboratories

[Signature]

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street

Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

Apex Companies, LLC - Richland

400 Bradley Blvd, Ste 106

Richland, WA 99352

Project: WWPSProject Number: Pasco Senior High / 2600345Project Manager: Justin Ware

Report ID:

A6A1834 - 02 05 26 1349

APEX LABS COOLER RECEIPT FORM

Client: Apex Companies Element WO#: A6A1834Project/Project #: Pasco Senior High 2600 3455

Delivery Info:

Date/time received: 1/29/26 @ 12100 By: ESTDelivered by: Apex Client ESS FedEx X UPS Radio Morgan SDS Evergreen OtherFrom USDA Regulated Origin? Yes X No XCooler Inspection Date/time inspected: 1/29/26 @ 12102 By: ESTChain of Custody included? Yes X No Signed/dated by client? Yes X No Contains USDA Reg. Soils? Yes No X Unsure (email RegSoils)

	Cooler #1	Cooler #2	Cooler #3	Cooler #4	Cooler #5	Cooler #6	Cooler #7
Temperature (°C)	<u>11.3</u>						
Custody seals? (Y/N)	<u>N</u>						
Received on ice? (Y/N)	<u>N</u>						
Temp. blanks? (Y/N)	<u>N</u>						
Ice type: (Gel/Real/Other)	<u>NA</u>						
Condition (In/Out):	<u>OUT</u>						

Cooler out of temp? (Y/N) Possible reason why: Drinking water

Green dots applied to out of temperature samples? Yes/No

Out of temperature samples form initiated? Yes/No

Sample Inspection: Date/time inspected: 1/29/26 @ 19:00 By: 2KMAll samples intact? Yes X No Comments: Bottle labels/COCs agree? Yes X No Comments: No Date on Coc, all
conts Date reads 1/21/26.COC/container discrepancies form initiated? Yes No XContainers/volumes received appropriate for analysis? Yes X No Comments: Do VOA vials have visible headspace? Yes No NA XComments: Water samples: pH checked: Yes X No NA pH appropriate? Yes X No NA pH ID: 1256271Comments: 8881 2886 5440Labeled by: 2KMWitness: KNCooler Inspected by: EST

Form Y-003 R-02 -

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.