



PO Box 279
River Edge, NJ 07661

November 15, 2025

Racquel Stubbs
Madison School District
Department of Facilities
284 Green Hill Rd.
Madison, CT 06443

Dear Racquel:

I have enclosed results for radon testing for your District. As you can see, the results are below the EPA action level of 4.0 pCi/L. Based on these results, no further action need be taken.

All rooms tested were done under closed conditions, with all windows shut and the HVAC system running under normal school use conditions in accordance with EPA and CT State guidelines.

Please call if you have questions. Thank you for using Environmental Transactions, Inc.

Sincerely,


Louis G. Esposito

New Jersey
Tel: 201-505-1010
Fax: 201-505-0209