



**ENVIRONMENTAL  
Transactions, Inc.**

PO Box 279  
River Edge, NJ 07661

March 20, 2026

Peter Anderson  
Madison School District  
Department of Facilities  
284 Green Hill Rd.  
Madison, CT 06443

Dear Peter:

I have enclosed results for radon testing for your Neck River School. As you can see, the results are below the EPA action level of 4.0 pCi/L. (Check to see if you can reduce the 3.7 pCi/L in The Kitchen Office). I recommend re-testing these rooms in the Fall of 2026.

All rooms tested were done under closed conditions, with all windows shut and the HVAC system running under normal school use conditions in accordance with EPA and CT State guidelines.

Please call if you have questions. Thank you for using Environmental Transactions, Inc.

Sincerely,

Louis G. Esposito

New Jersey  
Tel: 201-505-1010  
Fax: 201-505-0209