

Lead in School Drinking Water Report

Kingston High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-04-17

Date(s) analyzed: 2026-04-24, 2026-05-06, 2026-05-07

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	420253	2026-04-17	North Building	Pot Filler	Kitchen	3 of 4	Tap	center	33
2	420270	2026-04-17	North Building	Sink	Room 173	1 of 1	Tap	center	9
3	420276	2026-04-17	North Building	Sink - Multi-compartment	Room 215	2 of 2	Tap	left	7
4	420280	2026-04-17	North Building	Sink	Room 239	1 of 1	Tap	center	7
5	420259	2026-04-17	North Building	Sink - Multi-compartment	Room 144	2 of 2	Tap	left	5
6	420250	2026-04-17	North Building	Sink - Multi-compartment	Kitchen	1 of 4	Tap	left	4
7	420251	2026-04-17	North Building	Sink - Multi-compartment	Kitchen	1 of 4	Sprayer	right	4
8	420260	2026-04-17	North Building	Sink - Multi-compartment	Room 144	2 of 2	Tap	right	4
9	420266	2026-04-17	North Building	Sink	Room 168	1 of 1	Tap	center	4
10	420277	2026-04-17	North Building	Sink - Multi-compartment	Room 215	2 of 2	Tap	right	4
11	420284	2026-04-17	North Building	Sink	Library Office	1 of 1	Tap	center	3
12	420264	2026-04-17	North Building	Sink	Outside Of Room 163	1 of 1	Tap	center	2

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
13	420257	2026-04-17	North Building	Sink	Room 145	1 of 1	Tap	center	1
14	420258	2026-04-17	North Building	Sink - Multi-compartment	Room 144	1 of 2	Tap	center	1
15	420262	2026-04-17	North Building	Sink	Choice Academy Pod	2 of 2	Tap	right	1
16	420278	2026-04-17	North Building	Sink	Orange Pod	1 of 1	Tap	center	1
17	420279	2026-04-17	North Building	Sink	Blue Pod Outside Of Room 234	1 of 1	Tap	center	1
18	420283	2026-04-17	North Building	Fountain - Multi-level	Outside Of Blue Pod	1 of 1	Water Fountain	right	1
19	420240	2026-04-17	South Building	Fountain - Multi-level with Bottle Filler	Gym Hall	1 of 1	Water Fountain	left	<1
20	420241	2026-04-17	South Building	Fountain - Multi-level with Bottle Filler	Gym Hall	1 of 1	Water Bottle Filler	center	<1
21	420242	2026-04-17	South Building	Fountain - Multi-level with Bottle Filler	Gym Hall	1 of 1	Water Fountain	right	<1
22	420243	2026-04-17	South Building	Sink	Nurses Office	1 of 1	Tap	center	<1
23	420244	2026-04-17	South Building	Sink	Athletic Room 125	1 of 2	Tap	right	<1
24	420245	2026-04-17	South Building	Ice Machine	Athletic Room 125	2 of 2	Ice Machine	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
25	420246	2026-04-17	South Building	Fountain	Boys Locker Room	1 of 1	Water Fountain	right	<1
26	420247	2026-04-17	South Building	Fountain	Girls Locker Room	1 of 1	Water Fountain	right	<1
27	420248	2026-04-17	South Building	Sink	Room 115	1 of 1	Tap	center	<1
28	420249	2026-04-17	South Building	Sink	Room 117	1 of 1	Tap	center	<1
29	420252	2026-04-17	North Building	Sink	Kitchen	2 of 4	Tap	center	<1
30	420254	2026-04-17	North Building	Ice Machine	Kitchen	4 of 4	Ice Machine	center	<1
31	420255	2026-04-17	North Building	Fountain - Multi-level	Hallway Across From Commons	1 of 1	Water Fountain	left	<1
32	420256	2026-04-17	North Building	Fountain - Multi-level	Hallway Across From Commons	1 of 1	Water Fountain	right	<1
33	420261	2026-04-17	North Building	Fountain With Bottle Filler	Choice Academy Pod	1 of 2	Water Bottle Filler	center	<1
34	420263	2026-04-17	North Building	Sink	Student Store Room 131	1 of 1	Tap	center	<1
35	420265	2026-04-17	North Building	Sink	Room 169	1 of 1	Tap	center	<1
36	420267	2026-04-17	North Building	Fountain - Multi-level with Bottle Filler	Outside Of Red Pod	1 of 1	Water Fountain	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
37	420268	2026-04-17	North Building	Fountain - Multi-level with Bottle Filler	Outside Of Red Pod	1 of 1	Water Bottle Filler	center	<1
38	420269	2026-04-17	North Building	Fountain - Multi-level with Bottle Filler	Outside Of Red Pod	1 of 1	Water Fountain	right	<1
39	420271	2026-04-17	North Building	Fountain - Multi-level with Bottle Filler	Outside Of Orange Pod	1 of 1	Water Fountain	left	<1
40	420272	2026-04-17	North Building	Fountain - Multi-level with Bottle Filler	Outside Of Orange Pod	1 of 1	Water Bottle Filler	center	<1
41	420273	2026-04-17	North Building	Fountain - Multi-level with Bottle Filler	Outside Of Orange Pod	1 of 1	Water Fountain	right	<1
42	420274	2026-04-17	North Building	Sink	Room 214	1 of 1	Tap	center	<1
43	420275	2026-04-17	North Building	Sink - Multi-compartment	Room 215	1 of 2	Tap	center	<1
44	420281	2026-04-17	North Building	Sink	Room 240	1 of 1	Tap	center	<1
45	420282	2026-04-17	North Building	Fountain - Multi-level	Outside Of Blue Pod	1 of 1	Water Fountain	left	<1