

Lead in School Drinking Water Report

Kingston Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-04-16

Date(s) analyzed: 2026-04-28

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	420222	2026-04-16	One-story Building	Sink - Multi-compartment	Room D130	6 of 7	Tap	center	18
2	420211	2026-04-16	One-story Building	Fountain Tap Combo	Staff Lounge	1 of 1	Water Fountain	right	16
3	420219	2026-04-16	One-story Building	Sink - Multi-compartment	Room D130	3 of 7	Tap	center	15
4	420230	2026-04-16	Two-story Building	Sink	Hallway Across From Room B186	1 of 1	Tap	center	14
5	420212	2026-04-16	One-story Building	Fountain Tap Combo	Room E159	1 of 1	Tap	center	13
6	420221	2026-04-16	One-story Building	Sink - Multi-compartment	Room D130	5 of 7	Tap	center	13
7	420236	2026-04-16	Two-story Building	Sink	Next To Room C274	2 of 2	Tap	center	13
8	420218	2026-04-16	One-story Building	Sink - Multi-compartment	Room D130	2 of 7	Tap	center	12
9	420233	2026-04-16	Two-story Building	Fountain	Next To Room C285	1 of 2	Water Fountain	right	12
10	420213	2026-04-16	One-story Building	Fountain Tap Combo	Room E159	1 of 1	Water Fountain	right	11

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	420217	2026-04-16	One-story Building	Sink - Multi-compartment	Room D130	1 of 7. Demonstration sink	Tap	center	11
12	420220	2026-04-16	One-story Building	Sink - Multi-compartment	Room D130	4 of 7	Tap	center	11
13	420226	2026-04-16	One-story Building	Sink	Room A103	1 of 1	Tap	center	11
14	420215	2026-04-16	One-story Building	Sink	Band Office	1 of 1	Tap	center	9
15	420232	2026-04-16	Two-story Building	Sink	Hallway Next To Room B174	2 of 2	Tap	center	8
16	420223	2026-04-16	One-story Building	Sink - Multi-compartment	Room D130	7 of 7	Tap	center	7
17	420214	2026-04-16	One-story Building	Sink	Library Office	1 of 1	Tap	center	6
18	420210	2026-04-16	One-story Building	Fountain Tap Combo	Staff Lounge 157	1 of 1	Tap	center	5
19	420200	2026-04-16	One-story Building	Sink	Kitchen	1 of 1	Tap	center	4
20	420206	2026-04-16	One-story Building	Fountain	Main Gym	1 of 1	Water Fountain	left	4

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
21	420208	2026-04-16	One-story Building	Fountain With Bottle Filler	Girls Locker Room	1 of 1	Water Fountain	right	3
22	420204	2026-04-16	One-story Building	Fountain With Bottle Filler	Boys Locker Room	1 of 1	Water Bottle Filler	center	2
23	420205	2026-04-16	One-story Building	Fountain With Bottle Filler	Boys Locker Room	1 of 1	Water Fountain	right	2
24	420207	2026-04-16	One-story Building	Fountain With Bottle Filler	Girls Locker Room	1 of 1	Water Bottle Filler	center	2
25	420209	2026-04-16	One-story Building	Fountain	Hallway Next To Restroom 154	1 of 1	Water Fountain	right	2
26	420224	2026-04-16	One-story Building	Sink	Nurses Office	1 of 1	Tap	center	2
27	420227	2026-04-16	One-story Building	Fountain	Hallway Next Toa107	1 of 1	Water Fountain	right	2
28	420225	2026-04-16	One-story Building	Sink	Office Area	1 of 1	Tap	center	1
29	420201	2026-04-16	One-story Building	Fountain With Bottle Filler	Commons	1 of 1	Water Fountain	right	<1
30	420202	2026-04-16	One-story Building	Fountain With Bottle Filler	Commons	1 of 1	Water Bottle Filler	center	<1
31	420203	2026-04-16	One-story Building	Ice Machine	Room E141	1 of 1	Ice Machine	center	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
32	420216	2026-04-16	One-story Building	Water Bottle Filling Station	Hallway Next To Room D125	1 of 1	Water Bottle Filler	center	<1
33	420228	2026-04-16	Two-story Building	Fountain With Bottle Filler	Hallway Across From Room B185	1 of 1	Water Bottle Filler	center	<1
34	420229	2026-04-16	Two-story Building	Fountain With Bottle Filler	Hallway Across From Room B185	1 of 1	Water Fountain	right	<1
35	420231	2026-04-16	Two-story Building	Fountain	Hallway Next To Room B174	1 of 2	Water Fountain	right	<1
36	420234	2026-04-16	Two-story Building	Sink	Next To Room C285	2 of 2	Tap	center	<1
37	420235	2026-04-16	Two-story Building	Fountain	Next To Room C274	1 of 2	Water Fountain	right	<1