

Lead in School Drinking Water Report

Poulsbo Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-04-15

Date(s) analyzed: 2026-04-22, 2026-04-24

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	420171	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 1106	1 of 1	Tap	center	60
2	420138	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2112	1 of 1	Tap	center	33
3	420172	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 1106	1 of 1	Water Fountain	right	16
4	420173	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 1109	1 of 1	Tap	center	8
5	420122	2026-04-15	Building 2 - Gym/Cafeteria	Sink	Kitchen	3 of 4	Tap	center	7
6	420151	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2124	1 of 1	Tap	center	6
7	420155	2026-04-15	Bldg 1 - Classrooms	Sink	Room 2126	1 of 1	Tap	center	6
8	420128	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2101	1 of 1	Tap	center	5
9	420130	2026-04-15	Bldg 1 - Classrooms	Sink	Room 2102	1 of 1	Tap	center	4
10	420160	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2143	1 of 1	Water Fountain	right	4
11	420127	2026-04-15	Building 2 - Gym/Cafeteria	Sink	Staff Lounge 1218	1 of 1	Tap	center	3
12	420133	2026-04-15	Bldg 1 - Classrooms	Sink	Room 2106	1 of 1	Tap	center	3
13	420135	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2107	1 of 1	Water Fountain	right	3
14	420139	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2112	1 of 1	Water Fountain	right	3
15	420140	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2113	1 of 1	Tap	center	3

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
16	420157	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Staff Room 2150	1 of 1	Tap	center	3
17	420159	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2143	1 of 1	Tap	center	3
18	420174	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 1109	1 of 1	Water Fountain	right	3
19	420131	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2104	1 of 1	Tap	center	2
20	420142	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2114	1 of 1	Tap	center	2
21	420144	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2116	1 of 1	Tap	center	2
22	420149	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2121	1 of 1	Water Fountain	right	2
23	420120	2026-04-15	Building 2 - Gym/Cafeteria	Pot Filler	Kitchen	1 of 4	Tap	right	1
24	420121	2026-04-15	Building 2 - Gym/Cafeteria	Sink	Kitchen	2 of 4	Sprayer	center	1
25	420134	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2107	1 of 1	Tap	center	1
26	420136	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2108	1 of 1	Tap	center	1
27	420141	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2113	1 of 1	Water Fountain	right	1
28	420143	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2114	1 of 1	Water Fountain	right	1
29	420145	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2116	1 of 1	Water Fountain	right	1
30	420148	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2121	1 of 1	Tap	center	1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
31	420150	2026-04-15	Bldg 1 - Classrooms	Water Bottle Filling Station	Hallway Next To Room 2124	1 of 1	Water Bottle Filler	center	1
32	420152	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2124	1 of 1	Water Fountain	right	1
33	420153	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2125	1 of 1	Tap	center	1
34	420161	2026-04-15	Bldg 1 - Classrooms	Fountain	Room 1101	1 of 1	Water Fountain	left	1
35	420163	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Room 1104	2 of 7. Demo sink	Tap	right	1
36	420123	2026-04-15	Building 2 - Gym/Cafeteria	Pot Filler	Kitchen	4 of 4	Sprayer	left	<1
37	420124	2026-04-15	Building 2 - Gym/Cafeteria	Fountain	Small Gym	1 of 1	Water Fountain	right	<1
38	420125	2026-04-15	Building 2 - Gym/Cafeteria	Fountain - Multi-level	Main Gym	1 of 1	Water Fountain	left	<1
39	420126	2026-04-15	Building 2 - Gym/Cafeteria	Fountain - Multi-level	Main Gym	1 of 1	Water Fountain	right	<1
40	420129	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2101	1 of 1	Water Fountain	right	<1
41	420132	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2104	1 of 1	Water Fountain	right	<1
42	420137	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2108	1 of 1	Water Fountain	right	<1
43	420146	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2120	1 of 1	Tap	center	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	420147	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2120	1 of 1	Water Fountain	right	<1
45	420154	2026-04-15	Bldg 1 - Classrooms	Fountain Tap Combo	Room 2125	1 of 1	Water Fountain	right	<1
46	420156	2026-04-15	Bldg 1 - Classrooms	Sink	Nurses Office	1 of 1	Tap	center	<1
47	420158	2026-04-15	Bldg 1 - Classrooms	Sink	Room 2147	1 of 1	Tap	center	<1
48	420162	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Room 1104	1 of 7. Demo sink	Tap	left	<1
49	420164	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Room 1104	3 of 7. Station 1	Tap	center	<1
50	420165	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Room 1104	4 of 7. Station 2	Tap	center	<1
51	420166	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Room 1104	5 of 7. Station 3	Tap	center	<1
52	420167	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Room 1104	6 of 7. Station 4	Tap	center	<1
53	420168	2026-04-15	Bldg 1 - Classrooms	Sink - Multi-compartment	Room 1104	7 of 7. Station 5	Tap	center	<1
54	420169	2026-04-15	Bldg 1 - Classrooms	Fountain - Multi-level with Bottle Filler	Room 1105	1 of 1	Water Fountain	right	<1
55	420170	2026-04-15	Bldg 1 - Classrooms	Fountain - Multi-level with Bottle Filler	Room 1105	1 of 1	Water Bottle Filler	left	<1