

Addendum

DATE:	May 21, 2026
ADDENDUM NO:	01
PROJECT:	Northlake Elementary Fire Alarm
T0:	2602.1

The following Addendum forms part of and modifies the Bidding and Contract Documents for this project. Contractor shall acknowledge receipt of this Addendum on the Bid Form.

ITEM	SHEET/SECTION NO.	DESCRIPTION
01	Pre-bid Meeting	The Sign-in Sheet from the Prebid Meeting is attached.
02	Q/A from Prebid	<p>Q: Are we to pull new wire or are we using existing infrastructure?</p> <p>A: Existing fire alarm system infrastructure (raceway and wiring) may be used if it is functional and meets current NEC, Building, and Fire code requirements.</p>
03	Q/A from Prebid	<p>Q: What is the pathway of the wires from the portables to the main building?</p> <p>A: We cannot confirm the exact location of the conduit run under the ground going to the portables.</p>
04	Q/A from Prebid	<p>Q: Do all the devices of the existing fire alarm system need to be replaced, or are some devices to remain, be added, or removed?</p> <p>A: All proprietary fire alarm system devices are to be replaced, as well as any devices that are currently dysfunctional. Devices are to be added to meet current fire alarm system code requirements. Unless fire code requires it, no devices are to be removed without being replaced. The quantity of devices should remain as is or increase per code requirement.</p>
05	Q/A from Prebid	<p>Q: The school building uses wire mold for the current fire alarm system. Is the new routing to be done with wire mold as well or can EMT conduit be used?</p> <p>A: All new raceways are to be EMT conduit when routing indoors and RGS when routing outdoors. Exposed conduit in public spaces shall be painted to match the existing color of the surface being routed along (ceiling, wall, etc.). Existing conduit may be used where appropriate.</p>



ITEM	SHEET/SECTION NO.	DESCRIPTION
06	Q/A from Prebid	Q: Are fire alarm strobes needed? A: Yes, to accommodate those at Northlake Elementary School with hearing impairment.

END OF ADDENDUM

Prebid Attendance Sign-in Sheet

May 19, 2026

Northlake Elementary Fire Alarm, 2210 Olympia Way, Longview, WA 98632

Name	Company	Email	UBI#	Phone
David Brittell	Brittell Architecture, Inc.	david@brittellarch.com		360-636-5074
Cody Bague	Longview School District	cbrague@longviewschools.org		360-643-0238
Rob Reynolds	PST	Robert.Reynolds@PSTIntegrated.com		971-713-3889
RAY Jordan	INLAND ELECTRIC	RWJ@INLANDRGROUP.COM		360-749-2820
Tommy Fefelov	JH Kelly	tommy.fefelov@jhkelly.com		360-998-0338
Lucas (Gregory)	Accurate Electric	lucas@aeinc.com	602966 031	360-553-9762
Nathan Butz	GB Manchester	Nathan.B. @ GManchester		360-816-0484
Samantha Helman	R & W Engineering	sholman@rweng.com	COOR	503-726-3329
Kohl Nichols	Brittell Architecture Inc.	Kohl@Brittellarch.com		360-636-5074
Please write legibly - your information will be transcribed later. Thank you!				