



Monday, April 06, 2026

Attn: Jimmy Majewski
Millenium Water
647 Thompson Road
P.O. Box 303
Thompson, CT 06277

Project ID: SALEM ELEMENTARY
SDG ID: GCV60961
Sample ID#s: CV60961 - CV60962

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



SDG Comments

April 06, 2026

SDG I.D.: GCV60961

524.2 Analysis:

This SDG has been logged in for drinking water method 524.2, no trip blank was submitted. A Trip Blank must accompany all drinking water samples.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Sample Id Cross Reference

April 06, 2026

SDG I.D.: GCV60961

Project ID: SALEM ELEMENTARY

Client Id	Lab Id	Matrix	Col Date
MDBR	CV60961	DRINKING WATER	03/26/26 12:30
ENTRYPOINT	CV60962	DRINKING WATER	03/26/26 12:30



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

April 06, 2026

FOR: Attn: Jimmy Majewski
Millenium Water
647 Thompson Road
P.O. Box 303
Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
Location Code: MILLENIU
Rush Request: Standard
P.O.#:

Custody Information

Collected by:
Received by: SW
Analyzed by: see "By" below

Date

03/26/26
03/27/26

Time

12:30
12:00

Laboratory Data

SDG ID: GCV60961
Phoenix ID: CV60961

Project ID: SALEM ELEMENTARY
Client ID: MDBR

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/27/26 13:00	EK/KDB	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/27/26 13:00	EK/KDB	SM9223B-04
Color, Apparent	< 1	1	1	Color Units	15		15	03/27/26 18:55	KL1	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.	2		3	03/27/26 18:54	KL1	SM2150B-97
pH	7.88	1.00	1	pH Units			6.5-8.5	03/27/26 23:20	KL1	SM4500-H B-11
Turbidity	< 0.20	0.20	1	NTU	5		5	03/27/26 20:38	KL1	SM2130B-20
Chlorine Residual	ND	0.01	1	mg/L		4		03/26/26 12:30	*	SM4500Cl-G-00
CT EDI Reporting	Completed							03/27/26		

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): CT Public Health Code 19-13-B102.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The regulatory hold time for pH is immediately. This pH was performed in the laboratory and may be considered outside of hold-time.

Residual Chlorine was taken at the time of sample collection and is noted on the chain of custody.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

April 06, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102

Analysis Report

April 06, 2026

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: SW
 Analyzed by: see "By" below

Date

03/26/26
 03/27/26

Time

12:30
 12:00

Laboratory Data

SDG ID: GCV60961
 Phoenix ID: CV60962

Project ID: SALEM ELEMENTARY
 Client ID: ENTRYPOINT

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Nitrite as Nitrogen	< 0.004	0.004	1	mg/L		1		03/27/26 20:13	DD/GD	E300.0
Nitrate as Nitrogen	0.03	0.01	1	mg/L		10		03/27/26 20:13	DD/GD	E300.0
Extraction for 525.3	Completed							04/02/26	W/W	E525.3

Volatiles, Oxygenates

Diethyl ether	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Ethyl tert-butyl ether	ND	0.50	1	ug/L				04/01/26	MH	E524.2
tert-amyl methyl ether	ND	0.50	1	ug/L				04/01/26	MH	E524.2
tert-butyl alcohol	ND	10	1	ug/L				04/01/26	MH	E524.2

Volatiles

1,1,1,2-Tetrachloroethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,1,1-Trichloroethane	ND	0.50	1	ug/L		200		04/01/26	MH	E524.2
1,1,2,2-Tetrachloroethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,1,2-Trichloroethane	ND	0.50	1	ug/L		5		04/01/26	MH	E524.2
1,1,2-Trichlorotrifluoroethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,1-Dichloroethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,1-Dichloroethene	ND	0.50	1	ug/L		7		04/01/26	MH	E524.2
1,1-Dichloropropene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,2,3-Trichlorobenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,2,3-Trichloropropane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,2,4-Trichlorobenzene	ND	0.50	1	ug/L		70		04/01/26	MH	E524.2
1,2,4-Trimethylbenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,2-Dichlorobenzene	ND	0.50	1	ug/L		600		04/01/26	MH	E524.2
1,2-Dichloroethane	ND	0.50	1	ug/L		5		04/01/26	MH	E524.2
1,2-Dichloropropane	ND	0.50	1	ug/L		5		04/01/26	MH	E524.2
1,3,5-Trimethylbenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
1,3-Dichlorobenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,3-Dichloropropane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
1,4-Dichlorobenzene	ND	0.50	1	ug/L		75		04/01/26	MH	E524.2
2,2-Dichloropropane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
2-Chlorotoluene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
4-Chlorotoluene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Benzene	ND	0.50	1	ug/L		5		04/01/26	MH	E524.2
Bromobenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Bromochloromethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Bromodichloromethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Bromoform	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Bromomethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Carbon tetrachloride	ND	0.50	1	ug/L	0.5	5		04/01/26	MH	E524.2
Chlorobenzene	ND	0.50	1	ug/L		100		04/01/26	MH	E524.2
Chloroethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Chloroform	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Chloromethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
cis-1,2-Dichloroethene	ND	0.50	1	ug/L		70		04/01/26	MH	E524.2
cis-1,3-Dichloropropene	ND	0.40	1	ug/L				04/01/26	MH	E524.2
Dibromochloromethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Dibromomethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Dichlorodifluoromethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Ethylbenzene	ND	0.50	1	ug/L		700		04/01/26	MH	E524.2
Hexachlorobutadiene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Isopropylbenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
m&p-Xylene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Methyl t-butyl ether (MTBE)	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Methylene chloride	ND	0.50	1	ug/L		5		04/01/26	MH	E524.2
Naphthalene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
n-Butylbenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
n-Propylbenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
o-Xylene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
p-Isopropyltoluene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
sec-Butylbenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Styrene	ND	0.50	1	ug/L		100		04/01/26	MH	E524.2
tert-Butylbenzene	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Tetrachloroethene	ND	0.50	1	ug/L		5		04/01/26	MH	E524.2
Toluene	ND	0.50	1	ug/L		1000		04/01/26	MH	E524.2
Total 1,3-Dichloropropene	ND	0.40	1	ug/L				04/01/26	MH	E524.2
Total Trihalomethanes	ND	0.50	1	ug/L		80		04/01/26	MH	E524.2
Total Xylenes	ND	0.50	1	ug/L		10000		04/01/26	MH	E524.2
trans-1,2-Dichloroethene	ND	0.50	1	ug/L		100		04/01/26	MH	E524.2
trans-1,3-Dichloropropene	ND	0.40	1	ug/L				04/01/26	MH	E524.2
Trichloroethene	ND	0.50	1	ug/L	1	5		04/01/26	MH	E524.2
Trichlorofluoromethane	ND	0.50	1	ug/L				04/01/26	MH	E524.2
Vinyl chloride	ND	0.50	1	ug/L	0.5	2		04/01/26	MH	E524.2
QA/QC Surrogates										
% 1,2-dichlorobenzene-d4	89		1	%	NA	NA	NA	04/01/26	MH	70 - 130 %
% Bromofluorobenzene	92		1	%	NA	NA	NA	04/01/26	MH	70 - 130 %

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Volatile Library Search	Completed							04/02/26	MH	
Bis(2-ethylhexyl)phthalate	ND	0.60	1	ug/l		6		04/02/26	KCA	E525.3

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal
QA/QC Surrogates: Surrogates are compounds (preceeded with a %) added by the lab to determine analysis efficiency. Surrogate results(%) listed in the report are not "detected" compounds.

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; CT Public Health Code 19-13-B102. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): CT Public Health Code 19-13-B102.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

April 06, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102

QA/QC Report

April 06, 2026

QA/QC Data

SDG I.D.: GCV60961

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 832613 (NTU), QC Sample No: CV60961 (CV60961)													
Turbidity	BRL	0.20	<0.20	<0.20	NC	94.3						85 - 115	20
QA/QC Batch 832651 (PH), QC Sample No: CV61504 (CV60961)													
pH			7.80	7.78	0.30	100						85 - 115	20
QA/QC Batch 832949 (mg/L), QC Sample No: CV61821 (CV60962)													
Nitrate as Nitrogen	BRL	0.01	0.13	0.13	0	98.9			89.1			90 - 110	20 m
Nitrite as Nitrogen	BRL	0.004	<0.004	<0.004	NC	95.3			97.5			90 - 110	20

m = This parameter is outside laboratory MS/MSD specified recovery limits.



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102

QA/QC Report

April 06, 2026

QA/QC Data

SDG I.D.: GCV60961

Parameter	Blank	BLK RL	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 833361 (ug/L), QC Sample No: CV60962 (CV60962)

Semivolatile Organic Compounds - Drinking Water

Bis(2-ethylhexyl)phthalate	ND	0.60			109		109	115	5.4	70 - 130	20
----------------------------	----	------	--	--	-----	--	-----	-----	-----	----------	----

Comment:

Because insufficient sample volume was received, tap water, collected and dechlorinated in sample containers, was used as the MS and MSD.

g-chlordane recovery is reported as chlordane in the LCS

QA/QC Batch 833450 (ug/L), QC Sample No: CV62787 (CV60962)

Volatiles - Drinking Water

1,1,1,2-Tetrachloroethane	ND	0.50	110	103	6.6					70 - 130	30
1,1,1-Trichloroethane	ND	0.50	107	100	6.8					70 - 130	30
1,1,2,2-Tetrachloroethane	ND	0.50	101	99	2.0					70 - 130	30
1,1,2-Trichloroethane	ND	0.50	112	105	6.5					70 - 130	30
1,1-Dichloroethane	ND	0.50	113	105	7.3					70 - 130	30
1,1-Dichloroethene	ND	0.50	104	97	7.0					70 - 130	30
1,1-Dichloropropene	ND	0.40	98	90	8.5					70 - 130	30
1,2,3-Trichlorobenzene	ND	0.50	99	94	5.2					70 - 130	30
1,2,3-Trichloropropane	ND	0.50	101	101	0.0					70 - 130	30
1,2,4-Trichlorobenzene	ND	0.50	102	93	9.2					70 - 130	30
1,2,4-Trimethylbenzene	ND	0.50	105	99	5.9					70 - 130	30
1,2-Dichlorobenzene	ND	0.50	106	98	7.8					70 - 130	30
1,2-Dichloroethane	ND	0.50	112	106	5.5					70 - 130	30
1,2-Dichloropropane	ND	0.50	110	102	7.5					70 - 130	30
1,3,5-Trimethylbenzene	ND	0.50	106	99	6.8					70 - 130	30
1,3-Dichlorobenzene	ND	0.50	108	101	6.7					70 - 130	30
1,3-Dichloropropane	ND	0.50	110	103	6.6					70 - 130	30
1,4-Dichlorobenzene	ND	0.50	105	96	9.0					70 - 130	30
2,2-Dichloropropane	ND	0.50	104	98	5.9					70 - 130	30
2-Chlorotoluene	ND	0.50	103	95	8.1					70 - 130	30
4-Chlorotoluene	ND	0.50	106	95	10.9					70 - 130	30
Benzene	ND	0.50	111	104	6.5					70 - 130	30
Bromobenzene	ND	0.50	108	98	9.7					70 - 130	30
Bromochloromethane	ND	0.50	111	103	7.5					70 - 130	30
Bromodichloromethane	ND	0.50	113	106	6.4					70 - 130	30
Bromoform	ND	0.50	100	99	1.0					70 - 130	30
Bromomethane	ND	0.50	99	94	5.2					70 - 130	30
Carbon tetrachloride	ND	0.50	101	94	7.2					70 - 130	30
Chlorobenzene	ND	0.50	106	98	7.8					70 - 130	30
Chloroethane	ND	0.50	111	105	5.6					70 - 130	30
Chloroform	ND	0.50	112	104	7.4					70 - 130	30
Chloromethane	ND	0.50	100	94	6.2					70 - 130	30
cis-1,2-Dichloroethene	ND	0.50	115	107	7.2					70 - 130	30
cis-1,3-Dichloropropene	ND	0.40	112	103	8.4					70 - 130	30

QA/QC Data

SDG I.D.: GCV60961


Parameter	Blk		LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
	Blank	RL								
Dibromochloromethane	ND	0.50	103	98	5.0				70 - 130	30
Dibromomethane	ND	0.50	109	104	4.7				70 - 130	30
Dichlorodifluoromethane	ND	0.50	81	74	9.0				70 - 130	30
Ethyl ether	ND	1.0	110	109	0.9				70 - 130	30
Ethyl tert-butyl ether	ND	1.0	103	105	1.9				70 - 130	30
Ethylbenzene	ND	0.50	104	98	5.9				70 - 130	30
Hexachlorobutadiene	ND	0.40	100	87	13.9				70 - 130	30
Isopropylbenzene	ND	0.50	99	92	7.3				70 - 130	30
m&p-Xylene	ND	0.50	108	101	6.7				70 - 130	30
Methyl t-butyl ether (MTBE)	ND	0.50	99	101	2.0				70 - 130	30
Methylene chloride	ND	0.50	112	104	7.4				70 - 130	30
Naphthalene	ND	0.50	87	88	1.1				70 - 130	30
n-Butylbenzene	ND	0.50	104	95	9.0				70 - 130	30
n-Propylbenzene	ND	0.50	99	93	6.3				70 - 130	30
o-Xylene	ND	0.50	104	97	7.0				70 - 130	30
p-Isopropyltoluene	ND	0.50	98	93	5.2				70 - 130	30
sec-Butylbenzene	ND	0.50	98	92	6.3				70 - 130	30
Styrene	ND	0.50	108	100	7.7				70 - 130	30
tert-amyl methyl ether	ND	0.50	96	98	2.1				70 - 130	30
tert-butyl alcohol	ND	10	86	91	5.6				60 - 140	20
tert-Butylbenzene	ND	0.50	101	93	8.2				70 - 130	30
Tetrachloroethene	ND	0.50	99	92	7.3				70 - 130	30
Toluene	ND	0.50	108	100	7.7				70 - 130	30
trans-1,2-Dichloroethene	ND	0.50	103	96	7.0				70 - 130	30
trans-1,3-Dichloropropene	ND	0.40	111	106	4.6				70 - 130	30
Trichloroethene	ND	0.50	108	102	5.7				70 - 130	30
Trichlorofluoromethane	ND	0.50	97	90	7.5				70 - 130	30
Trichlorotrifluoroethane	ND	0.50	99	93	6.3				70 - 130	30
Vinyl chloride	ND	0.50	100	90	10.5				70 - 130	30
% 1,2-dichlorobenzene-d4	87	%	97	98	1.0				70 - 130	30
% Bromofluorobenzene	92	%	97	99	2.0				70 - 130	30

Comment:

This batch consists of a blank, LCS and LCSD.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 April 06, 2026

Monday, April 06, 2026

Criteria: CT: DW

State: CT

Sample Criteria Exceedances Report

GCV60961 - MILLENIU

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

April 06, 2026

SDG I.D.: GCV60961

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

Millenium Water LLC

A Division of LaFramboise Water Service, Inc.
 647 Thompson Road, PO Box 303
 Thompson, CT 06277
 Phone: 1-800-624-2327
 Fax: 860-923-9971

Connecticut Division

Contract Operations
 Certified Operators
 Monitoring/Reporting
 Treatment Systems

FOR LAB USE ONLY

Lab WO #

Project Manager

Date Collected: 3-26-24
 PWS Class NTNC
 Routine YES
 Is the Source Treated?

Q1 2026

PWS ID # CT **1219013**
 PWS Name: Salem Elementary
 Town: Salem

Job # **91139**

WSF ID:	Sampling Point ID	Sampling Point Description	Frequency	Sample Matrix	Time Collected	Sample Type	# of Bottles	Analysis Requested				COMMENTS		
								TC	PHYS	PHTHALATE	NOX		VOC	
00600	60961 MDBR	MDBR	Q	DS	1230	RT	2	X						
00700	60962 3	ENTRY POINT	Q	EP	1230	RT	6		X			X		
CUSTODY TRANSFER														
Sampler:					3-26-26		1230						TC- TRC: 0	
Relinquished By:					3-26-26		1445						1 X 250 ML ASIS, 1 X BACTASIS	
Received By:					3/27/26		10-						3 X VOA HCL, 1 X 250 ML ASIS	
Relinquished By:													IS, 2 X 1000 ML ASIS	
Received By:					3/27/26		12:00						(BSA)	

Conditions Upon Receipt: Cooled Ambient

1.7 WCLP
 C Upon receipt at Lab.

1/12/2026