

Addendum

DATE:	May 26, 2026
ADDENDUM NO:	02
PROJECT:	Northlake Elementary Fire Alarm
T0:	2602.4

The following Addendum forms part of and modifies the Bidding and Contract Documents for this project. Contractor shall acknowledge receipt of this Addendum on the Bid Form.

ITEM	SHEET/SECTION NO.	DESCRIPTION
01	Bidding - Q/A	<p>Q: Horn-strobe notification is shown, code requires speaker-strobes (voice evacuation).</p> <p>A: We defer to the fire alarm code in the case of the horn strobes: use the code-required speaker strobes.</p>
02	Bidding - Q/A	<p>Q: We don't see any information or direction provided for CO detection - are there plans to release a narrative and/or HVAC drawings showing gas-fired HVAC units and the distribution?</p> <p>A: The plans act as a narrative. The existing fire alarm system, including its components, is to be replaced in its entirety such that the current fire alarm code requirements are met. This includes the existing and any additional CO detectors that are required. No additional HVAC drawings or narrative will be provided.</p>
03	Bidding - Q/A	<p>Q: We'd like to request a bid extension.</p> <p>A: Since there are seven days before the bid is due, we do not feel an extension is necessary and therefore is not granted.</p>

END OF ADDENDUM