Stohl ENVIRONMENTAL BUFFALO ROCHESTER

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

April 30, 2026

Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, New York 14086

Re: Lead Testing in School Drinking Water

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Lancaster Central School District, including:

- **John A. Sciole Elementary – 86 Alys Drive, Lancaster, New York**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Recap of Initial Sampling and Analysis: In Compliance with NYS regulations, initial first draw water sampling was completed on June 14, 2024 and a total of 21 samples were identified as containing lead concentrations above the NYS Action Level of 5 ppb. Follow-up sampling occurred on April 5, 2025 on 10 of the 21 outlets identified as containing lead concentrations above the NYS action level. A total of 3 of the resampled outlets were identified as containing lead concentrations above the NYS Action Level of 5 ppb.

Mitigation by District and Follow-up Sampling by Stohl Environmental LLC:

- Following the receipt of initial sampling results on August 14, 2024 and resampling report on June 2, 2025, in accordance with guidance received from NYS, the District is reported to have prohibited use of the outlets analyzed as above the NYS Action Level of 5 ppb "(1) a lead remediation plan is implemented… and (2) test results indicate that the lead levels are at or below the action level".

- Subsequent to reported mitigation by the District, Stohl Environmental LLC was requested to perform additional follow-up sampling and laboratory analysis on 3 of the 3 outlets identified as containing lead concentrations above the NYS action level.

- Follow-up sampling was performed by Stohl Environmental LLC in accordance with the requirements and protocols outlined in NYS regulations, as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

- Results of Follow-up Sampling: As detailed in Section 1.2 *(Executive Summary)* of the accompanying report, based upon the follow-up sampling and analysis performed, the following is reported:

    - Of the 3 outlets sampled during the post mitigation follow up on June 27, 2025:

        - 2 outlets were analyzed by a certified and independent laboratory as at or below the action level; thus cleared for use.

        - 1 outlet was analyzed by a certified and independent laboratory as above the action level; thus needing further action.

    - Of the 1 outlet sampled during the post mitigation follow up on April 8, 2026:

        - 1 outlet was analyzed by a certified and independent laboratory as at or below the action level; thus cleared for use.

Thank you for the opportunity to be of service to Lancaster Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Lancaster Central School District

Prepared by:

Stohl BUFFALO ROCHESTER ENVIRONMENTAL SINCE 1988

3860 California Road
Orchard Park, New York 14127

Conditions as of April 8, 2026

Stohl BUFFALO ROCHESTER ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Summary Tabulation

Lead in Drinking Water Investigation

1.1. Scope of Work and Sampling Protocol

1.2. Executive Summary of Sampling and Analysis

1.3. Response Actions Required Under NYS Regulations

1.4. Laboratory Analytical Reports and Chain of Custody Documents

1.5. Laboratory Certifications

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **John A. Sciole Elementary – 86 Alys Drive, Lancaster, New York**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within John A. Sciole Elementary. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP).

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at John A. Sciole Elementary:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
John A. Sciole Elementary	June 14, 2024	66	45	21
	April 5, 2025	10	7	3
	June 27, 2025	3	2	1
	April 8, 2026	1	1	0

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)			
			6/14/2024	4/5/2025	6/27/2025	4/8/2026
104.7-2	Room 1	Sink	20.1	4.3 – Cleared	–	–
104.7-3	Room 4	Sink	7.3	–	–	–
104.7-4	Room 3	Sink	10.8	3.7 – Cleared	–	–
104.7-5	Room 6	Sink	11.7	–	–	–
104.7-6	Room 5	Sink	5.9	3.4 – Cleared	–	–
104.7-7	Room 8	Sink	5.7	–	–	–
104.7-8	Room 7	Sink	10	3.4 – Cleared	–	–
104.7-9	Room 10	Sink'	7.3	–	–	–
104.7-10	Room 9	Sink	7.7	16.4	12.4	<1.00–Cleared
104.7-12	Room 11	Sink	6.5	1.9 – Cleared	–	–
104.7-24	Library Media Center	Sink	6.9	–	–	–
104.7-30	Room 13	Sink	6.2	–	–	–
104.7-39	Room 24	Sink	7.6	–	–	–
104.7-40	Room 23	Sink	8.7	–	–	–
104.7-41	Art Room Front Left	Sink	9	–	–	–
104.7-46	Art Room Rear Right	Sink	35.1	–	–	–
104.7-55	Kitchen Handwash	Sink	6.6	3.7 – Cleared	–	–
104.7-56	Kitchen Prep Table Single Bay	Sink	5.2	7.5	<1.0 – Cleared	–
104.7-57	Kitchen Pan Fill	Sink	107	–	–	–
104.7-58	Kitchen 3 Bay Left Sink	Sink	9.9	5.3	<1.0 – Cleared	–
104.7-59	Kitchen 3 Bay Right	Sink	11.1	1.9 – Cleared	–	–

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

(a) Prohibit use of the outlet until:

(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and

(2) test results indicate that the lead levels are at or below the action level;

(b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;

(c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and

(d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.4 Laboratory Analytical Reports and Chain of Custody Documents

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 26-04-03363

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Received Date: 04/17/2026
Reported Date: 04/21/2026
Sampled By: P. Maier
Tech Certification #:

Project/Test Address: 2023-104.7; John A Sciole Elementary; 86 Alys Dr; Depew, NY 14043

Client Number: 33-5980

Laboratory Results

Fax Number: 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
26-04-03363-001	104.7-10	04/08/2026	ROOM 9	<1.00	04/21/2026	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NY 11714

Reviewed By Authorized Signatory: Melissa Kanode

Melissa Kanode
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023-104.7

Client: Lancaster CSD Contact: Michael Bryniarski

Building: John A Sciole Elementary Location: 86 Alys Dr Depew, NY 14043

LEAD
Water by 200.8 X

Turnaround
72 Hours

Sample #	Location	Outlet Type	Time
104.7-10	Room 9	Sink	14:30

26-04-03363

Due Date:
04/22/2026
(Wednesday)
AE

Notes:
Please e-mail lab results to labs@stohlenv.com ☑ If checked, also e-mail results to: Rfranjoine@stohlenvironmental.com

Sampled By: P. Maier Print Name Stohl Env: P. Maier Date: 4/8/2026

Relinquished By: M. Scinta Print Name Stohl Env: M. Scinta Date: 4/15/2026

Received (Name / Lab): Jamiel Ammons / EHS Date: 4/17/26 Time: 12:53pm

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2027
Issued April 01, 2026

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Metals I

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

Serial No.: 72235

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/lwc/elappublioweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 1