Lead in Water Test Results Summary: Riverside High School

Notes:

- **The lead in water Action Level is 15 parts per billion (ppb).**
  Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "**ND**" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
83- Nurse's Office Faucet	19221800-001NS	5/7/2026	5.4	Moderate	*[enter date]*	*[enter result]*	*[autofill]*
84- Healthroom Bathroom Faucet	19221800-002BF	5/7/2026	ND	Non-Detect			
87- Staff Bathroom Faucet	19221800-004BF	5/7/2026	ND	Non-Detect			
85- Staff Bathroom Faucet	19221800-005BF	5/7/2026	63	Action Req.			
82- Workroom Faucet	19221800-006SF	5/7/2026	9.4	Moderate			
109- Kitchen Serving Line Left Faucet	19221800-007KF	5/7/2026	9.8	Moderate			
109- Kitchen Serving Line Center Faucet	19221800-008KF	5/7/2026	1.5	Low			
109- Kitchen Serving Line Right Faucet	19221800-009KF	5/7/2026	25	Action Req.			
109- Kitchen Prep Island Southwest Faucet	19221800-010KF	5/7/2026	3	Low			
109- Kitchen Prep Island East Faucet	19221800-011KF	5/7/2026	4.9	Low			
109- Kitchen Prep on East Wall Faucet	19221800-012KF	5/7/2026	10	High			
109- Kitchen North wall Handwashing Faucet	19221800-013KF	5/7/2026	1.2	Low			
109- Kitchen North wall Dishwashing Faucet	19221800-014KF	5/7/2026	1.1	Low			
109- Kitchen North wall Dishwashing Sprayer	19221800-015KF	5/7/2026	ND	Non-Detect			
112- Kitchen Bathroom Faucet	19221800-016BF	5/7/2026	6.73	Moderate			
113- Classroom Faucet	19221800-017CF	5/7/2026	ND	Non-Detect			
107- Classroom Faucet	19221800-019CF	5/7/2026	4.1	Low			
107- Classroom Drinking Fountain	19221800-020DW	5/7/2026	8.9	Moderate			
105- Women's Bathroom Faucet	19221800-021BF	5/7/2026	ND	Non-Detect			
104- Men's Bathroom Faucet	19221800-022BF	5/7/2026	ND	Non-Detect			
103- Entry into Gym Drinking Fountain	19221800-023DW	5/7/2026	ND	Non-Detect			
119- Gym Drinking Fountain	19221800-024DW	5/7/2026	1.9	Low			
119- Gym Bottle Filler	19221800-025WB	5/7/2026	1.2	Low			
134- Women's Locker Bathroom Faucet Far Left	19221800-026BF	5/7/2026	6.9	Moderate			
134- Women's Locker Bathroom Faucet Center Left	19221800-027BF	5/7/2026	5.5	Moderate			
134- Women's Locker Bathroom Faucet Center Right	19221800-028BF	5/7/2026	4.9	Low			
134- Women's Locker Bathroom Faucet Far Right	19221800-029BF	5/7/2026	4.5	Low			
130- Training Room Ice Machine	19221800-050IM	5/7/2026	1.8	Low			
130- Training Room Staff Faucet	19221800-192SF	5/7/2026	5.5	Moderate			
126- Men's Locker Bathroom Faucet Far Left	19221800-070BF	5/7/2026	ND	Non-Detect			
126- Men's Locker Bathroom Faucet Center Left	19221800-071BF	5/7/2026	ND	Non-Detect			
126- Men's Locker Bathroom Faucet Center Right	19221800-072BF	5/7/2026	ND	Non-Detect			
126- Men's Locker Bathroom Faucet Far Right	19221800-073BF	5/7/2026	1.6	Low			
153.1- Single User Bathroom Faucet	19221800-074BF	5/7/2026	ND	Non-Detect			
143- Women's Staff Bathroom Faucet	19221800-075BF	5/7/2026	0.53	Low			
141- Men's Staff Bathroom Faucet	19221800-076BF	5/7/2026	0.55	Low			
140- Staff Room Faucet	19221800-077SF	5/7/2026	ND	Non-Detect			
140- Staff Room Hot Water Faucet	19221800-078SF	5/7/2026	ND	Non-Detect			
149- Conference Room Faucet	19221800-079SF	5/7/2026	5.3	Moderate			
155- Men's Bathroom Faucet Far Left	19221800-080BF	5/7/2026	1.7	Low			
155- Men's Bathroom Faucet Center Left	19221800-081BF	5/7/2026	1.5	Low			

155- Men's Bathroom Faucet Center Right	19221800-082BF	5/7/2026	1.2	Low			
155- Men's Bathroom Faucet Far Right	19221800-083BF	5/7/2026	0.64	Low			
158- Hallway Drinking Fountain	19221800-084DW	5/7/2026	ND	Non-Detect			
158- Hallway Bottle Filler	19221800-085WB	5/7/2026	ND	Non-Detect			
153- Women's Bathroom Faucet Far Left	19221800-086BF	5/7/2026	0.87	Low			
153- Women's Bathroom Faucet Center Left	19221800-087BF	5/7/2026	1.2	Low			
153- Women's Bathroom Faucet Center Right	19221800-088BF	5/7/2026	1.6	Low			
153- Women's Bathroom Faucet Far Right	19221800-089BF	5/7/2026	1.3	Low			
164- Classroom Faucet East	19221800-090CF	5/7/2026	6.3	Moderate			
164- Classroom Faucet West	19221800-091CF	5/7/2026	3.5	Low			
166- Classroom Faucet	19221800-092CF	5/7/2026	1.1	Low			
167- Classroom Faucet	19221800-093CF	5/7/2026	1.6	Low			
168- Classroom Faucet	19221800-094CF	5/7/2026	4	Low			
171- Science Classroom Middle Sink	19221800-096CF	5/7/2026	9.6	Moderate			
171- Science Classroom South Wall Left Sink	19221800-097CF	5/7/2026	2.8	Low			
171- Science Classroom South Wall Right Sink	19221800-098CF	5/7/2026	4.4	Low			
171- Science Classroom West Wall Left Sink	19221800-099CF	5/7/2026	1.2	Low			
171- Science Classroom West Wall Right Sink	19221800-100CF	5/7/2026	8.9	Moderate			
171- Science Classroom North Wall Left Sink	19221800-101CF	5/7/2026	4.3	Low			
171- Science Classroom North Wall Right Sink	19221800-102CF	5/7/2026	3	Low			
172- Science Prep Room Sink	19221800-103SF	5/7/2026	**24**	**Action Req.**			
173- Science Classroom Middle Sink	19221800-105CF	5/7/2026	**14**	**High**			
173- Science Classroom South Wall Left Sink	19221800-106CF	5/7/2026	1.6	Low			
173- Science Classroom South Wall Right Sink	19221800-107CF	5/7/2026	5.6	Moderate			
173- Science Classroom West Wall Left Sink	19221800-108CF	5/7/2026	**10**	**High**			
173- Science Classroom West Wall Right Sink	19221800-109CF	5/7/2026	7.1	Moderate			
173- Science Classroom North Wall Left Sink	19221800-110CF	5/7/2026	6.5	Moderate			
173- Science Classroom North Wall Right Sink	19221800-111CF	5/7/2026	3.7	Low			
176- Classroom Faucet	19221800-112CF	5/7/2026	2	Low			
177- Classroom Faucet	19221800-113CF	5/7/2026	1.6	Low			
178- Classroom Faucet	19221800-114CF	5/7/2026	1.5	Low			
179- Classroom Faucet Wash Basin	19221800-115CF	5/7/2026	1.6	Low			
179- Classroom Faucet North Wall Far Left #1	19221800-116CF	5/7/2026	0.64	Low			
179- Classroom Faucet North Wall #2	19221800-117CF	5/7/2026	2.2	Low			
179- Classroom Faucet North Wall #3	19221800-118CF	5/7/2026	1.8	Low			
179- Classroom Faucet North Wall #4	19221800-119CF	5/7/2026	0.81	Low			
179- Classroom Faucet North Wall #5	19221800-120CF	5/7/2026	1.9	Low			
179- Classroom Faucet North Wall #6	19221800-121CF	5/7/2026	2.6	Low			
179- Classroom Faucet North Wall #7	19221800-122CF	5/7/2026	5.2	Moderate			
179- Classroom Faucet North Wall Far Right #8	19221800-123CF	5/7/2026	1.1	Low			
181- Women's Bathroom Faucet Left	19221800-124BF	5/7/2026	1.9	Low			
181- Women's Bathroom Faucet Center	19221800-125BF	5/7/2026	1.3	Low			
181- Women's Bathroom Faucet Right	19221800-126BF	5/7/2026	0.87	Low			
188- Hallway Drinking Fountain	19221800-127DW	5/7/2026	ND	Non-Detect			
188- Hallway Bottle Filler	19221800-128WB	5/7/2026	ND	Non-Detect			
182- Men's Bathroom Faucet Left	19221800-129BF	5/7/2026	0.73	Low			
182- Men's Bathroom Faucet Center	19221800-130BF	5/7/2026	0.63	Low			
182- Men's Bathroom Faucet Right	19221800-131BF	5/7/2026	1.2	Low			
182- Men's Bathroom Faucet ADA	19221800-185BF	5/7/2026	ND	Non-Detect			
191- Workroom Faucet	19221800-132SF	5/7/2026	5.2	Moderate			
192- Classroom Faucet	19221800-133CF	5/7/2026	3.5	Low			
206- Men's Bathroom Faucet Far Left #1	19221800-134BF	5/7/2026	0.85	Low			
206- Men's Bathroom Faucet Center Left #2	19221800-135BF	5/7/2026	1.4	Low			
206- Men's Bathroom Faucet Center Right #3	19221800-136BF	5/7/2026	0.56	Low			
206- Men's Bathroom Faucet Far Right #4	19221800-137BF	5/7/2026	0.52	Low			
246- Hallway Drinking Fountain	19221800-138DW	5/7/2026	1.9	Low			
207- Women's Bathroom Faucet Far Left #1	19221800-140BF	5/7/2026	0.95	Low			
207- Women's Bathroom Faucet Center Left #2	19221800-141BF	5/7/2026	ND	Non-Detect			
207- Women's Bathroom Faucet Center Right #3	19221800-142BF	5/7/2026	0.63	Low			
207- Women's Bathroom Faucet Far Right #4	19221800-143BF	5/7/2026	ND	Non-Detect			
214- Classroom Faucet	19221800-144CF	5/7/2026	0.94	Low			

215- Classroom Faucet	19221800-145CF	5/7/2026	2.9	Low			
216- Classroom Faucet	19221800-146CF	5/7/2026	1.6	Low			
217- Classroom Faucet	19221800-147CF	5/7/2026	3.8	Low			
218- Classroom Faucet	19221800-148CF	5/7/2026	2.2	Low			
220- Staff Bathroom Faucet	19221800-149BF	5/7/2026	0.68	Low			
222- Science Classroom Middle of Room	19221800-151CF	5/7/2026	**16**	**Action Req.**			
222- Science Classroom South Wall Left	19221800-152CF	5/7/2026	**11**	**High**			
222- Science Classroom South Wall Right	19221800-153CF	5/7/2026	8.2	Moderate			
222- Science Classroom West Wall Left	19221800-154CF	5/7/2026	**13**	**High**			
222- Science Classroom West Wall Right	19221800-155CF	5/7/2026	**22**	**Action Req.**			
222- Science Classroom North Wall Left	19221800-156CF	5/7/2026	**10**	**High**			
222- Science Classroom North Wall Right	19221800-157CF	5/7/2026	7.5	Moderate			
223- Science Prep Room Faucet	19221800-158SF	5/7/2026	**24**	**Action Req.**			
223- Science Prep Room Drinking Fountain	19221800-159DW	5/7/2026	**12**	**High**			
224- Science Classroom Middle of Room	19221800-161CF	5/7/2026	**41**	**Action Req.**			
224- Science Classroom South Wall	19221800-162CF	5/7/2026	5.9	Moderate			
224- Science Classroom West Wall Left	19221800-163CF	5/7/2026	5.9	Moderate			
224- Science Classroom West Wall Right	19221800-164CF	5/7/2026	6.6	Moderate			
224- Science Classroom North Wall Left	19221800-165CF	5/7/2026	6.9	Moderate			
224- Science Classroom North Wall Right	19221800-166CF	5/7/2026	2.8	Low			
227- Classroom Faucet	19221800-167CF	5/7/2026	0.77	Low			
228- Classroom Faucet	19221800-168CF	5/7/2026	1.7	Low			
229- Classroom Faucet	19221800-169CF	5/7/2026	4.4	Low			
231-Classroom Faucet North Wall Left	19221800-170CF	5/7/2026	2.3	Low			
231-Classroom Faucet North Wall Right	19221800-171CF	5/7/2026	2.4	Low			
231-Classroom Faucet Wash Basin	19221800-172CF	5/7/2026	1.5	Low			
232- Women's Bathroom Faucet Far Left	19221800-173BF	5/7/2026	1.5	Low			
232- Women's Bathroom Faucet Center Left	19221800-174BF	5/7/2026	1.1	Low			
232- Women's Bathroom Faucet Center Right	19221800-175BF	5/7/2026	0.96	Low			
232- Women's Bathroom Faucet Far Right	19221800-176BF	5/7/2026	0.91	Low			
245- Hallway Drinking Fountain	19221800-177DW	5/7/2026	3.5	Low			
233- Men's Bathroom Faucet Far Left	19221800-178BF	5/7/2026	0.86	Low			
233- Men's Bathroom Faucet Center Left	19221800-179BF	5/7/2026	1.1	Low			
233- Men's Bathroom Faucet Center Right	19221800-180BF	5/7/2026	1	Low			
233- Men's Bathroom Faucet Far Right	19221800-181BF	5/7/2026	8.1	Moderate			
244- Classroom Faucet Left	19221800-182CF	5/7/2026	5.1	Moderate			
244- Classroom Faucet Right	19221800-183CF	5/7/2026	4.7	Low			
82- Workroom Coffee Maker	19221800-184OT	5/7/2026	1.5	Low			