

Lead in School Drinking Water Report

North Kitsap High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-04-25

Date(s) analyzed: 2026-05-05, 2026-05-14

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	420337	2026-04-25	Main	Pot Filler	Kitchen	5 of 5	Tap	center	171
2	420327	2026-04-25	100 Building	Fountain Tap Combo	Project Room 2	1 of 1	Water Fountain	right	52
3	420314	2026-04-25	100 Building	Fountain Tap Combo	Room 102	1 of 1	Water Fountain	right	34
4	420326	2026-04-25	100 Building	Fountain Tap Combo	Project Room 2	1 of 1	Tap	center	18
5	420329	2026-04-25	100 Building	Fountain Tap Combo	Room 110	1 of 1	Water Fountain	right	18
6	420324	2026-04-25	100 Building	Fountain Tap Combo	Room 108	1 of 1	Water Fountain	right	16
7	420312	2026-04-25	100 Building	Fountain Tap Combo	Room 101	1 of 1	Water Fountain	right	14
8	420322	2026-04-25	100 Building	Fountain Tap Combo	Room 107	1 of 1	Water Fountain	right	9
9	420321	2026-04-25	100 Building	Fountain Tap Combo	Room 107	1 of 1	Tap	center	7
10	420341	2026-04-25	Main	Fountain	Corridor 411	1 of 1	Water Fountain	right	7
11	420313	2026-04-25	100 Building	Fountain Tap Combo	Room 102	1 of 1	Tap	center	5

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
12	420334	2026-04-25	Main	Sink	Kitchen	2 of 5	Tap	right	5
13	420349	2026-04-25	Main	Fountain - Multi-level	500 Hall	1 of 1	Water Fountain	right	4
14	420299	2026-04-25	Gym	Fountain - Multi-level	Weight Room	1 of 1	Water Fountain	right	3
15	420315	2026-04-25	100 Building	Fountain Tap Combo	Room 103	1 of 1	Tap	center	3
16	420316	2026-04-25	100 Building	Fountain Tap Combo	Room 103	1 of 1	Water Fountain	right	3
17	420320	2026-04-25	100 Building	Fountain Tap Combo	Room 106	1 of 1	Tap	center	3
18	420328	2026-04-25	100 Building	Fountain Tap Combo	Room 110	1 of 1	Tap	center	3
19	420351	2026-04-25	Main	Sink	Student Store	1 of 1	Tap	center	3
20	420301	2026-04-25	Gym	Fountain - Multi-level	Girls Locker Room	1 of 1	Water Fountain	right	2
21	420308	2026-04-25	Gym	Sink	Room 803	1 of 1	Tap	center	2
22	420323	2026-04-25	100 Building	Fountain Tap Combo	Room 108	1 of 1	Tap	center	2
23	420325	2026-04-25	100 Building	Fountain Tap Combo	Room 109	1 of 1	Tap	center	2

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
24	420332	2026-04-25	Main	Sink - Multi-compartment	Kitchen	1 of 5	Sprayer	left	2
25	420340	2026-04-25	Main	Sink	Staff Room 237	1 of 1	Tap	center	2
26	420352	2026-04-25	Technology	Sink	Room 702	1 of 1	Tap	center	2
27	420353	2026-04-25	Technology	Fountain	Hallway	1 of 1	Water Fountain	right	2
28	420309	2026-04-25	Gym	Fountain	Aux Gym	1 of 1	Water Fountain	right	1
29	420311	2026-04-25	100 Building	Fountain Tap Combo	Room 101	1 of 1	Tap	center	1
30	420333	2026-04-25	Main	Sink - Multi-compartment	Kitchen	1 of 5	Tap	center	1
31	420342	2026-04-25	Main	Sink	Room 401	1 of 1	Tap	center	1
32	420350	2026-04-25	Main	Sink	Room 508	1 of 1	Tap	center	1
33	420295	2026-04-25	Gym	Fountain	Foyer	1 of 2	Water Fountain	left	<1
34	420296	2026-04-25	Gym	Water Bottle Filling Station	Foyer	2 of 2	Water Bottle Filler	right	<1
35	420297	2026-04-25	Gym	Sink - Multi-compartment	Gym Concessions	1 of 1	Tap	center	<1
36	420298	2026-04-25	Gym	Fountain - Multi-level	Weight Room	1 of 1	Water Fountain	left	<1
37	420300	2026-04-25	Gym	Fountain - Multi-level	Girls Locker Room	1 of 1	Water Fountain	left	<1

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
38	420302	2026-04-25	Gym	Fountain - Multi-level	Boys Locker Room	1 of 1	Water Fountain	left	<1
39	420303	2026-04-25	Gym	Fountain - Multi-level	Boys Locker Room	1 of 1	Water Fountain	right	<1
40	420304	2026-04-25	Gym	Water Bottle Filling Station	Outside Of Boys Locker Room	1 of 2	Water Bottle Filler	left	<1
41	420305	2026-04-25	Gym	Fountain	Outside Of Boys Locker Room	2 of 2	Water Fountain	right	<1
42	420306	2026-04-25	Gym	Sink - Multi-compartment	Training Room	1 of 2	Tap	center	<1
43	420307	2026-04-25	Gym	Ice Machine	Training Room	2 of 2	Ice Machine	center	<1
44	420310	2026-04-25	Music	Fountain	Choir Room	1 of 1	Water Fountain	right	<1
45	420317	2026-04-25	100 Building	Sink - Multi-compartment	Staff Room	1 of 1	Tap	center	<1
46	420318	2026-04-25	100 Building	Water Bottle Filling Station	Hallway Next To Room 105	1 of 2	Water Bottle Filler	left	<1
47	420319	2026-04-25	100 Building	Fountain	Hallway Next To Room 105	2 of 2	Water Fountain	right	<1
48	420330	2026-04-25	Main	Water Bottle Filling Station	Outside Of Commons	1 of 2	Water Bottle Filler	left	<1
49	420331	2026-04-25	Main	Fountain	Outside Of Commons	2 of 2	Water Fountain	right	<1

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
50	420335	2026-04-25	Main	Ice Machine	Ice Machine	3 of 5	Ice Machine	center	<1
51	420336	2026-04-25	Main	Sink	Kitchen	4 of 5 island sink	Tap	center	<1
52	420338	2026-04-25	Main	Sink	Asb Room 220	1 of 1	Tap	center	<1
53	420339	2026-04-25	Main	Sink	Nurses Office	1 of 1	Tap	center	<1
54	420343	2026-04-25	Main	Sink	Room 301	1 of 1	Tap	center	<1
55	420344	2026-04-25	Main	Fountain With Bottle Filler	300 Hall	1 of 1	Water Bottle Filler	center	<1
56	420345	2026-04-25	Main	Fountain With Bottle Filler	300 Hall	1 of 1	Water Fountain	right	<1
57	420346	2026-04-25	Main	Sink	Room 506	1 of 1	Tap	center	<1
58	420347	2026-04-25	Main	Sink	Room 505	1 of 1	Tap	center	<1
59	420348	2026-04-25	Main	Fountain - Multi-level	500 Hall	1 of 1	Water Fountain	left	<1