



October 1, 2025

Ms. Helen G. Haley
Voorhees Township Board of Education
329 Route 73
Voorhees, New Jersey 08043

RE: Copper Potable Water Re-Sampling
Voorhees Early Childhood Development Center
Classroom 215
250 Haddonfield Berlin Road
Gibbsboro, New Jersey 08026
Hillmann Project #: PH-4016

Dear Ms. Haley,

Thank you for retaining Hillmann Consulting, LLC (Hillmann) to address your environmental concerns. On September 23, 2025, Mr. Eric Thom, industrial hygienist of Hillmann, conducted potable water re-sampling within Classroom 215 of the Voorhees Early Childhood Development Center located at 250 Haddonfield Berlin Road in Gibbsboro, New Jersey. This re-sampling was performed following corrective actions that were taken in response to results of an initial sampling which indicated copper concentrations equal to the EPA action level at a water outlet within the space.

METHODS

On August 26, 2025, Hillmann performed an initial lead and copper potable water sampling throughout the building. In all samples collected, lead was either not detected or was detected below the EPA Action Level. Copper was either not detected or was detected below the EPA Action Level in all samples with the exception of that collected from the Classroom 215 Sink. In this location, copper was detected at the EPA Action Level of 1,300 µg/L. A report detailing these findings and providing corrective action recommendations was issued on September 15, 2025.

On September 23, 2025, Hillmann returned to the site to perform re-sampling after corrective actions had been completed. As reported to Hillmann, the filter of the Classroom 215 sink had been replaced on September 22, 2025. Hillmann collected one (1) first-draw water sample after water remained stagnant in the system for between 8 and 18 hours. The sample was sent to an appropriately accredited laboratory (EMSL Analytical, Inc., Cinnaminson, NJ) for analysis via EPA Method 200.8 for copper.

RESULTS


Copper was detected at a concentration of 320 µg/L in the re-sampling collected following the corrective action at the Classroom 215 Sink. This detected concentration is below the EPA Action Level of 1,300 µg/L for copper.

CONCLUSION AND RECOMMENDATIONS

Based on the re-sample analysis results for the Classroom 215 Sink, the corrective actions appear to have been effective as copper concentrations in water at this outlet were detected below the applicable EPA Action Level. No further corrective action is recommended at this time.

If you have any questions, or need additional information, please feel free to contact our office at (856)-581-9055.

Sincerely,
Hillmann Consulting, LLC



Eric Thom
Industrial Hygienist



John Murphy, CMC, CFSC
Project Manager

Enclosure: Laboratory Results

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012535701**LIMS Reference ID:** AD35701**EMSL Customer ID:** HILL50E

Attention: Eric Thom
Hillmann Consulting, LLC [HILL50E]
304 Harper Drive
Moorestown, NJ 08057
(908) 721-2302
Ethom@hillmannconsulting.com

Project Name: Voorhees ECDC

Project ID: _Master Project-HILL50E
Customer PO: PH-4016
Sales Rep: Justin Monturano
Received: 09/23/2025 09:00
Reported: 09/25/2025 18:48

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: Room 215 Sink Lims Reference ID: AD35701-01 Matrix: Drinking Water Sampled: 09/23/25 06:06:00									
Metals									
Copper	320		1	35	µg/L	09/24/25 11:13	09/24/25 15:30	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012535701

LIMS Reference ID: AD35701

EMSL Customer ID: HILL50E

Attention: Eric Thom
Hillmann Consulting, LLC [HILL50E]
304 Harper Drive
Moorestown, NJ 08057
(908) 721-2302
Ethom@hillmannconsulting.com

Project Name: Voorhees ECDC

Project ID: _Master Project-HILL50E
Customer PO: PH-4016
Sales Rep: Justin Monturano
Received: 09/23/2025 09:00
Reported: 09/25/2025 18:48

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

EPA 200.8 in Drinking Water

Copper	NJDEP
--------	-------

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2026
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2026
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2026
California ELAP	California Water Boards	1877	06/30/2026
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026
21-A2LA	A2LA Food Chem/Mat Sci	2845.15	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012535701**LIMS Reference ID:** AD35701**EMSL Customer ID:** HILL50E

Attention: Eric Thom
Hillmann Consulting, LLC [HILL50E]
304 Harper Drive
Moorestown, NJ 08057
(908) 721-2302
Ethom@hillmannconsulting.com

Project Name: Voorhees ECDC

Project ID: _Master Project-HILL50E
Customer PO: PH-4016
Sales Rep: Justin Monturano
Received: 09/23/2025 09:00
Reported: 09/25/2025 18:48

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
P2	Sample was preserved at the lab prior to analysis.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

GSA Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AD35701

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information	Customer ID: Hill50e	Billing Information	Billing ID:	
	Company Name: Hillmann Consulting		Company Name:	
	Contact Name: Eric Thom		Billing Contact:	
	Street Address: 304 Harper Drive		Street Address:	
	City, State, Zip: Moorestown NJ 08057		City, State, Zip:	Country:
	Country: US		Country:	
Phone: 856-581-9055	Phone:			
Email(s) for Report: ethom@hillmann.com	Email(s) for Invoice:			

Project Information		Purchase Order: PH-4016
Project Name/No: Voorhees ECDC		
EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected: NJ	State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Sampled By Name: Eric Thom	Sampled By Signature: [Signature]	No. of Samples in Shipment: 1

*Analysis completed in accordance with EMSL's Terms and Conditions located on page 2 of this Chain of Custody

GSA Drinking Water Analysis Panels - Please Check

☐ Legionella - Test Code M345 - ISO 11731:2017	Accreditation: ISO 17025:2017 (AIHA or A2LA) or CDC ELITE Sample Volume: 250mL (Na-thio) Source: Hot water - first draw Turnaround-time (TAT): 2 week Hold Time: None (48 hours for New York State)
☐ Total Coliform including E.coli - Test Code M017 - EPA 9223 B-1997	Accreditation: State Certification Sample Volume: 100mL (Na-thio) Source: Cold water - first draw Turnaround-time (TAT): 2 day Hold Time: 30 hours
☒ Lead and Copper - Test Method 200.8 - ICP-MS Copper Only	Accreditation: NELAC Sample Volume: 250mL (unpreserved or Nitric acid) Source: Cold water - first draw Turnaround-time (TAT): 24 Hour Hold Time: None

Sampling Site	Date and Time Collected	Lab Use Only Temp. upon Receipt (°C)
Room 215 Sink (PH-4016-01)	9/23/25 06:06	

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Method, Limits of Detection, etc.)

HNO₃ added @ 0805 on 9/23-LD.

Method of Shipment: Delivered	Sample Condition Upon Receipt:	Received on Ice? ☐
Relinquished by: [Signature]	Date/Time: 9/23/25 06:40	Relinquished by: [Signature] DB
Relinquished by: [Signature]	Date/Time: 9/23/25 0900	Date/Time: 9/23/25 0900

Controlled Document - COC-95 GSA R1 02/28/2025

☒ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

GSA Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AD35701

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information	Customer ID: Hill 50e	Billing Information	Billing ID:
	Company Name: Hillmann Consulting		Company Name:
	Contact Name: Eric Thom		Billing Contact:
	Street Address: 304 Harper Drive		Street Address:
	City, State, Zip: Moorestown NJ 08057 Country: US		City, State, Zip: Country:
	Phone: 856-581-9055		Phone:
	Email(s) for Report: ethom@hillmann.com		Email(s) for Invoice:

Project Name/No: Voorhees ECDC		Purchase Order: PH-4016
EMSL LIMS Project ID: (if applicable, EMSL will provide)	US State where samples collected: NJ	State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Sampled By Name: Eric Thom	Sampled By Signature: [Signature]	No. of Samples in Shipment: 1

*Analysis completed in accordance with EMSL's Terms and Conditions located on page 2 of this Chain of Custody

GSA Drinking Water Analysis Panels - Please Check

☐ Legionella - Test Code M345 - ISO 11731:2017	Accreditation: ISO 17025:2017 (AIHA or A2LA) or CDC ELITE Sample Volume: 250mL (Na-thio) Source: Hot water - first draw Turnaround-time (TAT): 2 week Hold Time: None (48 hours for New York State)
☐ Total Coliform including E.coli - Test Code M017 - EPA 9223 B-1997	Accreditation: State Certification Sample Volume: 100mL (Na-thio) Source: Cold water - first draw Turnaround-time (TAT): 2 day Hold Time: 30 hours
☒ Lead and Copper - Test Method 200.8 - ICP-MS Copper Only	Accreditation: NELAC Sample Volume: 250mL (unpreserved or Nitric acid) Source: Cold water - first draw Turnaround-time (TAT): 24 Hour Hold Time: None

Sampling Site	Date and Time Collected	Lab Use Only Temp. upon Receipt (°C)
Room 215 Sink (PH-4016-01)	9/23/25 06:06	

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Method, Limits of Detection, etc.):

HNO₃ added @ 0805 on 9/23-LD.

Method of Shipment: Delivered	Sample Condition Upon Receipt:	Received on Ice? Check if Yes: ☐
Relinquished by: [Signature]	Date/Time: 9/23/25 06:40	Received by: [Signature] DB
Relinquished by: [Signature]	Date/Time: 9/23/25 0900	Received by: [Signature] (DB)

Controlled Document - CDC-88 GSA R1 02/28/2025

☒ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



September 15, 2025

Ms. Helen G. Haley
Voorhees Township Board of Education
329 Route 73
Voorhees, New Jersey 08043

RE: Lead & Copper Potable Water Sampling
Voorhees Early Childhood Development Center
250 Haddonfield Berlin Road
Gibbsboro, New Jersey 08026
Hillmann Project #: PH-4016

Dear Ms. Haley,

Thank you for retaining Hillmann Consulting, LLC (Hillmann) to address your environmental concerns. On August 26, 2025, Mr. Ian Hinterleiter, industrial hygienist of Hillmann, conducted potable water sampling within the Voorhees Early Childhood Development Center located at 250 Haddonfield Berlin Road in Gibbsboro, New Jersey.

METHODS

The sampling scheme for the project was to collect first-draw water samples after water remained stagnant in the system for between 8 and 18 hours. Hillmann sampled all outlets that may be used for drinking and/or food prep and at least 50% of all the outlets utilized by the child care center. A total of fifty-five (55) outlets were selected for water sampling at the Voorhees Early Childhood Development Center. The samples were sent to an appropriately accredited laboratory (EMSL Analytical, Inc., Cinnaminson, NJ) for analysis via EPA Method 200.8, and the parameters were Lead (Pb) and Copper (Cu).

RESULTS

Copper concentrations levels detected by analysis ranged from below the limit of detection to 1300 µg/L. All samples were below the EPA Action Level for copper of 1300 µg/L, with the exception of the Classroom 215 sink.

Lead concentrations ranged from the below the analytical limit of detection to 9.51 µg/L and were below the EPA Action Level for lead of 10 µg/L.

CONCLUSION AND RECOMMENDATIONS

Based on the sample analysis results for Voorhees Early Childhood Development Center, there are no elevations of lead within the sampled outlets.

Classroom 215 sink meets the USEPA Action Level and is considered elevated for Copper. All other outlets were below the Action Level for Copper.

Hillmann recommends the following for Classroom 215 Sink:

- Remove aerator and clean off any debris, or replace fixture.
- While the aerators are removed perform a thorough flushing of both the cold and hot water lines.
- After appropriate cleaning and or replacement measures have been completed, Hillmann recommends this outlet be retested for Copper in Water.


If you have any questions, or need additional information, please feel free to contact our office at (908) 688-7800.

Sincerely,

Hillmann Consulting, LLC



Ian Hinterleiter
Industrial Hygienist



Jill Asch, MPH, CIH, CSP
Corporate Health and Safety Officer

NJDOH Licensed Lead Inspector/Risk Assessor 036163
Enclosure: Laboratory Results

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026**Project ID:**

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IH01/Classroom 108 sink Lims Reference ID: AD32390-01 Matrix: Drinking Water Sampled: 08/26/25 06:25:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 14:09	08/27/25 14:36	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:36	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH02/Classroom 108 Bathroom sink Lims Reference ID: AD32390-02 Matrix: Drinking Water Sampled: 08/26/25 06:26:00									
Metals									
Copper	72		1	35	µg/L	08/26/25 13:54	08/26/25 14:50	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.02		1	1.00	µg/L	08/26/25 13:54	08/26/25 14:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH03/Classroom 111 sink Lims Reference ID: AD32390-03 Matrix: Drinking Water Sampled: 08/26/25 06:28:00									
Metals									
Copper	260		1	35	µg/L	08/26/25 13:54	08/26/25 14:59	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 14:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH04/Classroom 112 sink Lims Reference ID: AD32390-04 Matrix: Drinking Water Sampled: 08/26/25 06:30:00									
Metals									
Copper	630		1	35	µg/L	08/26/25 13:54	08/26/25 15:01	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH05/Classroom 112 Bathroom sink Lims Reference ID: AD32390-05 Matrix: Drinking Water Sampled: 08/26/25 06:30:00									
Metals									
Copper	100		1	35	µg/L	08/26/25 12:01	08/27/25 13:49	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	1.99		1	1.00	µg/L	08/26/25 12:01	08/27/25 13:49	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH06/Hallway water bottle filler Lims Reference ID: AD32390-06 Matrix: Drinking Water Sampled: 08/26/25 06:32:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:54	08/26/25 15:03	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH07/Classroom 113 sink Lims Reference ID: AD32390-07 Matrix: Drinking Water Sampled: 08/26/25 06:34:00									
Metals									
Copper	650		1	35	µg/L	08/26/25 13:54	08/26/25 15:16	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:16	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026**Project ID:**

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IH08/Classroom 114 sink Lims Reference ID: AD32390-08 Matrix: Drinking Water Sampled: 08/26/25 06:37:00									
Metals									
Copper	380		1	35	µg/L	08/26/25 13:54	08/26/25 15:18	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH09/Classroom 114 Bathroom sink Lims Reference ID: AD32390-09 Matrix: Drinking Water Sampled: 08/26/25 06:37:00									
Metals									
Copper	260		1	35	µg/L	08/26/25 13:54	08/26/25 15:20	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.63		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH10/Hallway bathroom sink Lims Reference ID: AD32390-10 Matrix: Drinking Water Sampled: 08/26/25 06:38:00									
Metals									
Copper	840		1	35	µg/L	08/26/25 13:54	08/26/25 15:22	PL	EPA 200.8 (DA)/EPA 200.8
Lead	3.36		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH11/Classroom 120 sink Lims Reference ID: AD32390-11 Matrix: Drinking Water Sampled: 08/26/25 06:40:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 12:01	08/27/25 13:18	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 12:01	08/27/25 13:18	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH12/Classroom 120 Bathroom sink Lims Reference ID: AD32390-12 Matrix: Drinking Water Sampled: 08/26/25 06:40:00									
Metals									
Copper	100		1	35	µg/L	08/26/25 13:54	08/26/25 15:24	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.17		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH13/Classroom 121 sink Lims Reference ID: AD32390-13 Matrix: Drinking Water Sampled: 08/26/25 06:42:00									
Metals									
Copper	41		1	35	µg/L	08/26/25 12:01	08/27/25 13:55	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 12:01	08/27/25 13:55	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH14/Hallway bottle filler, by multi purpose Rm Lims Reference ID: AD32390-14 Matrix: Drinking Water Sampled: 08/26/25 06:44:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:54	08/26/25 15:27	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:27	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:

PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026

Project ID:

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: IH14/Hallway bottle filler, by multi purpose
Rm (Continued)

Lims Reference ID: AD32390-14 Matrix: Drinking Water

Sampled: 08/26/25 06:44:00

Metals (Continued)

Sample: IH15/Multi purpose room bathroom sink

Lims Reference ID: AD32390-15 Matrix: Drinking Water

Sampled: 08/26/25 06:46:00

Metals

Copper	120	1	35	µg/L	08/26/25 13:54	08/26/25 15:25	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.40	1	1.00	µg/L	08/26/25 13:54	08/26/25 15:25	PL	EPA 200.8 (DA)/EPA 200.8

Sample: IH16/Kitchen hand wash sink 1

Lims Reference ID: AD32390-16 Matrix: Drinking Water

Sampled: 08/26/25 06:51:00

Metals

Copper	120	1	35	µg/L	08/26/25 13:54	08/26/25 15:33	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.80	1	1.00	µg/L	08/26/25 13:54	08/26/25 15:33	PL	EPA 200.8 (DA)/EPA 200.8

Sample: IH17/Kitchen Dish washing station

Lims Reference ID: AD32390-17 Matrix: Drinking Water

Sampled: 08/26/25 06:55:00

Metals

Copper	370	1	35	µg/L	08/26/25 13:54	08/26/25 15:39	PL	EPA 200.8 (DA)/EPA 200.8
Lead	9.51	1	1.00	µg/L	08/26/25 13:54	08/26/25 15:39	PL	EPA 200.8 (DA)/EPA 200.8

Sample: IH18/Kitchen Ice Maker

Lims Reference ID: AD32390-18 Matrix: Drinking Water

Sampled: 08/26/25 06:59:00

Metals

Copper	ND	1	35	µg/L	08/26/25 13:54	08/26/25 15:41	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1	1.00	µg/L	08/26/25 13:54	08/26/25 15:41	PL	EPA 200.8 (DA)/EPA 200.8

Sample: IH19/Kitchen P wash sink

Lims Reference ID: AD32390-19 Matrix: Drinking Water

Sampled: 08/26/25 07:05:00

Metals

Copper	680	1	35	µg/L	08/26/25 13:54	08/26/25 15:43	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1	1.00	µg/L	08/26/25 13:54	08/26/25 15:43	PL	EPA 200.8 (DA)/EPA 200.8

Sample: IH20/Kitchen C sink

Lims Reference ID: AD32390-20 Matrix: Drinking Water

Sampled: 08/26/25 07:09:00

Metals

Copper	380	1	35	µg/L	08/26/25 13:54	08/26/25 15:45	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1	1.00	µg/L	08/26/25 13:54	08/26/25 15:45	PL	EPA 200.8 (DA)/EPA 200.8

Sample: IH21/Kitchen hand wash sink 2

Lims Reference ID: AD32390-21 Matrix: Drinking Water

Sampled: 08/26/25 07:12:00

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026**Project ID:**

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IH21/Kitchen hand wash sink 2 (Continued) Lims Reference ID: AD32390-21 Matrix: Drinking Water Sampled: 08/26/25 07:12:00									
Metals									
Copper	490		1	35	µg/L	08/26/25 13:54	08/26/25 15:47	PL	EPA 200.8 (DA)/EPA 200.8
Lead	2.89		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH22/Work room 135 sink Lims Reference ID: AD32390-22 Matrix: Drinking Water Sampled: 08/26/25 07:15:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:54	08/26/25 15:49	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH23/Classroom 127 sink Lims Reference ID: AD32390-23 Matrix: Drinking Water Sampled: 08/26/25 07:19:00									
Metals									
Copper	240		1	35	µg/L	08/26/25 13:54	08/26/25 15:50	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:54	08/26/25 15:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH24/Classroom 127 Bathroom sink Lims Reference ID: AD32390-24 Matrix: Drinking Water Sampled: 08/26/25 07:20:00									
Metals									
Copper	350		1	35	µg/L	08/26/25 13:58	08/26/25 16:08	PL	EPA 200.8 (DA)/EPA 200.8
Lead	2.22		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH25/Classroom 128 sink Lims Reference ID: AD32390-25 Matrix: Drinking Water Sampled: 08/26/25 07:23:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 12:01	08/27/25 13:57	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	2.22		1	1.00	µg/L	08/26/25 12:01	08/27/25 13:57	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH26/Classroom 129 sink Lims Reference ID: AD32390-26 Matrix: Drinking Water Sampled: 08/26/25 07:26:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:13	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH27/Classroom 129 Bathroom sink Lims Reference ID: AD32390-27 Matrix: Drinking Water Sampled: 08/26/25 07:27:00									
Metals									
Copper	110		1	35	µg/L	08/26/25 12:01	08/27/25 14:04	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	2.94		1	1.00	µg/L	08/26/25 12:01	08/27/25 14:04	SE	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026**Project ID:**

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IH28/Classroom 134 sink Lims Reference ID: AD32390-28 Matrix: Drinking Water Sampled: 08/26/25 07:29:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:15	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH29/Classroom 130 sink Lims Reference ID: AD32390-29 Matrix: Drinking Water Sampled: 08/26/25 07:31:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:17	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH30/Classroom 130 bathroom sink Lims Reference ID: AD32390-30 Matrix: Drinking Water Sampled: 08/26/25 07:32:00									
Metals									
Copper	120		1	35	µg/L	08/26/25 13:58	08/26/25 16:19	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.42		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH31/Classroom 131 sink Lims Reference ID: AD32390-31 Matrix: Drinking Water Sampled: 08/26/25 07:34:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 12:01	08/27/25 14:06	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	2.10		1	1.00	µg/L	08/26/25 12:01	08/27/25 14:06	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH32/Nurses room sink Lims Reference ID: AD32390-32 Matrix: Drinking Water Sampled: 08/26/25 07:36:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:25	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH33/Classroom 102 sink Lims Reference ID: AD32390-33 Matrix: Drinking Water Sampled: 08/26/25 07:37:00									
Metals									
Copper	320		1	35	µg/L	08/26/25 13:58	08/26/25 16:27	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH34/Classroom 102 bathroom sink Lims Reference ID: AD32390-34 Matrix: Drinking Water Sampled: 08/26/25 07:38:00									
Metals									
Copper	120		1	35	µg/L	08/26/25 14:09	08/27/25 14:30	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	2.75		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:30	SE	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026**Project ID:**

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IH35/Hallway water bottle filter by room 102 Lims Reference ID: AD32390-35 Matrix: Drinking Water Sampled: 08/26/25 07:40:00									
Metals									
Copper	530		1	35	µg/L	08/26/25 13:58	08/26/25 16:29	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH36/Classroom 103 sink Lims Reference ID: AD32390-36 Matrix: Drinking Water Sampled: 08/26/25 07:41:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:31	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH37/Classroom 104 sink Lims Reference ID: AD32390-37 Matrix: Drinking Water Sampled: 08/26/25 07:43:00									
Metals									
Copper	470		1	35	µg/L	08/26/25 13:58	08/26/25 16:33	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.01		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH38/Classroom 104 bathroom sink Lims Reference ID: AD32390-38 Matrix: Drinking Water Sampled: 08/26/25 07:44:00									
Metals									
Copper	340		1	35	µg/L	08/26/25 13:58	08/26/25 16:35	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.44		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH39/Classroom 105 sink Lims Reference ID: AD32390-39 Matrix: Drinking Water Sampled: 08/26/25 07:46:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:40	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH40/Faculty room sink Lims Reference ID: AD32390-40 Matrix: Drinking Water Sampled: 08/26/25 07:48:00									
Metals									
Copper	310		1	35	µg/L	08/26/25 13:58	08/26/25 16:42	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH41/Classroom 208 sink Lims Reference ID: AD32390-41 Matrix: Drinking Water Sampled: 08/26/25 07:52:00									
Metals									
Copper	400		1	35	µg/L	08/26/25 13:58	08/26/25 16:48	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:48	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026**Project ID:**

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IH42/Classroom 208 bathroom sink Lims Reference ID: AD32390-42 Matrix: Drinking Water Sampled: 08/26/25 07:52:00									
Metals									
Copper	400		1	35	µg/L	08/26/25 14:09	08/27/25 14:39	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	5.98		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:39	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH43/Classroom 215 sink Lims Reference ID: AD32390-43 Matrix: Drinking Water Sampled: 08/26/25 07:54:00									
Metals									
Copper	1300		1	35	µg/L	08/26/25 14:09	08/27/25 14:41	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	1.41		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:41	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH44/Hallway water bottle filter by room 215 Lims Reference ID: AD32390-44 Matrix: Drinking Water Sampled: 08/26/25 07:56:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:50	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH45/Room 213 sink Lims Reference ID: AD32390-45 Matrix: Drinking Water Sampled: 08/26/25 07:58:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 14:09	08/27/25 14:43	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	1.99		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:43	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH46/Classroom 208 sink Lims Reference ID: AD32390-46 Matrix: Drinking Water Sampled: 08/26/25 08:00:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 14:09	08/27/25 14:45	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	2.74		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:45	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH47/Classroom 209 Bathroom sink Lims Reference ID: AD32390-47 Matrix: Drinking Water Sampled: 08/26/25 08:00:00									
Metals									
Copper	230		1	35	µg/L	08/26/25 14:09	08/27/25 14:47	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	3.60		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:47	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH48/Classroom 207 sink Lims Reference ID: AD32390-48 Matrix: Drinking Water Sampled: 08/26/25 08:02:00									
Metals									
Copper	130		1	35	µg/L	08/26/25 14:09	08/27/25 14:50	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	8.53		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:50	SE	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026**Project ID:**

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IH49/Classroom 206 sink Lims Reference ID: AD32390-49 Matrix: Drinking Water Sampled: 08/26/25 08:04:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:52	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH50/Classroom 206 bathroom sink Lims Reference ID: AD32390-50 Matrix: Drinking Water Sampled: 08/26/25 08:04:00									
Metals									
Copper	350		1	35	µg/L	08/26/25 14:09	08/27/25 14:56	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	3.77		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:56	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH51/Hallway water bottle filter by room 206 Lims Reference ID: AD32390-51 Matrix: Drinking Water Sampled: 08/26/25 08:06:00									
Metals									
Copper	36		1	35	µg/L	08/26/25 13:58	08/26/25 16:54	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH52/Classroom 204 sink Lims Reference ID: AD32390-52 Matrix: Drinking Water Sampled: 08/26/25 08:09:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:56	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH53/Classroom 203 sink Lims Reference ID: AD32390-53 Matrix: Drinking Water Sampled: 08/26/25 08:11:00									
Metals									
Copper	ND		1	35	µg/L	08/26/25 13:58	08/26/25 16:58	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.06		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IH54/Classroom 203 bathroom sink Lims Reference ID: AD32390-54 Matrix: Drinking Water Sampled: 08/26/25 08:12:00									
Metals									
Copper	620		1	35	µg/L	08/26/25 14:09	08/27/25 14:58	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	2.66		1	1.00	µg/L	08/26/25 14:09	08/27/25 14:58	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: IH55/Room 220 sink Lims Reference ID: AD32390-55 Matrix: Drinking Water Sampled: 08/26/25 08:14:00									
Metals									
Copper	240		1	35	µg/L	08/26/25 13:58	08/26/25 16:59	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	08/26/25 13:58	08/26/25 16:59	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390**LIMS Reference ID:** AD32390**EMSL Customer ID:** HILL50E**Attention:** Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]

304 Harper Drive

Moorestown, NJ 08057

(267) 541-4780

ihinterleiter@hillmann.com

Project Name:

PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026

Project ID:

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Work Order Case Narrative

This is a revised report replacing initial reports dated 8/27/25. Added project nnumber/name.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390

LIMS Reference ID: AD32390

EMSL Customer ID: HILL50E

Attention: Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]
304 Harper Drive
Moorestown, NJ 08057
(267) 541-4780
ihinterleiter@hillmann.com

Project Name:

PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026

Project ID:

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Copper	NJDEP
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2026
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2026
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2026
California ELAP	California Water Boards	1877	06/30/2026
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012532390**LIMS Reference ID:** AD32390**EMSL Customer ID:** HILL50E**Attention:** Ian Hinterleiter

Hillmann Consulting, LLC [HILL50E]
304 Harper Drive
Moorestown, NJ 08057
(267) 541-4780
ihinterleiter@hillmann.com

Project Name:

PH-4016: Voorhees Early Childhood Development
Center/250 Haddonfield Berlin Rd, Gibbsboro, New
Jersey 08026

Project ID:

_Master Project-HILL50E

Customer PO:**Sales Rep:**

Justin Monturano

Received:

08/26/2025 10:15

Reported:

08/28/2025 14:05

Notes and Definitions

Item	Definition
P3	Sample was preserved by client prior to getting into laboratory.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

AD32390

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE:

EMAIL: (800) 220-3675
CinnaminsonLeadLab@emsl.com

Customer Information	Customer ID: Hill 50E	Billing Information	Billing ID:
	Company Name: Hillman		Company Name:
	Contact Name: Ian Highteiler		Billing Contact:
	Street Address: 304 Wadsworth Ave #207		Street Address:
	City, State, Zip: Maple Grove, NJ		City, State, Zip:
	Phone: 201-541-1780		Phone:
Email(s) for Report: ian@highteiler.com		Email(s) for Invoice:	

Project Information		Purchase Order:
Project Name/No:	US State where samples collected: NJ	State of Connecticut (CT) must select project location:
EMSL LIMS Project ID: (If applicable, EMSL will provide)	Commercial (Taxable)	Residential (Non-Taxable)
Sampled By Name: Ian Highteiler	Sampled By Signature: [Signature]	No. of Samples in Shipper: 55

Turn-Around-Time (TAT)					
3 Hour	6 Hour	24 Hour	32 Hour	48 Hour	72 Hour
☐	☐	☒	☐	☐	☐
MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION	
CHIPS % by wt. ppm (mg/kg) mg/cm ² *Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - 1 is recommended.	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.004% - 64 ppm - mg/cm ² - RL is Variable		
	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.004% - 4 ppm - mg/cm ² - RL is Variable		
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter		
	NIOSH 7303M	ICP-OES	1.0 µg/filter		
	NIOSH 7303M	ICP-MS	0.05 µg/filter		
WIPE ASTM NON-ASTM *If no box is checked, non-ASTM wipe is assumed	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe		
	SW 846-6010D*	ICP-OES	1.0 µg/wipe		
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)		
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)		
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)		
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)		
TTLIC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)		
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)		
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)		
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)		
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)		
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)		
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)		
Unpreserved	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)		
Preserved with HNO ₃	EPA 200.5	ICP-OES	0.003 mg/L (ppm)		
Drinking Water	EPA 200.8	ICP-MS	0.001 mg/L (ppm)		
Unpreserved	40 CFR Part 50	ICP-OES	12 µg/filter		
Preserved with HNO ₃		ICP-MS	0.6 µg/filter		
TSP/SPM Filter					
Other:					

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1 I H01	Class Room 108, sink	250	8/26/26 6:25
2 I H02	Class Room 108, Bathroom sink		6:26
3 I H03	Class Room 111, sink		6:29
4 I H04	Class Room 112, sink		6:30
5 I H05	Class Room 112, Bathroom sink		6:30

Method of Shipment: Drop Off		Sample Condition Upon Receipt:	
Relinquished by: Ian Highteiler	Date/Time: 8/26/25 10:15 am	Received by: [Signature]	Date/Time: 8/26/25 10:15 am
Relinquished by: [Signature]	Date/Time: 8/26/25 10:15 am	Received by: [Signature]	Date/Time: 8/26/25 10:15 am



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE:

EMAIL:

(800) 220-3675

CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
6 IH 06	Hallway Water bottle filler	250	8/26/25 6:32
7 IH 07	Classroom 113 sink		6:34
8 IH 08	Classroom 114 sink		6:37
9 IH 09	Classroom 114 Bathroom sink		6:37
10 IH 10	Hallway bathroom sink		6:38
11 IH 11	Classroom 120, sink		6:40
12 IH 12	Classroom 120, bathroom sink		6:40
13 IH 13	Classroom 121, sink		6:42
14 IH 14	Hallway bottle filler, by multi purpose room		6:44
15 IH 15	Multi-purpose room bathroom sink		6:46
16 IH 16	Kitchen hand wash sink 1		6:51
17 IH 17	Kitchen Dish washing station		6:55
18 IH 18	Kitchen, ice maker		6:51
19 IH 19	Kitchen, Pan wash sink		7:05
20 IH 20	Kitchen, Center sink		7:09
21 IH 21	Kitchen, hand wash sink 2		7:12
22 IH 22	Work room 135 sink		7:15
23 IH 23	Classroom 127 sink		7:19
24 IH 24	Classroom 127, Bathroom sink		7:20
25 IH 25	Classroom 128, sink		7:23
26 IH 26	Classroom 129, sink		7:26
27 IH 27	Classroom 129, Bathroom sink		7:27
28 IH 28	Classroom 133 sink		7:29
29 IH 29	Classroom 130, sink		7:31
30 IH 30	Classroom 130, Bathroom sink		7:32

Method of Shipment:

Sample Condition Upon Receipt:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Controlled Document COC-25 Lead R22 03/28/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc. Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of sample to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 2 of 2

Page 13 of 14



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE:

EMAIL:

(800) 220-3675

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

CinnaminsonLeadLab@emsl.com

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
31 IH 31	Classroom 171, sink	250	8/26/25 7:34
32 IH 32	Nurses Room, sink		7:36
33 IH 33	Classroom 102, sink		7:37
34 IH 34	Classroom 102, Bathroom sink		7:38
35 IH 35	Hallway, water bottle filler, by Room 102		7:40
36 IH 36	Classroom 103, sink		7:41
37 IH 37	Classroom 104, sink		7:43
38 IH 38	Classroom 104 Bathroom sink		7:44
39 IH 39	Classroom 105, sink		7:46
40 IH 40	Faculty Room, sink,		7:48
41 IH 41	Classroom 208, sink		7:52
42 IH 42	Classroom 208 Bathroom sink		7:52
43 IH 43	Classroom 215, sink		7:54
44 IH 44	Hallway, water bottle filler by Room 215		7:56
45 IH 45	Room 219, sink		7:58
46 IH 46	Classroom 209, sink		8:00
47 IH 47	Classroom 209 Bathroom sink		8:00
48 IH 48	Classroom 207, sink		8:02
49 IH 49	Classroom 206, sink		8:04
50 IH 50	Classroom 206 Bathroom sink		8:04
51 IH 51	Hallway, water bottle filler, by Room 206		8:06
52 IH 52	Classroom 204, sink		8:09
53 IH 53	Classroom 203, sink		8:11
54 IH 54	Classroom 203 Bathroom sink		8:12
55 IH 55	Room 220, sink		8:14

Method of Shipment:

Sample Condition Upon Receipt:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Controlled Document CCG-25 Lead R22 03/28/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc. Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of sample to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 2 of 2

Page 14 of 14