



Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

November 19, 2025

Kim Gadaree
Salem School District
200 Hartford Road
Salem, CT 06420

Re: **Radon Testing (11/3 - 6/25)**
Salem School
200 Hartford Road; Salem, CT

Dear Kim:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on November 3rd – 6th, 2025. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services. The testing was conducted by a Certified Radon Specialist, Christopher Muller (NRSB License #6SS0019).

The results for radon in air are summarized below:

Location	Radon Test Kit #	Result (pCi/L)
Gym Office	12224005	1.6
L09	12224011	0.6
L27 (dup.)	12224019	0.9
L27	12224022	0.8
B1 –Blank	12224051	<0.3

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation. **All locations are safe for occupancy under current EPA standards for radon.**

Thank you for selecting Mystic Air Quality to perform these services.

Sincerely,

Christopher J. Eident CIH, CSP, MPH
CEO





STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH
RADON PROGRAM

SCHOOL RADON RE-EVALUATION REPORT FORM



July 2023

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel.

Do not send test results or other documents.

Submit this signed form by **email** to the Radon Program at:

DPH.RadonReports@ct.gov

Name of School:

SALEM SCHOOL

Address:

(Street, town, zip code)

200 HARTFORD ROAD

SALEM, CT 06420

Measurement Company:

MUSKIE AVE. QUINCY CONSULTANTS

Please provide the following summary information:

Dates of Testing:

(Deployment/retrieval dates. Include confirmatory testing dates, if applicable.)

11/03/2025 TO 11/04/2025

Total # of Rooms Tested:

3

Total # of Rooms Requiring Re-Testing:

0

Total # of Rooms Where Average Results Were at or above 4.0 pCi/L:

0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Cherise M. ... / 6550019
Measurement Professional / NRPP/NRSB #

Christoph ...
Signature

11/19/25
Date

School Designee / Title

Signature

Date



Phone: (860) 509-7300
Telephone Device for the Deaf (860) 509-7191
410 Capitol Avenue - MS # 12-RAD
P.O. Box 340308, Hartford, CT 06134
An Equal Opportunity Employer

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
12224005	2025-11-03	7:00 am	2025-11-06	8:00 am	70	SALEM, CT	200 HARTFORD ROAD	GYM OFFICE		0	1.6
12224011	2025-11-03	7:00 am	2025-11-06	8:00 am	70	SALEM, CT	200 HARTFORD ROAD	L09		0	0.6
12224019	2025-11-03	7:00 am	2025-11-06	8:00 am	70	SALEM, CT	200 HARTFORD ROAD	L27		0	0.9
12224022	2025-11-03	7:00 am	2025-11-06	8:00 am	70	SALEM, CT	200 HARTFORD ROAD	L27		0	0.8
12224051	2025-11-03	7:00 am	2025-11-06	8:00 am	70	SALEM, CT	200 HARTFORD ROAD	B1		3	< 0.3

200 HARTFORD RD
SALEM, CT 06420

Mystic Air Quality Consultants, Inc.
1204 North Road, Groton, Connecticut 06340 (860) 449-8903

Detector ID	Sample Location	Start Time	End Time	Notes
		11/3 0700	11/6 0800	
12224022	L27			
12224019	L27 Dup			
12224005	GYM OFFICE			
12224011	L09			
12224051	B1	↓	↓	
Dup.				
Dup.				