ADDENDUM

Date May 28, 2026

To Prospective Bidders

Re Addendum No. 2 to the Construction Documents for:

MSAD#75
Bowdoin Central School
ADA Restroom
Bowdoin, Maine
Project No. 25276

This Addendum forms a part of the Contract Documents and modifies the original Construction Documents dated May 12, 2026 and Addendum No. 1 dated May 12, 2026. Acknowledge receipt of this Addendum in the space provided in the Bid Form.

This Addendum consists of one page.

Harriman



Lisa Sawin, AIA
Principal

QUESTIONS AND ANSWERS

Q1. Which direction is the carpet tile in the music room supposed to be orientated? I'm told the orientation changes the counts on the material significantly with the shape of this room. Is there a preference or should we just approach in the most economical way?

A1. Install the carpet tile in the most economical direction to reduce material cost.

Q2. A10-1 states "DOOR HARDWARE: EXISTING DOOR AND FRAME. REPLACE DOOR HARDWARE TO A MORTISE PRIVACY LOCK. MATCH DOOR MANUFACTURER AND SERIES TO THE EXISTING SCHOOL HARDWARE STANDARD." However, the existing door slab is cored for and utilizes a cylindrical lock. Should we assume a cylindrical lock and reusing the door or a new door slab with a mortise lock?

A2: Replace the door hardware with a matching cylindrical privacy lock.