


Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrch.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	JUNCTION SCHOOL DISTRICT
Water System Number:	CA4500163

The water system named above hereby certifies that its Consumer Confidence Report was distributed on **June 1, 2026** (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Don Price	
	Signature:		
	Title:	Director of Maintenance and Operations	
	Phone Number:	(530) 945-8521	Date: May 29, 2026

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☒ Posted the CCR on the internet at [http:// www.junctionesd.net/district-home/required-reporting](http://www.junctionesd.net/district-home/required-reporting)
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☒ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://>_____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2025 Consumer Confidence Report

Posted the CCR in public places:

- Junction District Office Window
- Junction Elementary Front Window
- Junction Staff Lounges
 - Elementary Campus
 - Middle School Campus

2025 Consumer Confidence Report

Water System Name: JUNCTION SCHOOL DISTRICT

Report Date: May 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Ground water

Your water comes from 2 source(s): ELEMENTARY SCHOOL WELL - RAW and JR HIGH SCHOOL WELL - RAW

Opportunities for public participation in decisions that affect drinking water quality: For questions and concerns about your drinking water you may attend the board meeting held the third Tuesday of each month, except the months of June and July. Or you may contact Darin Pust at 530-547-3274

For more information about this report, or any questions relating to your drinking water, please call 530-547-3274 and ask for Darin Pust or email dpust@junctionesd.net or visit our website at junctionesd.net.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2 and 3 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	0 (2025)	ND	no more than 1 positive monthly sample	0	Naturally present in the environment.
Fecal coliform and E. coli	0 (2025)	ND			Human and animal fecal waste.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2025)	5	0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2025)	5	0.06	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2024 - 2025)	3	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Barium (mg/L)	(2025)	0.25	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (ug/L)	(2024 - 2025)	ND	ND - 11	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Hexavalent Chromium (ug/L)	(2024)	ND	ND - 1.8	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2025)	1.3	0.5 - 2.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 4 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2025)	3	n/a	80	n/a	No	By-product of drinking water disinfection
Chlorine, Free (mg/L)	(2025)	0.35	0.06 - 0.71	4.0	4.0	No	Drinking water disinfectant added for treatment.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Junction Elementary School District* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2025 Consumer Confidence Report

Drinking Water Assessment Information

Discussion of Vulnerability

The sources were evaluated by the county in November 2001, to determine if there were possible contaminating activities that might compromise the quality of the water. At that time, there were no associated contaminants detected in the water supply, however the source was still considered vulnerable to nearby automobile repair shops, and sewer collection and septic systems. A copy of the complete report is available upon request.

Acquiring Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Junction Elementary School District

Analytical Results By FGL - 2025

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			ND	-
District Office	CH 2590709-1					2025-10-30	Absent		
District Office	CH 2577010-1					2025-07-21	Absent		
District Office	CH 2573518-1					2025-04-24	Absent		
District Office	CH 2570300-1					2025-01-13	Absent		
Gym Hose Bib	CH 2591425-1					2025-11-21	Absent		
Gym Hose Bib	CH 2578049-1					2025-08-11	Absent		
Gym Hose Bib	CH 2574024-1					2025-05-12	Absent		
Gym Hose Bib	CH 2571533-1					2025-02-26	Absent		
Room 2 Hose Bib	CH 2592078-1					2025-12-16	Absent		
Room 2 Hose Bib	CH 2579061-1					2025-09-10	Absent		
Room 2 Hose Bib	CH 2574996-1					2025-06-09	Absent		
Room 2 Hose Bib	CH 2572326-1					2025-03-26	Absent		
Fecal coliform and E. coli				0	n/a			ND	-
District Office	CH 2590709-1					2025-10-30	Absent		
District Office	CH 2577010-1					2025-07-21	Absent		
District Office	CH 2573518-1					2025-04-24	Absent		
District Office	CH 2570300-1					2025-01-13	Absent		
Gym Hose Bib	CH 2591425-1					2025-11-21	Absent		
Gym Hose Bib	CH 2578049-1					2025-08-11	Absent		
Gym Hose Bib	CH 2574024-1					2025-05-12	Absent		
Gym Hose Bib	CH 2571533-1					2025-02-26	Absent		
Room 2 Hose Bib	CH 2592078-1					2025-12-16	Absent		
Room 2 Hose Bib	CH 2579061-1					2025-09-10	Absent		
Room 2 Hose Bib	CH 2574996-1					2025-06-09	Absent		
Room 2 Hose Bib	CH 2572326-1					2025-03-26	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
A Building RM 2	CH 2579062-5	ug/L				2025-09-06	ND		
D.O. Kitchen	CH 2579062-1	ug/L				2025-09-06	ND		
P-3 Middle School	CH 2579062-2	ug/L				2025-09-06	ND		
P-4 Middle School	CH 2579062-3	ug/L				2025-09-06	ND		
Staff Lounge	CH 2579062-4	ug/L				2025-09-06	ND		
Copper		mg/L		1.3	.3			0.055	5
A Building RM 2	CH 2579062-5	mg/L				2025-09-06	0.05		
D.O. Kitchen	CH 2579062-1	mg/L				2025-09-06	ND		
P-3 Middle School	CH 2579062-2	mg/L				2025-09-06	0.06		
P-4 Middle School	CH 2579062-3	mg/L				2025-09-06	ND		
Staff Lounge	CH 2579062-4	mg/L				2025-09-06	ND		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			3	3 - 3
ELEMENTARY SCHOOL WELL - RAW	CH 2475347-1	ug/L				2024-06-26	3		
ELEMENTARY SCHOOL WELL - RAW	CH 2475347-1	ug/L				2024-06-26	3		
JR HIGH SCHOOL WELL - RAW	CH 2574026-1	ug/L				2025-05-12	3		
Barium		mg/L	2	1	2			0.25	0.25 - 0.25
JR HIGH SCHOOL WELL - RAW	CH 2574026-1	mg/L				2025-05-12	0.25		

Chromium		ug/L	100	50.0	n/a			ND	ND - 11
ELEMENTARY SCHOOL WELL - RAW	CH 2475347-1	ug/L				2024-06-26	11		
ELEMENTARY SCHOOL WELL - RAW	CH 2475347-1	ug/L				2024-06-26	11		
JR HIGH SCHOOL WELL - RAW	CH 2574026-1	ug/L				2025-05-12	ND		
Hexavalent Chromium		ug/L		10	0.02			ND	ND - 1.8
ELEMENTARY SCHOOL WELL - RAW	CH 2479722-1	ug/L				2024-10-23	1.8		
ELEMENTARY SCHOOL WELL - RAW	CH 2479722-1	ug/L				2024-10-23	1.8		
JR HIGH SCHOOL WELL - RAW	CH 2479722-2	ug/L				2024-10-23	ND		
JR HIGH SCHOOL WELL - RAW	CH 2479722-2	ug/L				2024-10-23	ND		
Nitrate as N		mg/L		10	10			1.3	0.5 - 2.0
ELEMENTARY SCHOOL WELL - RAW	CH 2575106-1	mg/L				2025-06-09	2.0		
JR HIGH SCHOOL WELL - RAW	CH 2574027-1	mg/L				2025-05-12	0.5		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			3	3 - 3
9087 DESCHUTES ROAD	CH 2577011-1	ug/L				2025-07-21	3		
Average 9087 DESCHUTES ROAD								3	
Chlorine		mg/L		4.0	4.0			0.35	0.06 - 0.71
District Office	CH 2590709-1	mg/L				2025-10-30	0.12		
District Office	CH 2577010-1	mg/L				2025-07-21	0.71		
District Office	CH 2573518-1	mg/L				2025-04-24	0.23		
District Office	CH 2570300-1	mg/L				2025-01-13	0.13		
Average District Office								0.3	
Gym Hose Bib	CH 2591425-1	mg/L				2025-11-21	0.10		
Gym Hose Bib	CH 2578049-1	mg/L				2025-08-11	0.06		
Gym Hose Bib	CH 2574024-1	mg/L				2025-05-12	0.21		
Gym Hose Bib	CH 2571533-1	mg/L				2025-02-26	0.28		
Average Gym Hose Bib								0.16	
Room 2 Hose Bib	CH 2592078-1	mg/L				2025-12-16	0.22		
Room 2 Hose Bib	CH 2579061-1	mg/L				2025-09-10	0.19		
Room 2 Hose Bib	CH 2574996-1	mg/L				2025-06-09	0.69		
Room 2 Hose Bib	CH 2572326-1	mg/L				2025-03-26	0.31		
Average Room 2 Hose Bib								0.35	

Junction Elementary School District

CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
DBP801	CH 2577011-1	2025-07-21	EPA 551.1	9087 DESCHUTES ROAD	Disinfection Byproducts
DST_LCR	CH 2579062-5	2025-09-06	Metals, Total	A Building RM 2	Lead & Copper Monitoring
	CH 2579062-1	2025-09-06	Metals, Total	D.O. Kitchen	Lead & Copper Monitoring
ROU 1	CH 2570300-1	2025-01-13	Field Test	District Office	Routine Monitoring-1
	CH 2570300-1	2025-01-13	Coliform	District Office	Routine Monitoring-1
	CH 2573518-1	2025-04-24	Coliform	District Office	Routine Monitoring-1
	CH 2573518-1	2025-04-24	Field Test	District Office	Routine Monitoring-1
	CH 2577010-1	2025-07-21	Coliform	District Office	Routine Monitoring-1
	CH 2577010-1	2025-07-21	Field Test	District Office	Routine Monitoring-1
	CH 2590709-1	2025-10-30	Field Test	District Office	Routine Monitoring-1
	CH 2590709-1	2025-10-30	Coliform	District Office	Routine Monitoring-1
WELL1RAW	CH 2475347-1	2024-06-26	Metals, Total	ELEMENTARY SCHOOL WELL - RAW	Elementary School Well - WQ
	CH 2479722-1	2024-10-23	Wet Chemistry	ELEMENTARY SCHOOL WELL - RAW	Chromium 6 Monitoring
	CH 2575106-1	2025-06-09	Wet Chemistry	ELEMENTARY SCHOOL WELL - RAW	Elementary School Well - WQ
ROU 2	CH 2571533-1	2025-02-26	Coliform	Gym Hose Bib	Routine Monitoring-2
	CH 2571533-1	2025-02-26	Field Test	Gym Hose Bib	Routine Monitoring-2
	CH 2574024-1	2025-05-12	Field Test	Gym Hose Bib	Routine Monitoring-2
	CH 2574024-1	2025-05-12	Coliform	Gym Hose Bib	Routine Monitoring-2
	CH 2578049-1	2025-08-11	Coliform	Gym Hose Bib	Routine Monitoring-2
	CH 2578049-1	2025-08-11	Field Test	Gym Hose Bib	Routine Monitoring-2
	CH 2591425-1	2025-11-21	Coliform	Gym Hose Bib	Routine Monitoring-2
	CH 2591425-1	2025-11-21	Field Test	Gym Hose Bib	Routine Monitoring-2
JRHSWELL	CH 2479722-2	2024-10-23	Wet Chemistry	JR HIGH SCHOOL WELL - RAW	Chromium 6 Monitoring
	CH 2574027-1	2025-05-12	Wet Chemistry	JR HIGH SCHOOL WELL - RAW	Jr. High School Well - WQ
	CH 2574026-1	2025-05-12	Metals, Total	JR HIGH SCHOOL WELL - RAW	Jr. High School Well-IOC/VOC
DST_LCR	CH 2579062-2	2025-09-06	Metals, Total	P-3 Middle School	Lead & Copper Monitoring
	CH 2579062-3	2025-09-06	Metals, Total	P-4 Middle School	Lead & Copper Monitoring
ROU 3	CH 2572326-1	2025-03-26	Coliform	Room 2 Hose Bib	Routine Monitoring-3
	CH 2572326-1	2025-03-26	Field Test	Room 2 Hose Bib	Routine Monitoring-3
	CH 2574996-1	2025-06-09	Coliform	Room 2 Hose Bib	Routine Monitoring-3
	CH 2574996-1	2025-06-09	Field Test	Room 2 Hose Bib	Routine Monitoring-3
	CH 2579061-1	2025-09-10	Field Test	Room 2 Hose Bib	Routine Monitoring-3
	CH 2579061-1	2025-09-10	Coliform	Room 2 Hose Bib	Routine Monitoring-3
	CH 2592078-1	2025-12-16	Coliform	Room 2 Hose Bib	Routine Monitoring-3
	CH 2592078-1	2025-12-16	Field Test	Room 2 Hose Bib	Routine Monitoring-3
DST_LCR	CH 2579062-4	2025-09-06	Metals, Total	Staff Lounge	Lead & Copper Monitoring