

Lead in Water Test Results Summary:			Riverdale High School				
Notes:							
• The lead in water Action Level is 15 parts per billion (ppb) . Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.							
• A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [H] ppb.							
Legend:							
• Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.							
• Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.							
Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
21880200-018CF25A	Main Building; Lower Level, Art Room 102, Northeast Wall, North Faucet - Classroom Fixture	01/11/2025	1.84	Low	enter date	enter result	autofill
21880200-019CF25A	Main Building; Lower Level, Art Room 102, Northeast Wall, South Faucet - Classroom Fixture	01/11/2025	1.18	Low			
21880200-020CF25A	Main Building; Lower Level, Art Room 102, Southeast Wall, East Faucet - Classroom Fixture	01/11/2025	1.35	Low			
21880200-021CF25A	Main Building; Lower Level, Art Room 102, Southeast Wall, West Faucet - Classroom Fixture	01/11/2025	1.38	Low			
21880200-001WB25A	Main Building; Lower Level, Gym Lobby - Bottle Filler	01/11/2025	ND	Low			
21880200-002DW25A	Main Building; Lower Level, Gym Lobby - Drinking Fountain	01/11/2025	ND	Low			
21880200-004BF25A	Main Building; Lower Level, Gym Lobby, Men's Restroom, Middle Faucet - Bathroom Fixture	01/11/2025	2.5	Low			
21880200-005BF25A	Main Building; Lower Level, Gym Lobby, Men's Restroom, North Faucet - Bathroom Fixture	01/11/2025	2.44	Low			
21880200-003BF25A	Main Building; Lower Level, Gym Lobby, Men's Restroom, South Faucet - Bathroom Fixture	01/11/2025	2.36	Low			
21880200-007BF25A	Main Building; Lower Level, Gym Lobby, Women's Restroom, Middle Faucet - Bathroom Fixture	01/11/2025	2.26	Low			
21880200-006BF25A	Main Building; Lower Level, Gym Lobby, Women's Restroom, North Faucet - Bathroom Fixture	01/11/2025	2.25	Low			
21880200-008BF25A	Main Building; Lower Level, Gym Lobby, Women's Restroom, South Faucet - Bathroom Fixture	01/11/2025	3.51	Low			
21880200-012DW25A	Main Building; Lower Level, Lobby Outside Weight Room - Drinking Fountain	01/11/2025	0.223	Low			
21880200-009BF25A	Main Building; Lower Level, Men's Locker Room Office Restroom - Bathroom Fixture	01/11/2025	26.8	High	5/4/26	2.09	Low
21880200-010BF25A	Main Building; Lower Level, Men's Locker Room, East Faucet - Bathroom Fixture	01/11/2025	17.1	High	5/4/26	ND	Low
21880200-011BF25A	Main Building; Lower Level, Men's Locker Room, West Faucet - Bathroom Fixture	01/11/2025	19.6	High	5/4/26	ND	Low
21880200-022SF25A	Main Building; Lower Level, Staff Workroom - Staff Fixture	01/11/2025	1.83	Low			
21880200-013IM25A	Main Building; Lower Level, Weight Room - Ice Maker	01/11/2025	ND	Low			
21880200-026BF25A	Main Building; Lower Level, West Corridor, Men's Restroom, Middle Faucet - Bathroom Fixture	01/11/2025	6.26	Low			
21880200-025BF25A	Main Building; Lower Level, West Corridor, Men's Restroom, North Faucet - Bathroom Fixture	01/11/2025	23.9	High	5/4/26	ND	Low
21880200-027BF25A	Main Building; Lower Level, West Corridor, Men's Restroom, South Faucet - Bathroom Fixture	01/11/2025	14.6	Med	5/4/26	ND	Low
21880200-023DW25A	Main Building; Lower Level, West Corridor, North Fountain - Drinking Fountain	01/11/2025	ND	Low			
21880200-024DW25A	Main Building; Lower Level, West Corridor, South Fountain - Drinking Fountain	01/11/2025	ND	Low			
21880200-029BF25A	Main Building; Lower Level, West Corridor, Women's Restroom, Middle Faucet - Bathroom Fixture	01/11/2025	11.3	Low			
21880200-030BF25A	Main Building; Lower Level, West Corridor, Women's Restroom, North Faucet - Bathroom Fixture	01/11/2025	15	High	5/4/26	1.71	Low
21880200-028BF25A	Main Building; Lower Level, West Corridor, Women's Restroom, South Faucet - Bathroom Fixture	01/11/2025	5.34	Low			
21880200-014BF25A	Main Building; Lower Level, Women's Locker Room Office Restroom - Bathroom Fixture	01/11/2025	27.8	High	5/4/2026	1.67	Low
21880200-015BF25A	Main Building; Lower Level, Women's Locker Room, East Faucet - Bathroom Fixture	01/11/2025	17.5	High	5/4/2026	6.09	Low
21880200-016BF25A	Main Building; Lower Level, Women's Locker Room, West Faucet - Bathroom Fixture	01/11/2025	10.1	Low			
21880200-031SF25A	Main Building; Upper Level, Break Room 18 - Staff Fixture	01/11/2025	0.96	Low			
21880200-039BF25A	Main Building; Upper Level, Break Room 18 Restroom - Bathroom Fixture	01/11/2025	11.7	Low			
21880200-049DW25A	Main Building; Upper Level, East Corridor - Drinking Fountain	01/11/2025	0.211	Low			
21880200-035KF25A	Main building; Upper Level, Kitchen, East Wall, Faucet - Kitchen Fixture	01/11/2025	6	Low			
21880200-038IM25A	Main Building; Upper Level, Kitchen, Ice Maker - Ice Maker	01/11/2025	ND	Low			
21880200-050KF25A	Main Building; Upper Level, Kitchen, IslandHandwashing Sink - Kitchen Fixture	01/11/2025	1.07	Low			
21880200-034KF25A	Main Building; Upper Level, Kitchen, North Wall, East Faucet - Kitchen Fixture	01/11/2025	3.52	Low			
21880200-032KF25A	Main Building; Upper Level, Kitchen, North Wall, Sprayer - Kitchen Fixture	01/11/2025	3.28	Low			
21880200-033KF25A	Main Building; Upper Level, Kitchen, North Wall, West Faucet - Kitchen Fixture	01/11/2025	2.43	Low			
21880200-037KF25A	Main Building; Upper Level, Kitchen, West Wall, Faucet - Kitchen Fixture	01/11/2025	0.856	Low			
21880200-036KF25A	Main Building; Upper Level, Kitchen, West Wall, Sprayer - Kitchen Fixture	01/11/2025	3.6	Low			
21880200-048NS25A	Main Building; Upper Level, Nurses Office - Nurses Station	01/11/2025	10.5	Low			
21880200-040WB25A	Main Building; Upper Level, West Corridor - Bottle Filler	01/11/2025	0.37	Low			
21880200-041DW25A	Main Building; Upper Level, West Corridor - Drinking Fountain	01/11/2025	ND	Low			
21880200-043BF25A	Main Building; Upper Level, West Corridor, Men's Restroom, Middle Faucet - Bathroom Fixture	01/11/2025	5.77	Low			
21880200-042BF25A	Main Building; Upper Level, West Corridor, Men's Restroom, North Faucet - Bathroom Fixture	01/11/2025	19.3	High	5/4/2026	ND	Low
21880200-044BF25A	Main Building; Upper Level, West Corridor, Men's Restroom, South Faucet - Bathroom Fixture	01/11/2025	14	Med	5/4/2026	ND	Low
21880200-046BF25A	Main Building; Upper Level, West Corridor, Women's Restroom, Middle Faucet - Bathroom Fixture	01/11/2025	6.04	Low			
21880200-047BF25A	Main Building; Upper Level, West Corridor, Women's Restroom, North Faucet - Bathroom Fixture	01/11/2025	14.3	Med	5/4/2026	1.87	Low
21880200-045BF25A	Main Building; Upper Level, West Corridor, Women's Restroom, South Faucet - Bathroom Fixture	01/11/2025	15.4	High	5/4/2026	2.17	Low