



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 05/14/2026
Received: 05/05/2026
Sampled By: Dave Warren
Work Order: 6125003

Paid CC

C
L
I
E
N
T
Riverdale School
Attn: Dave Warren
9727 S Terwilliger
Portland OR, 97219
Phone: (503) 788-2316

Project: High School Lead
Project # : -
Sample Type :

Sampling Location: High School

Lab Number

		Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6125003-01	Sample Name: Lower Level 025 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	05/12/26 15:41
6125003-02	Sample Name: Lower Level 027 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	05/12/26 15:45
6125003-03	Sample Name: Lower Level 030 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	1.71	ppb	1.00	15 ppb	05/12/26 15:49
6125003-04	Sample Name: Lower Level 009 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	2.09	ppb	1.00	15 ppb	05/12/26 15:53
6125003-05	Sample Name: Lower Level 010 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	05/12/26 15:57
6125003-06	Sample Name: Lower Level 011 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	ND	ppb	1.00	15 ppb	05/12/26 16:01
6125003-07	Sample Name: Lower Level 014 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	1.67	ppb	1.00	15 ppb	05/12/26 16:05
6125003-08	Sample Name: Lower Level 015 Sampled: 5/4/26 14:00							Matrix: Water
A	<i>Lead</i>	1030	EPA 200.8	6.09	ppb	1.00	15 ppb	05/12/26 16:09



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 05/14/2026
Received: 05/05/2026
Sampled By: Dave Warren
Work Order: 6125003

Paid CC

C
L
I
E
N
T
Riverdale School
Attn: Dave Warren
9727 S Terwilliger
Portland OR, 97219
Phone: (503) 788-2316

Project: High School Lead
Project # : -
Sample Type :

Sampling Location: High School

Lab Number

		Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6125003-09	Sample Name: Upper Level 042 Sampled: 5/4/26 14:00							Matrix: Water
A	Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	05/12/26 16:13
6125003-10	Sample Name: Upper Level 044 Sampled: 5/4/26 14:00							Matrix: Water
A	Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	05/12/26 16:37
6125003-11	Sample Name: Upper Level 045 Sampled: 5/4/26 14:00							Matrix: Water
A	Lead	1030	EPA 200.8	1.87	ppb	1.00	15 ppb	05/12/26 16:41
6125003-12	Sample Name: Upper Level 047 Sampled: 5/4/26 14:00							Matrix: Water
A	Lead	1030	EPA 200.8	2.17	ppb	1.00	15 ppb	05/12/26 16:45

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

A All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director