

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

EL CAMINO HIGH SCHOOL

4300 EL CAMINO AVE
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, December 04, 2025

Test Session:01 Dec 2025 16:00 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	EL CAMINO HIGH SCHOOL	CONTACT
ADDRESS	4300 EL CAMINO AVE	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	139	139(100%)	139(100%)	0(0%)
Ventilation and Cooking Equipment	6	0(0%)	0(0%)	0(0%)
Fire Control Panel	11	11(100%)	11(100%)	0(0%)
Initiating Device	685	634(93%)	634(93%)	0(0%)
Power Supplies	2	2(100%)	2(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, December 04, 2025

ACCEPTED BY 12/04/2025
Building Representative


TESTED BY 12/04/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Admin Area IDF Closet Headend
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

ADDRESS/ SCAN ADDRESS	DESCRIPTION	New Theatre Rear Upstairs electrical rm
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE	06/12/2019	

Primary Power

ADDRESS/ SCAN ADDRESS	/ 138	DESCRIPTION	20 Wing Office 26
TYPE	Primary Power	PROTECTION	
NOMINAL VOLTAGE		AMPS	
NOMINAL AMPS		DISCONNECT	
LOCATION			

ADDRESS/ SCAN ADDRESS	/ 245	DESCRIPTION	40 Wing Mens Staff RR
TYPE	Primary Power	PROTECTION	
NOMINAL VOLTAGE		AMPS	
NOMINAL AMPS		DISCONNECT	
LOCATION			

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Range Suppression	Alarm Connection	
	Created By:	Casey Smith
	Creation Date:	08/28/2025
	Corrective Action:	Fire panel did not receive signal from suppression system
	Proposed Solution:	Have alarm tech diagnose problem and fix
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	120	20 Wing Classroom 21	Manual	12/1/2025 4:45:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	121	20 Wing Classroom 22	Manual	12/1/2025 4:45:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	122	20 Wing Classroom 23	Manual	12/1/2025 4:46:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	123	20 Wing Classroom 24	Manual	12/1/2025 4:46:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	124	20 Wing Classroom 25	Manual	12/1/2025 4:46:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	125	20 Wing Classroom 27	Manual	12/1/2025 4:46:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	126	20 Wing Classroom 28	Manual	12/1/2025 4:46:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	127	20 Wing Classroom 29	Manual	12/1/2025 4:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	128	20 Wing Classroom 29A	Manual	12/1/2025 4:46:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	130	20 Wing Hall OS Classrm 21	Manual	12/1/2025 4:46:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	136	20 Wing Hall OS Classrm 23	Manual	12/1/2025 4:46:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	20 Wing Hall OS Classrm 25	Manual	12/1/2025 4:46:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	132	20 Wing Hall OS Classrm 27	Manual	12/1/2025 4:46:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	137	20 Wing Hall OS Classrm 28	Manual	12/1/2025 4:46:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	20 Wing Hall OS Classrm 29	Manual	12/1/2025 4:46:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	2.080 129	20 Wing Main Hallway	Manual	12/1/2025 4:47:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	134	20 Wing Office 26	Manual	12/1/2025 4:47:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	135	20 Wing Office 26A	Manual	12/1/2025 4:46:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	118	20 Wing Southeast Exterior	Manual	12/1/2025 4:45:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	119	20 Wing Southwest Exterior	Manual	12/1/2025 4:45:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	184	30 Wing Boys Restroom	Manual	12/1/2025 4:46:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	170	30 Wing Classroom 31	Manual	12/1/2025 4:46:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	171	30 Wing Classroom 32	Manual	12/1/2025 4:46:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	172	30 Wing Classroom 33	Manual	12/1/2025 4:46:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	173	30 Wing Classroom 34	Manual	12/1/2025 4:46:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	174	30 Wing Classroom 35	Manual	12/1/2025 4:46:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	175	30 Wing Classroom 36	Manual	12/1/2025 4:46:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	176	30 Wing Classroom 37	Manual	12/1/2025 4:46:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	177	30 Wing Classroom 38	Manual	12/1/2025 4:46:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	178	30 Wing Classroom 39	Manual	12/1/2025 4:46:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	185	30 Wing Girls Restroom	Manual	12/1/2025 4:46:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	180	30 Wing Hall OS Classrm 31	Manual	12/1/2025 4:46:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	186	30 Wing Hall OS Classrm 33	Manual	12/1/2025 4:46:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	182	30 Wing Hall OS Classrm 35	Manual	12/1/2025 4:46:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	187	30 Wing Hall OS Classrm 37	Manual	12/1/2025 4:46:48 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	183	30 Wing Hall OS Classrm 39	Manual	12/1/2025 4:46:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	181	30 Wing Hall OS Custodial	Manual	12/1/2025 4:46:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	179	30 Wing Main Hallway	Manual	12/1/2025 4:46:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	168	30 Wing Southeast Exterior	Manual	12/1/2025 4:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	169	30 Wing Southwest Exterior	Manual	12/1/2025 4:45:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	224	40 Wing Classroom 40	Manual	12/1/2025 4:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	237	40 Wing Classroom 40	Manual	12/1/2025 4:43:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	225	40 Wing Classroom 41	Manual	12/1/2025 4:44:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	226	40 Wing Classroom 42	Manual	12/1/2025 4:44:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	227	40 Wing Classroom 45	Manual	12/1/2025 4:44:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	228	40 Wing Classroom 46	Manual	12/1/2025 4:44:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	229	40 Wing Classroom 47	Manual	12/1/2025 4:44:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	230	40 Wing Classroom 48	Manual	12/1/2025 4:44:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	239	40 Wing Classroom 48 Office	Manual	12/1/2025 4:43:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	231	40 Wing Classroom 49	Manual	12/1/2025 4:44:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	240	40 Wing Classroom 49 Office	Manual	12/1/2025 4:43:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	235	40 Wing Hall OS Classrm 41	Manual	12/1/2025 4:43:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	243	40 Wing Hall OS Classrm 45	Manual	12/1/2025 4:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	236	40 Wing Hall OS Classrm 47	Manual	12/1/2025 4:43:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	244	40 Wing Hall OS Custodial	Manual	12/1/2025 4:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	234	40 Wing Main Hallway	Manual	12/1/2025 4:43:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	232	40 Wing Mens Staff RR	Manual	12/1/2025 4:44:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	241	40 Wing Mens Staff RR	Manual	12/1/2025 4:43:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	238	40 Wing Room 40A Storage	Manual	12/1/2025 4:43:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	222	40 Wing Southeast Exterior	Manual	12/1/2025 4:44:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	223	40 Wing Southwest Exterior	Manual	12/1/2025 4:44:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	233	40 Wing Womens Staff RR	Manual	12/1/2025 4:44:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	242	40 Wing Womens Staff RR	Manual	12/1/2025 4:43:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	299	50 Wing Boys Restroom	Manual	12/1/2025 4:45:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	286	50 Wing Classroom 50	Manual	12/1/2025 4:45:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	298	50 Wing Classroom 50 Foyer	Manual	12/1/2025 4:45:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	287	50 Wing Classroom 51	Manual	12/1/2025 4:45:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	288	50 Wing Classroom 52	Manual	12/1/2025 4:45:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	289	50 Wing Classroom 53	Manual	12/1/2025 4:45:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	290	50 Wing Classroom 55	Manual	12/1/2025 4:45:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	291	50 Wing Classroom 56	Manual	12/1/2025 4:45:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	292	50 Wing Classroom 57	Manual	12/1/2025 4:45:11 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	293	50 Wing Classroom 58	Manual	12/1/2025 4:45:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	294	50 Wing Classroom 59	Manual	12/1/2025 4:45:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	300	50 Wing Girls Restroom	Manual	12/1/2025 4:45:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	301	50 Wing Girls Restroom	Manual	12/1/2025 4:45:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	296	50 Wing Hall OS Classrm 51	Manual	12/1/2025 4:45:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	302	50 Wing Hall OS Classrm 55	Manual	12/1/2025 4:45:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	297	50 Wing Hall OS Classrm 58	Manual	12/1/2025 4:45:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	303	50 Wing Hall OS Custodial	Manual	12/1/2025 4:45:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	295	50 Wing Main Hallway	Manual	12/1/2025 4:45:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	284	50 Wing Southeast Exterior	Manual	12/1/2025 4:45:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	285	50 Wing Southwest Exterior	Manual	12/1/2025 4:45:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	349	60 Wing Classrm 60 Storage	Manual	12/1/2025 4:44:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	336	60 Wing Classroom 60	Manual	12/1/2025 4:44:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	337	60 Wing Classroom 60	Manual	12/1/2025 4:44:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	338	60 Wing Classroom 61	Manual	12/1/2025 4:44:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	350	60 Wing Classroom 61	Manual	12/1/2025 4:45:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	339	60 Wing Classroom 62	Manual	12/1/2025 4:44:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	340	60 Wing Classroom 63	Manual	12/1/2025 4:44:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	341	60 Wing Classroom 65	Manual	12/1/2025 4:44:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	342	60 Wing Classroom 66	Manual	12/1/2025 4:44:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	343	60 Wing Classroom 67	Manual	12/1/2025 4:44:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	344	60 Wing Classroom 68	Manual	12/1/2025 4:44:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	345	60 Wing Classroom 69	Manual	12/1/2025 4:44:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	347	60 Wing Hall OS Classrm 61	Manual	12/1/2025 4:44:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	351	60 Wing Hall OS Classrm 63	Manual	12/1/2025 4:44:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	352	60 Wing Hall OS Classrm 65	Manual	12/1/2025 4:45:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	348	60 Wing Hall OS Classrm 68	Manual	12/1/2025 4:44:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	346	60 Wing Main Hallway	Manual	12/1/2025 4:44:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	334	60 Wing Southeast Exterior	Manual	12/1/2025 4:44:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	335	60 Wing Southwest Exterior	Manual	12/1/2025 4:44:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	407	A Wing Bldgs Custodial A1	Manual	12/1/2025 4:43:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	409	A Wing Bldgs Room A4	Manual	12/1/2025 4:43:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	410	A Wing Bldgs Room A5	Manual	12/1/2025 4:46:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	411	A Wing Bldgs Room A6	Manual	12/1/2025 4:46:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	412	A Wing Bldgs Room A7	Manual	12/1/2025 4:46:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	413	A Wing Bldgs Room A8	Manual	12/1/2025 4:46:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	414	A Wing Bldgs Room A9	Manual	12/1/2025 4:46:55 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	405	A Wing Bldgs South Exterior	Manual	12/1/2025 4:43:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	404	A Wing Bldgs South Exterior	Manual	12/1/2025 4:43:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	403	A Wing Bldgs South Exterior	Manual	12/1/2025 4:43:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	408	A Wing Bldgs Storage A2	Manual	12/1/2025 4:43:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	406	A Wing Bldgs West Exterior	Manual	12/1/2025 4:43:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	061	Admin Area Attendance Office	Manual	12/1/2025 4:43:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	065	Admin Area Buss Office	Manual	12/1/2025 4:44:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	066	Admin Area Buss Office Foyer	Manual	12/1/2025 4:45:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	063	Admin Area Conf Room 19	Manual	12/1/2025 4:45:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	073	Admin Area Conf Room 19	Manual	12/1/2025 4:43:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	074	Admin Area Conf Room 19	Manual	12/1/2025 4:45:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	075	Admin Area Conf Staff Restroom	Manual	12/1/2025 4:44:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	057	Admin Area East Exterior	Manual	12/1/2025 4:45:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	060	Admin Area Hallway	Manual	12/1/2025 4:44:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	058	Admin Area Hallway	Manual	12/1/2025 4:45:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	059	Admin Area Hallway	Manual	12/1/2025 4:45:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	064	Admin Area Hallway	Manual	12/1/2025 4:44:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	078	Admin Area Mail Room 9	Manual	12/1/2025 4:47:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	077	Admin Area Mens Staff RR	Manual	12/1/2025 4:44:26 PM
		Visual inspection	Passed (Manual)	
Visible	080	Admin Area Office Room 11	Manual	12/1/2025 4:44:25 PM
		Visual inspection	Passed (Manual)	
Visible	067	Admin Area Principal SecretOff	Manual	12/1/2025 4:45:01 PM
		Visual inspection	Passed (Manual)	
Visible	068	Admin Area Principals Office	Manual	12/1/2025 4:45:03 PM
		Visual inspection	Passed (Manual)	
Visible	079	Admin Area Records Room 10	Manual	12/1/2025 4:47:06 PM
		Visual inspection	Passed (Manual)	
Audible	056	Admin Area Southeast Exterior	Manual	12/1/2025 4:45:42 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	062	Admin Area VP Office Hall	Manual	12/1/2025 4:43:20 PM
		Visual inspection	Passed (Manual)	
Visible	069	Admin Area VP Office Room 15	Manual	12/1/2025 4:45:08 PM
		Visual inspection	Passed (Manual)	
Visible	070	Admin Area VP Office Room 16	Manual	12/1/2025 4:44:19 PM
		Visual inspection	Passed (Manual)	
Visible	071	Admin Area VP Office Room 17	Manual	12/1/2025 4:43:19 PM
		Visual inspection	Passed (Manual)	
Visible	072	Admin Area VP Office Room 18	Manual	12/1/2025 4:43:16 PM
		Visual inspection	Passed (Manual)	
Visible	076	Admin Area Womens Staff RR	Manual	12/1/2025 4:44:23 PM
		Visual inspection	Passed (Manual)	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	188	30 Wing Custodial Room	Manual	12/2/2025 9:02:33 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	305	50 Wing Custodial Storage	Manual	12/2/2025 9:02:35 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	304	50 Wing Custodial Storage	Manual	12/2/2025 9:02:36 PM
		Visual inspection	Passed (Manual)	
Fire Alarm Panel		Admin Area IDF Closet Headend	Manual	12/2/2025 9:02:30 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	081	Admin Area IDF Closet Headend	Manual	12/2/2025 9:02:24 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	082	Admin Area IDF Closet Headend	Manual	12/2/2025 9:02:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	083	Admin Area IDF Closet Headend	Manual	12/2/2025 9:02:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	084	Admin Area IDF Closet Headend	Manual	12/2/2025 9:02:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Admin Area Principal SecretOff	Manual	12/2/2025 6:59:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		New Theatre Rear Upstairs electrical rm	Manual	12/2/2025 4:33:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		New Theatre Rear Upstairs electrical rm	Manual	12/2/2025 4:33:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	117	20 Wing Attic Classrm 29A	Manual	12/1/2025 5:13:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	115	20 Wing Attic Classrm 29A	Manual	12/1/2025 5:13:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	116	20 Wing Attic Classrm 29A	Manual	12/1/2025 5:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.103 085	20 Wing Classroom 21	Manual	12/1/2025 5:20:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.102 086	20 Wing Classroom 22	Manual	12/1/2025 5:20:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.101 087	20 Wing Classroom 23	Manual	12/1/2025 5:20:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.100 088	20 Wing Classroom 24	Manual	12/1/2025 5:20:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.099 089	20 Wing Classroom 25	Manual	12/1/2025 5:20:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.085 093	20 Wing Classroom 27	Manual	12/1/2025 5:20:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.086 092	20 Wing Classroom 27	Manual	12/1/2025 5:20:22 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.088 094	20 Wing Classroom 28	Manual	12/1/2025 5:06:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.087 095	20 Wing Classroom 28	Manual	12/1/2025 5:07:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.112 098	20 Wing Classroom 29	Manual	12/1/2025 5:10:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.093 097	20 Wing Classroom 29	Manual	12/1/2025 5:10:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.092 096	20 Wing Classroom 29	Manual	12/1/2025 5:10:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.113 099	20 Wing Classroom 29	Manual	12/1/2025 5:10:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.090 101	20 Wing Classroom 29A	Manual	12/1/2025 5:07:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.091 100	20 Wing Classroom 29A	Manual	12/1/2025 5:13:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.089 102	20 Wing Classroom 29A Office	Manual	12/1/2025 5:07:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.108 105	20 Wing Hall OS Classrm 21	Manual	12/1/2025 5:13:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.107 106	20 Wing Hall OS Classrm 22	Manual	12/1/2025 5:13:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.106 107	20 Wing Hall OS Classrm 23	Manual	12/1/2025 5:13:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.105 108	20 Wing Hall OS Classrm 24	Manual	12/1/2025 5:13:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.104 109	20 Wing Hall OS Classrm 25	Manual	12/1/2025 5:10:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.095 111	20 Wing Hall OS Classrm 27	Manual	12/1/2025 5:12:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.94 110	20 Wing Hall OS Classrm 27	Manual	12/1/2025 5:12:58 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2.096 112	20 Wing Hall OS Classrm 28	Manual	12/1/2025 5:06:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.098 113	20 Wing Hall OS Classrm 29	Manual	12/1/2025 5:10:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.098	20 Wing Hall OS Classrm 29	Manual	12/1/2025 5:10:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	114	20 Wing Hall OS Classrm 29A	Manual	12/1/2025 5:10:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.097	20 Wing Hall OS Classrm 29A	Manual	12/1/2025 5:10:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	104	20 Wing Main Hall by 20 Wing	Manual	12/1/2025 5:13:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	103	20 Wing Main Hall by 20 Wing	Manual	12/1/2025 5:13:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.084 090	20 Wing Office 26	Manual	12/1/2025 5:13:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.083 091	20 Wing Office 26A	Manual	12/1/2025 5:13:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.015 148	30 Wing Boys Restroom	Manual	12/1/2025 5:31:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.023 139	30 Wing Classroom 31	Manual	12/1/2025 5:31:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.022 140	30 Wing Classroom 32	Manual	12/1/2025 5:31:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.021 141	30 Wing Classroom 33	Manual	12/1/2025 4:07:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.020 142	30 Wing Classroom 34	Manual	12/1/2025 5:31:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.005 143	30 Wing Classroom 35	Manual	12/1/2025 5:31:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.006 144	30 Wing Classroom 36	Manual	12/1/2025 5:31:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.007 145	30 Wing Classroom 37	Manual	12/1/2025 5:31:21 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3.008 146	30 Wing Classroom 38	Manual	12/1/2025 5:31:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.009 147	30 Wing Classroom 39	Manual	12/1/2025 5:31:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.017 149	30 Wing Custodial Room	Manual	12/1/2025 5:31:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	165	30 Wing Electrical Room	Manual	12/2/2025 9:02:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	164	30 Wing Electrical Room	Manual	12/2/2025 9:02:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.018 150	30 Wing Girls Restroom	Manual	12/1/2025 5:31:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.028 154	30 Wing Hall OS Classrm 31	Manual	12/1/2025 5:31:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.027 155	30 Wing Hall OS Classrm 32	Manual	12/1/2025 5:31:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.026 156	30 Wing Hall OS Classrm 33	Manual	12/1/2025 5:31:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.025 157	30 Wing Hall OS Classrm 34	Manual	12/1/2025 5:31:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.010 159	30 Wing Hall OS Classrm 35	Manual	12/1/2025 5:31:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.011 160	30 Wing Hall OS Classrm 36	Manual	12/1/2025 5:31:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.012 161	30 Wing Hall OS Classrm 37	Manual	12/1/2025 5:31:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.013 162	30 Wing Hall OS Classrm 38	Manual	12/1/2025 5:31:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.014 163	30 Wing Hall OS Classrm 39	Manual	12/1/2025 5:31:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.024 158	30 Wing Hall OS Custodial	Manual	12/1/2025 5:31:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	153	30 Wing Main Hall by 30 Wing	Manual	12/1/2025 5:31:42 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	152	30 Wing Main Hall by 30 Wing	Manual	12/1/2025 5:31:43 PM
		Functional Inspection	Passed	
Smoke Detector - General	151	30 Wing Main Hall by 30 Wing	Manual	12/1/2025 5:31:53 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.097 197	40 Wing Classrm 42 Storage	Manual	12/1/2025 5:45:16 PM
		Functional Inspection	Passed	
Smoke Detector - General	3.095 190	40 Wing Classroom 40	Manual	12/1/2025 5:45:04 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.094 189	40 Wing Classroom 40	Manual	12/1/2025 5:45:06 PM
		Functional Inspection	Passed	
Smoke Detector - General	3.093 194	40 Wing Classroom 41	Manual	12/1/2025 5:45:10 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.092 193	40 Wing Classroom 41	Manual	12/1/2025 5:45:12 PM
		Functional Inspection	Passed	
Smoke Detector - General	3.090 195	40 Wing Classroom 42	Manual	12/1/2025 5:45:13 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.091 196	40 Wing Classroom 42	Manual	12/1/2025 5:45:15 PM
		Functional Inspection	Passed	
Smoke Detector - General	3.075 198	40 Wing Classroom 45	Manual	12/1/2025 5:45:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.076 199	40 Wing Classroom 46	Manual	12/1/2025 5:45:01 PM
		Functional Inspection	Passed	
Smoke Detector - General	3.077 200	40 Wing Classroom 47	Manual	12/1/2025 5:45:00 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.078 201	40 Wing Classroom 48	Manual	12/1/2025 5:44:58 PM
		Functional Inspection	Passed	
Smoke Detector - General	3.085 202	40 Wing Classroom 48 Office	Manual	12/1/2025 5:44:51 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	203	40 Wing Classroom 49	Manual	12/1/2025 5:44:46 PM
		Functional Inspection	Passed	
Smoke Detector - General	204	40 Wing Classroom 49	Manual	12/1/2025 5:44:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	205	40 Wing Classroom 49 Office	Manual	12/1/2025 5:44:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	221	40 Wing Fire Doors	Manual	12/1/2025 5:44:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.101 213	40 Wing Hall OS Classrm 40	Manual	12/1/2025 5:44:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.100 214	40 Wing Hall OS Classrm 41	Manual	12/1/2025 5:44:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.098 216	40 Wing Hall OS Classrm 42	Manual	12/1/2025 5:44:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.099 215	40 Wing Hall OS Classrm 42	Manual	12/1/2025 5:44:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.081 217	40 Wing Hall OS Classrm 45	Manual	12/1/2025 5:44:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.082 218	40 Wing Hall OS Classrm 45	Manual	12/1/2025 5:44:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.083 219	40 Wing Hall OS Classrm 46	Manual	12/1/2025 5:44:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.084 220	40 Wing Hall OS Classrm 47	Manual	12/1/2025 5:44:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	212	40 Wing Main Hall by 40 Wing	Manual	12/1/2025 5:44:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	211	40 Wing Main Hall by 40 Wing	Manual	12/1/2025 5:44:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	210	40 Wing Mens Staff RR	Manual	12/1/2025 5:44:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	209	40 Wing Mens Staff RR	Manual	12/1/2025 5:44:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.103 191	40 Wing Room 40A Storage	Manual	12/1/2025 5:45:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.102 192	40 Wing Room 40A1 Storage	Manual	12/1/2025 5:44:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.072 208	40 Wing Telecom Room	Manual	12/1/2025 5:44:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.074 206	40 Wing Womens Staff RR	Manual	12/1/2025 5:44:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.073 207	40 Wing Womens Staff RR	Manual	12/1/2025 5:44:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	277	50 Wing Attic Classroom 55	Manual	12/2/2025 9:02:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	278	50 Wing Attic Classroom 56	Manual	12/2/2025 9:02:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	279	50 Wing Attic Classroom 57	Manual	12/2/2025 9:02:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	280	50 Wing Attic Classroom 58	Manual	12/2/2025 9:02:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	281	50 Wing Attic Classroom 59	Manual	12/2/2025 9:02:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.267 263	50 Wing Boys Restroom	Manual	12/1/2025 5:55:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.283 250	50 Wing Classrm 50 Storage	Manual	12/1/2025 5:56:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.282 249	50 Wing Classrm 50 Storage	Manual	12/1/2025 5:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.264 261	50 Wing Classrm 59 Storage	Manual	12/1/2025 5:56:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.263 262	50 Wing Classrm 59 Storage	Manual	12/1/2025 5:56:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.275 248	50 Wing Classroom 50	Manual	12/1/2025 5:55:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.280 246	50 Wing Classroom 50 Foyer	Manual	12/1/2025 5:54:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.281 247	50 Wing Classroom 50 Foyer	Manual	12/1/2025 5:55:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.274 251	50 Wing Classroom 51	Manual	12/1/2025 5:55:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.273 252	50 Wing Classroom 52	Manual	12/1/2025 5:55:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.272 253	50 Wing Classroom 53	Manual	12/1/2025 5:55:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.252 254	50 Wing Classroom 55	Manual	12/1/2025 5:56:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.253 255	50 Wing Classroom 56	Manual	12/1/2025 5:56:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.254 256	50 Wing Classroom 57	Manual	12/1/2025 5:56:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.255 258	50 Wing Classroom 58	Manual	12/1/2025 5:56:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.256 257	50 Wing Classroom 58	Manual	12/1/2025 5:56:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.257 260	50 Wing Classroom 59	Manual	12/1/2025 5:56:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.258 259	50 Wing Classroom 59	Manual	12/1/2025 5:56:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.268	50 Wing Custodial RR	Manual	12/1/2025 5:55:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	264	50 Wing Custodial Storage	Manual	12/1/2025 5:55:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.269 265	50 Wing Girls Restroom	Manual	12/1/2025 5:55:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.279 269	50 Wing Hall OS Classrm 51	Manual	12/1/2025 5:55:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.278 270	50 Wing Hall OS Classrm 52	Manual	12/1/2025 5:55:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.276 272	50 Wing Hall OS Classrm 53	Manual	12/1/2025 5:55:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.277 271	50 Wing Hall OS Classrm 53	Manual	12/1/2025 5:55:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.259 273	50 Wing Hall OS Classrm 55	Manual	12/1/2025 5:55:34 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.260 274	50 Wing Hall OS Classrm 56	Manual	12/1/2025 5:55:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.261 275	50 Wing Hall OS Classrm 57	Manual	12/1/2025 5:55:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.262 276	50 Wing Hall OS Classrm 58	Manual	12/1/2025 5:55:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	268	50 Wing Main Hall by 50 Wing	Manual	12/1/2025 5:54:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	267	50 Wing Main Hall by 50 Wing	Manual	12/1/2025 5:54:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	266	50 Wing Main Hall by 50 Wing	Manual	12/1/2025 5:54:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	333	60 Wing Attic Classroom 69	Manual	12/2/2025 9:02:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.312 307	60 Wing Classrm 60 Storage	Manual	12/1/2025 6:03:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	311	60 Wing Classrm 61 Storage	Manual	12/1/2025 6:04:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	320	60 Wing Classrm 69 Storage	Manual	12/1/2025 6:03:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	321	60 Wing Classrm 69 Storage	Manual	12/1/2025 6:03:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	322	60 Wing Classrm 69 Storage	Manual	12/1/2025 6:03:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.307 306	60 Wing Classroom 60	Manual	12/1/2025 6:03:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.303 308	60 Wing Classroom 61	Manual	12/1/2025 6:03:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.304 309	60 Wing Classroom 61	Manual	12/1/2025 6:03:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.305 310	60 Wing Classroom 61	Manual	12/1/2025 6:04:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.302 312	60 Wing Classroom 62	Manual	12/1/2025 6:04:04 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.301 313	60 Wing Classroom 63	Manual	12/1/2025 6:04:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.286 314	60 Wing Classroom 65	Manual	12/1/2025 6:04:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.287 315	60 Wing Classroom 66	Manual	12/1/2025 6:04:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.288 316	60 Wing Classroom 67	Manual	12/1/2025 6:04:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.289 317	60 Wing Classroom 68	Manual	12/1/2025 6:04:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.290 319	60 Wing Classroom 69	Manual	12/1/2025 6:03:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.291 318	60 Wing Classroom 69	Manual	12/1/2025 6:03:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.311 325	60 Wing Hall OS Classrm 61	Manual	12/1/2025 6:03:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.310 326	60 Wing Hall OS Classrm 61	Manual	12/1/2025 6:03:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.309 327	60 Wing Hall OS Classrm 62	Manual	12/1/2025 6:03:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.308 328	60 Wing Hall OS Classrm 63	Manual	12/1/2025 6:03:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.292 329	60 Wing Hall OS Classrm 65	Manual	12/1/2025 6:03:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.293 330	60 Wing Hall OS Classrm 66	Manual	12/1/2025 6:03:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.294 331	60 Wing Hall OS Classrm 67	Manual	12/1/2025 6:03:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.295 332	60 Wing Hall OS Classrm 68	Manual	12/1/2025 6:03:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	323	60 Wing Main Hall by 60 Wing	Manual	12/1/2025 6:03:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	324	60 Wing Main Hall by 60 Wing	Manual	12/1/2025 6:03:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	399	A Wing Bldgs Attic Room A10	Manual	12/2/2025 6:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	397	A Wing Bldgs Attic Room A10	Manual	12/2/2025 6:56:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	398	A Wing Bldgs Attic Room A10	Manual	12/2/2025 6:56:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	396	A Wing Bldgs Attic Room A10	Manual	12/2/2025 6:56:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	357	A Wing Bldgs Custodial A1	Manual	12/2/2025 5:31:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	356	A Wing Bldgs Custodial A1	Manual	12/2/2025 5:32:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	354	A Wing Bldgs Custodial A1	Manual	12/2/2025 5:32:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	353	A Wing Bldgs Custodial A1	Manual	12/2/2025 5:32:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	355	A Wing Bldgs Custodial A1	Manual	12/2/2025 5:32:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	359	A Wing Bldgs Custodial A1	Manual	12/2/2025 5:32:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	358	A Wing Bldgs Custodial A1	Manual	12/2/2025 5:32:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	402	A Wing Bldgs PIV East Exterior	Manual	12/2/2025 9:01:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	400	A Wing Bldgs Rm A10 East Exterior	Manual	12/2/2025 9:01:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	401	A Wing Bldgs Rm A10 East Exterior	Manual	12/2/2025 9:01:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	382	A Wing Bldgs Rm A7A8 Custodial	Manual	12/2/2025 6:41:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	383	A Wing Bldgs Rm A7A8 Storage	Manual	12/2/2025 6:39:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	394	A Wing Bldgs Room A10	Manual	12/2/2025 6:48:18 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	395	A Wing Bldgs Room A10	Manual	12/2/2025 6:48:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	392	A Wing Bldgs Room A10	Manual	12/2/2025 6:48:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	393	A Wing Bldgs Room A10	Manual	12/2/2025 6:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	365	A Wing Bldgs Room A4	Manual	12/2/2025 6:38:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	366	A Wing Bldgs Room A4	Manual	12/2/2025 6:38:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	367	A Wing Bldgs Room A4	Manual	12/2/2025 6:38:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	368	A Wing Bldgs Room A4	Manual	12/2/2025 6:38:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	369	A Wing Bldgs Room A5	Manual	12/2/2025 6:40:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	370	A Wing Bldgs Room A5	Manual	12/2/2025 6:40:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	371	A Wing Bldgs Room A5	Manual	12/2/2025 6:40:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	372	A Wing Bldgs Room A5	Manual	12/2/2025 6:40:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	373	A Wing Bldgs Room A5 Storage	Manual	12/2/2025 6:40:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	374	A Wing Bldgs Room A6	Manual	12/2/2025 6:41:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	377	A Wing Bldgs Room A6	Manual	12/2/2025 6:41:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	375	A Wing Bldgs Room A6	Manual	12/2/2025 6:41:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	376	A Wing Bldgs Room A6	Manual	12/2/2025 6:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	378	A Wing Bldgs Room A7	Manual	12/2/2025 6:41:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	379	A Wing Bldgs Room A7	Manual	12/2/2025 6:41:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	380	A Wing Bldgs Room A7	Manual	12/2/2025 6:41:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	381	A Wing Bldgs Room A7	Manual	12/2/2025 6:41:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	386	A Wing Bldgs Room A8	Manual	12/2/2025 6:39:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	387	A Wing Bldgs Room A8	Manual	12/2/2025 6:39:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	385	A Wing Bldgs Room A8	Manual	12/2/2025 6:39:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	384	A Wing Bldgs Room A8	Manual	12/2/2025 6:39:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	391	A Wing Bldgs Room A9	Manual	12/2/2025 6:38:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	390	A Wing Bldgs Room A9	Manual	12/2/2025 6:38:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	389	A Wing Bldgs Room A9	Manual	12/2/2025 6:38:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	388	A Wing Bldgs Room A9	Manual	12/2/2025 6:38:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	360	A Wing Bldgs Storage A2	Manual	12/2/2025 5:30:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	361	A Wing Bldgs Storage A2	Manual	12/2/2025 5:30:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	362	A Wing Bldgs Storage A2	Manual	12/2/2025 5:30:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	363	A Wing Bldgs Storage A2	Manual	12/2/2025 5:30:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	364	A Wing Bldgs Storage A2	Manual	12/2/2025 5:30:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.004 006	Admin Area Attendance Office	Manual	12/1/2025 4:02:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	051	Admin Area Attic Admin Hall	Manual	12/2/2025 6:22:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	050	Admin Area Attic Admin Hall	Manual	12/2/2025 6:22:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	049	Admin Area Attic Admin Hall	Manual	12/2/2025 6:22:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	048	Admin Area Attic Admin Hall	Manual	12/2/2025 6:23:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	047	Admin Area Attic Admin Hall	Manual	12/2/2025 6:23:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	045	Admin Area Attic Admin Hall	Manual	12/2/2025 6:23:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	046	Admin Area Attic Admin Hall	Manual	12/2/2025 6:23:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	044	Admin Area Attic Rms 9 10 11	Manual	12/2/2025 6:23:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	043	Admin Area Attic Rms 9 10 11	Manual	12/2/2025 6:23:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	054	Admin Area Buss Off Foyer Clst	Manual	12/2/2025 9:02:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	053	Admin Area Buss Off Foyer Clst	Manual	12/2/2025 9:02:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	009	Admin Area Buss Off Foyer Clst	Manual	12/1/2025 4:14:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.005 007	Admin Area Buss Office	Manual	12/1/2025 4:01:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.098 008	Admin Area Buss Office Foyer	Manual	12/1/2025 4:01:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.019 024	Admin Area Conf Rm Closet	Manual	12/1/2025 4:05:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.024 022	Admin Area Conf Rm Storage	Manual	12/1/2025 4:48:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	023	Admin Area Conf Rm Storage	Manual	12/1/2025 4:48:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.022 018	Admin Area Conf Room 19	Manual	12/1/2025 4:03:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.025 020	Admin Area Conf Room 19	Manual	12/1/2025 4:03:38 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2.018 019	Admin Area Conf Room 19	Manual	12/1/2025 4:03:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023 021	Admin Area Conf Staff Restroom	Manual	12/1/2025 4:06:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	040	Admin Area Electrical Room	Manual	12/2/2025 6:23:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	004	Admin Area Hall East	Manual	12/1/2025 4:48:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	003	Admin Area Hall West	Manual	12/1/2025 4:48:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.037 032	Admin Area Hallway	Manual	12/1/2025 4:03:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036 031	Admin Area Hallway	Manual	12/1/2025 4:08:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.035 030	Admin Area Hallway	Manual	12/1/2025 4:13:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034 029	Admin Area Hallway	Manual	12/1/2025 4:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.033 028	Admin Area Hallway	Manual	12/1/2025 4:48:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	039	Admin Area IDF Closet Headend	Manual	12/2/2025 6:23:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.002 005	Admin Area IDF Closet Headend	Manual	12/1/2025 4:01:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.032 036	Admin Area Mail Room 9	Manual	12/1/2025 4:48:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	035	Admin Area Main Hall	Manual	12/1/2025 4:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.080 034	Admin Area Main Hall	Manual	12/1/2025 4:48:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.079 033	Admin Area Main Hall OS Records	Manual	12/1/2025 4:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.016 026	Admin Area Mens Staff RR	Manual	12/1/2025 4:11:01 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.030 038	Admin Area Office Room 11	Manual	12/1/2025 4:48:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	041	Admin Area OS E Boys RR	Manual	12/2/2025 5:48:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	042	Admin Area OS E Girls RR	Manual	12/2/2025 6:22:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	052	Admin Area OS East RR Chase	Manual	12/2/2025 9:03:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	002	Admin Area Principal SecretOff	Manual	12/1/2025 4:48:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.008 010	Admin Area Principal SecretOff	Manual	12/1/2025 4:13:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	011	Admin Area Principals Office	Manual	12/1/2025 4:48:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.031 037	Admin Area Records Room 10	Manual	12/1/2025 4:48:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	055	Admin Area Roof	Manual	12/2/2025 9:03:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.020 027	Admin Area VP Hallway Storage	Manual	12/1/2025 4:09:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.012 013	Admin Area VP Office Hall	Manual	12/1/2025 4:09:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.011 012	Admin Area VP Office Hall	Manual	12/1/2025 4:09:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.010 014	Admin Area VP Office Room 15	Manual	12/1/2025 4:12:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.013 015	Admin Area VP Office Room 16	Manual	12/1/2025 4:13:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.014 016	Admin Area VP Office Room 17	Manual	12/1/2025 4:12:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.017 017	Admin Area VP Office Room 18	Manual	12/1/2025 4:10:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.015 025	Admin Area Womens Staff RR	Manual	12/1/2025 4:11:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Attic Kitchen	Manual	12/1/2025 4:38:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Attic Kitchen	Manual	12/1/2025 4:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Cafeteria Bldg Attic Kitchen Snack Bar	Manual	12/1/2025 4:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:38:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:38:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria	Manual	12/1/2025 4:39:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria Copy Rm	Manual	12/1/2025 4:38:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.146	Cafeteria Bldg Cafeteria East	Manual	12/1/2025 4:03:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria Office	Manual	12/1/2025 4:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria Strg	Manual	12/1/2025 4:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria Strg	Manual	12/1/2025 4:39:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Cafeteria Strg	Manual	12/1/2025 4:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Cafeteria Bldg Cafeteria West	Manual	12/1/2025 4:38:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Faculty Dining	Manual	12/1/2025 4:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Faculty Dining	Manual	12/1/2025 4:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Faculty Dining Strg	Manual	12/1/2025 4:38:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Cafeteria Bldg Kitchen	Manual	12/1/2025 4:38:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Cafeteria Bldg Kitchen	Manual	12/1/2025 4:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Kitchen fridge	Manual	12/1/2025 4:39:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Cafeteria Bldg Kitchen Snack Bar	Manual	12/1/2025 4:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Kitchen Staff RR	Manual	12/1/2025 4:38:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		Cafeteria Bldg Kitchen Staff RR	Manual	12/1/2025 4:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Cafeteria Bldg Kitchen Strg	Manual	12/1/2025 4:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Cafeteria Bldg O/S Boiler Rm	Manual	12/1/2025 4:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Cafeteria Bldg O/S Custodial	Manual	12/1/2025 4:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Large Gym Booth	Manual	12/2/2025 9:02:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer	Manual	12/2/2025 6:11:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer	Manual	12/2/2025 6:13:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer	Manual	12/2/2025 6:13:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer	Manual	12/2/2025 6:13:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer Boys RR	Manual	12/2/2025 5:47:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Large Gym Foyer E	Manual	12/2/2025 6:10:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer Girls RR	Manual	12/2/2025 6:13:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer Snack Rm	Manual	12/2/2025 6:14:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer Strg	Manual	12/2/2025 6:13:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer Strg	Manual	12/2/2025 6:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Foyer Strg	Manual	12/2/2025 6:13:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Large Gym Foyer W	Manual	12/2/2025 6:10:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct		Large Gym HVAC W	Manual	12/2/2025 9:03:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:40 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Large Gym	Manual	12/2/2025 9:01:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Large Gym N/E	Manual	12/2/2025 6:10:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Large Gym N/W	Manual	12/2/2025 6:10:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Large Gym S/E	Manual	12/2/2025 6:10:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Large Gym S/W	Manual	12/2/2025 6:10:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym S/W Strg Rm	Manual	12/2/2025 6:14:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot		Large Gym Visitor Dressing Rm	Manual	12/2/2025 9:02:13 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot		Functional Inspection	Passed	
		Large Gym Visitor Dressing Rm	Manual	12/2/2025 9:02:15 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Wrestling Rm Strg	Manual	12/2/2025 5:38:28 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Large Gym Wrestling Rm Strg	Manual	12/2/2025 5:38:30 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Large Gym Wrestling Rm Strg	Manual	12/2/2025 5:38:31 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Library Bldg Book Strg	Manual	12/1/2025 6:55:58 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Book Strg	Manual	12/1/2025 6:56:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Library Bldg Boys RR	Manual	12/1/2025 6:56:00 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Computer Lab	Manual	12/1/2025 6:56:11 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Library Bldg Counsel Reception	Manual	12/1/2025 6:54:09 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Counsel Rm 3	Manual	12/1/2025 6:54:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Library Bldg Counsel Rm 4	Manual	12/1/2025 6:54:05 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Counsel Rm 5	Manual	12/1/2025 6:54:07 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Library Bldg Counsel Rm 6	Manual	12/1/2025 6:54:11 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Counsel Rm G2	Manual	12/1/2025 6:54:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Library Bldg Girls RR	Manual	12/1/2025 6:56:02 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General		Functional Inspection	Passed	
		Library Bldg Library	Manual	12/1/2025 6:56:04 PM
Smoke Detector - General		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library	Manual	12/1/2025 6:56:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library Checkout	Manual	12/1/2025 6:56:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library Office	Manual	12/1/2025 6:56:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library Work Rm	Manual	12/1/2025 6:56:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Library Bldg Library Work Rm Closet	Manual	12/1/2025 6:56:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Library Bldg O/S Custodial Strg	Manual	12/2/2025 9:03:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Locker Rm Bldg Boys Locker Office	Manual	12/2/2025 5:46:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Locker Rm Bldg Boys Locker Office	Manual	12/2/2025 5:47:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Locker Rm Bldg Boys Locker Office	Manual	12/2/2025 5:47:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Locker Rm Bldg Boys Locker Office	Manual	12/2/2025 5:47:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Locker Rm Bldg Boys Locker Office	Manual	12/2/2025 5:47:10 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:47:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:47:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:47:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:47:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:47:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Locker Rm Bldg Boys Locker Rm	Manual	12/2/2025 5:48:19 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Locker Rm Bldg Boys Locker Rm		Manual	12/2/2025 5:48:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Locker Rm Bldg Boys Locker Rm		Manual	12/2/2025 5:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Locker Rm Bldg Boys Locker Rm		Manual	12/2/2025 5:48:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Locker Rm Bldg Boys Locker Rm		Manual	12/2/2025 5:48:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Locker Rm Bldg Boys Locker Rm		Manual	12/2/2025 5:48:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Locker Rm Bldg Boys Locker Rm		Manual	12/2/2025 5:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Locker Rm Bldg Boys Locker Rm		Manual	12/2/2025 5:48:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Music Bldg Attic M2-M4 Hallway		Manual	12/2/2025 9:02:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	Music Bldg Hallway		Manual	12/1/2025 7:01:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	Music Bldg Hallway		Manual	12/1/2025 7:01:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	Music Bldg Hallway		Manual	12/1/2025 7:01:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	Music Bldg Hallway		Manual	12/1/2025 7:01:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Music Bldg Office		Manual	12/2/2025 9:02:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	Music Bldg Office		Manual	12/2/2025 9:02:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	Music Bldg Practice Rm		Manual	12/1/2025 7:01:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	Music Bldg Practice Rm		Manual	12/1/2025 7:01:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	Music Bldg Practice Rm		Manual	12/1/2025 7:02:00 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Practice Rm	Manual	12/1/2025 7:02:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Practice Rm	Manual	12/1/2025 7:02:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Practice Rm	Manual	12/1/2025 7:02:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M2	Manual	12/1/2025 7:01:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M2	Manual	12/1/2025 7:01:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M2	Manual	12/1/2025 7:01:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M2	Manual	12/1/2025 7:01:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M2 Strg	Manual	12/1/2025 7:01:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M3	Manual	12/1/2025 7:01:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M3	Manual	12/1/2025 7:01:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M4	Manual	12/1/2025 7:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Music Bldg Rm M4	Manual	12/1/2025 7:01:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3.127	new theatre backstage exit	Manual	12/2/2025 4:33:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3.126	new theatre backstage exit	Manual	12/2/2025 4:33:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Bldg Front Hall	Manual	12/2/2025 4:33:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Bldg Front Hall	Manual	12/2/2025 4:33:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Bldg Front Hall	Manual	12/2/2025 4:33:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Bldg N Hall	Manual	12/2/2025 4:33:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station		New Theatre Bldg near RR	Manual	12/2/2025 4:33:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Bldg RR	Manual	12/2/2025 4:33:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Bldg RR	Manual	12/2/2025 4:33:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Bldg S Hall	Manual	12/2/2025 4:33:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		New Theatre Bldg side entrance	Manual	12/2/2025 4:33:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct		New Theatre Rear Upstairs	Manual	12/2/2025 4:33:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct		New Theatre Rear Upstairs electrical rm	Manual	12/2/2025 4:33:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		New Theatre Rear Upstairs electrical rm	Manual	12/2/2025 4:33:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Boiler Rm By S1	Manual	12/2/2025 3:59:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Boiler Rm By S1	Manual	12/2/2025 3:59:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Boiler Rm By S1	Manual	12/2/2025 3:59:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Boys RR	Manual	12/1/2025 7:46:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-301	S Wings Bldg Custodial Strg	Manual	12/2/2025 3:59:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Girls RR	Manual	12/1/2025 7:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S1	Manual	12/1/2025 7:24:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S1	Manual	12/1/2025 7:24:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S1	Manual	12/1/2025 7:24:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S1	Manual	12/1/2025 7:24:20 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:25 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:28 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:29 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:31 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:32 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:34 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:36 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1	Visual inspection	Manual	12/1/2025 7:24:37 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1 AV Studio	Visual inspection	Manual	12/1/2025 7:24:11 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1 Office	Visual inspection	Manual	12/1/2025 7:24:12 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1 Strg	Visual inspection	Manual	12/1/2025 7:24:09 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S1 Strg	Visual inspection	Manual	12/1/2025 7:24:14 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S2	Visual inspection	Manual	12/1/2025 7:24:42 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S2	Visual inspection	Manual	12/1/2025 7:24:44 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S2	Visual inspection	Manual	12/1/2025 7:24:45 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S2	Visual inspection	Manual	12/1/2025 7:24:47 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S2	Visual inspection	Manual	12/1/2025 7:24:49 PM
		Functional Inspection	Passed (Manual)	
Smoke Detector - General	S Wings Bldg Rm S2	Visual inspection	Manual	12/1/2025 7:24:50 PM
		Functional Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		S Wings Bldg Rm S2 Strg	Manual	12/1/2025 7:24:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S2 Strg	Manual	12/1/2025 7:24:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:45:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:45:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:45:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:46:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:46:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:46:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:46:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3	Manual	12/1/2025 7:46:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S3 Office	Manual	12/1/2025 7:45:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S4	Manual	12/1/2025 7:46:20 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5		Manual	12/1/2025 7:22:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Boys RR		Manual	12/1/2025 7:22:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Boys RR		Manual	12/1/2025 7:22:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Girls RR		Manual	12/1/2025 7:46:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Girls RR		Manual	12/1/2025 7:46:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Hall		Manual	12/1/2025 7:22:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Hall Strg		Manual	12/1/2025 7:22:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Hall Strg		Manual	12/1/2025 7:22:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Office		Manual	12/1/2025 7:21:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	S Wings Bldg Rm S5 Strg		Manual	12/1/2025 7:22:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		S Wings Bldg Rm S6	Manual	12/1/2025 7:21:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S6	Manual	12/1/2025 7:21:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S6	Manual	12/1/2025 7:21:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S6	Manual	12/1/2025 7:22:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S6	Manual	12/1/2025 7:22:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S6 Strg	Manual	12/1/2025 7:22:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S6/S7 Foyer	Manual	12/1/2025 7:21:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7	Manual	12/1/2025 7:21:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7 Office	Manual	12/1/2025 7:21:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S7 Strg	Manual	12/1/2025 7:21:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S8	Manual	12/2/2025 9:02:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot		S Wings Bldg Rm S8	Manual	12/2/2025 9:02:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S8	Manual	12/2/2025 9:02:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S8	Manual	12/2/2025 9:02:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S8 Office	Manual	12/1/2025 7:21:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S8 Office	Manual	12/1/2025 7:21:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9	Manual	12/1/2025 7:21:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S9 Industrial Area	Manual	12/2/2025 4:13:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S9 Industrial Area	Manual	12/2/2025 4:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S9 Industrial Area	Manual	12/2/2025 4:13:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S9 Industrial Area	Manual	12/2/2025 4:13:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S9 Industrial Area	Manual	12/2/2025 4:13:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S9 Industrial Area	Manual	12/2/2025 4:13:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Office	Manual	12/1/2025 7:21:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		S Wings Bldg Rm S9 Strg	Manual	12/2/2025 4:13:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Strg	Manual	12/1/2025 7:21:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tech Lab	Manual	12/1/2025 7:21:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tool Strg	Manual	12/1/2025 7:21:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		S Wings Bldg Rm S9 Tool Strg	Manual	12/1/2025 7:21:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Small Gym Bldg Boiler Rm	Manual	12/2/2025 6:34:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Boys RR	Manual	12/2/2025 5:47:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Classroom 4	Manual	12/2/2025 6:28:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Classroom 4	Manual	12/2/2025 6:28:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Classroom 4	Manual	12/2/2025 6:28:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Classroom 4	Manual	12/2/2025 6:28:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Main Electrical Rm	Manual	12/2/2025 6:38:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:30:24 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:30:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:30:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:30:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:30:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:34:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:35:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:36:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:36:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Small Gym	Manual	12/2/2025 6:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Strg	Manual	12/2/2025 6:35:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Small Gym Bldg Strg S	Manual	12/2/2025 6:24:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Small Gym N/E	Manual	12/2/2025 6:28:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Small Gym N/W	Manual	12/2/2025 6:28:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Small Gym S/E	Manual	12/2/2025 6:28:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station		Small Gym S/W	Manual	12/2/2025 6:28:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Track Snack Shack	Manual	12/2/2025 9:02:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot		Track Snack Shack Attic Snack Shack	Manual	12/2/2025 9:03:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Track Snack Shack Strg	Manual	12/2/2025 9:02:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Weight Rm Bldg Above Office	Manual	12/2/2025 9:02:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Weight Rm Bldg Boys RR	Manual	12/2/2025 5:48:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Weight Rm Bldg Custodial Strg	Manual	12/2/2025 9:03:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Weight Rm Bldg Lockers	Manual	12/2/2025 6:22:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Weight Rm Bldg O/S Strg	Manual	12/2/2025 9:02:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Weight Rm Bldg Office	Manual	12/2/2025 9:02:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct		Weight Rm Bldg Roof AC	Manual	12/2/2025 9:03:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Weight Rm Bldg Showers	Manual	12/2/2025 9:03:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Weight Rm Bldg Weight Rm	Manual	12/2/2025 9:02:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Weight Rm Bldg Weight Rm	Manual	12/2/2025 9:02:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Weight Rm Bldg Weight Rm	Manual	12/2/2025 9:02:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Weight Rm Bldg Weight Rm	Manual	12/2/2025 9:02:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Wrestling Rm Bldg Attic E Strg	Manual	12/2/2025 9:03:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Wrestling Rm Bldg Attic E Strg	Manual	12/2/2025 9:03:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Wrestling Rm Bldg Attic W Strg	Manual	12/2/2025 9:03:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Dressing Rm	Manual	12/2/2025 5:42:00 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Wrestling Rm Bldg Storage	Manual	12/2/2025 9:03:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Storage	Manual	12/2/2025 5:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Storage	Manual	12/2/2025 5:41:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Storage	Manual	12/2/2025 5:41:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Storage	Manual	12/2/2025 5:42:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Storage By Wrestling	Manual	12/2/2025 5:41:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Wrestling Rm	Manual	12/2/2025 5:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Wrestling Rm	Manual	12/2/2025 5:38:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Wrestling Rm	Manual	12/2/2025 5:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Wrestling Rm	Manual	12/2/2025 5:38:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Wrestling Rm Bldg Wrestling Rm Closet	Manual	12/2/2025 5:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	166	30 Wing Boys RR Plumb Chse	Manual	12/2/2025 5:54:27 PM
Heat Detector - Restorable Spot	167	30 Wing Girls RR Plum Chse	Manual	12/2/2025 6:21:02 PM
Heat Detector - Restorable Spot	283	50 Wing Boys RR Plum Chse	Manual	12/2/2025 5:54:24 PM
Heat Detector - Restorable Spot	282	50 Wing Girls RR Plumb Chse	Manual	12/2/2025 6:20:59 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:21:10 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:21:14 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:21:56 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:21:59 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:22:01 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:22:04 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:22:07 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker	Manual	12/2/2025 6:22:09 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Office	Manual	12/2/2025 6:21:05 PM
Smoke Detector - General		Locker Rm Bldg Girls Locker Office	Manual	12/2/2025 6:20:45 PM
Smoke Detector - General		Locker Rm Bldg Girls Locker Office	Manual	12/2/2025 6:20:53 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:17 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:20 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:23 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:25 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:28 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:31 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:34 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:37 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:39 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:42 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:45 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:48 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:50 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:21:54 PM
Heat Detector - Restorable Spot		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:22:12 PM
Smoke Detector - General		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:20:47 PM
Smoke Detector - General		Locker Rm Bldg Girls Locker Rm	Manual	12/2/2025 6:20:51 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:09 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:12 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:15 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:17 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:20 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:23 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:25 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:28 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:31 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:33 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:36 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:39 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:41 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:44 PM
Smoke Detector - General		New Theatre Bldg Main Theatre	Manual	12/2/2025 5:42:48 PM
Heat Detector - Restorable Spot		S Wings Bldg Boys RR Chs	Manual	12/2/2025 5:54:31 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot		S Wings Bldg Girls RR Chs	Manual	12/2/2025 6:22:17 PM
Smoke Detector - General		Small Gym Bldg Girls RR	Manual	12/2/2025 6:20:56 PM
Heat Detector - Restorable Spot		Weight Rm Bldg Girls RR	Manual	12/2/2025 6:22:15 PM

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Primary Power	138	20 Wing Office 26	Manual	12/2/2025 9:02:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Primary Power	245	40 Wing Mens Staff RR	Manual	12/2/2025 9:02:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	12/1/2025 4:41:03 PM
Fusible Links	Fusible Links		Manual	12/1/2025 4:40:52 PM
Range Hood	Hood		Manual	12/1/2025 4:40:57 PM
Range Suppression	Suppression System		Manual	12/1/2025 4:40:50 PM
Range Suppression	Alarm Connection		Manual	12/1/2025 4:41:00 PM
Range Suppression Tank	RG4GS Cylinder		Manual	12/1/2025 4:40:47 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
056	Admin Area Southeast Exterior				
057	Admin Area East Exterior				
118	20 Wing Southeast Exterior				
119	20 Wing Southwest Exterior				
168	30 Wing Southeast Exterior				
169	30 Wing Southwest Exterior				
222	40 Wing Southeast Exterior				
223	40 Wing Southwest Exterior				
284	50 Wing Southeast Exterior				
285	50 Wing Southwest Exterior				
334	60 Wing Southeast Exterior				
335	60 Wing Southwest Exterior				
403	A Wing Bldgs South Exterior				
404	A Wing Bldgs South Exterior				
405	A Wing Bldgs South Exterior				
406	A Wing Bldgs West Exterior				
Audible And Visible					
058	Admin Area Hallway				
059	Admin Area Hallway				
060	Admin Area Hallway				
061	Admin Area Attendance Office				
062	Admin Area VP Office Hall				
063	Admin Area Conf Room 19				
120	20 Wing Classroom 21				
121	20 Wing Classroom 22				
122	20 Wing Classroom 23				
123	20 Wing Classroom 24				
124	20 Wing Classroom 25				
125	20 Wing Classroom 27				
126	20 Wing Classroom 28				
127	20 Wing Classroom 29				
128	20 Wing Classroom 29A				
2.080	20 Wing Main Hallway				
129					
130	20 Wing Hall OS Classrm 21				
131	20 Wing Hall OS Classrm 25				
132	20 Wing Hall OS Classrm 27				
133	20 Wing Hall OS Classrm 29				
170	30 Wing Classroom 31				
171	30 Wing Classroom 32				
172	30 Wing Classroom 33				
173	30 Wing Classroom 34				
174	30 Wing Classroom 35				
175	30 Wing Classroom 36				
176	30 Wing Classroom 37				
177	30 Wing Classroom 38				
178	30 Wing Classroom 39				
179	30 Wing Main Hallway				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
180	30 Wing Hall OS Classrm 31				
181	30 Wing Hall OS Custodial				
182	30 Wing Hall OS Classrm 35				
183	30 Wing Hall OS Classrm 39				
224	40 Wing Classroom 40				
225	40 Wing Classroom 41				
226	40 Wing Classroom 42				
227	40 Wing Classroom 45				
228	40 Wing Classroom 46				
229	40 Wing Classroom 47				
230	40 Wing Classroom 48				
231	40 Wing Classroom 49				
232	40 Wing Mens Staff RR				
233	40 Wing Womens Staff RR				
234	40 Wing Main Hallway				
235	40 Wing Hall OS Classrm 41				
236	40 Wing Hall OS Classrm 47				
286	50 Wing Classroom 50				
287	50 Wing Classroom 51				
288	50 Wing Classroom 52				
289	50 Wing Classroom 53				
290	50 Wing Classroom 55				
291	50 Wing Classroom 56				
292	50 Wing Classroom 57				
293	50 Wing Classroom 58				
294	50 Wing Classroom 59				
295	50 Wing Main Hallway				
296	50 Wing Hall OS Classrm 51				
297	50 Wing Hall OS Classrm 58				
336	60 Wing Classroom 60				
337	60 Wing Classroom 60				
338	60 Wing Classroom 61				
339	60 Wing Classroom 62				
340	60 Wing Classroom 63				
341	60 Wing Classroom 65				
342	60 Wing Classroom 66				
343	60 Wing Classroom 67				
344	60 Wing Classroom 68				
345	60 Wing Classroom 69				
346	60 Wing Main Hallway				
347	60 Wing Hall OS Classrm 61				
348	60 Wing Hall OS Classrm 68				
407	A Wing Bldgs Custodial A1				
408	A Wing Bldgs Storage A2				
409	A Wing Bldgs Room A4				
410	A Wing Bldgs Room A5				
411	A Wing Bldgs Room A6				
412	A Wing Bldgs Room A7				
413	A Wing Bldgs Room A8				
414	A Wing Bldgs Room A9				
Visible					
064	Admin Area Hallway				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
065	Admin Area Buss Office				
066	Admin Area Buss Office Foyer				
067	Admin Area Principal SecretOff				
068	Admin Area Principals Office				
069	Admin Area VP Office Room 15				
070	Admin Area VP Office Room 16				
071	Admin Area VP Office Room 17				
072	Admin Area VP Office Room 18				
073	Admin Area Conf Room 19				
074	Admin Area Conf Room 19				
075	Admin Area Conf Staff Restroom				
076	Admin Area Womens Staff RR				
077	Admin Area Mens Staff RR				
078	Admin Area Mail Room 9				
079	Admin Area Records Room 10				
080	Admin Area Office Room 11				
134	20 Wing Office 26				
135	20 Wing Office 26A				
136	20 Wing Hall OS Classrm 23				
137	20 Wing Hall OS Classrm 28				
184	30 Wing Boys Restroom				
185	30 Wing Girls Restroom				
186	30 Wing Hall OS Classrm 33				
187	30 Wing Hall OS Classrm 37				
237	40 Wing Classroom 40				
238	40 Wing Room 40A Storage				
239	40 Wing Classroom 48 Office				
240	40 Wing Classroom 49 Office				
241	40 Wing Mens Staff RR				
242	40 Wing Womens Staff RR				
243	40 Wing Hall OS Classrm 45				
244	40 Wing Hall OS Custodial				
298	50 Wing Classroom 50 Foyer				
299	50 Wing Boys Restroom				
300	50 Wing Girls Restroom				
301	50 Wing Girls Restroom				
302	50 Wing Hall OS Classrm 55				
303	50 Wing Hall OS Custodial				
349	60 Wing Classrm 60 Storage				
350	60 Wing Classroom 61				
351	60 Wing Hall OS Classrm 63				
352	60 Wing Hall OS Classrm 65				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Area Principal SecretOff				
NAC Power Extender Panel					
081	Admin Area IDF Closet Headend				
082	Admin Area IDF Closet Headend				
083	Admin Area IDF Closet Headend				
084	Admin Area IDF Closet Headend				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
188	30 Wing Custodial Room				
304	50 Wing Custodial Storage				
305	50 Wing Custodial Storage				
	New Theatre Rear Upstairs electrical rm				06/13/2019
Fire Alarm Panel					
	Admin Area IDF Closet Headend				
	New Theatre Rear Upstairs electrical rm				06/13/2019

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
002	Admin Area Principal SecretOff				
003	Admin Area Hall West				
004	Admin Area Hall East				
	Cafeteria Bldg Cafeteria West				
2.146	Cafeteria Bldg Cafeteria East				
	Small Gym S/E				
	Small Gym S/W				
	Small Gym N/W				
	Small Gym N/E				
	Large Gym Foyer W				
	Large Gym Foyer E				
	Large Gym S/E				
	Large Gym S/W				
	Large Gym N/W				
	Large Gym N/E				
	New Theatre Bldg near RR				06/12/2019
	New Theatre Bldg side entrance				06/12/2019
3.127	new theatre backstage exit				
3.126	new theatre backstage exit				

Smoke Detector - General

2.002 005	Admin Area IDF Closet Headend				
2.004 006	Admin Area Attendance Office				
2.005 007	Admin Area Buss Office				
3.098 008	Admin Area Buss Office Foyer				
009	Admin Area Buss Off Foyer Clst				
2.008 010	Admin Area Principal SecretOff				
011	Admin Area Principals Office				
2.011 012	Admin Area VP Office Hall				
2.012 013	Admin Area VP Office Hall				
2.010 014	Admin Area VP Office Room 15				
2.013 015	Admin Area VP Office Room 16				
2.014 016	Admin Area VP Office Room 17				
2.017 017	Admin Area VP Office Room 18				
2.022 018	Admin Area Conf Room 19				
2.018 019	Admin Area Conf Room 19				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.025 020	Admin Area Conf Room 19				
2.023 021	Admin Area Conf Staff Restroom				
2.024 022	Admin Area Conf Rm Storage				
023	Admin Area Conf Rm Storage				
2.019 024	Admin Area Conf Rm Closet				
2.015 025	Admin Area Womens Staff RR				
2.016 026	Admin Area Mens Staff RR				
2.020 027	Admin Area VP Hallway Storage				
2.033 028	Admin Area Hallway				
2.034 029	Admin Area Hallway				
2.035 030	Admin Area Hallway				
2.036 031	Admin Area Hallway				
2.037 032	Admin Area Hallway				
2.079 033	Admin Area Main Hall OS Records				
2.080 034	Admin Area Main Hall				
035	Admin Area Main Hall				
2.032 036	Admin Area Mail Room 9				
2.031 037	Admin Area Records Room 10				
2.030 038	Admin Area Office Room 11				
2.103 085	20 Wing Classroom 21				
2.102 086	20 Wing Classroom 22				
2.101 087	20 Wing Classroom 23				
2.100 088	20 Wing Classroom 24				
2.099 089	20 Wing Classroom 25				
2.084 090	20 Wing Office 26				
2.083 091	20 Wing Office 26A				
2.086 092	20 Wing Classroom 27				
2.085 093	20 Wing Classroom 27				
2.088 094	20 Wing Classroom 28				
2.087 095	20 Wing Classroom 28				
2.092 096	20 Wing Classroom 29				
2.093 097	20 Wing Classroom 29				
2.112 098	20 Wing Classroom 29				
2.113 099	20 Wing Classroom 29				
2.091 100	20 Wing Classroom 29A				
2.090 101	20 Wing Classroom 29A				
2.089 102	20 Wing Classroom 29A Office				
103	20 Wing Main Hall by 20 Wing				
104	20 Wing Main Hall by 20 Wing				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.108 105	20 Wing Hall OS Classrm 21				
2.107 106	20 Wing Hall OS Classrm 22				
2.106 107	20 Wing Hall OS Classrm 23				
2.105 108	20 Wing Hall OS Classrm 24				
2.104 109	20 Wing Hall OS Classrm 25				
2.94 110	20 Wing Hall OS Classrm 27				
2.095 111	20 Wing Hall OS Classrm 27				
2.096 112	20 Wing Hall OS Classrm 28				
2.098 113	20 Wing Hall OS Classrm 29				
114	20 Wing Hall OS Classrm 29A				
3.023 139	30 Wing Classroom 31				
3.022 140	30 Wing Classroom 32				
3.021 141	30 Wing Classroom 33				
3.020 142	30 Wing Classroom 34				
3.005 143	30 Wing Classroom 35				
3.006 144	30 Wing Classroom 36				
3.007 145	30 Wing Classroom 37				
3.008 146	30 Wing Classroom 38				
3.009 147	30 Wing Classroom 39				
3.015 148	30 Wing Boys Restroom				
3.017 149	30 Wing Custodial Room				
3.018 150	30 Wing Girls Restroom				
151	30 Wing Main Hall by 30 Wing				
152	30 Wing Main Hall by 30 Wing				
153	30 Wing Main Hall by 30 Wing				
3.028 154	30 Wing Hall OS Classrm 31				
3.027 155	30 Wing Hall OS Classrm 32				
3.026 156	30 Wing Hall OS Classrm 33				
3.025 157	30 Wing Hall OS Classrm 34				
3.024 158	30 Wing Hall OS Custodial				
3.010 159	30 Wing Hall OS Classrm 35				
3.011 160	30 Wing Hall OS Classrm 36				
3.012 161	30 Wing Hall OS Classrm 37				
3.013 162	30 Wing Hall OS Classrm 38				
3.014 163	30 Wing Hall OS Classrm 39				
3.094 189	40 Wing Classroom 40				
3.095 190	40 Wing Classroom 40				
3.103 191	40 Wing Room 40A Storage				
3.102 192	40 Wing Room 40A1 Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.092 193	40 Wing Classroom 41				
3.093 194	40 Wing Classroom 41				
3.090 195	40 Wing Classroom 42				
3.091 196	40 Wing Classroom 42				
3.097 197	40 Wing Classrm 42 Storage				
3.075 198	40 Wing Classroom 45				
3.076 199	40 Wing Classroom 46				
3.077 200	40 Wing Classroom 47				
3.078 201	40 Wing Classroom 48				
3.085 202	40 Wing Classroom 48 Office				
203	40 Wing Classroom 49				
204	40 Wing Classroom 49				
205	40 Wing Classroom 49 Office				
3.074 206	40 Wing Womens Staff RR				
3.073 207	40 Wing Womens Staff RR				
3.072 208	40 Wing Telecom Room				
209	40 Wing Mens Staff RR				
210	40 Wing Mens Staff RR				
211	40 Wing Main Hall by 40 Wing				
212	40 Wing Main Hall by 40 Wing				
3.101 213	40 Wing Hall OS Classrm 40				
3.100 214	40 Wing Hall OS Classrm 41				
3.099 215	40 Wing Hall OS Classrm 42				
3.098 216	40 Wing Hall OS Classrm 42				
3.081 217	40 Wing Hall OS Classrm 45				
3.082 218	40 Wing Hall OS Classrm 45				
3.083 219	40 Wing Hall OS Classrm 46				
3.084 220	40 Wing Hall OS Classrm 47				
221	40 Wing Fire Doors				
3.280 246	50 Wing Classroom 50 Foyer				
3.281 247	50 Wing Classroom 50 Foyer				
3.275 248	50 Wing Classroom 50				
3.282 249	50 Wing Classrm 50 Storage				
3.283 250	50 Wing Classrm 50 Storage				
3.274 251	50 Wing Classroom 51				
3.273 252	50 Wing Classroom 52				
3.272 253	50 Wing Classroom 53				
3.252 254	50 Wing Classroom 55				
3.253 255	50 Wing Classroom 56				
3.254 256	50 Wing Classroom 57				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.256 257	50 Wing Classroom 58				
3.255 258	50 Wing Classroom 58				
3.258 259	50 Wing Classroom 59				
3.257 260	50 Wing Classroom 59				
3.264 261	50 Wing Classrm 59 Storage				
3.263 262	50 Wing Classrm 59 Storage				
3.267 263	50 Wing Boys Restroom				
264	50 Wing Custodial Storage				
3.269 265	50 Wing Girls Restroom				
266	50 Wing Main Hall by 50 Wing				
267	50 Wing Main Hall by 50 Wing				
268	50 Wing Main Hall by 50 Wing				
3.279 269	50 Wing Hall OS Classrm 51				
3.278 270	50 Wing Hall OS Classrm 52				
3.277 271	50 Wing Hall OS Classrm 53				
3.276 272	50 Wing Hall OS Classrm 53				
3.259 273	50 Wing Hall OS Classrm 55				
3.260 274	50 Wing Hall OS Classrm 56				
3.261 275	50 Wing Hall OS Classrm 57				
3.262 276	50 Wing Hall OS Classrm 58				
3.307 306	60 Wing Classroom 60				
3.312 307	60 Wing Classrm 60 Storage				
3.303 308	60 Wing Classroom 61				
3.304 309	60 Wing Classroom 61				
3.305 310	60 Wing Classroom 61				
311	60 Wing Classrm 61 Storage				
3.302 312	60 Wing Classroom 62				
3.301 313	60 Wing Classroom 63				
3.286 314	60 Wing Classroom 65				
3.287 315	60 Wing Classroom 66				
3.288 316	60 Wing Classroom 67				
3.289 317	60 Wing Classroom 68				
3.291 318	60 Wing Classroom 69				
3.290 319	60 Wing Classroom 69				
320	60 Wing Classrm 69 Storage				
321	60 Wing Classrm 69 Storage				
322	60 Wing Classrm 69 Storage				
323	60 Wing Main Hall by 60 Wing				
324	60 Wing Main Hall by 60 Wing				
3.311 325	60 Wing Hall OS Classrm 61				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.310 326	60 Wing Hall OS Classrm 61				
3.309 327	60 Wing Hall OS Classrm 62				
3.308 328	60 Wing Hall OS Classrm 63				
3.292 329	60 Wing Hall OS Classrm 65				
3.293 330	60 Wing Hall OS Classrm 66				
3.294 331	60 Wing Hall OS Classrm 67				
3.295 332	60 Wing Hall OS Classrm 68				
353	A Wing Bldgs Custodial A1				
354	A Wing Bldgs Custodial A1				
355	A Wing Bldgs Custodial A1				
356	A Wing Bldgs Custodial A1				
357	A Wing Bldgs Custodial A1				
358	A Wing Bldgs Custodial A1				
359	A Wing Bldgs Custodial A1				
360	A Wing Bldgs Storage A2				
361	A Wing Bldgs Storage A2				
362	A Wing Bldgs Storage A2				
363	A Wing Bldgs Storage A2				
364	A Wing Bldgs Storage A2				
365	A Wing Bldgs Room A4				
366	A Wing Bldgs Room A4				
367	A Wing Bldgs Room A4				
368	A Wing Bldgs Room A4				
369	A Wing Bldgs Room A5				
370	A Wing Bldgs Room A5				
371	A Wing Bldgs Room A5				
372	A Wing Bldgs Room A5				
373	A Wing Bldgs Room A5 Storage				
374	A Wing Bldgs Room A6				
375	A Wing Bldgs Room A6				
376	A Wing Bldgs Room A6				
377	A Wing Bldgs Room A6				
378	A Wing Bldgs Room A7				
379	A Wing Bldgs Room A7				
380	A Wing Bldgs Room A7				
381	A Wing Bldgs Room A7				
382	A Wing Bldgs Rm A7A8 Custodial				
383	A Wing Bldgs Rm A7A8 Storage				
384	A Wing Bldgs Room A8				
385	A Wing Bldgs Room A8				
386	A Wing Bldgs Room A8				
387	A Wing Bldgs Room A8				
388	A Wing Bldgs Room A9				
389	A Wing Bldgs Room A9				
390	A Wing Bldgs Room A9				
391	A Wing Bldgs Room A9				
392	A Wing Bldgs Room A10				
393	A Wing Bldgs Room A10				
394	A Wing Bldgs Room A10				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
395	A Wing Bldgs Room A10				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Kitchen fridge				
	Cafeteria Bldg Kitchen Staff RR				
	Cafeteria Bldg Kitchen Strg				
	Cafeteria Bldg Kitchen Staff RR				
	Cafeteria Bldg Faculty Dining Strg				
	Cafeteria Bldg Faculty Dining				
	Cafeteria Bldg Faculty Dining				
	Cafeteria Bldg Cafeteria Copy Rm				
	Cafeteria Bldg Cafeteria Office				
	Cafeteria Bldg Cafeteria Strg				
	Cafeteria Bldg Cafeteria Strg				
	Cafeteria Bldg Cafeteria Strg				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Cafeteria				
	Cafeteria Bldg Attic Kitchen				
	Cafeteria Bldg Attic Kitchen				
	Library Bldg Counsel Rm 3				
	Library Bldg Counsel Rm 4				
	Library Bldg Counsel Reception				
	Library Bldg Counsel Rm 5				
	Library Bldg Counsel Rm 6				
	Library Bldg Counsel Rm G2				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library				
	Library Bldg Library Checkout				
	Library Bldg Library				
	Library Bldg Library Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Library Bldg Library Work Rm				
	Library Bldg Library Work Rm Closet				
	Library Bldg Boys RR				
	Library Bldg Girls RR				
	Library Bldg Computer Lab				
	Library Bldg Book Strg				
	Library Bldg Book Strg				
	Music Bldg Rm M3				
	Music Bldg Rm M3				
	Music Bldg Rm M4				
	Music Bldg Rm M4				
	Music Bldg Hallway				
	Music Bldg Rm M2 Strg				
	Music Bldg Rm M2				
	Music Bldg Rm M2				
	Music Bldg Rm M2				
	Music Bldg Rm M2				
	Music Bldg Hallway				
	Music Bldg Practice Rm				
	Music Bldg Practice Rm				
	Music Bldg Practice Rm				
	Music Bldg Practice Rm				
	Music Bldg Practice Rm				
	Music Bldg Hallway				
	Music Bldg Hallway				
	Music Bldg Practice Rm				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1 AV Studio				
	S Wings Bldg Rm S1 Strg				
	S Wings Bldg Rm S1 Office				
	S Wings Bldg Rm S1 Strg				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S1				
	S Wings Bldg Rm S2				
	S Wings Bldg Rm S2				
	S Wings Bldg Rm S2				
	S Wings Bldg Rm S2 Strg				
	S Wings Bldg Rm S2				
	S Wings Bldg Rm S2				
	S Wings Bldg Rm S2				
	S Wings Bldg Rm S2 Strg				
	S Wings Bldg Rm S3 Office				
	S Wings Bldg Rm S3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	S Wings Bldg Rm S3				
	S Wings Bldg Rm S3				
	S Wings Bldg Rm S3				
	S Wings Bldg Rm S3				
	S Wings Bldg Rm S3				
	S Wings Bldg Rm S3				
	S Wings Bldg Rm S3				
	S Wings Bldg Rm S4				
	S Wings Bldg Rm S4				
	S Wings Bldg Rm S4				
	S Wings Bldg Rm S4				
	S Wings Bldg Rm S4				
	S Wings Bldg Rm S4				
	S Wings Bldg Rm S4				
	S Wings Bldg Rm S4				
	S Wings Bldg Girls RR				
	S Wings Bldg Boys RR				
	S Wings Bldg Rm S5 Office				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S5 Strg				
	S Wings Bldg Rm S5 Girls RR				
	S Wings Bldg Rm S5 Girls RR				
	S Wings Bldg Rm S5 Boys RR				
	S Wings Bldg Rm S5 Boys RR				
	S Wings Bldg Rm S6 Strg				
	S Wings Bldg Rm S5 Hall Strg				
	S Wings Bldg Rm S5 Hall Strg				
	S Wings Bldg Rm S5 Hall				
	S Wings Bldg Rm S6				
	S Wings Bldg Rm S6				
	S Wings Bldg Rm S6				
	S Wings Bldg Rm S6				
	S Wings Bldg Rm S6/S7 Foyer				
	S Wings Bldg Rm S7 Strg				
	S Wings Bldg Rm S7 Office				
	S Wings Bldg Rm S7				
	S Wings Bldg Rm S7				
	S Wings Bldg Rm S7				
	S Wings Bldg Rm S7				
	S Wings Bldg Rm S7				
	S Wings Bldg Rm S7				
	S Wings Bldg Rm S8 Office				
	S Wings Bldg Rm S8 Office				
	S Wings Bldg Rm S5				
	S Wings Bldg Rm S7				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	New Theatre Rear Upstairs electrical rm				06/13/2019
3.268	50 Wing Custodial RR				
2.098	20 Wing Hall OS Classrm 29				
2.097	20 Wing Hall OS Classrm 29A				
Heat Detector - Restorable Spot					
039	Admin Area IDF Closet Headend				
040	Admin Area Electrical Room				
041	Admin Area OS E Boys RR				
042	Admin Area OS E Girls RR				
043	Admin Area Attic Rms 9 10 11				
044	Admin Area Attic Rms 9 10 11				
045	Admin Area Attic Admin Hall				
046	Admin Area Attic Admin Hall				
047	Admin Area Attic Admin Hall				
048	Admin Area Attic Admin Hall				
049	Admin Area Attic Admin Hall				
050	Admin Area Attic Admin Hall				
051	Admin Area Attic Admin Hall				
052	Admin Area OS East RR Chase				
115	20 Wing Attic Classrm 29A				
116	20 Wing Attic Classrm 29A				
117	20 Wing Attic Classrm 29A				
164	30 Wing Electrical Room				
165	30 Wing Electrical Room				
166	30 Wing Boys RR Plumb Chse				
167	30 Wing Girls RR Plum Chse				
277	50 Wing Attic Classroom 55				
278	50 Wing Attic Classroom 56				
279	50 Wing Attic Classroom 57				
280	50 Wing Attic Classroom 58				
281	50 Wing Attic Classroom 59				
282	50 Wing Girls RR Plumb Chse				
283	50 Wing Boys RR Plum Chse				
333	60 Wing Attic Classroom 69				
396	A Wing Bldgs Attic Room A10				
397	A Wing Bldgs Attic Room A10				
398	A Wing Bldgs Attic Room A10				
399	A Wing Bldgs Attic Room A10				
	Cafeteria Bldg Kitchen Snack Bar				
	Cafeteria Bldg O/S Custodial				
	Cafeteria Bldg Kitchen				
	Cafeteria Bldg Kitchen				
	Cafeteria Bldg O/S Boiler Rm				
	Cafeteria Bldg Attic Kitchen Snack Bar				
	Library Bldg O/S Custodial Strg				
	Music Bldg Office				
	Music Bldg Office				
	S Wings Bldg Boiler Rm By S1				
	S Wings Bldg Boiler Rm By S1				
	S Wings Bldg Boiler Rm By S1				
	S Wings Bldg Girls RR Chs				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-301	S Wings Bldg Custodial Strg				
	S Wings Bldg Boys RR Chs				
	Music Bldg Attic M2-M4 Hallway				
	S Wings Bldg Rm S8				
	S Wings Bldg Rm S8				
	S Wings Bldg Rm S8				
	S Wings Bldg Rm S8				
	S Wings Bldg Rm S9 Industrial Area				
	S Wings Bldg Rm S9 Industrial Area				
	S Wings Bldg Rm S9 Industrial Area				
	S Wings Bldg Rm S9 Industrial Area				
	S Wings Bldg Rm S9 Industrial Area				
	S Wings Bldg Rm S9 Industrial Area				
	S Wings Bldg Rm S9 Strg				
	Weight Rm Bldg Custodial Strg				
	Weight Rm Bldg O/S Strg				
	Weight Rm Bldg Showers				
	Weight Rm Bldg Boys RR				
	Weight Rm Bldg Girls RR				
	Track Snack Shack Strg				
	Track Snack Shack				
	Small Gym Bldg Boiler Rm				
	Track Snack Shack Attic Snack Shack				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Office				
	Locker Rm Bldg Girls Locker Rm				
	Locker Rm Bldg Girls Locker Rm				
	Wrestling Rm Bldg Storage				
	Large Gym Booth				
	Locker Rm Bldg Girls Locker				
	Locker Rm Bldg Boys Locker Rm				
	Locker Rm Bldg Boys Locker Rm				
	Locker Rm Bldg Boys Locker Rm				
	Locker Rm Bldg Boys Locker Rm				
	Locker Rm Bldg Boys Locker Rm				
	Locker Rm Bldg Boys Locker Rm				
	Locker Rm Bldg Boys Locker Rm				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression					
	Suppression System				01/01/2019
	Alarm Connection				01/01/2019
Fusible Links					
	Fusible Links				08/28/2025
Range Hood					
	Hood				01/01/2019
Cooking Equipment					
	Appliances				01/01/2019