

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

CA MONTESSORI COLEMAN

6545 BEACH AVE  
, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Thursday, July 24, 2025

Test Session :21 Jul 2025 11:43 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	CA MONTESSORI COLEMAN	CONTACT
ADDRESS	6545 BEACH AVE	PHONE
CITY/STATE/ZIP	, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	47	47(100%)	47(100%)	0(0%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	114	114(100%)	114(100%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 24, 2025

ACCEPTED BY      07/24/2025  
  
Building Representative

  
TESTED BY      07/24/2025  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS / SCAN ADDRESS	DESCRIPTION	Rooms 1-6 Bldg Room E FACP Rm
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	017	Admin Building Admin Meeting Rm	Manual	7/24/2025 7:03:33 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	016	Admin Building Admin Office	Manual	7/24/2025 7:03:37 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	018	Admin Building Kindergarten	Manual	7/24/2025 7:03:36 AM
		Visual inspection	Passed (Manual)	
Visible	019	Admin Building Kindergarten RR	Manual	7/24/2025 7:02:57 AM
		Visual inspection	Passed (Manual)	
Audible	155	Multi-Purpose Bldg East Exterior	Manual	7/24/2025 7:03:40 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	158	Multi-Purpose Bldg Kitchen	Manual	7/24/2025 7:03:04 AM
		Visual inspection	Passed (Manual)	
Visible	161	Multi-Purpose Bldg Kitchen Restroom	Manual	7/24/2025 7:02:35 AM
		Visual inspection	Passed (Manual)	
Visible	160	Multi-Purpose Bldg Kitchen Restroom	Manual	7/24/2025 7:02:36 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	157	Multi-Purpose Bldg MP Room	Manual	7/24/2025 7:03:05 AM
		Visual inspection	Passed (Manual)	
Visible	162	Multi-Purpose Bldg Music Hallway	Manual	7/24/2025 7:02:33 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	159	Multi-Purpose Bldg Music Room	Manual	7/24/2025 7:03:01 AM
		Visual inspection	Passed (Manual)	
Audible	156	Multi-Purpose Bldg West Exterior	Manual	7/24/2025 7:03:38 AM
		Visual inspection	Passed (Manual)	
Visible	127	Preschool Area Boys Restroom	Manual	7/24/2025 7:02:39 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	118	Preschool Area Classroom 13	Manual	7/24/2025 7:03:12 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	119	Preschool Area Classroom 16	Manual	7/24/2025 7:03:10 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	120	Preschool Area Classroom 17	Manual	7/24/2025 7:03:07 AM
		Visual inspection	Passed (Manual)	
Visible	124	Preschool Area Classroom 17 RR	Manual	7/24/2025 7:02:41 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	123	Preschool Area Classroom 17 RR	Manual	7/24/2025 7:02:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	116	Preschool Area East Exterior	Manual	7/24/2025 7:03:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	128	Preschool Area Girls Restroom	Manual	7/24/2025 7:02:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	115	Preschool Area North Exterior	Manual	7/24/2025 7:03:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	121	Preschool Area Preschool	Manual	7/24/2025 7:03:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	126	Preschool Area Preschool Restroom	Manual	7/24/2025 7:02:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	125	Preschool Area Preschool Restroom	Manual	7/24/2025 7:02:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	117	Preschool Area South Exterior	Manual	7/24/2025 7:03:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	122	Preschool Area Staff RR Classrm 17	Manual	7/24/2025 7:02:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	083	Room 15 Bldg Classroom 15	Manual	7/24/2025 7:03:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	082	Room 15 Bldg North Exterior	Manual	7/24/2025 7:03:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	041	Rooms 1-6 Bldg Classroom 1	Manual	7/24/2025 7:03:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	042	Rooms 1-6 Bldg Classroom 2	Manual	7/24/2025 7:03:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	043	Rooms 1-6 Bldg Classroom 3	Manual	7/24/2025 7:03:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	044	Rooms 1-6 Bldg Classroom 4	Manual	7/24/2025 7:03:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	045	Rooms 1-6 Bldg Classroom 5	Manual	7/24/2025 7:03:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	046	Rooms 1-6 Bldg Classroom 6	Manual	7/24/2025 7:03:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	038	Rooms 1-6 Bldg North Exterior	Manual	7/24/2025 7:03:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	039	Rooms 1-6 Bldg South Exterior	Manual	7/24/2025 7:03:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	040	Rooms 1-6 Bldg West Exterior	Manual	7/24/2025 7:03:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	073	Rooms 7-12 Bldg Boys RR by Rm 9	Manual	7/24/2025 7:02:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	070	Rooms 7-12 Bldg Classroom 10	Manual	7/24/2025 7:03:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	Rooms 7-12 Bldg Classroom 11	Manual	7/24/2025 7:03:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	072	Rooms 7-12 Bldg Classroom 12	Manual	7/24/2025 7:03:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	067	Rooms 7-12 Bldg Classroom 7	Manual	7/24/2025 7:03:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	Rooms 7-12 Bldg Classroom 8	Manual	7/24/2025 7:03:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	069	Rooms 7-12 Bldg Classroom 9	Manual	7/24/2025 7:03:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	074	Rooms 7-12 Bldg Girls RR by Rm 10	Manual	7/24/2025 7:02:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	065	Rooms 7-12 Bldg North Exterior	Manual	7/24/2025 7:03:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	066	Rooms 7-12 Bldg South Exterior	Manual	7/24/2025 7:03:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Building Admin Office	Manual	7/22/2025 7:02:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	129	Preschool Area Classrm 13 E Closet - P.E. "B"	Manual	7/22/2025 7:02:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator		Preschool Area Classroom 13	Manual	7/22/2025 7:02:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 1-6 Bldg Room E FACP Rm	Manual	7/22/2025 7:02:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	047	Rooms 1-6 Bldg Room E FACP Rm - P.E. "A"	Manual	7/22/2025 7:02:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	075	Rooms 7-12 Bldg Telco Rm by Rm 12 - P.E. "C"	Manual	7/22/2025 7:02:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Initiating Device**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-285 007	Admin Building Admin Meeting Rm	Manual	7/24/2025 7:02:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 006	Admin Building Admin MTG Closet	Manual	7/24/2025 7:02:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 004	Admin Building Admin NE Storage	Manual	7/24/2025 7:02:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 005	Admin Building Admin Nurse	Manual	7/24/2025 7:02:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 009	Admin Building Admin Nurse Restrm	Manual	7/24/2025 7:02:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-381 002	Admin Building Admin Office	Manual	7/24/2025 7:02:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 003	Admin Building Admin Office	Manual	7/24/2025 7:02:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 008	Admin Building Admin Principal Office	Manual	7/24/2025 7:01:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 010	Admin Building Admin Restroom	Manual	7/24/2025 7:01:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 015	Admin Building Kinder Supply Closet	Manual	7/24/2025 7:01:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 012	Admin Building Kindergarten	Manual	7/24/2025 7:02:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 011	Admin Building Kindergarten	Manual	7/24/2025 7:02:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 013	Admin Building Kindergarten RR	Manual	7/24/2025 7:02:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 014	Admin Building Kindergarten Storage	Manual	7/24/2025 7:02:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-251	Kitchen Lobby	Manual	7/24/2025 7:01:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-377 154	Multi-Purpose Bldg Attic Music Room	Manual	7/22/2025 7:02:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-260 145	Multi-Purpose Bldg Food Pantry	Manual	7/24/2025 7:01:16 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-261 153	Multi-Purpose Bldg Kitchen	Manual	7/22/2025 7:09:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-258 142	Multi-Purpose Bldg Kitchen Restroom	Manual	7/24/2025 7:01:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-257 143	Multi-Purpose Bldg Kitchen Restroom	Manual	7/24/2025 7:01:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-254 136	Multi-Purpose Bldg MP Room NE	Manual	7/24/2025 7:01:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-253 135	Multi-Purpose Bldg MP Room North	Manual	7/24/2025 7:01:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-376 130	Multi-Purpose Bldg MP Room NW	Manual	7/24/2025 7:01:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-259 144	Multi-Purpose Bldg MP Room NW	Manual	7/24/2025 7:01:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-252 134	Multi-Purpose Bldg MP Room NW	Manual	7/24/2025 7:01:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-380 133	Multi-Purpose Bldg MP Room SE	Manual	7/24/2025 7:01:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-272 137	Multi-Purpose Bldg MP Room SE	Manual	7/24/2025 7:01:39 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-379 132	Multi-Purpose Bldg MP Room South	Manual	7/24/2025 7:01:31 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-271 138	Multi-Purpose Bldg MP Room South	Manual	7/24/2025 7:01:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-255 140	Multi-Purpose Bldg MP Room Storage	Manual	7/24/2025 7:01:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-378 131	Multi-Purpose Bldg MP Room SW	Manual	7/24/2025 7:01:29 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-270 139	Multi-Purpose Bldg MP Room SW	Manual	7/24/2025 7:01:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-267 151	Multi-Purpose Bldg Music Elect Room	Manual	7/24/2025 7:02:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-266 146	Multi-Purpose Bldg Music Hallway	Manual	7/24/2025 7:02:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-268 152	Multi-Purpose Bldg Music Pump Room	Manual	7/24/2025 7:01:04 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-263 149	Multi-Purpose Bldg Music Room	Manual	7/24/2025 7:02:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-264 148	Multi-Purpose Bldg Music Room	Manual	7/24/2025 7:02:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-265 147	Multi-Purpose Bldg Music Room	Manual	7/24/2025 7:02:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-269 150	Multi-Purpose Bldg Music Supplies Rm	Manual	7/24/2025 7:02:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-256 141	Multi-Purpose Bldg Water Heater Closet	Manual	7/24/2025 7:01:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-262	Music Room	Manual	7/24/2025 7:02:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 113	Preschool Area Attic Classrm 17 RR	Manual	7/22/2025 6:51:31 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 114	Preschool Area Attic Classrm 17 RR	Manual	7/22/2025 6:52:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-131 112	Preschool Area Attic Classroom 17	Manual	7/22/2025 6:48:37 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-131 111	Preschool Area Attic Classroom 17	Manual	7/22/2025 6:48:39 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-131 110	Preschool Area Attic Classroom 17	Manual	7/22/2025 6:48:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-131	Preschool Area Attic Classroom 17	Manual	7/22/2025 6:52:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-036 108	Preschool Area Boys Restroom	Manual	7/24/2025 7:01:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-130 084	Preschool Area Classroom 13	Manual	7/21/2025 1:24:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 085	Preschool Area Classroom 13	Manual	7/21/2025 1:21:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 086	Preschool Area Classroom 13	Manual	7/21/2025 1:21:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 087	Preschool Area Classroom 13	Manual	7/21/2025 1:21:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 090	Preschool Area Classroom 16	Manual	7/21/2025 1:20:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 091	Preschool Area Classroom 16	Manual	7/21/2025 1:20:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 092	Preschool Area Classroom 16	Manual	7/24/2025 7:01:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 094	Preschool Area Classroom 17	Manual	7/21/2025 1:28:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 097	Preschool Area Classroom 17 RR	Manual	7/21/2025 1:28:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 098	Preschool Area Classroom 17 RR	Manual	7/21/2025 1:28:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 109	Preschool Area Girls Restroom	Manual	7/24/2025 7:01:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 093	Preschool Area N Classroom 17	Manual	7/21/2025 1:27:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 100	Preschool Area Preschool	Manual	7/21/2025 1:18:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 099	Preschool Area Preschool	Manual	7/21/2025 1:18:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 103	Preschool Area Preschool Hallway	Manual	7/21/2025 1:19:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-038 102	Preschool Area Preschool Kitchen	Manual	7/21/2025 1:20:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 105	Preschool Area Preschool Restroom	Manual	7/21/2025 1:19:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 104	Preschool Area Preschool Restroom	Manual	7/24/2025 7:01:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 095	Preschool Area S Classroom 17	Manual	7/21/2025 1:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 096	Preschool Area Staff RR Classrm 17	Manual	7/21/2025 1:27:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 107	Preschool Area West Storage	Manual	7/24/2025 7:01:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 106	Preschool Area West Storage	Manual	7/24/2025 7:01:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 081	Room 15 Bldg Attic Classroom 15	Manual	7/22/2025 7:02:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 078	Room 15 Bldg Attic Classroom 15	Manual	7/22/2025 7:02:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 080	Room 15 Bldg Attic Classroom 15	Manual	7/22/2025 7:02:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 079	Room 15 Bldg Attic Classroom 15	Manual	7/22/2025 7:02:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 076	Room 15 Bldg Classroom 15	Manual	7/21/2025 1:34:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 077	Room 15 Bldg Classroom 15	Manual	7/21/2025 1:34:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 036	Rooms 1-6 Bldg Boiler Room	Manual	7/24/2025 7:02:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 033	Rooms 1-6 Bldg Boys Restroom	Manual	7/21/2025 1:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 021	Rooms 1-6 Bldg Classroom 1	Manual	7/21/2025 1:17:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-018 020	Rooms 1-6 Bldg Classroom 1	Manual	7/21/2025 1:17:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 022	Rooms 1-6 Bldg Classroom 2	Manual	7/21/2025 1:13:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 023	Rooms 1-6 Bldg Classroom 2	Manual	7/21/2025 1:14:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 024	Rooms 1-6 Bldg Classroom 3	Manual	7/21/2025 1:15:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 025	Rooms 1-6 Bldg Classroom 3	Manual	7/21/2025 1:15:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 026	Rooms 1-6 Bldg Classroom 4	Manual	7/21/2025 1:12:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 027	Rooms 1-6 Bldg Classroom 4	Manual	7/21/2025 1:12:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 028	Rooms 1-6 Bldg Classroom 5	Manual	7/21/2025 1:13:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 029	Rooms 1-6 Bldg Classroom 5	Manual	7/21/2025 1:13:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 030	Rooms 1-6 Bldg Classroom 6	Manual	7/21/2025 1:15:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 031	Rooms 1-6 Bldg Classroom 6	Manual	7/24/2025 7:01:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 035	Rooms 1-6 Bldg Girls Restroom	Manual	7/21/2025 1:11:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-009 034	Rooms 1-6 Bldg Janitor Room	Manual	7/22/2025 7:08:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 037	Rooms 1-6 Bldg Room E FACP Rm	Manual	7/24/2025 7:01:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 032	Rooms 1-6 Bldg Teacher Room A	Manual	7/24/2025 7:01:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 063	Rooms 7-12 Bldg Boys RR B10	Manual	7/21/2025 1:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-289 050	Rooms 7-12 Bldg Classroom 8	Manual	7/24/2025 7:01:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 048	Rooms 7-12 Bldg Classroom B01	Manual	7/21/2025 1:36:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 049	Rooms 7-12 Bldg Classroom B02	Manual	7/21/2025 1:37:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 051	Rooms 7-12 Bldg Classroom B02	Manual	7/21/2025 1:37:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 052	Rooms 7-12 Bldg Classroom B03	Manual	7/21/2025 1:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 053	Rooms 7-12 Bldg Classroom B03	Manual	7/21/2025 1:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 054	Rooms 7-12 Bldg Classroom B04	Manual	7/21/2025 1:32:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 055	Rooms 7-12 Bldg Classroom B04	Manual	7/21/2025 1:32:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 056	Rooms 7-12 Bldg Classroom B05	Manual	7/21/2025 1:33:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 057	Rooms 7-12 Bldg Classroom B05	Manual	7/21/2025 1:33:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 058	Rooms 7-12 Bldg Classroom B06	Manual	7/21/2025 1:33:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 059	Rooms 7-12 Bldg Classroom B06	Manual	7/21/2025 1:34:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 061	Rooms 7-12 Bldg Girls RR B08	Manual	7/21/2025 1:30:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 062	Rooms 7-12 Bldg Janitor Rm by Rm 9	Manual	7/21/2025 1:30:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 060	Rooms 7-12 Bldg Telco Rm by Rm 12	Manual	7/21/2025 1:31:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 064	Rooms 7-12 Staff Rm B11	Manual	7/21/2025 1:39:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-025 089	Strg Rm D03.2	Manual	7/21/2025 1:25:54 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-034 101	Strg rm D04.1	Manual	7/21/2025 1:26:52 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-026 088	Wash rm D03.1	Manual	7/21/2025 1:25:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

# Device/Equipment Details

## Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
016	Admin Building Admin Office				
017	Admin Building Admin Meeting Rm				
018	Admin Building Kindergarten				
041	Rooms 1-6 Bldg Classroom 1				
042	Rooms 1-6 Bldg Classroom 2				
043	Rooms 1-6 Bldg Classroom 3				
044	Rooms 1-6 Bldg Classroom 4				
045	Rooms 1-6 Bldg Classroom 5				
046	Rooms 1-6 Bldg Classroom 6				
067	Rooms 7-12 Bldg Classroom 7				
068	Rooms 7-12 Bldg Classroom 8				
069	Rooms 7-12 Bldg Classroom 9				
070	Rooms 7-12 Bldg Classroom 10				
071	Rooms 7-12 Bldg Classroom 11				
072	Rooms 7-12 Bldg Classroom 12				
083	Room 15 Bldg Classroom 15				
118	Preschool Area Classroom 13				
119	Preschool Area Classroom 16				
120	Preschool Area Classroom 17				
121	Preschool Area Preschool				
157	Multi-Purpose Bldg MP Room				
158	Multi-Purpose Bldg Kitchen				
159	Multi-Purpose Bldg Music Room				
Visible					
019	Admin Building Kindergarten RR				
073	Rooms 7-12 Bldg Boys RR by Rm 9				
074	Rooms 7-12 Bldg Girls RR by Rm 10				
122	Preschool Area Staff RR Classrm 17				
123	Preschool Area Classroom 17 RR				
124	Preschool Area Classroom 17 RR				
125	Preschool Area Preschool Restroom				
126	Preschool Area Preschool Restroom				
127	Preschool Area Boys Restroom				
128	Preschool Area Girls Restroom				
160	Multi-Purpose Bldg Kitchen Restroom				
161	Multi-Purpose Bldg Kitchen Restroom				
162	Multi-Purpose Bldg Music Hallway				
Audible					
038	Rooms 1-6 Bldg North Exterior				
039	Rooms 1-6 Bldg South Exterior				
040	Rooms 1-6 Bldg West Exterior				
065	Rooms 7-12 Bldg North Exterior				
066	Rooms 7-12 Bldg South Exterior				
082	Room 15 Bldg North Exterior				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
115	Preschool Area North Exterior				
116	Preschool Area East Exterior				
117	Preschool Area South Exterior				
155	Multi-Purpose Bldg East Exterior				
156	Multi-Purpose Bldg West Exterior				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Admin Office				
	Preschool Area Classroom 13				

### NAC Power Extender Panel

047	Rooms 1-6 Bldg Room E FACP Rm - P.E. "A"				
075	Rooms 7-12 Bldg Telco Rm by Rm 12 - P.E. "C"				
129	Preschool Area Classrm 13 E Closet - P.E. "B"				

### Fire Alarm Panel

	Rooms 1-6 Bldg Room E FACP Rm				
--	----------------------------------	--	--	--	--

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-381 002	Admin Building Admin Office				
2-130 084	Preschool Area Classroom 13				
2-376 130	Multi-Purpose Bldg MP Room NW				
2-378 131	Multi-Purpose Bldg MP Room SW				
2-379 132	Multi-Purpose Bldg MP Room South				
2-380 133	Multi-Purpose Bldg MP Room SE				

### Smoke Detector - General

2-280 003	Admin Building Admin Office				
2-277 004	Admin Building Admin NE Storage				
2-279 005	Admin Building Admin Nurse				
2-283 006	Admin Building Admin MTG Closet				
2-285 007	Admin Building Admin Meeting Rm				
2-284 008	Admin Building Admin Principal Office				
2-282 009	Admin Building Admin Nurse Restrm				
2-281 010	Admin Building Admin Restroom				
2-273 011	Admin Building Kindergarten				
2-274 012	Admin Building Kindergarten				
2-278 013	Admin Building Kindergarten RR				
2-276 014	Admin Building Kindergarten Storage				
2-275 015	Admin Building Kinder Supply Closet				
2-018 020	Rooms 1-6 Bldg Classroom 1				
2-019 021	Rooms 1-6 Bldg Classroom 1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-021 022	Rooms 1-6 Bldg Classroom 2				
2-020 023	Rooms 1-6 Bldg Classroom 2				
2-023 024	Rooms 1-6 Bldg Classroom 3				
2-022 025	Rooms 1-6 Bldg Classroom 3				
2-012 026	Rooms 1-6 Bldg Classroom 4				
2-013 027	Rooms 1-6 Bldg Classroom 4				
2-014 028	Rooms 1-6 Bldg Classroom 5				
2-015 029	Rooms 1-6 Bldg Classroom 5				
2-016 030	Rooms 1-6 Bldg Classroom 6				
2-017 031	Rooms 1-6 Bldg Classroom 6				
2-011 032	Rooms 1-6 Bldg Teacher Room A				
2-010 033	Rooms 1-6 Bldg Boys Restroom				
2-008 035	Rooms 1-6 Bldg Girls Restroom				
2-007 036	Rooms 1-6 Bldg Boiler Room				
2-006 037	Rooms 1-6 Bldg Room E FACP Rm				
2-291 048	Rooms 7-12 Bldg Classroom B01				
2-292 049	Rooms 7-12 Bldg Classroom B02				
2-289 050	Rooms 7-12 Bldg Classroom 8				
2-290 051	Rooms 7-12 Bldg Classroom B02				
2-287 052	Rooms 7-12 Bldg Classroom B03				
2-288 053	Rooms 7-12 Bldg Classroom B03				
2-298 054	Rooms 7-12 Bldg Classroom B04				
2-297 055	Rooms 7-12 Bldg Classroom B04				
2-300 056	Rooms 7-12 Bldg Classroom B05				
2-299 057	Rooms 7-12 Bldg Classroom B05				
2-302 058	Rooms 7-12 Bldg Classroom B06				
2-301 059	Rooms 7-12 Bldg Classroom B06				
2-296 060	Rooms 7-12 Bldg Telco Rm by Rm 12				
2-295 061	Rooms 7-12 Bldg Girls RR B08				
2-294 062	Rooms 7-12 Bldg Janitor Rm by Rm 9				
2-293 063	Rooms 7-12 Bldg Boys RR B10				
2-286 064	Rooms 7-12 Staff Rm B11				
2-305 076	Room 15 Bldg Classroom 15				
2-304 077	Room 15 Bldg Classroom 15				
2-027 085	Preschool Area Classroom 13				
2-029 086	Preschool Area Classroom 13				
2-028 087	Preschool Area Classroom 13				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-026 088	Wash rm D03.1				
2-025 089	Strg Rm D03.2				
2-031 090	Preschool Area Classroom 16				
2-030 091	Preschool Area Classroom 16				
2-040 092	Preschool Area Classroom 16				
2-048 093	Preschool Area N Classroom 17				
2-049 094	Preschool Area Classroom 17				
2-050 095	Preschool Area S Classroom 17				
2-051 096	Preschool Area Staff RR Classrm 17				
2-047 097	Preschool Area Classroom 17 RR				
2-046 098	Preschool Area Classroom 17 RR				
2-032 099	Preschool Area Preschool				
2-033 100	Preschool Area Preschool				
2-034 101	Strg rm D04.1				
2-038 102	Preschool Area Preschool Kitchen				
2-043 103	Preschool Area Preschool Hallway				
2-042 104	Preschool Area Preschool Restroom				
2-044 105	Preschool Area Preschool Restroom				
2-041 106	Preschool Area West Storage				
2-039 107	Preschool Area West Storage				
2-036 108	Preschool Area Boys Restroom				
2-037 109	Preschool Area Girls Restroom				
2-252 134	Multi-Purpose Bldg MP Room NW				
2-253 135	Multi-Purpose Bldg MP Room North				
2-254 136	Multi-Purpose Bldg MP Room NE				
2-272 137	Multi-Purpose Bldg MP Room SE				
2-271 138	Multi-Purpose Bldg MP Room South				
2-270 139	Multi-Purpose Bldg MP Room SW				
2-255 140	Multi-Purpose Bldg MP Room Storage				
2-256 141	Multi-Purpose Bldg Water Heater Closet				
2-258 142	Multi-Purpose Bldg Kitchen Restroom				
2-257 143	Multi-Purpose Bldg Kitchen Restroom				
2-259 144	Multi-Purpose Bldg MP Room NW				
2-260 145	Multi-Purpose Bldg Food Pantry				
2-266 146	Multi-Purpose Bldg Music Hallway				
2-265 147	Multi-Purpose Bldg Music Room				
2-264 148	Multi-Purpose Bldg Music Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-263 149	Multi-Purpose Bldg Music Room				
2-269 150	Multi-Purpose Bldg Music Supplies Rm				
2-267 151	Multi-Purpose Bldg Music Elect Room				
2-268 152	Multi-Purpose Bldg Music Pump Room				
2-251	Kitchen Lobby				
2-262	Music Room				
Heat Detector - Restorable Spot					
2-009 034	Rooms 1-6 Bldg Janitor Room				
2-384 078	Room 15 Bldg Attic Classroom 15				
2-384 079	Room 15 Bldg Attic Classroom 15				
2-384 080	Room 15 Bldg Attic Classroom 15				
2-384 081	Room 15 Bldg Attic Classroom 15				
2-131 110	Preschool Area Attic Classroom 17				
2-131 111	Preschool Area Attic Classroom 17				
2-131 112	Preschool Area Attic Classroom 17				
2-132 113	Preschool Area Attic Classrm 17 RR				
2-132 114	Preschool Area Attic Classrm 17 RR				
2-261 153	Multi-Purpose Bldg Kitchen				
2-377 154	Multi-Purpose Bldg Attic Music Room				
2-131	Preschool Area Attic Classroom 17				