

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

MARVIN MARSHALL

5309 KENNETH AVE
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Monday, May 04, 2026

Test Session:05 Mar 2026 14:01 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	MARVIN MARSHALL	CONTACT
ADDRESS	5309 KENNETH AVE	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	80	80(100%)	80(100%)	0(0%)
Supervising Station Transmitting Equipment	1	1(100%)	1(100%)	0(0%)
Fire Control Panel	7	7(100%)	1(14%)	6(86%)
Initiating Device	126	126(100%)	126(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, May 04, 2026

ACCEPTED BY 05/04/2026

Building Representative


TESTED BY 05/04/2026
Riley Goyet
Technician

System Details

Monitoring Information

Rooms 14-19 Bldg MDF Rm - Dialer Panel			
TYPE	Digital Alarm Communicator Transmitter	INSTALL DATE	
MANUFACTURER	Bosch	TEST START	03/05/2026
MODEL	B9512G	TEST COMPLETE	05/04/2026
SERIAL NUMBER		Time to Transmit to Supervising Station	
MONITORING ORGANIZATION	Central Station / SJUSD Dispatch	ALARM SIGNAL	
MONITORING ORGANIZATION PHONE	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	ALARM RESTORE	
MONITORING ORGANIZATION EMAIL		TROUBLE SIGNAL	
MONITORING ORGANIZATION ACCOUNT NUMBER	Central Station # 881-8016	TROUBLE RESTORE	
MONITORING PHONE LINE 1		SUPERVISORY SIGNAL	
MONITORING PHONE LINE 2		SUPERVISORY RESTORE	
MONITORING RETRANSMISSION ENTITY			

Open Corrective Action & Solution Summary

The following 8 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	088	Rooms 5-8 Bldg Boiler Rm at Rm 5 - P.E. "D"
	Created By:	Riley Goyet
	Creation Date:	02/08/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	02/04/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Rooms 14-19 Bldg MDF Rm - FACP
	Created By:	Riley Goyet
	Creation Date:	02/08/2024
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
	Created By:	Riley Goyet
	Creation Date:	02/04/2025
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
NAC Power Extender Panel	135	Rooms 9-13 Bldg Staff Room 9A
	Created By:	Riley Goyet
	Creation Date:	02/08/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries shows trouble on Nac panel but not on fire panel.
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	053	Rooms 1-4 Bldg Hall at Room 4 - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	02/04/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	181	Rooms 14-19 Bldg MDF Rm - P.E. "A"
	Created By:	Riley Goyet
	Creation Date:	02/04/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	182	Rooms 14-19 Bldg MDF Rm - P.E. "B"
	Created By:	Riley Goyet

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
	Creation Date:	02/04/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Multi-Purpose Bldg East Foyer	Manual	3/5/2026 10:43:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Kitchen	Manual	3/5/2026 10:43:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	3/5/2026 10:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	3/5/2026 10:43:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg North Exterior	Manual	3/5/2026 10:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Registration Office	Manual	3/5/2026 10:43:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg South Exterior	Manual	3/5/2026 10:41:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg South Exterior	Manual	3/5/2026 10:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg South Foyer Entry	Manual	3/5/2026 10:43:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg West Exterior	Manual	3/5/2026 10:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg West Exterior	Manual	3/5/2026 10:41:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-4 Bldg Boys RR at Room 4	Manual	3/5/2026 10:43:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg East Exterior	Manual	3/5/2026 10:42:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-4 Bldg Girls RR at Room 4	Manual	3/5/2026 10:43:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Hall at Room 2	Manual	3/5/2026 10:43:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Hall at Room 4	Manual	3/5/2026 10:43:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-4 Bldg Hall at Room 4	Manual	3/5/2026 10:43:48 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg North Exterior	Manual	3/5/2026 10:43:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg North Exterior	Manual	3/5/2026 10:43:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-4 Bldg Public RR at Room 1	Manual	3/5/2026 10:42:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 1	Manual	3/5/2026 10:43:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 2	Manual	3/5/2026 10:43:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 3	Manual	3/5/2026 10:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 4	Manual	3/5/2026 10:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg South Exterior	Manual	3/5/2026 10:42:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg South Exterior	Manual	3/5/2026 10:42:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-4 Bldg Speech Office	Manual	3/5/2026 10:42:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-4 Bldg Staff RR at Room 1	Manual	3/5/2026 10:42:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Storage Outside Rm 1	Manual	3/5/2026 10:43:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 14-19 Bldg Admin Hallway	Manual	3/5/2026 10:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 14-19 Bldg Admin Office RR	Manual	3/5/2026 10:42:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 14-19 Bldg Admin Office RR	Manual	3/5/2026 10:42:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Admin Reception	Manual	3/5/2026 10:43:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 14-19 Bldg East Exterior	Manual	3/5/2026 10:41:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 14-19 Bldg North Exterior	Manual	3/5/2026 10:41:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Rooms 14-19 Bldg North Exterior	Manual	3/5/2026 10:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 14-19 Bldg Office Rm 16 Storage	Manual	3/5/2026 10:42:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Office Room 14	Manual	3/5/2026 10:43:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Office Room 15	Manual	3/5/2026 10:43:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Office Room 16	Manual	3/5/2026 10:43:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Office Room 17	Manual	3/5/2026 10:43:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Office Room 18	Manual	3/5/2026 10:43:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Office Room 19	Manual	3/5/2026 10:43:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 14-19 Bldg Office RR Room 19	Manual	3/5/2026 10:42:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 14-19 Bldg Program Mang Office	Manual	3/5/2026 10:43:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 14-19 Bldg South Exterior	Manual	3/5/2026 10:41:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 14-19 Bldg South Exterior	Manual	3/5/2026 10:41:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 14-19 Bldg West Exterior	Manual	3/5/2026 10:41:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 5-8 Bldg Boys RR at Room 8	Manual	3/5/2026 10:42:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-8 Bldg East Exterior	Manual	3/5/2026 10:42:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 5-8 Bldg Girls RR at Room 8	Manual	3/5/2026 10:42:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-8 Bldg North Exterior	Manual	3/5/2026 10:42:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-8 Bldg North Exterior	Manual	3/5/2026 10:42:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Rooms 5-8 Bldg North Exterior	Manual	3/5/2026 10:42:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-8 Bldg Room 5	Manual	3/5/2026 10:43:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-8 Bldg Room 6	Manual	3/5/2026 10:43:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-8 Bldg Room 7	Manual	3/5/2026 10:43:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-8 Bldg Room 8	Manual	3/5/2026 10:43:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-8 Bldg South Exterior	Manual	3/5/2026 10:42:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-8 Bldg South Exterior	Manual	3/5/2026 10:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 9-13 Bldg East Exterior	Manual	3/5/2026 10:41:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 9-13 Bldg North Exterior	Manual	3/5/2026 10:42:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 9-13 Bldg North Exterior	Manual	3/5/2026 10:42:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 9-13 Bldg Room 10	Manual	3/5/2026 10:43:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Room 10A RR	Manual	3/5/2026 10:42:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Room 10B RR	Manual	3/5/2026 10:42:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 9-13 Bldg Room 11	Manual	3/5/2026 10:43:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Room 11A RR	Manual	3/5/2026 10:42:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Room 11B RR	Manual	3/5/2026 10:42:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 9-13 Bldg Room 12	Manual	3/5/2026 10:43:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Room 12A RR	Manual	3/5/2026 10:42:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Room 12B RR	Manual	3/5/2026 10:42:23 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 9-13 Bldg Room 13	Manual	3/5/2026 10:43:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Room 13 Restroom	Manual	3/5/2026 10:42:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 9-13 Bldg Room 9	Manual	3/5/2026 10:43:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 9-13 Bldg Room 9	Manual	3/5/2026 10:43:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 9-13 Bldg South Exterior	Manual	3/5/2026 10:41:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 9-13 Bldg South Exterior	Manual	3/5/2026 10:41:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 9-13 Bldg Staff Room 9 RR	Manual	3/5/2026 10:42:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 9-13 Bldg West Exterior	Manual	3/5/2026 10:41:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Rooms 1-4 Bldg Speech Office	Manual	3/5/2026 3:09:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Rooms 1-4 Bldg Hall at Room 4 - P.E. "C"	Manual	3/5/2026 10:41:24 PM
Fire Alarm Panel		Rooms 14-19 Bldg MDF Rm - FACP	Manual	3/5/2026 10:41:29 PM
		Manufacturer	EST	
		Model	3	
NAC Power Extender Panel		Rooms 14-19 Bldg MDF Rm - P.E. "A"	Manual	3/5/2026 10:41:34 PM
NAC Power Extender Panel		Rooms 14-19 Bldg MDF Rm - P.E. "B"	Manual	3/5/2026 10:41:38 PM
NAC Power Extender Panel		Rooms 5-8 Bldg Boiler Rm at Rm 5 - P.E. "D"	Manual	3/5/2026 10:41:46 PM
NAC Power Extender Panel		Rooms 9-13 Bldg Staff Room 9A	Manual	3/5/2026 10:41:42 PM

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-061 075	Boys RR at Room 20	Manual	3/5/2026 3:09:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 197	Multi-Purpose Bldg East Foyer	Manual	3/5/2026 3:10:43 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-087 198	Multi-Purpose Bldg Kitchen	Manual	3/5/2026 3:10:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-088 199	Multi-Purpose Bldg Kitchen	Manual	3/5/2026 3:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 187	Multi-Purpose Bldg Kitchen	Manual	3/5/2026 3:11:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-132 200	Multi-Purpose Bldg MP Beam East	Manual	3/5/2026 3:11:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-134 201	Multi-Purpose Bldg MP Beam West	Manual	3/5/2026 3:11:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-144 189	Multi-Purpose Bldg MP East Foyer East	Manual	3/5/2026 3:10:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-143 188	Multi-Purpose Bldg MP East Foyer North	Manual	3/5/2026 3:10:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-141 186	Multi-Purpose Bldg MP Room Northeast	Manual	3/5/2026 3:11:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-140 185	Multi-Purpose Bldg MP Room Northwest	Manual	3/5/2026 3:11:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-139 184	Multi-Purpose Bldg MP Room Southeast	Manual	3/5/2026 3:11:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 196	Multi-Purpose Bldg MP Storage	Manual	3/5/2026 3:11:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 193	Multi-Purpose Bldg Registration Office	Manual	3/5/2026 3:10:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 191	Multi-Purpose Bldg Registration Office	Manual	3/5/2026 3:10:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 195	Multi-Purpose Bldg Registration Office Kitchen	Manual	3/5/2026 3:10:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-138 183	Multi-Purpose Bldg South Foyer Entry	Manual	3/5/2026 3:11:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 190	Multi-Purpose Bldg South Hall at MP Rm	Manual	3/5/2026 3:09:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-080 194	Multi-Purpose Bldg Speech Rm	Manual	3/5/2026 3:10:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 030	Rooms 1-4 Bldg Boys RR at Room 4	Manual	3/5/2026 3:12:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 031	Rooms 1-4 Bldg Girls RR at Room 4	Manual	3/5/2026 3:12:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 019	Rooms 1-4 Bldg Hall at Room 1	Manual	3/5/2026 3:11:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 021	Rooms 1-4 Bldg Hall at Room 1	Manual	3/5/2026 3:11:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 024	Rooms 1-4 Bldg Hall at Room 2	Manual	3/5/2026 3:11:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 025	Rooms 1-4 Bldg Hall at Room 2	Manual	3/5/2026 3:11:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 026	Rooms 1-4 Bldg Hall at Room 3	Manual	3/5/2026 3:11:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 027	Rooms 1-4 Bldg Hall at Room 4	Manual	3/5/2026 3:11:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 028	Rooms 1-4 Bldg Hall at Room 4	Manual	3/5/2026 3:11:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 029	Rooms 1-4 Bldg Hall at Room 4	Manual	3/5/2026 3:12:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 033	Rooms 1-4 Bldg Outside Strg at Rm 4	Manual	3/5/2026 3:09:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 022	Rooms 1-4 Bldg Public RR at Room 1	Manual	3/5/2026 3:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 006	Rooms 1-4 Bldg Room 1	Manual	3/5/2026 3:11:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 005	Rooms 1-4 Bldg Room 1	Manual	3/5/2026 3:11:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 004	Rooms 1-4 Bldg Room 1	Manual	3/5/2026 3:11:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-049 003	Rooms 1-4 Bldg Room 1	Manual	3/5/2026 3:11:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 008	Rooms 1-4 Bldg Room 2	Manual	3/5/2026 3:11:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 009	Rooms 1-4 Bldg Room 2	Manual	3/5/2026 3:11:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 010	Rooms 1-4 Bldg Room 2	Manual	3/5/2026 3:11:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 007	Rooms 1-4 Bldg Room 2	Manual	3/5/2026 3:11:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 012	Rooms 1-4 Bldg Room 3	Manual	3/5/2026 3:11:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 013	Rooms 1-4 Bldg Room 3	Manual	3/5/2026 3:11:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 014	Rooms 1-4 Bldg Room 3	Manual	3/5/2026 3:11:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 011	Rooms 1-4 Bldg Room 3	Manual	3/5/2026 3:11:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 016	Rooms 1-4 Bldg Room 4	Manual	3/5/2026 3:11:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 017	Rooms 1-4 Bldg Room 4	Manual	3/5/2026 3:11:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 018	Rooms 1-4 Bldg Room 4	Manual	3/5/2026 3:11:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 015	Rooms 1-4 Bldg Room 4	Manual	3/5/2026 3:11:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-054 034	Rooms 1-4 Bldg School Laundry	Manual	3/5/2026 3:11:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-130 002	Rooms 1-4 Bldg Speech Office	Manual	3/5/2026 3:09:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 032	Rooms 1-4 Bldg Speech Office	Manual	3/5/2026 3:12:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-053 023	Rooms 1-4 Bldg Staff Restroom at Rm 1	Manual	3/5/2026 3:11:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 020	Rooms 1-4 Bldg Storage Outside Rm 1	Manual	3/5/2026 3:11:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 143	Rooms 14-19 Bldg Admin Office RR	Manual	3/5/2026 3:12:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 142	Rooms 14-19 Bldg Admin Office RR	Manual	3/5/2026 3:12:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-136 136	Rooms 14-19 Bldg Admin Reception	Manual	3/5/2026 3:12:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 137	Rooms 14-19 Bldg Admin Reception	Manual	3/5/2026 3:12:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 161	Rooms 14-19 Bldg MDF Rm / Headend	Manual	3/5/2026 3:09:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 139	Rooms 14-19 Bldg MDF Rm / Headend	Manual	3/5/2026 3:09:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 138	Rooms 14-19 Bldg Office Director	Manual	3/5/2026 3:09:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 151	Rooms 14-19 Bldg Office Rm 16 Storage	Manual	3/5/2026 3:12:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 145	Rooms 14-19 Bldg Office Room 14	Manual	3/5/2026 3:12:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 146	Rooms 14-19 Bldg Office Room 14	Manual	3/5/2026 3:12:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 148	Rooms 14-19 Bldg Office Room 15	Manual	3/5/2026 3:12:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 147	Rooms 14-19 Bldg Office Room 15	Manual	3/5/2026 3:12:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 150	Rooms 14-19 Bldg Office Room 16	Manual	3/5/2026 3:12:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 149	Rooms 14-19 Bldg Office Room 16	Manual	3/5/2026 3:12:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-018 152	Rooms 14-19 Bldg Office Room 17	Manual	3/5/2026 3:12:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 153	Rooms 14-19 Bldg Office Room 17	Manual	3/5/2026 3:12:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 155	Rooms 14-19 Bldg Office Room 18	Manual	3/5/2026 3:12:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 154	Rooms 14-19 Bldg Office Room 18	Manual	3/5/2026 3:12:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 157	Rooms 14-19 Bldg Office Room 19	Manual	3/5/2026 3:12:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 156	Rooms 14-19 Bldg Office Room 19	Manual	3/5/2026 3:12:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 158	Rooms 14-19 Bldg Office RR Room 19	Manual	3/5/2026 3:12:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 159	Rooms 14-19 Bldg Office SMUD Room	Manual	3/5/2026 3:12:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 141	Rooms 14-19 Bldg Office Supply Closet	Manual	3/5/2026 3:09:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 144	Rooms 14-19 Bldg Program Managers Office	Manual	3/5/2026 3:12:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 160	Rooms 14-19 Bldg SMUD Room Storage	Manual	3/5/2026 3:12:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 140	Rooms 14-19 Bldg Staff Breakroom	Manual	3/5/2026 3:09:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 054	Rooms 5-8 Bldg Boiler Rm at Rm 5	Manual	3/5/2026 3:10:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 055	Rooms 5-8 Bldg Boiler Rm at Rm 5	Manual	3/5/2026 3:10:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 073	Rooms 5-8 Bldg Custodial Office	Manual	3/5/2026 3:09:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 074	Rooms 5-8 Bldg Custodial Office	Manual	3/5/2026 3:09:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-058 072	Rooms 5-8 Bldg Girls RR at Room 8	Manual	3/5/2026 3:09:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 057	Rooms 5-8 Bldg Room 5	Manual	3/5/2026 3:09:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 058	Rooms 5-8 Bldg Room 5	Manual	3/5/2026 3:09:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 059	Rooms 5-8 Bldg Room 5	Manual	3/5/2026 3:09:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 056	Rooms 5-8 Bldg Room 5	Manual	3/5/2026 3:09:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 060	Rooms 5-8 Bldg Room 6	Manual	3/5/2026 3:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 063	Rooms 5-8 Bldg Room 6	Manual	3/5/2026 3:09:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 062	Rooms 5-8 Bldg Room 6	Manual	3/5/2026 3:09:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 061	Rooms 5-8 Bldg Room 6	Manual	3/5/2026 3:09:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 066	Rooms 5-8 Bldg Room 7	Manual	3/5/2026 3:09:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 065	Rooms 5-8 Bldg Room 7	Manual	3/5/2026 3:09:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 067	Rooms 5-8 Bldg Room 7	Manual	3/5/2026 3:09:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 064	Rooms 5-8 Bldg Room 7	Manual	3/5/2026 3:09:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 068	Rooms 5-8 Bldg Room 8	Manual	3/5/2026 3:09:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 069	Rooms 5-8 Bldg Room 8	Manual	3/5/2026 3:09:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 070	Rooms 5-8 Bldg Room 8	Manual	3/5/2026 3:09:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-065 071	Rooms 5-8 Bldg Room 8	Manual	3/5/2026 3:09:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 097	Rooms 9-13 Bldg Outside Rm 9 Storage	Manual	3/5/2026 3:10:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 099	Rooms 9-13 Bldg Room 10	Manual	3/5/2026 3:10:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 100	Rooms 9-13 Bldg Room 10	Manual	3/5/2026 3:10:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 098	Rooms 9-13 Bldg Room 10	Manual	3/5/2026 3:10:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 103	Rooms 9-13 Bldg Room 10 Kitchen	Manual	3/5/2026 3:10:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 101	Rooms 9-13 Bldg Room 10A RR	Manual	3/5/2026 3:10:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 102	Rooms 9-13 Bldg Room 10B RR	Manual	3/5/2026 3:10:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 105	Rooms 9-13 Bldg Room 11	Manual	3/5/2026 3:10:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 104	Rooms 9-13 Bldg Room 11	Manual	3/5/2026 3:10:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 106	Rooms 9-13 Bldg Room 11A RR	Manual	3/5/2026 3:10:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 107	Rooms 9-13 Bldg Room 11B RR	Manual	3/5/2026 3:10:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 109	Rooms 9-13 Bldg Room 12	Manual	3/5/2026 3:10:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 108	Rooms 9-13 Bldg Room 12	Manual	3/5/2026 3:10:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 110	Rooms 9-13 Bldg Room 12A RR	Manual	3/5/2026 3:10:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 111	Rooms 9-13 Bldg Room 12B RR	Manual	3/5/2026 3:10:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-276 112	Rooms 9-13 Bldg Room 13	Manual	3/5/2026 3:09:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 113	Rooms 9-13 Bldg Room 13	Manual	3/5/2026 3:09:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 114	Rooms 9-13 Bldg Room 13 Restroom	Manual	3/5/2026 3:09:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 095	Rooms 9-13 Bldg Staff Rm 9 Kitchen	Manual	3/5/2026 3:10:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 089	Rooms 9-13 Bldg Staff Room 9	Manual	3/5/2026 3:09:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 090	Rooms 9-13 Bldg Staff Room 9	Manual	3/5/2026 3:10:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 091	Rooms 9-13 Bldg Staff Room 9	Manual	3/5/2026 3:10:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 092	Rooms 9-13 Bldg Staff Room 9	Manual	3/5/2026 3:10:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 096	Rooms 9-13 Bldg Staff Room 9 RR	Manual	3/5/2026 3:10:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 093	Rooms 9-13 Bldg Staff Room 9A	Manual	3/5/2026 3:10:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 094	Rooms 9-13 Bldg Staff Room 9B	Manual	3/5/2026 3:09:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 192	Soeech Rm	Manual	3/5/2026 3:10:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Supervising Station Transmitting Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Digital Alarm Communicator Transmitter		Rooms 14-19 Bldg MDF Rm - Dialer Panel	Manual	3/5/2026 3:09:30 PM
		Manufacturer	Bosch	
		Model	B9512G	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	Central Station # 881-8016	
		Monitoring Organization	Central Station / SJUSD Dispatch	
		Monitoring Organization Phone	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
035	Rooms 1-4 Bldg North Exterior				
036	Rooms 1-4 Bldg North Exterior				
037	Rooms 1-4 Bldg East Exterior				
038	Rooms 1-4 Bldg South Exterior				
039	Rooms 1-4 Bldg South Exterior				
076	Rooms 5-8 Bldg North Exterior				
077	Rooms 5-8 Bldg North Exterior				
078	Rooms 5-8 Bldg North Exterior				
079	Rooms 5-8 Bldg East Exterior				
080	Rooms 5-8 Bldg South Exterior				
081	Rooms 5-8 Bldg South Exterior				
115	Rooms 9-13 Bldg North Exterior				
116	Rooms 9-13 Bldg North Exterior				
117	Rooms 9-13 Bldg East Exterior				
118	Rooms 9-13 Bldg South Exterior				
119	Rooms 9-13 Bldg South Exterior				
120	Rooms 9-13 Bldg West Exterior				
162	Rooms 14-19 Bldg North Exterior				
163	Rooms 14-19 Bldg North Exterior				
164	Rooms 14-19 Bldg East Exterior				
165	Rooms 14-19 Bldg South Exterior				
166	Rooms 14-19 Bldg South Exterior				
167	Rooms 14-19 Bldg West Exterior				
202	Multi-Purpose Bldg North Exterior				
203	Multi-Purpose Bldg South Exterior				
204	Multi-Purpose Bldg South Exterior				
205	Multi-Purpose Bldg West Exterior				
206	Multi-Purpose Bldg West Exterior				
Audible And Visible					
040	Rooms 1-4 Bldg Room 1				
041	Rooms 1-4 Bldg Room 2				
042	Rooms 1-4 Bldg Room 3				
043	Rooms 1-4 Bldg Room 4				
044	Rooms 1-4 Bldg Hall at Room 2				
045	Rooms 1-4 Bldg Hall at Room 4				
046	Rooms 1-4 Bldg Storage Outside Rm 1				
082	Rooms 5-8 Bldg Room 5				
083	Rooms 5-8 Bldg Room 6				
084	Rooms 5-8 Bldg Room 7				
085	Rooms 5-8 Bldg Room 8				
121	Rooms 9-13 Bldg Room 9				
122	Rooms 9-13 Bldg Room 9				
123	Rooms 9-13 Bldg Room 10				
124	Rooms 9-13 Bldg Room 11				
125	Rooms 9-13 Bldg Room 12				
126	Rooms 9-13 Bldg Room 13				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
168	Rooms 14-19 Bldg Admin Reception				
169	Rooms 14-19 Bldg Program Mang Office				
170	Rooms 14-19 Bldg Office Room 14				
171	Rooms 14-19 Bldg Office Room 15				
172	Rooms 14-19 Bldg Office Room 16				
173	Rooms 14-19 Bldg Office Room 17				
174	Rooms 14-19 Bldg Office Room 18				
175	Rooms 14-19 Bldg Office Room 19				
207	Multi-Purpose Bldg South Foyer Entry				
208	Multi-Purpose Bldg Registration Office				
209	Multi-Purpose Bldg MP Room				
210	Multi-Purpose Bldg MP Room				
211	Multi-Purpose Bldg Kitchen				
212	Multi-Purpose Bldg East Foyer				
Visible					
047	Rooms 1-4 Bldg Public RR at Room 1				
048	Rooms 1-4 Bldg Staff RR at Room 1				
049	Rooms 1-4 Bldg Speech Office				
050	Rooms 1-4 Bldg Girls RR at Room 4				
051	Rooms 1-4 Bldg Boys RR at Room 4				
052	Rooms 1-4 Bldg Hall at Room 4				
086	Rooms 5-8 Bldg Girls RR at Room 8				
087	Rooms 5-8 Bldg Boys RR at Room 8				
127	Rooms 9-13 Bldg Staff Room 9 RR				
128	Rooms 9-13 Bldg Room 10A RR				
129	Rooms 9-13 Bldg Room 10B RR				
130	Rooms 9-13 Bldg Room 11A RR				
131	Rooms 9-13 Bldg Room 11B RR				
132	Rooms 9-13 Bldg Room 12A RR				
133	Rooms 9-13 Bldg Room 12B RR				
134	Rooms 9-13 Bldg Room 13 Restroom				
176	Rooms 14-19 Bldg Admin Hallway				
177	Rooms 14-19 Bldg Admin Office RR				
178	Rooms 14-19 Bldg Admin Office RR				
179	Rooms 14-19 Bldg Office Rm 16 Storage				
180	Rooms 14-19 Bldg Office RR Room 19				
Fire Control Panel					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Rooms 1-4 Bldg Speech Office				
NAC Power Extender Panel					
053	Rooms 1-4 Bldg Hall at Room 4 - P.E. "C"				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
088	Rooms 5-8 Bldg Boiler Rm at Rm 5 - P.E. "D"				
135	Rooms 9-13 Bldg Staff Room 9A				
181	Rooms 14-19 Bldg MDF Rm - P.E. "A"				
182	Rooms 14-19 Bldg MDF Rm - P.E. "B"				
Fire Alarm Panel					
	Rooms 14-19 Bldg MDF Rm - FACP	EST		3	

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-130 002	Rooms 1-4 Bldg Speech Office				
2-136 136	Rooms 14-19 Bldg Admin Reception				
2-138 183	Multi-Purpose Bldg South Foyer Entry				
2-139 184	Multi-Purpose Bldg MP Room Southeast				
2-140 185	Multi-Purpose Bldg MP Room Northwest				
2-141 186	Multi-Purpose Bldg MP Room Northeast				
2-142 187	Multi-Purpose Bldg Kitchen				
2-143 188	Multi-Purpose Bldg MP East Foyer North				
2-144 189	Multi-Purpose Bldg MP East Foyer East				
Smoke Detector - General					
2-049 003	Rooms 1-4 Bldg Room 1				
2-048 004	Rooms 1-4 Bldg Room 1				
2-050 005	Rooms 1-4 Bldg Room 1				
2-051 006	Rooms 1-4 Bldg Room 1				
2-044 007	Rooms 1-4 Bldg Room 2				
2-045 008	Rooms 1-4 Bldg Room 2				
2-047 009	Rooms 1-4 Bldg Room 2				
2-046 010	Rooms 1-4 Bldg Room 2				
2-039 011	Rooms 1-4 Bldg Room 3				
2-038 012	Rooms 1-4 Bldg Room 3				
2-040 013	Rooms 1-4 Bldg Room 3				
2-041 014	Rooms 1-4 Bldg Room 3				
2-033 015	Rooms 1-4 Bldg Room 4				
2-034 016	Rooms 1-4 Bldg Room 4				
2-036 017	Rooms 1-4 Bldg Room 4				
2-035 018	Rooms 1-4 Bldg Room 4				
2-056 019	Rooms 1-4 Bldg Hall at Room 1				
2-085 020	Rooms 1-4 Bldg Storage Outside Rm 1				
2-052 021	Rooms 1-4 Bldg Hall at Room 1				
2-055 022	Rooms 1-4 Bldg Public RR at Room 1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-053 023	Rooms 1-4 Bldg Staff Restroom at Rm 1				
2-043 024	Rooms 1-4 Bldg Hall at Room 2				
2-042 025	Rooms 1-4 Bldg Hall at Room 2				
2-037 026	Rooms 1-4 Bldg Hall at Room 3				
2-032 027	Rooms 1-4 Bldg Hall at Room 4				
2-031 028	Rooms 1-4 Bldg Hall at Room 4				
2-029 029	Rooms 1-4 Bldg Hall at Room 4				
2-027 030	Rooms 1-4 Bldg Boys RR at Room 4				
2-028 031	Rooms 1-4 Bldg Girls RR at Room 4				
2-030 032	Rooms 1-4 Bldg Speech Office				
2-095 033	Rooms 1-4 Bldg Outside Strg at Rm 4				
2-092 054	Rooms 5-8 Bldg Boiler Rm at Rm 5				
2-093 055	Rooms 5-8 Bldg Boiler Rm at Rm 5				
2-076 056	Rooms 5-8 Bldg Room 5				
2-075 057	Rooms 5-8 Bldg Room 5				
2-077 058	Rooms 5-8 Bldg Room 5				
2-078 059	Rooms 5-8 Bldg Room 5				
2-071 060	Rooms 5-8 Bldg Room 6				
2-072 061	Rooms 5-8 Bldg Room 6				
2-074 062	Rooms 5-8 Bldg Room 6				
2-073 063	Rooms 5-8 Bldg Room 6				
2-068 064	Rooms 5-8 Bldg Room 7				
2-067 065	Rooms 5-8 Bldg Room 7				
2-069 066	Rooms 5-8 Bldg Room 7				
2-070 067	Rooms 5-8 Bldg Room 7				
2-063 068	Rooms 5-8 Bldg Room 8				
2-064 069	Rooms 5-8 Bldg Room 8				
2-066 070	Rooms 5-8 Bldg Room 8				
2-065 071	Rooms 5-8 Bldg Room 8				
2-058 072	Rooms 5-8 Bldg Girls RR at Room 8				
2-059 073	Rooms 5-8 Bldg Custodial Office				
2-060 074	Rooms 5-8 Bldg Custodial Office				
2-061 075	Boys RR at Room 20				
2-254 089	Rooms 9-13 Bldg Staff Room 9				
2-259 090	Rooms 9-13 Bldg Staff Room 9				
2-260 091	Rooms 9-13 Bldg Staff Room 9				
2-257 092	Rooms 9-13 Bldg Staff Room 9				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-280 093	Rooms 9-13 Bldg Staff Room 9A				
2-278 094	Rooms 9-13 Bldg Staff Room 9B				
2-258 095	Rooms 9-13 Bldg Staff Rm 9 Kitchen				
2-255 096	Rooms 9-13 Bldg Staff Room 9 RR				
2-279 097	Rooms 9-13 Bldg Outside Rm 9 Storage				
2-263 098	Rooms 9-13 Bldg Room 10				
2-256 099	Rooms 9-13 Bldg Room 10				
2-264 100	Rooms 9-13 Bldg Room 10				
2-262 101	Rooms 9-13 Bldg Room 10A RR				
2-261 102	Rooms 9-13 Bldg Room 10B RR				
2-265 103	Rooms 9-13 Bldg Room 10 Kitchen				
2-268 104	Rooms 9-13 Bldg Room 11				
2-269 105	Rooms 9-13 Bldg Room 11				
2-267 106	Rooms 9-13 Bldg Room 11A RR				
2-266 107	Rooms 9-13 Bldg Room 11B RR				
2-272 108	Rooms 9-13 Bldg Room 12				
2-273 109	Rooms 9-13 Bldg Room 12				
2-270 110	Rooms 9-13 Bldg Room 12A RR				
2-271 111	Rooms 9-13 Bldg Room 12B RR				
2-276 112	Rooms 9-13 Bldg Room 13				
2-277 113	Rooms 9-13 Bldg Room 13				
2-275 114	Rooms 9-13 Bldg Room 13 Restroom				
2-005 137	Rooms 14-19 Bldg Admin Reception				
2-004 138	Rooms 14-19 Bldg Office Director				
2-002 139	Rooms 14-19 Bldg MDF Rm / Headend				
2-008 140	Rooms 14-19 Bldg Staff Breakroom				
2-006 141	Rooms 14-19 Bldg Office Supply Closet				
2-007 142	Rooms 14-19 Bldg Admin Office RR				
2-009 143	Rooms 14-19 Bldg Admin Office RR				
2-010 144	Rooms 14-19 Bldg Program Managers Office				
2-025 145	Rooms 14-19 Bldg Office Room 14				
2-024 146	Rooms 14-19 Bldg Office Room 14				
2-022 147	Rooms 14-19 Bldg Office Room 15				
2-023 148	Rooms 14-19 Bldg Office Room 15				
2-020 149	Rooms 14-19 Bldg Office Room 16				
2-021 150	Rooms 14-19 Bldg Office Room 16				
2-015 151	Rooms 14-19 Bldg Office Rm 16 Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-018 152	Rooms 14-19 Bldg Office Room 17				
2-019 153	Rooms 14-19 Bldg Office Room 17				
2-016 154	Rooms 14-19 Bldg Office Room 18				
2-017 155	Rooms 14-19 Bldg Office Room 18				
2-011 156	Rooms 14-19 Bldg Office Room 19				
2-012 157	Rooms 14-19 Bldg Office Room 19				
2-013 158	Rooms 14-19 Bldg Office RR Room 19				
2-014 159	Rooms 14-19 Bldg Office SMUD Room				
2-094 160	Rooms 14-19 Bldg SMUD Room Storage				
2-057 190	Multi-Purpose Bldg South Hall at MP Rm				
2-083 191	Multi-Purpose Bldg Registration Office				
2-081 192	Soeech Rm				
2-082 193	Multi-Purpose Bldg Registration Office				
2-080 194	Multi-Purpose Bldg Speech Rm				
2-084 195	Multi-Purpose Bldg Registration Office Kitchen				
2-090 196	Multi-Purpose Bldg MP Storage				
2-079 197	Multi-Purpose Bldg East Foyer				
Heat Detector - Restorable Spot					
2-054 034	Rooms 1-4 Bldg School Laundry				
2-003 161	Rooms 14-19 Bldg MDF Rm / Headend				
2-087 198	Multi-Purpose Bldg Kitchen				
2-088 199	Multi-Purpose Bldg Kitchen				
Smoke Detector - Projected Beam					
2-132 200	Multi-Purpose Bldg MP Beam East				
2-134 201	Multi-Purpose Bldg MP Beam West				
Supervising Station Transmitting Equipment					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Digital Alarm Communicator Transmitter					
	Rooms 14-19 Bldg MDF Rm - Dialer Panel	Bosch	B9512G		