

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

CARRIAGE DRIVE ELEMENTARY

7519 CARRIAGE DR  
CITRUS HEIGHTS, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Monday, May 04, 2026

Test Session: 25 Mar 2026 14:00 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	CARRIAGE DRIVE ELEMENTARY	CONTACT
ADDRESS	7519 CARRIAGE DR	PHONE
CITY/STATE	CITRUS HEIGHTS, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Fire Control Panel	5	5(100%)	5(100%)	0(0%)
Initiating Device	226	206(91%)	206(91%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, May 04, 2026

ACCEPTED BY 05/04/2026  
  
Building Representative

  
TESTED BY 05/04/2026  
Riley Goyet  
Technician

# Testing Details

## Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Building 11 Storage BPS-C	Manual	5/4/2026 9:32:39 AM
		Manufacturer	Edwards	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Classroom 22 Storage BPS-D	Manual	5/4/2026 9:33:20 AM
		Manufacturer	Edwards	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		MP Room Storage FACP	Manual	5/4/2026 9:33:16 AM
		Manufacturer	Edwards	
		Model	EST-3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		MP Room Storage FACP BPS-A	Manual	5/4/2026 9:33:21 AM
		Manufacturer	Edwards	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		MP Room Storage FACP BPS-B	Manual	5/4/2026 9:33:19 AM
		Manufacturer	Edwards	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

## Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.009	Admin Alcove	Manual	3/25/2026 3:11:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.021	Admin Men's RR	Manual	3/25/2026 3:10:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.022	Admin Men's RR Water Heater	Manual	3/25/2026 3:12:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.020	Admin MP Hall	Manual	3/25/2026 3:10:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.171	Admin MP Lobby	Manual	3/25/2026 3:26:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.017	Admin MP Lobby	Manual	3/25/2026 3:11:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.018	Admin MP Lobby	Manual	3/25/2026 3:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.014	Admin Nurse Clst	Manual	3/25/2026 3:11:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.013	Admin Nurse Rm	Manual	3/25/2026 2:43:15 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.010	Admin Nurse RR	Manual	3/25/2026 3:11:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.143	Admin Office	Manual	3/25/2026 3:26:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.011	Admin Office	Manual	3/25/2026 3:11:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.012	Admin Office	Manual	3/25/2026 3:11:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.008	Admin Principal Clst	Manual	3/25/2026 3:10:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.006	Admin Principal Conf	Manual	3/25/2026 3:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.007	Admin Principal Office	Manual	3/25/2026 3:10:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.015	Admin Program Clst	Manual	3/25/2026 3:11:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.016	Admin Program Office	Manual	3/25/2026 3:11:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023	Admin Womens RR	Manual	3/25/2026 3:10:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.141	Attic Admin Nurse	Manual	3/25/2026 2:47:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.142	Attic Admin Office	Manual	3/25/2026 2:44:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.155	Attic Kitchen	Manual	3/25/2026 2:47:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.152	Attic Kitchen	Manual	3/25/2026 2:47:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.159	Attic Kitchen Walk in	Manual	3/25/2026 2:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.168	Attic MP Rm West Entry	Manual	3/25/2026 2:44:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.166	Attic Music Rm	Manual	3/25/2026 2:44:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2.139	Attic Principals Office	Manual	3/25/2026 2:47:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.145	Attic Rep Rm	Manual	3/25/2026 2:44:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.146	Attic Rep Rm	Manual	3/25/2026 2:44:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.178	Attic Rm 1	Manual	3/25/2026 2:48:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.177	Attic Rm 1&2	Manual	3/25/2026 2:48:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.176	Attic Rm 2	Manual	3/25/2026 2:48:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.183	Attic Rm 3	Manual	3/25/2026 2:47:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.185	Attic Rm 4	Manual	3/25/2026 2:47:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.182	Attic Rm 5	Manual	3/25/2026 2:47:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.181	Attic Rm 6	Manual	3/25/2026 2:47:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.162	Attic Stage Strg	Manual	3/25/2026 2:44:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.144	Attic War Rm	Manual	3/25/2026 2:44:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.027	AV Rm	Manual	3/25/2026 3:11:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.270	Boys RR By Rm 9	Manual	3/25/2026 3:10:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.040	Computer Lab	Manual	3/25/2026 3:10:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.039	Computer lab	Manual	3/25/2026 3:10:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.041	Computer Lab	Manual	3/25/2026 3:10:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2.271	Custodian Strg By Rm 9	Manual	5/4/2026 9:32:41 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.076	Field Strg	Manual	3/25/2026 3:09:07 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.075	Field Strg	Manual	3/25/2026 3:11:32 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.272	Girls RR By Rm 9	Manual	3/25/2026 3:10:10 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2.058	Kitchen	Manual	3/25/2026 2:48:13 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.059	Kitchen Hall	Manual	3/25/2026 3:12:25 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.060	Kitchen Office	Manual	3/25/2026 3:12:23 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.030	Library	Manual	3/25/2026 3:09:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.029	Library	Manual	3/25/2026 3:10:31 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.032	Library	Manual	3/25/2026 3:10:33 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.031	Library	Manual	3/25/2026 3:10:34 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.028	Library	Manual	3/25/2026 3:10:35 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.025	Men's RR	Manual	3/25/2026 3:10:41 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.005	MP Elect Rm	Manual	3/25/2026 3:12:13 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.019	MP Lobby Strg	Manual	3/25/2026 3:10:54 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.046	MP Rm	Manual	3/25/2026 3:12:00 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Duct	2.150	MP Rm Chair Strg	Manual	3/25/2026 3:11:53 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.055	MP Rm Chair Strg	Manual	3/25/2026 3:12:22 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.056	MP Rm Custodian Clst	Manual	3/25/2026 3:25:57 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.057	MP Rm E Entrance	Manual	3/25/2026 3:26:14 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.074	MP Rm W Entry	Manual	3/25/2026 3:11:35 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2.151	MP Room East	Manual	3/25/2026 3:26:38 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2.169	MP Room West	Manual	3/25/2026 3:26:33 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.065	MP Stage	Manual	3/25/2026 3:26:02 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.063	MP Stage	Manual	3/25/2026 3:26:04 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.062	MP Stage	Manual	3/25/2026 3:26:09 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.066	MP Stage	Manual	3/25/2026 3:26:11 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.064	MP Stage	Manual	3/25/2026 3:26:13 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.061	MP Stage Strg	Manual	3/25/2026 3:26:07 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.069	Music Rm	Manual	3/25/2026 3:11:36 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.073	Music Rm	Manual	3/25/2026 3:11:38 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.068	Music Rm	Manual	3/25/2026 3:11:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.071	Music Rm	Manual	3/25/2026 3:11:42 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.072	Music Rm	Manual	3/25/2026 3:11:43 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.070	Music Rm	Manual	3/25/2026 3:11:49 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.067	Music Rm	Manual	3/25/2026 3:12:42 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Duct	2-160	Reading Rm Attic	Manual	3/25/2026 3:26:00 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.038	Reading Rm	Manual	3/25/2026 3:10:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.037	Reading Rm Strg	Manual	3/25/2026 3:10:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.033	Rep Rm	Manual	3/25/2026 3:10:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034	Rep Rm Clst	Manual	3/25/2026 3:10:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.088	Rm 1	Manual	3/25/2026 3:11:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.090	Rm 1	Manual	3/25/2026 3:11:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.089	Rm 1	Manual	3/25/2026 3:11:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.086	Rm 1 & 2	Manual	3/25/2026 3:12:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.091	Rm 1 RR	Manual	3/25/2026 3:12:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.087	Rm 1 Strg	Manual	3/25/2026 3:12:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.267	Rm 10	Manual	3/25/2026 3:09:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.266	Rm 10	Manual	3/25/2026 3:09:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.269	Rm 10	Manual	3/25/2026 3:09:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.268	Rm 10 Strg	Manual	3/25/2026 3:09:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.263	Rm 11	Manual	3/25/2026 3:09:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.264	Rm 11	Manual	3/25/2026 3:09:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.265	Rm 11	Manual	3/25/2026 3:09:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.262	Rm 11 Strg	Manual	3/25/2026 3:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-278	Rm 12	Manual	3/25/2026 3:09:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.279	Rm 12	Manual	3/25/2026 3:09:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-280	Rm 12	Manual	3/25/2026 3:09:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.277	Rm 12 Strg	Manual	3/25/2026 3:09:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-289	Rm 13	Manual	3/25/2026 3:09:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-291	Rm 13	Manual	3/25/2026 3:09:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-292	Rm 13	Manual	3/25/2026 3:09:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.290	Rm 13 Strg	Manual	3/25/2026 3:09:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-288	Rm 14	Manual	3/25/2026 3:09:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-288	Rm 14	Manual	3/25/2026 3:09:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-286	Rm 14	Manual	3/25/2026 2:43:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-287	Rm 14	Manual	3/25/2026 3:09:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-297	Rm 14 Strg	Manual	3/25/2026 3:09:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-281	Rm 15	Manual	3/25/2026 3:09:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-283	Rm 15	Manual	3/25/2026 3:09:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-282	Rm 15	Manual	3/25/2026 3:09:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-285	Rm 15	Manual	3/25/2026 3:09:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-295	Rm 16	Manual	3/25/2026 3:09:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-293	Rm 16	Manual	3/25/2026 3:09:26 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296	Rm 16	Manual	3/25/2026 3:09:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294	Rm 16 Strg	Manual	3/25/2026 3:09:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.051	Rm 17	Manual	3/25/2026 3:09:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.050	Rm 17	Manual	3/25/2026 3:09:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.049	Rm 17	Manual	3/25/2026 3:09:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.048	Rm 17 storage	Manual	3/25/2026 3:09:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.045	Rm 18	Manual	3/25/2026 2:43:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.046	Rm 18	Manual	3/25/2026 2:43:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.047	Rm 18	Manual	3/25/2026 2:43:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.044	Rm 18 Storage	Manual	3/25/2026 2:43:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.037	Rm 19	Manual	3/25/2026 2:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.038	Rm 19	Manual	3/25/2026 2:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.039	Rm 19	Manual	3/25/2026 3:10:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.036	Rm 19 storage	Manual	3/25/2026 2:43:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.082	Rm 2	Manual	3/25/2026 3:12:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.084	Rm 2	Manual	3/25/2026 3:12:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.083	Rm 2	Manual	3/25/2026 3:12:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.0	Rm 2 OS Strg	Manual	3/25/2026 3:09:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.081	Rm 2 RR	Manual	3/25/2026 3:12:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.085	Rm 2 Strg	Manual	3/25/2026 3:12:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.041	Rm 20	Manual	3/25/2026 2:43:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.042	Rm 20	Manual	3/25/2026 2:43:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.040	Rm 20	Manual	3/25/2026 2:43:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.043	Rm 20 storage	Manual	3/25/2026 2:43:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.034	Rm 21	Manual	3/25/2026 2:43:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.032	Rm 21	Manual	3/25/2026 2:43:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.035	Rm 21	Manual	3/25/2026 2:43:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.033	Rm 21 storage	Manual	3/25/2026 2:43:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.022	Rm 22	Manual	3/25/2026 2:43:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.023	Rm 22	Manual	3/25/2026 2:43:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.024	Rm 22	Manual	3/25/2026 2:43:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.021	Rm 22 storage	Manual	3/25/2026 2:43:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.029	Rm 23	Manual	3/25/2026 2:43:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.030	Rm 23	Manual	3/25/2026 2:43:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.028	Rm 23	Manual	3/25/2026 2:43:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.031	Rm 23 Storage	Manual	3/25/2026 2:43:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.020	Rm 24	Manual	3/25/2026 2:43:17 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.018	Rm 24	Manual	3/25/2026 3:11:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.017	Rm 24	Manual	3/25/2026 2:43:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.019	Rm 24 Strg	Manual	3/25/2026 2:43:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.007	Rm 25	Manual	3/25/2026 2:43:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.008	Rm 25	Manual	3/25/2026 2:43:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.006	Rm 25	Manual	3/25/2026 2:43:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.005	Rm 25 Strg	Manual	3/25/2026 2:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.016	Rm 26	Manual	3/25/2026 2:42:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.014	Rm 26	Manual	3/25/2026 2:42:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.013	Rm 26	Manual	3/25/2026 3:11:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.015	Rm 26 storage	Manual	3/25/2026 2:42:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.011	Rm 27	Manual	3/25/2026 2:43:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.010	Rm 27	Manual	3/25/2026 2:43:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.009	Rm 27	Manual	3/25/2026 2:43:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.012	Rm 27	Manual	3/25/2026 2:43:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.100	Rm 3	Manual	3/25/2026 3:12:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.103	Rm 3	Manual	3/25/2026 3:12:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.102	Rm 3	Manual	3/25/2026 3:12:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.101	Rm 3 Strg	Manual	3/25/2026 3:12:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.104	Rm 4	Manual	3/25/2026 3:12:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.105	Rm 4	Manual	3/25/2026 3:12:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.107	Rm 4	Manual	3/25/2026 3:12:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.106	Rm 4 Strg	Manual	3/25/2026 3:26:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.097	Rm 5	Manual	3/25/2026 3:11:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.099	Rm 5	Manual	3/25/2026 3:11:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.096	Rm 5	Manual	3/25/2026 3:11:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.098	Rm 5 Strg	Manual	3/25/2026 3:11:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.094	Rm 6	Manual	3/25/2026 3:11:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.095	Rm 6	Manual	3/25/2026 3:11:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.093	Rm 6	Manual	3/25/2026 3:11:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.092	Rm 6 Strg	Manual	3/25/2026 3:11:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.258	Rm 7	Manual	3/25/2026 3:11:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.259	Rm 7	Manual	3/25/2026 3:11:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.257	Rm 7	Manual	3/25/2026 3:11:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.260	Rm 7 Strg	Manual	3/25/2026 3:10:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.255	Rm 8	Manual	3/25/2026 3:10:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.254	Rm 8	Manual	3/25/2026 3:10:49 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.256	Rm 8	Manual	3/25/2026 3:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.253	Rm 8 Strg	Manual	3/25/2026 3:10:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.273	Rm 9	Manual	3/25/2026 3:10:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.274	Rm 9	Manual	3/25/2026 3:10:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.276	Rm 9	Manual	3/25/2026 3:10:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.275	Rm 9 Strg	Manual	3/25/2026 3:10:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.140	Soffit Bldg A South	Manual	5/4/2026 9:32:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.035	Speech Therapy	Manual	3/25/2026 3:10:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036	Speech Therapy	Manual	3/25/2026 3:10:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.025	Staff Rm	Manual	3/25/2026 3:10:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.024	Staff Rm	Manual	3/25/2026 3:10:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.026	War Rm	Manual	3/25/2026 3:10:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.154	Water Heater Outside Kitchen	Manual	5/4/2026 9:33:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.157	Waterflow Kitchen	Manual	5/4/2026 9:32:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.027	Women's RR	Manual	3/25/2026 3:11:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Skipped				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.051	MP Rm	Manual	3/25/2026 3:25:34 PM
Smoke Detector - General	2.054	MP Rm	Manual	3/25/2026 3:25:37 PM
Smoke Detector - General	2.049	MP Rm	Manual	3/25/2026 3:25:40 PM
Smoke Detector - General	2.053	MP Rm	Manual	3/25/2026 3:25:43 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.052	MP Rm	Manual	3/25/2026 3:25:46 PM
Smoke Detector - General	2.050	MP Rm	Manual	3/25/2026 3:25:49 PM
Smoke Detector - General	2.047	MP Rm	Manual	3/25/2026 3:25:51 PM
Smoke Detector - General	2.044	MP Rm	Manual	3/25/2026 3:25:54 PM
Smoke Detector - General	2.045	MP Rm	Manual	3/25/2026 3:26:16 PM
Smoke Detector - General	2.048	MP Rm	Manual	3/25/2026 3:26:19 PM
Smoke Detector - General	2.043	MP Rm	Manual	3/25/2026 3:26:23 PM
Heat Detector - Restorable Spot	2.153	Soffit Bldg A East Kitchen	Manual	5/4/2026 9:32:49 AM
Heat Detector - Restorable Spot	2.167	Soffit Bldg A North Music	Manual	5/4/2026 9:33:00 AM
Heat Detector - Restorable Spot	2.148	Soffit Bldg A West Speech	Manual	5/4/2026 9:32:52 AM
Heat Detector - Restorable Spot	2.175	Soffit Bldg B E Rm 1&2	Manual	5/4/2026 9:33:05 AM
Heat Detector - Restorable Spot	2.179	Soffit Bldg B West Rm 1&2	Manual	5/4/2026 9:33:03 AM
Heat Detector - Restorable Spot	2.180	Soffit Bldg C East Rm 3-6	Manual	5/4/2026 9:33:08 AM
Heat Detector - Restorable Spot	2.184	Soffit Bldg C East Rm 3-6	Manual	5/4/2026 9:33:12 AM
Heat Detector - Restorable Spot	2.164	Soffit Stage Front	Manual	5/4/2026 9:32:55 AM
Heat Detector - Restorable Spot	2.165	Soffit Stage Rear	Manual	5/4/2026 9:32:57 AM

## Device/Equipment details

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Panel					
	MP Room Storage FACP	Edwards	EST-3		10/19/2020
NAC Power Extender Panel					
	MP Room Storage FACP BPS-A	Edwards			10/19/2020
	MP Room Storage FACP BPS-B	Edwards			10/19/2020
	Building 11 Storage BPS-C	Edwards			10/19/2020
	Classroom 22 Storage BPS-D	Edwards			10/19/2020

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2.151	MP Room East				09/29/2019
2.143	Admin Office				09/29/2019
2.169	MP Room West				09/29/2019
2.171	Admin MP Lobby				09/29/2019
Smoke Detector - General					
2.005	MP Elect Rm				09/29/2019
2.006	Admin Principal Conf				09/29/2019
2.007	Admin Principal Office				09/29/2019
2.008	Admin Principal Clst				09/29/2019
2.009	Admin Alcove				09/29/2019
2.010	Admin Nurse RR				09/29/2019
2.011	Admin Office				09/29/2019
2.012	Admin Office				09/29/2019
2.013	Admin Nurse Rm				09/29/2019
2.014	Admin Nurse Clst				09/29/2019
2.015	Admin Program Clst				09/29/2019
2.016	Admin Program Office				09/29/2019
2.017	Admin MP Lobby				09/29/2019
2.018	Admin MP Lobby				09/29/2019
2.019	MP Lobby Strg				09/29/2019
2.020	Admin MP Hall				09/29/2019
2.021	Admin Men's RR				09/29/2019
2.022	Admin Men's RR Water Heater				09/29/2019
2.023	Admin Womens RR				09/29/2019
2.024	Staff Rm				09/29/2019
2.025	Staff Rm				09/29/2019
2.026	War Rm				09/29/2019
2.027	AV Rm				09/29/2019
2.028	Library				09/29/2019
2.029	Library				09/29/2019
2.030	Library				09/29/2019
2.031	Library				09/29/2019
2.032	Library				09/29/2019
2.033	Rep Rm				09/29/2019
2.034	Rep Rm Clst				09/29/2019
2.035	Speech Therapy				09/29/2019
2.036	Speech Therapy				09/29/2019
2.037	Reading Rm Strg				09/29/2019

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.038	Reading Rm				09/29/2019
2.039	Computer lab				09/29/2019
2.040	Computer Lab				09/29/2019
2.041	Computer Lab				09/29/2019
2.043	MP Rm				09/29/2019
2.044	MP Rm				09/29/2019
2.045	MP Rm				09/29/2019
2.046	MP Rm				09/29/2019
2.047	MP Rm				09/29/2019
2.048	MP Rm				09/29/2019
2.049	MP Rm				09/29/2019
2.050	MP Rm				09/29/2019
2.051	MP Rm				09/29/2019
2.052	MP Rm				09/29/2019
2.053	MP Rm				09/29/2019
2.054	MP Rm				09/29/2019
2.055	MP Rm Chair Strg				09/29/2019
2.056	MP Rm Custodian Clst				09/29/2019
2.057	MP Rm E Entrance				09/29/2019
2.059	Kitchen Hall				09/29/2019
2.060	Kitchen Office				09/29/2019
2.061	MP Stage Strg				09/29/2019
2.062	MP Stage				09/29/2019
2.063	MP Stage				09/29/2019
2.064	MP Stage				09/29/2019
2.065	MP Stage				09/29/2019
2.066	MP Stage				09/29/2019
2.067	Music Rm				09/29/2019
2.068	Music Rm				09/29/2019
2.069	Music Rm				09/29/2019
2.070	Music Rm				09/29/2019
2.071	Music Rm				09/29/2019
2.072	Music Rm				09/29/2019
2.073	Music Rm				09/29/2019
2.074	MP Rm W Entry				09/29/2019
2.075	Field Strg				09/29/2019
2.076	Field Strg				09/29/2019
2.0	Rm 2 OS Strg				09/29/2019
2.081	Rm 2 RR				09/29/2019
2.082	Rm 2				09/29/2019
2.083	Rm 2				09/29/2019
2.084	Rm 2				09/29/2019
2.085	Rm 2 Strg				09/29/2019
2.086	Rm 1 & 2				09/29/2019
2.087	Rm 1 Strg				09/29/2019
2.088	Rm 1				09/29/2019
2.089	Rm 1				09/29/2019
2.090	Rm 1				09/29/2019
2.091	Rm 1 RR				09/29/2019
2.092	Rm 6 Strg				09/29/2019
2.093	Rm 6				09/29/2019
2.094	Rm 6				09/29/2019

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.095	Rm 6				09/29/2019
2.096	Rm 5				09/29/2019
2.097	Rm 5				09/29/2019
2.098	Rm 5 Strg				09/29/2019
2.099	Rm 5				09/29/2019
2.100	Rm 3				09/29/2019
2.101	Rm 3 Strg				09/29/2019
2.102	Rm 3				09/29/2019
2.103	Rm 3				09/29/2019
2.104	Rm 4				09/29/2019
2.105	Rm 4				09/29/2019
2.106	Rm 4 Strg				09/29/2019
2.107	Rm 4				09/29/2019
2.253	Rm 8 Strg				09/29/2019
2.254	Rm 8				09/29/2019
2.255	Rm 8				09/29/2019
2.256	Rm 8				09/29/2019
2.257	Rm 7				09/29/2019
2.258	Rm 7				09/29/2019
2.259	Rm 7				09/29/2019
2.260	Rm 7 Strg				09/29/2019
2.262	Rm 11 Strg				09/29/2019
2.263	Rm 11				09/29/2019
2.264	Rm 11				09/29/2019
2.265	Rm 11				09/29/2019
2.266	Rm 10				09/29/2019
2.267	Rm 10				09/29/2019
2.268	Rm 10 Strg				09/29/2019
2.269	Rm 10				09/29/2019
2.270	Boys RR By Rm 9				09/29/2019
2.272	Girls RR By Rm 9				09/29/2019
2.273	Rm 9				09/29/2019
2.274	Rm 9				09/29/2019
2.275	Rm 9 Strg				09/29/2019
2.276	Rm 9				09/29/2019
2.277	Rm 12 Strg				09/29/2019
3.009	Rm 27				09/29/2019
3.012	Rm 27				09/29/2019
3.011	Rm 27				09/29/2019
3.010	Rm 27				09/29/2019
3.016	Rm 26				09/29/2019
3.013	Rm 26				09/29/2019
3.015	Rm 26 storage				09/29/2019
3.014	Rm 26				09/29/2019
3.025	Men's RR				09/29/2019
3.027	Women's RR				09/29/2019
3.028	Rm 23				09/29/2019
3.030	Rm 23				09/29/2019
3.031	Rm 23 Storage				09/29/2019
3.029	Rm 23				09/29/2019
3.032	Rm 21				09/29/2019
3.034	Rm 21				09/29/2019

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.033	Rm 21 storage				09/29/2019
3.035	Rm 21				09/29/2019
3.023	Rm 22				09/29/2019
3.021	Rm 22 storage				09/29/2019
3.022	Rm 22				09/29/2019
3.040	Rm 20				09/29/2019
3.041	Rm 20				09/29/2019
3.042	Rm 20				09/29/2019
3.043	Rm 20 storage				09/29/2019
3.039	Rm 19				09/29/2019
3.037	Rm 19				09/29/2019
3.038	Rm 19				09/29/2019
3.036	Rm 19 storage				09/29/2019
3.045	Rm 18				09/29/2019
3.046	Rm 18				09/29/2019
3.047	Rm 18				09/29/2019
3.044	Rm 18 Storage				09/29/2019
3.049	Rm 17				09/29/2019
3.051	Rm 17				09/29/2019
3.050	Rm 17				09/29/2019
3.048	Rm 17 storage				09/29/2019
2-292	Rm 13				
2-289	Rm 13				
2.290	Rm 13 Strg				
2-291	Rm 13				06/29/2021
2-280	Rm 12				
2.279	Rm 12				
2-278	Rm 12				
2-288	Rm 14				
2-288	Rm 14				
2-297	Rm 14 Strg				
2-286	Rm 14				
2-281	Rm 15				
2-283	Rm 15				
2-296	Rm 16				
2-293	Rm 16				
2-294	Rm 16 Strg				
2-295	Rm 16				
3.024	Rm 22				09/29/2019
3.008	Rm 25				
3.007	Rm 25				
3.005	Rm 25 Strg				
3.006	Rm 25				
3.017	Rm 24				
3.018	Rm 24				
3.019	Rm 24 Strg				
3.020	Rm 24				
2-285	Rm 15				
2-282	Rm 15				
2-287	Rm 14				
Heat Detector - Restorable Spot					
2.058	Kitchen				09/29/2019

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.139	Attic Principals Office				09/29/2019
2.140	Soffit Bldg A South				09/29/2019
2.141	Attic Admin Nurse				09/29/2019
2.142	Attic Admin Office				09/29/2019
2.144	Attic War Rm				09/29/2019
2.145	Attic Rep Rm				09/29/2019
2.146	Attic Rep Rm				09/29/2019
2.148	Soffit Bldg A West Speech				09/29/2019
2.152	Attic Kitchen				09/29/2019
2.153	Soffit Bldg A East Kitchen				09/29/2019
2.154	Water Heater Outside Kitchen				09/29/2019
2.155	Attic Kitchen				09/29/2019
2.159	Attic Kitchen Walk in				09/29/2019
2.162	Attic Stage Strg				09/29/2019
2.164	Soffit Stage Front				09/29/2019
2.165	Soffit Stage Rear				09/29/2019
2.166	Attic Music Rm				09/29/2019
2.167	Soffit Bldg A North Music				09/29/2019
2.168	Attic MP Rm West Entry				09/29/2019
2.179	Soffit Bldg B West Rm 1&2				09/29/2019
2.176	Attic Rm 2				09/29/2019
2.177	Attic Rm 1&2				09/29/2019
2.178	Attic Rm 1				09/29/2019
2.175	Soffit Bldg B E Rm 1&2				09/29/2019
2.180	Soffit Bldg C East Rm 3-6				09/29/2019
2.181	Attic Rm 6				09/29/2019
2.182	Attic Rm 5				09/29/2019
2.183	Attic Rm 3				09/29/2019
2.184	Soffit Bldg C East Rm 3-6				09/29/2019
2.185	Attic Rm 4				09/29/2019
2.271	Custodian Strg By Rm 9				09/29/2019
Mechanical, Electrosonic, or Pressure Waterflow Device					
2.157	Waterflow Kitchen				
Smoke Detector - Duct					
2-160	Reading Rm Attic				
2.150	MP Rm Chair Strg				