

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

GRAND OAKS ELEMMENTARY

7901 ROSSWOOD DR
CITRUS HEIGHTS, California 95621
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Monday, May 04, 2026

Test Session:17 Mar 2026 15:12 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	GRAND OAKS ELEMMENTARY	CONTACT
ADDRESS	7901 ROSSWOOD DR	PHONE
CITY/STATE	CITRUS HEIGHTS, California 95621	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	72	72(100%)	72(100%)	0(0%)
Power Supplies	10	10(100%)	9(90%)	1(10%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	174	174(100%)	174(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, May 04, 2026

ACCEPTED BY 05/04/2026

Building Representative


TESTED BY 05/04/2026
Riley Goyet
Technician

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Battery - Sealed Lead-acid	8232	Building I - I5 Headend / FACP Rm - FACP Battery Left
	Created By:	Riley Goyet
	Creation Date:	02/06/2024
	Corrective Action:	Replace 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Duracell
	Model:	DURDC12-55/FR-F
	Created By:	Riley Goyet
	Creation Date:	02/05/2025
	Corrective Action:	Replace 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Duracell
	Model:	DURDC12-55/FR-F
	Created By:	Riley Goyet
	Creation Date:	03/17/2026
	Corrective Action:	Replace 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Duracell
	Model:	DURDC12-55/FR-F

Resolved Corrective Action & Solution Summary

The following 2 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	Description
Battery - Sealed Lead-acid	8233	Building I - I5 Headend / FACP Rm - FACP Battery Right

Created By: Riley Goyet
 Creation Date: 02/05/2025
 Corrective Action: Replace 12V 55AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 05/04/2026
 Manufacturer: Duracell
 Model: DURDC12-55/FR-F

Smoke Detector - General	2.038 8180	Building F - Classroom F3
--------------------------	---------------	---------------------------

Created By: Riley Goyet
 Creation Date: 02/06/2025
 Corrective Action: Disabled on panel
 Resolution: Resolved
 Resolved By: Riley Goyet
 Resolved On: 03/17/2026
 Manufacturer: Honeywell
 Model:

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Bldg. A - Admin Attendance	Manual	3/17/2026 3:13:24 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Bldg. A - Admin Conference Room	Manual	3/17/2026 3:12:54 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Bldg. A - Admin East Exterior	Manual	3/17/2026 3:15:00 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Bldg. A - Admin Principals Office	Manual	3/17/2026 3:12:51 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Bldg. A - Admin Reception	Manual	3/17/2026 3:12:53 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Bldg. A - Admin Reception	Manual	3/17/2026 3:13:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Bldg. A - Admin Staff Restroom	Manual	3/17/2026 3:13:17 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Bldg. A - Admin Staff Restroom	Manual	3/17/2026 3:13:22 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Bldg. A - Admin Staff Work Room	Manual	3/17/2026 3:12:56 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Bldg. B - MP Bldg. B4 Custodial Office	Manual	3/17/2026 3:13:12 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Bldg. B - MP Bldg. East Exterior	Manual	3/17/2026 3:14:57 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Bldg. B - MP Bldg. Kitchen	Manual	3/17/2026 3:14:11 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Bldg. B - MP Bldg. Kitchen Staff RR	Manual	3/17/2026 3:14:06 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Visible	Bldg. B - MP Bldg. Kitchen Staff RR	Manufacturer	Manual	3/17/2026 3:13:20 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Bldg. B - MP Bldg. MP Room	Manufacturer	Manual	3/17/2026 3:14:12 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Bldg. B - MP Bldg. MP Room	Manufacturer	Manual	3/17/2026 3:14:14 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible	Bldg. B - MP Bldg. Northwest Exterior	Manufacturer	Manual	3/17/2026 3:14:54 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Bldg. B - MP Bldg. Stage	Manufacturer	Manual	3/17/2026 3:14:09 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Building C - Classroom C1	Manufacturer	Manual	3/17/2026 3:14:04 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Visible	Building C - Classroom C1 RR	Manufacturer	Manual	3/17/2026 3:13:14 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Building C - Classroom C2	Manufacturer	Manual	3/17/2026 3:14:07 PM
		Visual inspection	Honeywell	
		Functional Inspection	Passed (Manual)	
Visible	Building C - Classroom C2 RR	Manufacturer	Manual	3/17/2026 3:13:16 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible	Building C - East Exterior	Manufacturer	Manual	3/17/2026 3:14:52 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Building D - Classroom D1	Manufacturer	Manual	3/17/2026 3:13:59 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Building D - Classroom D2	Manufacturer	Manual	3/17/2026 3:14:00 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Building D - Classroom D3	Manufacturer	Manual	3/17/2026 3:13:57 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	
Audible And Visible	Building D - Classroom D4	Manufacturer	Manual	3/17/2026 3:14:03 PM
		Visual inspection	Gentex	
		Functional Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Building D - Classroom D5	Manual	3/17/2026 3:13:54 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building D - Classroom D5 RR	Manual	3/17/2026 3:13:07 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building D - Classroom D6	Manual	3/17/2026 3:13:55 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building D - Classroom D6 RR	Manual	3/17/2026 3:13:09 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building D - North Exterior	Manual	3/17/2026 3:14:35 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building D - North Exterior	Manual	3/17/2026 3:14:39 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building D - North Exterior	Manual	3/17/2026 3:14:55 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E - Classroom E1	Manual	3/17/2026 3:13:50 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E - Classroom E2	Manual	3/17/2026 3:13:52 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E - Classroom E3	Manual	3/17/2026 3:13:44 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E - Classroom E4	Manual	3/17/2026 3:13:45 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E - Classroom E5	Manual	3/17/2026 3:13:47 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E - Classroom E6	Manual	3/17/2026 3:13:48 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E - North Exterior	Manual	3/17/2026 3:14:31 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E - North Exterior	Manual	3/17/2026 3:14:34 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building E - North Exterior		Manual	3/17/2026 3:14:37 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building F - Classroom F1		Manual	3/17/2026 3:13:38 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building F - Classroom F2		Manual	3/17/2026 3:13:40 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building F - Classroom F3		Manual	3/17/2026 3:13:37 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building F - Classroom F4		Manual	3/17/2026 3:13:41 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building F - Classroom F5		Manual	3/17/2026 3:13:34 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building F - Classroom F6		Manual	3/17/2026 3:13:33 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building F - North Exterior		Manual	3/17/2026 3:14:26 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building F - North Exterior		Manual	3/17/2026 3:14:29 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building F - North Exterior		Manual	3/17/2026 3:14:32 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building G - G1 Custodial Room		Manual	3/17/2026 3:13:10 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building G - G2 Staff Restroom		Manual	3/17/2026 3:13:04 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building G - North Exterior		Manual	3/17/2026 3:14:27 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building H - Classroom H3		Manual	3/17/2026 3:13:30 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible And Visible	Building H - Classroom H4	Manufacturer	Manual	3/17/2026 3:13:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building H - Classroom H5	Manufacturer	Manual	3/17/2026 3:13:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building H - Classroom H6	Manufacturer	Manual	3/17/2026 3:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building H - Classroom H7	Manufacturer	Manual	3/17/2026 3:13:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building H - East Exterior	Manufacturer	Manual	3/17/2026 3:14:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building H - North Exterior	Manufacturer	Manual	3/17/2026 3:14:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building H - North Exterior	Manufacturer	Manual	3/17/2026 3:14:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building H - Speech H1	Manufacturer	Manual	3/17/2026 3:13:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building H - Speech H2	Manufacturer	Manual	3/17/2026 3:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building H - West Exterior	Manufacturer	Manual	3/17/2026 3:14:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building I - I1 Boys Restroom	Manufacturer	Manual	3/17/2026 3:13:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building I - I4 Girls Restroom	Manufacturer	Manual	3/17/2026 3:13:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building I - West Exterior	Manufacturer	Manual	3/17/2026 3:14:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building J - J1 Boys Restroom	Manufacturer	Manual	3/17/2026 3:12:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Building J - J4 Girls Restroom	Manual	3/17/2026 3:12:57 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building J - West Exterior	Manual	3/17/2026 3:14:16 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Bldg. A - Admin Reception	Manual	3/17/2026 3:47:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Bldg. A - Admin Reception - P.E. "A"	Manual	3/17/2026 3:47:25 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building I - I5 Headend / FACP Rm - FACP	Manual	5/4/2026 9:36:33 AM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building I - I5 Headend / FACP Rm - P.E. "C"	Manual	5/4/2026 9:36:30 AM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building I - I5 Headend / FACP Rm - P.E. "E"	Manual	5/4/2026 9:36:28 AM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building I - I5 Headend / FACP Rm - P.E. "Master"	Manual	5/4/2026 9:36:32 AM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.302 8066	Bldg. A - Admin Attendance	Manual	3/17/2026 3:47:39 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.292 8069	Bldg. A - Admin Conf. Room Closet	Manual	3/17/2026 3:47:18 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.298 8065	Bldg. A - Admin Conference Room	Manual	3/17/2026 3:47:41 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.299 8068	Bldg. A - Admin O/S Staff Restroom	Manual	3/17/2026 3:47:24 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.297	Bldg. A - Admin Office	Manual	3/17/2026 3:47:42 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.295 8063	Bldg. A - Admin Principals Office	Manual	3/17/2026 3:47:46 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.376 8062	Bldg. A - Admin Reception	Manual	3/17/2026 3:47:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.301 8067	Bldg. A - Admin Staff Restroom	Manual	3/17/2026 3:47:16 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.296 8064	Bldg. A - Admin Staff Work Room	Manual	3/17/2026 3:47:44 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.377 8093	Bldg. B - MP Bldg. Attic B4 Custodial Office	Manual	3/17/2026 3:46:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.381 8092	Bldg. B - MP Bldg. Attic Kitchen Walk In Freezer	Manual	3/17/2026 3:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.317 8076	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:29 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.315 8077	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:31 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.316 8078	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:32 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.314 8079	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:34 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.313 8080	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:35 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.311 8082	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:36 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2.312 8081	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:38 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.318 8075	Bldg. B - MP Bldg. B1 MP Room	Manual	3/17/2026 3:46:40 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.138 8073	Bldg. B - MP Bldg. B1 MP Room N.E.	Manual	3/17/2026 3:46:45 PM
		Manufacturer	FCI	
		Model	MS-2	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.139 8074	Bldg. B - MP Bldg. B1 Stage	Manual	3/17/2026 3:46:49 PM
		Manufacturer	FCI	
		Model	MS-2	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.319 8083	Bldg. B - MP Bldg. B1 Stage	Manual	3/17/2026 3:46:47 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.320 8084	Bldg. B - MP Bldg. B1 Stage	Manual	3/17/2026 3:46:48 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.310 8085	Bldg. B - MP Bldg. B1 Storage	Manual	3/17/2026 3:46:41 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.307 8088	Bldg. B - MP Bldg. B2 Kitchen	Manual	3/17/2026 3:46:27 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.309 8086	Bldg. B - MP Bldg. B2B Kitchen Food Storage	Manual	3/17/2026 3:46:43 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.306 8089	Bldg. B - MP Bldg. B2C Kitchen Staff RR	Manual	3/17/2026 3:46:24 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.305 8090	Bldg. B - MP Bldg. B2C1 Kitchen Staff RR	Manual	3/17/2026 3:46:26 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.378 8091	Bldg. B - MP Bldg. B3 Water Heater Closet	Manual	3/17/2026 3:46:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.321 8087	Bldg. B - MP Bldg. B4 Custodial Office	Manual	3/17/2026 3:46:51 PM
		Manufacturer	Honeywell	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2.379 8095	Bldg. B - MP Bldg. MP Stage East	Manual	3/17/2026 3:46:17 PM
		Manufacturer	Fenwal	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2.380 8094	Bldg. B - MP Bldg. MP Stage West	Manual	3/17/2026 3:46:18 PM
		Manufacturer	Fenwal	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.130 8216	Building - H Attic Classroom H4	Manual	3/17/2026 4:16:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.001 8097	Building C - Classroom C1	Manual	3/17/2026 3:48:15 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.003 8096	Building C - Classroom C1	Manual	3/17/2026 3:48:16 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.010 8099	Building C - Classroom C1	Manual	3/17/2026 3:48:19 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.002 8098	Building C - Classroom C1	Manual	3/17/2026 3:48:21 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.019 8100	Building C - Classroom C1 RR	Manual	3/17/2026 3:48:18 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.024 8102	Building C - Classroom C2	Manual	3/17/2026 3:48:23 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023 8103	Building C - Classroom C2	Manual	3/17/2026 3:48:24 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.021 8104	Building C - Classroom C2	Manual	3/17/2026 3:48:26 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.022 8101	Building C - Classroom C2	Manual	3/17/2026 3:48:27 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.020 8105	Building C - Classroom C2 RR	Manual	3/17/2026 3:48:35 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General		Building C Northwest Exterior	Manual	3/17/2026 3:48:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.264 8110	Building D - Classroom D1	Manual	3/17/2026 3:48:42 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.261 8107	Building D - Classroom D1	Manual	3/17/2026 3:48:44 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.262 8106	Building D - Classroom D1	Manual	3/17/2026 3:48:46 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.260 8108	Building D - Classroom D1	Manual	3/17/2026 3:48:48 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.263 8109	Building D - Classroom D1	Manual	3/17/2026 3:48:49 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.268 8113	Building D - Classroom D2	Manual	3/17/2026 3:48:51 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.269 8114	Building D - Classroom D2	Manual	3/17/2026 3:48:52 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.267 8115	Building D - Classroom D2	Manual	3/17/2026 3:48:54 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.266 8112	Building D - Classroom D2	Manual	3/17/2026 3:48:55 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.265 8111	Building D - Classroom D2	Manual	3/17/2026 3:48:57 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.273 8118	Building D - Classroom D3	Manual	3/17/2026 3:48:58 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.274 8119	Building D - Classroom D3	Manual	3/17/2026 3:49:00 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.271 8117	Building D - Classroom D3	Manual	3/17/2026 3:49:01 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.272 8120	Building D - Classroom D3	Manual	3/17/2026 3:49:03 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.270 8116	Building D - Classroom D3	Manual	3/17/2026 3:49:05 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.279 8124	Building D - Classroom D4	Manual	3/17/2026 3:48:40 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.278 8123	Building D - Classroom D4	Manual	3/17/2026 3:49:07 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.277 8125	Building D - Classroom D4	Manual	3/17/2026 3:49:08 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.276 8122	Building D - Classroom D4	Manual	3/17/2026 3:49:10 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.275 8121	Building D - Classroom D4	Manual	3/17/2026 3:49:11 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.280 8126	Building D - Classroom D5	Manual	3/17/2026 3:48:39 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.281 8127	Building D - Classroom D5	Manual	3/17/2026 3:49:14 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.282 8130	Building D - Classroom D5	Manual	3/17/2026 3:49:16 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.284 8129	Building D - Classroom D5	Manual	3/17/2026 3:49:20 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.283 8128	Building D - Classroom D5	Manual	3/17/2026 3:49:21 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.285 8131	Building D - Classroom D5 RR	Manual	3/17/2026 3:49:23 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.289 8134	Building D - Classroom D6	Manual	3/17/2026 3:49:26 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.288 8136	Building D - Classroom D6	Manual	3/17/2026 3:49:28 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.290 8135	Building D - Classroom D6	Manual	3/17/2026 3:49:30 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.287 8133	Building D - Classroom D6	Manual	3/17/2026 3:49:32 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.286 8132	Building D - Classroom D6	Manual	3/17/2026 3:49:33 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.291 8137	Building D - Classroom D6 RR	Manual	3/17/2026 3:49:25 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.070 8141	Building E - Classroom E1	Manual	3/17/2026 4:03:19 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.066 8138	Building E - Classroom E1	Manual	3/17/2026 4:03:20 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.069 8140	Building E - Classroom E1	Manual	3/17/2026 4:03:22 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.068 8142	Building E - Classroom E1	Manual	3/17/2026 4:03:23 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.067 8139	Building E - Classroom E1	Manual	3/17/2026 4:03:24 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.071 8143	Building E - Classroom E2	Manual	3/17/2026 4:01:11 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.074 8145	Building E - Classroom E2	Manual	3/17/2026 4:01:14 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.075 8146	Building E - Classroom E2	Manual	3/17/2026 4:01:16 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.072 8144	Building E - Classroom E2	Manual	3/17/2026 4:01:18 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.073 8147	Building E - Classroom E2	Manual	3/17/2026 4:01:21 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.076 8148	Building E - Classroom E3	Manual	3/17/2026 3:59:41 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.077 8149	Building E - Classroom E3	Manual	3/17/2026 3:59:44 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.078 8152	Building E - Classroom E3	Manual	3/17/2026 3:59:45 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.080 8151	Building E - Classroom E3	Manual	3/17/2026 3:59:47 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.079 8150	Building E - Classroom E3	Manual	3/17/2026 3:59:49 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.081 8153	Building E - Classroom E4	Manual	3/17/2026 3:53:46 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.082 8154	Building E - Classroom E4	Manual	3/17/2026 3:53:48 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.083 8157	Building E - Classroom E4	Manual	3/17/2026 3:53:49 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.085 8156	Building E - Classroom E4	Manual	3/17/2026 3:53:51 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.084 8155	Building E - Classroom E4	Manual	3/17/2026 3:53:52 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.086 8158	Building E - Classroom E5	Manual	3/17/2026 3:53:38 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.087 8159	Building E - Classroom E5	Manual	3/17/2026 3:53:39 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.090 8161	Building E - Classroom E5	Manual	3/17/2026 3:53:41 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.088 8162	Building E - Classroom E5	Manual	3/17/2026 3:53:43 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.089 8160	Building E - Classroom E5	Manual	3/17/2026 3:53:45 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.091 8163	Building E - Classroom E6	Manual	3/17/2026 3:53:30 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.092 8164	Building E - Classroom E6	Manual	3/17/2026 3:53:32 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.093 8167	Building E - Classroom E6	Manual	3/17/2026 3:53:33 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.095 8166	Building E - Classroom E6	Manual	3/17/2026 3:53:35 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.094 8165	Building E - Classroom E6	Manual	3/17/2026 3:53:36 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.025 8168	Building F - Classroom F1	Manual	3/17/2026 4:23:31 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.026 8169	Building F - Classroom F1	Manual	3/17/2026 4:23:33 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.029 8171	Building F - Classroom F1	Manual	3/17/2026 4:23:34 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.027 8172	Building F - Classroom F1	Manual	3/17/2026 4:23:36 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.028 8170	Building F - Classroom F1	Manual	3/17/2026 4:23:37 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.030 8173	Building F - Classroom F2	Manual	3/17/2026 4:23:00 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034 8176	Building F - Classroom F2	Manual	3/17/2026 4:23:25 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.033 8175	Building F - Classroom F2	Manual	3/17/2026 4:23:26 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.032 8177	Building F - Classroom F2	Manual	3/17/2026 4:23:28 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.031 8174	Building F - Classroom F2	Manual	3/17/2026 4:23:30 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.038 8180	Building F - Classroom F3	Manual	3/17/2026 3:51:06 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.035 8178	Building F - Classroom F3	Manual	3/17/2026 4:23:02 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.037 8182	Building F - Classroom F3	Manual	3/17/2026 4:23:04 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.039 8181	Building F - Classroom F3	Manual	3/17/2026 4:23:06 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036 8179	Building F - Classroom F3	Manual	3/17/2026 4:23:08 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.042 8187	Building F - Classroom F4	Manual	3/17/2026 4:23:09 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.043 8185	Building F - Classroom F4	Manual	3/17/2026 4:23:11 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.044 8186	Building F - Classroom F4	Manual	3/17/2026 4:23:12 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.040 8183	Building F - Classroom F4	Manual	3/17/2026 4:23:14 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.041 8184	Building F - Classroom F4	Manual	3/17/2026 4:23:16 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.047 8192	Building F - Classroom F5	Manual	3/17/2026 4:23:18 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.048 8190	Building F - Classroom F5	Manual	3/17/2026 4:23:19 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.046 8189	Building F - Classroom F5	Manual	3/17/2026 4:23:21 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.049 8191	Building F - Classroom F5	Manual	3/17/2026 4:23:23 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.045 8188	Building F - Classroom F5	Manual	3/17/2026 4:23:38 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.050 8193	Building F - Classroom F6	Manual	3/17/2026 4:23:40 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.051 8194	Building F - Classroom F6	Manual	3/17/2026 4:23:43 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.052 8197	Building F - Classroom F6	Manual	3/17/2026 4:23:44 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.053 8195	Building F - Classroom F6	Manual	3/17/2026 4:23:46 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.054 8196	Building F - Classroom F6	Manual	3/17/2026 4:23:47 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.017 8198	Building G - G1 Custodial Room	Manual	3/17/2026 4:36:40 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.018 8199	Building G - G2 Staff Restroom	Manual	3/17/2026 4:36:41 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.129 8215	Building H - Attic Classroom H3	Manual	3/17/2026 4:15:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.129 8214	Building H - Attic Classroom H3	Manual	3/17/2026 4:15:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.130 8217	Building H - Attic Classroom H4	Manual	3/17/2026 4:15:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.131 8218	Building H - Attic Classroom H5	Manual	3/17/2026 4:15:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.131 8219	Building H - Attic Classroom H5	Manual	3/17/2026 4:15:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.131 8220	Building H - Attic Classroom H5	Manual	3/17/2026 4:15:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.132 8221	Building H - Attic Classroom H6	Manual	3/17/2026 4:15:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.132 8222	Building H - Attic Classroom H6	Manual	3/17/2026 4:15:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.132 8223	Building H - Attic Classroom H6	Manual	3/17/2026 4:15:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.133 8224	Building H - Attic Classroom H7	Manual	3/17/2026 4:15:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.133 8225	Building H - Attic Classroom H7	Manual	3/17/2026 4:15:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2.128	Building H - Attic Speech H1 & H2	Manual	3/17/2026 4:15:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.128 8213	Building H - Attic Speech H1 & H2	Manual	3/17/2026 4:15:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.009 8203	Building H - Classroom H3	Manual	3/17/2026 4:15:55 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.008 8202	Building H - Classroom H3	Manual	3/17/2026 4:15:57 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.006 8205	Building H - Classroom H4	Manual	3/17/2026 4:15:52 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.007 8204	Building H - Classroom H4	Manual	3/17/2026 4:15:54 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.011 8207	Building H - Classroom H5	Manual	3/17/2026 4:15:49 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.012 8206	Building H - Classroom H5	Manual	3/17/2026 4:15:51 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.056 8208	Building H - Classroom H5 Closet	Manual	3/17/2026 4:15:48 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.013 8210	Building H - Classroom H6	Manual	3/17/2026 4:15:45 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.014 8209	Building H - Classroom H6	Manual	3/17/2026 4:15:46 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.015 8212	Building H - Classroom H7	Manual	3/17/2026 4:15:42 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.016 8211	Building H - Classroom H7	Manual	3/17/2026 4:15:43 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.005 8200	Building H - Speech H1	Manual	3/17/2026 4:15:59 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.004 8201	Building H - Speech H2	Manual	3/17/2026 4:16:00 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.293 8229	Building I - I1 Boys Restroom	Manual	3/17/2026 4:36:50 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.259 8226	Building I - I2 Staff Restroom	Manual	3/17/2026 4:36:48 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.257 8227	Building I - I3 Storage Room	Manual	3/17/2026 4:16:36 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.256 8230	Building I - I4 Girls Restroom	Manual	3/17/2026 4:36:45 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.258 8228	Building I - I5 Headend / FACP Rm	Manual	3/17/2026 4:36:43 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.254 8244	Building J - J1 Boys Restroom	Manual	3/17/2026 4:37:00 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.255 8245	Building J - J2 Custodial Closet	Manual	3/17/2026 4:36:58 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.252 8246	Building J - J3 Storage	Manual	3/17/2026 4:36:56 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.251 8247	Building J - J4 Girls Restroom	Manual	3/17/2026 4:36:53 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.253 8243	Building J - J5 Storage	Manual	3/17/2026 4:36:55 PM
		Manufacturer	Honeywell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Bldg. A - Admin Reception - P.E. "A" Battery Left	Manual	3/17/2026 3:47:27 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Duracell	
		Model	Dura12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Battery Location	Power Supply	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Bldg. A - Admin Reception - P.E. "A" Battery Right	Manual	3/17/2026 3:47:37 PM
		Manufacturer	Duracell	
		Model	Dura12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Battery Location	Power Supply	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building I - I5 Headend / FACP Rm - FACP Battery Right	Manual	5/4/2026 9:36:43 AM
		Manufacturer	Duracell	
		Model	DURDC12-55/FR-F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	55	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building I - I5 Headend / FACP Rm - P.E. "C" Battery Left	Manual	5/4/2026 9:36:52 AM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building I - I5 Headend / FACP Rm - P.E. "C" Battery Right	Manual	5/4/2026 9:36:50 AM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building I - I5 Headend / FACP Rm - P.E. "E" Battery Left	Manual	5/4/2026 9:36:44 AM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building I - I5 Headend / FACP Rm - P.E. "E" Battery Right	Manual	5/4/2026 9:36:46 AM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building I - I5 Headend / FACP Rm - P.E. "Master" Battery Left	Manual	5/4/2026 9:36:49 AM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Building I - 15 Headend / FACP Rm - P.E. "Master" Battery Right	Manual	5/4/2026 9:36:47 AM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Building I - 15 Headend / FACP Rm - FACP Battery Left	Manual	3/17/2026 4:16:57 PM
		Manufacturer	Duracell	
		Model	DURDC12-55/FR-F	
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
		Amp Hours	55	
		Nominal Voltage	12	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
010	Bldg. A - Admin East Exterior	Honeywell			
043	Bldg. B - MP Bldg. East Exterior	Gentex			
044	Bldg. B - MP Bldg. Northwest Exterior	Gentex			
064	Building C - East Exterior	Gentex			
102	Building D - North Exterior	Gentex			
103	Building D - North Exterior	Gentex			
104	Building D - North Exterior	Gentex			
144	Building E - North Exterior	Gentex			
145	Building E - North Exterior	Gentex			
146	Building E - North Exterior	Gentex			
184	Building F - North Exterior	Gentex			
185	Building F - North Exterior	Gentex			
186	Building F - North Exterior	Gentex			
196	Building G - North Exterior	Gentex			
226	Building H - West Exterior	Gentex			
227	Building H - North Exterior	Gentex			
228	Building H - North Exterior	Gentex			
229	Building H - East Exterior	Gentex			
243	Building I - West Exterior	Gentex			
255	Building J - West Exterior	Gentex			
Audible And Visible					
011	Bldg. A - Admin Staff Work Room	Gentex			
012	Bldg. A - Admin Conference Room	Gentex			
013	Bldg. A - Admin Reception	Gentex			
045	Bldg. B - MP Bldg. MP Room	Gentex			
046	Bldg. B - MP Bldg. MP Room	Gentex			
047	Bldg. B - MP Bldg. Stage	Gentex			
048	Bldg. B - MP Bldg. Kitchen	Gentex			
049	Bldg. B - MP Bldg. Kitchen Staff RR	Gentex			
065	Building C - Classroom C1	Gentex			
066	Building C - Classroom C2	Honeywell			
105	Building D - Classroom D1	Gentex			
106	Building D - Classroom D2	Gentex			
107	Building D - Classroom D3	Gentex			
108	Building D - Classroom D4	Gentex			
109	Building D - Classroom D5	Gentex			
110	Building D - Classroom D6	Gentex			
147	Building E - Classroom E1	Gentex			
148	Building E - Classroom E2	Gentex			
149	Building E - Classroom E3	Gentex			
150	Building E - Classroom E4	Gentex			
151	Building E - Classroom E5	Gentex			
152	Building E - Classroom E6	Gentex			
187	Building F - Classroom F1	Gentex			
188	Building F - Classroom F2	Gentex			
189	Building F - Classroom F3	Gentex			
190	Building F - Classroom F4	Gentex			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
191	Building F - Classroom F5	Gentex			
192	Building F - Classroom F6	Gentex			
230	Building H - Speech H2	Gentex			
231	Building H - Classroom H3	Gentex			
232	Building H - Classroom H4	Gentex			
233	Building H - Classroom H5	Gentex			
234	Building H - Classroom H6	Gentex			
235	Building H - Classroom H7	Gentex			

Visible

014	Bldg. A - Admin Principals Office	Gentex			
015	Bldg. A - Admin Attendance	Gentex			
016	Bldg. A - Admin Staff Restroom	Gentex			
017	Bldg. A - Admin Staff Restroom	Gentex			
018	Bldg. A - Admin Reception				
050	Bldg. B - MP Bldg. Kitchen Staff RR	Gentex			
051	Bldg. B - MP Bldg. B4 Custodial Office	Gentex			
067	Building C - Classroom C1 RR	Gentex			
068	Building C - Classroom C2 RR	Gentex			
111	Building D - Classroom D5 RR	Gentex			
112	Building D - Classroom D6 RR	Gentex			
197	Building G - G1 Custodial Room	Gentex			
198	Building G - G2 Staff Restroom	Gentex			
236	Building H - Speech H1	Gentex			
244	Building I - I1 Boys Restroom	Gentex			
245	Building I - I4 Girls Restroom	Gentex			
256	Building J - J1 Boys Restroom	Gentex			
257	Building J - J4 Girls Restroom	Gentex			

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
8061	Bldg. A - Admin Reception	EST			
NAC Power Extender Panel					
8070	Bldg. A - Admin Reception - P.E. "A"	Fire-Lite			
8234	Building I - I5 Headend / FACP Rm - P.E. "Master"	Fire-Lite			
8237	Building I - I5 Headend / FACP Rm - P.E. "C"	Fire-Lite			
8240	Building I - I5 Headend / FACP Rm - P.E. "E"	Fire-Lite			

Fire Alarm Panel

8231	Building I - I5 Headend / FACP Rm - FACP	EST	3		
------	--	-----	---	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2.376 8062	Bldg. A - Admin Reception	EST			
2.139 8074	Bldg. B - MP Bldg. B1 Stage	FCI	MS-2		
2.138 8073	Bldg. B - MP Bldg. B1 MP Room N.E.	FCI	MS-2		

Smoke Detector - General

2.295 8063	Bldg. A - Admin Principals Office	Honeywell			
---------------	-----------------------------------	-----------	--	--	--

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.296 8064	Bldg. A - Admin Staff Work Room	Honeywell			
2.298 8065	Bldg. A - Admin Conference Room	Honeywell			
2.302 8066	Bldg. A - Admin Attendance	Honeywell			
2.301 8067	Bldg. A - Admin Staff Restroom	Honeywell			
2.299 8068	Bldg. A - Admin O/S Staff Restroom	Honeywell			
2.318 8075	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.317 8076	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.315 8077	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.316 8078	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.314 8079	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.313 8080	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.312 8081	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.319 8083	Bldg. B - MP Bldg. B1 Stage	Honeywell			
2.320 8084	Bldg. B - MP Bldg. B1 Stage	Honeywell			
2.310 8085	Bldg. B - MP Bldg. B1 Storage	Honeywell			
2.309 8086	Bldg. B - MP Bldg. B2B Kitchen Food Storage	Honeywell			
2.321 8087	Bldg. B - MP Bldg. B4 Custodial Office	Honeywell			
2.003 8096	Building C - Classroom C1	Honeywell			
2.001 8097	Building C - Classroom C1	Honeywell			
2.002 8098	Building C - Classroom C1	Honeywell			
2.010 8099	Building C - Classroom C1	Honeywell			
2.019 8100	Building C - Classroom C1 RR	Honeywell			
2.022 8101	Building C - Classroom C2	Honeywell			
2.024 8102	Building C - Classroom C2	Honeywell			
2.023 8103	Building C - Classroom C2	Honeywell			
2.021 8104	Building C - Classroom C2	Honeywell			
2.020 8105	Building C - Classroom C2 RR	Honeywell			
063	Building C Northwest Exterior				
2.262 8106	Building D - Classroom D1	Honeywell			
2.261 8107	Building D - Classroom D1	Honeywell			
2.260 8108	Building D - Classroom D1	Honeywell			
2.263 8109	Building D - Classroom D1	Honeywell			
2.264 8110	Building D - Classroom D1	Honeywell			
2.265 8111	Building D - Classroom D2	Honeywell			
2.266 8112	Building D - Classroom D2	Honeywell			
2.268 8113	Building D - Classroom D2	Honeywell			
2.269 8114	Building D - Classroom D2	Honeywell			
2.267 8115	Building D - Classroom D2	Honeywell			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.270 8116	Building D - Classroom D3	Honeywell			
2.271 8117	Building D - Classroom D3	Honeywell			
2.273 8118	Building D - Classroom D3	Honeywell			
2.274 8119	Building D - Classroom D3	Honeywell			
2.272 8120	Building D - Classroom D3	Honeywell			
2.275 8121	Building D - Classroom D4	Honeywell			
2.276 8122	Building D - Classroom D4	Honeywell			
2.278 8123	Building D - Classroom D4	Honeywell			
2.279 8124	Building D - Classroom D4	Honeywell			
2.277 8125	Building D - Classroom D4	Honeywell			
2.280 8126	Building D - Classroom D5	Honeywell			
2.281 8127	Building D - Classroom D5	Honeywell			
2.283 8128	Building D - Classroom D5	Honeywell			
2.284 8129	Building D - Classroom D5	Honeywell			
2.282 8130	Building D - Classroom D5	Honeywell			
2.285 8131	Building D - Classroom D5 RR	Honeywell			
2.286 8132	Building D - Classroom D6	Honeywell			
2.287 8133	Building D - Classroom D6	Honeywell			
2.289 8134	Building D - Classroom D6	Honeywell			
2.290 8135	Building D - Classroom D6	Honeywell			
2.288 8136	Building D - Classroom D6	Honeywell			
2.291 8137	Building D - Classroom D6 RR	Honeywell			
2.066 8138	Building E - Classroom E1	Honeywell			
2.067 8139	Building E - Classroom E1	Honeywell			
2.069 8140	Building E - Classroom E1	Honeywell			
2.070 8141	Building E - Classroom E1	Honeywell			
2.068 8142	Building E - Classroom E1	Honeywell			
2.071 8143	Building E - Classroom E2	Honeywell			
2.072 8144	Building E - Classroom E2	Honeywell			
2.074 8145	Building E - Classroom E2	Honeywell			
2.075 8146	Building E - Classroom E2	Honeywell			
2.073 8147	Building E - Classroom E2	Honeywell			
2.076 8148	Building E - Classroom E3	Honeywell			
2.077 8149	Building E - Classroom E3	Honeywell			
2.079 8150	Building E - Classroom E3	Honeywell			
2.080 8151	Building E - Classroom E3	Honeywell			
2.078 8152	Building E - Classroom E3	Honeywell			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.081 8153	Building E - Classroom E4	Honeywell			
2.082 8154	Building E - Classroom E4	Honeywell			
2.084 8155	Building E - Classroom E4	Honeywell			
2.085 8156	Building E - Classroom E4	Honeywell			
2.083 8157	Building E - Classroom E4	Honeywell			
2.086 8158	Building E - Classroom E5	Honeywell			
2.087 8159	Building E - Classroom E5	Honeywell			
2.089 8160	Building E - Classroom E5	Honeywell			
2.090 8161	Building E - Classroom E5	Honeywell			
2.088 8162	Building E - Classroom E5	Honeywell			
2.091 8163	Building E - Classroom E6	Honeywell			
2.092 8164	Building E - Classroom E6	Honeywell			
2.094 8165	Building E - Classroom E6	Honeywell			
2.095 8166	Building E - Classroom E6	Honeywell			
2.093 8167	Building E - Classroom E6	Honeywell			
2.025 8168	Building F - Classroom F1	Honeywell			
2.026 8169	Building F - Classroom F1	Honeywell			
2.028 8170	Building F - Classroom F1	Honeywell			
2.029 8171	Building F - Classroom F1	Honeywell			
2.027 8172	Building F - Classroom F1	Honeywell			
2.030 8173	Building F - Classroom F2	Honeywell			
2.031 8174	Building F - Classroom F2	Honeywell			
2.033 8175	Building F - Classroom F2	Honeywell			
2.034 8176	Building F - Classroom F2	Honeywell			
2.032 8177	Building F - Classroom F2	Honeywell			
2.035 8178	Building F - Classroom F3	Honeywell			
2.036 8179	Building F - Classroom F3	Honeywell			
2.038 8180	Building F - Classroom F3	Honeywell			
2.039 8181	Building F - Classroom F3	Honeywell			
2.037 8182	Building F - Classroom F3	Honeywell			
2.040 8183	Building F - Classroom F4	Honeywell			
2.041 8184	Building F - Classroom F4	Honeywell			
2.043 8185	Building F - Classroom F4	Honeywell			
2.044 8186	Building F - Classroom F4	Honeywell			
2.042 8187	Building F - Classroom F4	Honeywell			
2.045 8188	Building F - Classroom F5	Honeywell			
2.046 8189	Building F - Classroom F5	Honeywell			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.048 8190	Building F - Classroom F5	Honeywell			
2.049 8191	Building F - Classroom F5	Honeywell			
2.047 8192	Building F - Classroom F5	Honeywell			
2.050 8193	Building F - Classroom F6	Honeywell			
2.051 8194	Building F - Classroom F6	Honeywell			
2.053 8195	Building F - Classroom F6	Honeywell			
2.054 8196	Building F - Classroom F6	Honeywell			
2.052 8197	Building F - Classroom F6	Honeywell			
2.005 8200	Building H - Speech H1	Honeywell			
2.004 8201	Building H - Speech H2	Honeywell			
2.008 8202	Building H - Classroom H3	Honeywell			
2.009 8203	Building H - Classroom H3	Honeywell			
2.007 8204	Building H - Classroom H4	Honeywell			
2.006 8205	Building H - Classroom H4	Honeywell			
2.012 8206	Building H - Classroom H5	Honeywell			
2.011 8207	Building H - Classroom H5	Honeywell			
2.056 8208	Building H - Classroom H5 Closet	Honeywell			
2.014 8209	Building H - Classroom H6	Honeywell			
2.013 8210	Building H - Classroom H6	Honeywell			
2.016 8211	Building H - Classroom H7	Honeywell			
2.015 8212	Building H - Classroom H7	Honeywell			
2.259 8226	Building I - I2 Staff Restroom	Honeywell			
2.257 8227	Building I - I3 Storage Room	Honeywell			
2.258 8228	Building I - I5 Headend / FACP Rm	Honeywell			
2.253 8243	Building J - J5 Storage	Honeywell			
2.311 8082	Bldg. B - MP Bldg. B1 MP Room	Honeywell			
2.297	Bldg. A - Admin Office	Honeywell			
Heat Detector - Restorable Spot					
2.292 8069	Bldg. A - Admin Conf. Room Closet	Honeywell			
2.307 8088	Bldg. B - MP Bldg. B2 Kitchen	Honeywell			
2.306 8089	Bldg. B - MP Bldg. B2C Kitchen Staff RR	Honeywell			
2.305 8090	Bldg. B - MP Bldg. B2C1 Kitchen Staff RR	Honeywell			
2.378 8091	Bldg. B - MP Bldg. B3 Water Heater Closet				
2.381 8092	Bldg. B - MP Bldg. Attic Kitchen Walk In Freezer				
2.377 8093	Bldg. B - MP Bldg. Attic B4 Custodial Office				
2.017 8198	Building G - G1 Custodial Room	Honeywell			
2.018 8199	Building G - G2 Staff Restroom	Honeywell			
2.128 8213	Building H - Attic Speech H1 & H2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.129 8214	Building H - Attic Classroom H3				
2.129 8215	Building H - Attic Classroom H3				
2.130 8216	Building - H Attic Classroom H4				
2.130 8217	Building H - Attic Classroom H4				
2.131 8218	Building H - Attic Classroom H5				
2.131 8219	Building H - Attic Classroom H5				
2.131 8220	Building H - Attic Classroom H5				
2.132 8221	Building H - Attic Classroom H6				
2.132 8222	Building H - Attic Classroom H6				
2.132 8223	Building H - Attic Classroom H6				
2.133 8224	Building H - Attic Classroom H7				
2.133 8225	Building H - Attic Classroom H7				
2.293 8229	Building I - I1 Boys Restroom	Honeywell			
2.256 8230	Building I - I4 Girls Restroom	Honeywell			
2.254 8244	Building J - J1 Boys Restroom	Honeywell			
2.255 8245	Building J - J2 Custodial Closet	Honeywell			
2.252 8246	Building J - J3 Storage	Honeywell			
2.251 8247	Building J - J4 Girls Restroom	Honeywell			
2.128	Building H - Attic Speech H1 & H2				
Smoke Detector - Duct					
2.379 8095	Bldg. B - MP Bldg. MP Stage East	Fenwal			
2.380 8094	Bldg. B - MP Bldg. MP Stage West	Fenwal			

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
8071	Bldg. A - Admin Reception - P.E. "A" Battery Left	Duracell	Dura12-8F		05/07/2017
8072	Bldg. A - Admin Reception - P.E. "A" Battery Right	Duracell	Dura12-8F		07/05/2017
8235	Building I - I5 Headend / FACP Rm - P.E. "Master" Battery Left	Duracell	Dura 12-8F		
8236	Building I - I5 Headend / FACP Rm - P.E. "Master" Battery Right	Duracell	Dura 12-8F		
8238	Building I - I5 Headend / FACP Rm - P.E. "C" Battery Left	Duracell	Dura 12-8F		
8239	Building I - I5 Headend / FACP Rm - P.E. "C" Battery Right	Duracell	Dura 12-8F		
8241	Building I - I5 Headend / FACP Rm - P.E. "E" Battery Left	Duracell	Dura 12-8F		03/29/2018
8242	Building I - I5 Headend / FACP Rm - P.E. "E" Battery Right	Duracell	Dura 12-8F		03/29/2018
8232	Building I - I5 Headend / FACP Rm - FACP Battery Left	Duracell	DURDC12-55/FR-F		05/01/2018
8233	Building I - I5 Headend / FACP Rm - FACP Battery Right	Duracell	DURDC12-55/FR-F		05/01/2018