

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

BELLA VISTA HS

8301 MADISON AVE
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, February 11, 2026

Test Session:05 Jan 2026 15:42 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	BELLA VISTA HS	CONTACT
ADDRESS	8301 MADISON AVE	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	3	3(100%)	3(100%)	0(0%)
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Fire Control Panel	15	15(100%)	15(100%)	0(0%)
Initiating Device	703	703(100%)	703(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, February 11, 2026

ACCEPTED BY 02/11/2026

Building Representative


TESTED BY 02/11/2026
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	/ 152	DESCRIPTION	Building B Electrical Room
MANUFACTURER		S/W VERSION	
MODEL		LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 2 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Heat Detector - Restorable Spot	3-269 319	Building I Room I-3
	Created By:	Riley Goyet
	Creation Date:	03/05/2024
	Corrective Action:	Comes in as smoke but is a heat
	Proposed Solution:	
	Manufacturer:	
	Model:	
Heat Detector - Restorable Spot	2-141 144	Building B Attic Attend Off B1
	Created By:	Riley Goyet
	Creation Date:	03/06/2024
	Corrective Action:	Description comes in as "Waterflow Active Heat Attic Bldg B Attn Off B1"
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Entire Campus	Manual	1/6/2026 2:46:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Entire Campus	Manual	1/6/2026 2:46:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Entire Campus	Manual	1/6/2026 2:46:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Building Admin Office	Manual	1/8/2026 8:22:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Admin Building IDF Room A1E1 BPS A	Manual	1/8/2026 8:23:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building B Electrical Room	Manual	1/8/2026 8:19:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building B Electrical Room BPS - B	Manual	1/8/2026 8:18:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building B Electrical Room BPS - C	Manual	1/8/2026 8:18:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Electrical Room D7 - BPS D	Manual	1/8/2026 8:18:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Electrical Room D7 - BPS E	Manual	1/8/2026 8:18:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building G Room G7 BPS G	Manual	1/8/2026 8:18:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building J Data Room J1C BPS F	Manual	1/8/2026 8:18:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building J Data Room J1C BPS I	Manual	1/8/2026 8:18:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building N Room N1 BPS H	Manual	1/8/2026 8:18:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building N Room N1 BPS J	Manual	1/8/2026 8:18:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Building P Large Gym P9	Manual	1/8/2026 8:19:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building Q Storage Q3A BPS K	Manual	1/8/2026 8:18:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building Q Storage Q3A BPS L	Manual	1/8/2026 8:18:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-084 056	Admin Building A10 Mechanical Room	Manual	1/5/2026 4:02:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 007	Admin Building A1C Open Office	Manual	1/5/2026 3:52:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 018	Admin Building A1L Hallway	Manual	1/5/2026 3:58:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 017	Admin Building A1L2 Storage	Manual	1/5/2026 3:57:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 019	Admin Building A1M Restroom	Manual	1/7/2026 3:30:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 021	Admin Building A1N Conference Rm	Manual	1/5/2026 4:00:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 020	Admin Building A1N Conference Rm	Manual	1/5/2026 4:00:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 023	Admin Building A1P Mech Storage	Manual	1/5/2026 4:03:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 022	Admin Building A1P Mechanical Room	Manual	1/5/2026 4:02:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-150 002	Admin Building Admin Office	Manual	1/8/2026 8:23:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-155 081	Admin Building Attic A10 Mech Rm	Manual	1/8/2026 8:23:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-156 067	Admin Building Attic Admin Bldg	Manual	1/5/2026 3:56:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 068	Admin Building Attic Room A1Q	Manual	1/8/2026 8:19:04 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 069	Admin Building Attic Room A1R	Manual	1/8/2026 8:19:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 070	Admin Building Attic Room A1S	Manual	1/8/2026 8:23:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 071	Admin Building Attic Room A1U	Manual	1/8/2026 8:19:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-209 077	Admin Building Attic Room A7	Manual	1/7/2026 5:31:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 033	Admin Building Hallway	Manual	1/5/2026 3:50:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 034	Admin Building Hallway	Manual	1/5/2026 3:52:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 031	Admin Building Hallway	Manual	1/5/2026 4:05:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 032	Admin Building Hallway	Manual	1/5/2026 4:05:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 036	Admin Building Hallway Closet	Manual	1/5/2026 4:08:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 035	Admin Building Hallway South	Manual	1/5/2026 3:54:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 037	Admin Building IDF Room	Manual	1/5/2026 3:54:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 003	Admin Building Lobby	Manual	1/5/2026 3:59:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 005	Admin Building Restroom A1B East	Manual	1/7/2026 5:31:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 061	Admin Building Room 13	Manual	1/5/2026 4:23:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 062	Admin Building Room 13A	Manual	1/5/2026 4:22:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 054	Admin Building Room A10	Manual	1/5/2026 4:20:10 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-104 055	Admin Building Room A10	Manual	1/5/2026 4:20:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-164 080	Admin Building Room A10 Soffit	Manual	1/7/2026 5:31:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 057	Admin Building Room A11	Manual	1/5/2026 4:21:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 058	Admin Building Room A11	Manual	1/5/2026 4:21:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-165 082	Admin Building Room A11 Soffit	Manual	1/7/2026 5:31:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 059	Admin Building Room A12	Manual	1/5/2026 4:22:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-166 083	Admin Building Room A13 Soffit	Manual	1/7/2026 5:31:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 060	Admin Building Room A13A	Manual	1/5/2026 4:23:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-114 066	Admin Building Room A14	Manual	1/5/2026 4:08:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-112 064	Admin Building Room A14	Manual	1/5/2026 4:24:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 063	Admin Building Room A14	Manual	1/5/2026 4:24:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-113 065	Admin Building Room A14	Manual	1/5/2026 4:25:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-167 084	Admin Building Room A14 Soffit	Manual	1/7/2026 5:31:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 004	Admin Building Room A1A	Manual	1/5/2026 3:51:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 006	Admin Building Room A1C	Manual	1/5/2026 3:52:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 008	Admin Building Room A1C Closet	Manual	1/5/2026 6:41:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-072 009	Admin Building Room A1D	Manual	1/5/2026 3:53:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 010	Admin Building Room A1E	Manual	1/5/2026 3:53:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 011	Admin Building Room A1F	Manual	1/5/2026 3:54:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 012	Admin Building Room A1G	Manual	1/5/2026 3:55:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 013	Admin Building Room A1H	Manual	1/5/2026 3:55:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 014	Admin Building Room A1J	Manual	1/5/2026 3:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 015	Admin Building Room A1K	Manual	1/5/2026 3:56:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 016	Admin Building Room A1L	Manual	1/5/2026 3:57:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 024	Admin Building Room A1Q	Manual	1/5/2026 4:04:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 025	Admin Building Room A1R	Manual	1/5/2026 4:04:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 026	Admin Building Room A1S	Manual	1/5/2026 4:05:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 027	Admin Building Room A1T	Manual	1/5/2026 4:06:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 028	Admin Building Room A1U	Manual	1/5/2026 4:07:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 038	Admin Building Room A2	Manual	1/5/2026 4:10:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 039	Admin Building Room A2	Manual	1/5/2026 4:11:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-157 072	Admin Building Room A2 Soffit	Manual	1/7/2026 5:31:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-089 040	Admin Building Room A3	Manual	1/5/2026 4:12:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 041	Admin Building Room A3	Manual	1/5/2026 4:12:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-158 073	Admin Building Room A3 Soffit	Manual	1/7/2026 5:31:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 042	Admin Building Room A4	Manual	1/5/2026 4:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 043	Admin Building Room A4	Manual	1/5/2026 4:13:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-159 074	Admin Building Room A4 Soffit	Manual	1/7/2026 5:31:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 044	Admin Building Room A5	Manual	1/5/2026 4:14:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 045	Admin Building Room A5	Manual	1/5/2026 4:14:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-160 075	Admin Building Room A5 Soffit	Manual	1/5/2026 3:56:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 047	Admin Building Room A6	Manual	1/5/2026 4:15:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 046	Admin Building Room A6	Manual	1/5/2026 4:16:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-161 076	Admin Building Room A6 Soffit	Manual	1/7/2026 5:31:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 048	Admin Building Room A7	Manual	1/5/2026 4:17:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 049	Admin Building Room A7A	Manual	1/5/2026 4:17:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 050	Admin Building Room A8	Manual	1/5/2026 4:17:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 051	Admin Building Room A8	Manual	1/5/2026 4:18:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-162 078	Admin Building Room A8 Soffit	Manual	1/7/2026 5:31:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 052	Admin Building Room A9	Manual	1/5/2026 4:19:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 053	Admin Building Room A9	Manual	1/5/2026 4:19:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-163 079	Admin Building Room A9 Soffit	Manual	1/7/2026 5:31:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 029	Admin Building VP Sec Open Office	Manual	1/5/2026 3:56:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 030	Admin Building VP Secretary Closet	Manual	1/5/2026 4:08:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 136	Building B Above FACP	Manual	1/5/2026 6:37:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 110	Building B ADA Restroom B6	Manual	1/7/2026 5:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 096	Building B Attend B1 Hall	Manual	1/5/2026 6:49:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 089	Building B Attend Office B1	Manual	1/5/2026 6:50:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 091	Building B Attend Office B1A	Manual	1/5/2026 6:52:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 092	Building B Attend Office B1B	Manual	1/5/2026 6:51:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 090	Building B Attend Office B1-B1	Manual	1/5/2026 6:51:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 093	Building B Attend Office B1C	Manual	1/5/2026 6:51:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 094	Building B Attend Office B1D	Manual	1/5/2026 6:50:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 095	Building B Attend Office B1E	Manual	1/5/2026 6:50:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-135 138	Building B Attic ADA RR B6	Manual	1/8/2026 8:23:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 144	Building B Attic Attend Off B1	Manual	1/8/2026 8:23:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 143	Building B Attic Library	Manual	1/8/2026 8:22:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 142	Building B Attic Room B3-B2 (located B2-A4)	Manual	1/8/2026 8:23:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 098	Building B B2A Lounge	Manual	1/5/2026 6:45:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 099	Building B B2A Storage	Manual	1/5/2026 6:46:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 100	Building B B2A Storage	Manual	1/5/2026 6:47:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 104	Building B B2-B1 Restroom	Manual	1/5/2026 6:48:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 139	Building B B7 Plumbing Chase	Manual	1/8/2026 8:19:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 101	Building B Conference Rm B2A1	Manual	1/5/2026 6:47:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-204 149	Building B Exterior Electrical Room	Manual	1/8/2026 8:22:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 134	Building B Girls Restroom	Manual	1/7/2026 5:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 117	Building B Library B11	Manual	1/5/2026 6:23:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 115	Building B Library B11	Manual	1/5/2026 6:24:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 118	Building B Library B11	Manual	1/5/2026 6:25:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 116	Building B Library B11	Manual	1/5/2026 6:26:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-037 120	Building B Library B11	Manual	1/5/2026 6:26:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 119	Building B Library B11	Manual	1/5/2026 6:26:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 121	Building B Library Office B11A	Manual	1/5/2026 6:24:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 133	Building B Mens Restroom	Manual	1/7/2026 3:30:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 148	Building B Mens RR Chase	Manual	1/8/2026 8:19:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 114	Building B Room B10	Manual	1/5/2026 4:25:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 113	Building B Room B10	Manual	1/5/2026 6:33:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 122	Building B Room B12	Manual	1/5/2026 6:31:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 123	Building B Room B12	Manual	1/5/2026 6:32:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 145	Building B Room B12 Chase	Manual	1/8/2026 8:23:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 124	Building B Room B13	Manual	1/5/2026 6:28:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 125	Building B Room B13	Manual	1/5/2026 6:29:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 146	Building B Room B13 Chase	Manual	1/8/2026 8:23:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 127	Building B Room B14	Manual	1/7/2026 3:30:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 126	Building B Room B14	Manual	1/7/2026 3:30:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 147	Building B Room B14 Soffit	Manual	1/8/2026 8:23:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-044 128	Building B Room B15	Manual	1/7/2026 3:30:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 129	Building B Room B15	Manual	1/7/2026 3:30:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 130	Building B Room B16	Manual	1/5/2026 6:22:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 131	Building B Room B16	Manual	1/5/2026 6:22:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 132	Building B Room B16A	Manual	1/5/2026 6:23:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 097	Building B Room B2	Manual	1/5/2026 6:42:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 103	Building B Room B2-A4 Conf Rm	Manual	1/5/2026 6:43:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 102	Building B Room B2-A4 RR	Manual	1/5/2026 6:43:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 105	Building B Room B3 Office	Manual	1/5/2026 6:42:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 106	Building B Room B4	Manual	1/5/2026 4:21:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 107	Building B Room B4	Manual	1/5/2026 6:41:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 108	Building B Room B5	Manual	1/5/2026 6:39:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 109	Building B Room B5	Manual	1/5/2026 6:39:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 141	Building B Room B5 Chase	Manual	1/8/2026 8:23:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 111	Building B Room B9	Manual	1/5/2026 6:34:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 112	Building B Room B9	Manual	1/5/2026 6:35:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-004 137	Building B Storage	Manual	1/5/2026 6:36:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 140	Building B Women's RR Plumbing Chase	Manual	1/8/2026 8:22:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 135	Building B Womens Restroom	Manual	1/7/2026 3:30:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 192	Building C Mens Restroom	Manual	1/5/2026 4:53:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 161	Building C Photo Lab C1A	Manual	1/5/2026 5:40:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 162	Building C Photo Lab C1A	Manual	1/5/2026 6:57:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 164	Building C Photo Pic C1A	Manual	1/5/2026 6:57:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 163	Building C Photo Pic C1A	Manual	1/5/2026 6:58:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 159	Building C Room C1	Manual	1/5/2026 5:42:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 157	Building C Room C1	Manual	1/5/2026 6:55:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 158	Building C Room C1	Manual	1/5/2026 6:58:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 188	Building C Room C10	Manual	1/6/2026 3:49:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 189	Building C Room C10	Manual	1/6/2026 3:49:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 187	Building C Room C10	Manual	1/6/2026 3:49:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 186	Building C Room C10	Manual	1/6/2026 3:50:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-275 191	Building C Room C10 Breakroom	Manual	1/8/2026 8:22:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-376 194	Building C Room C10 Chase	Manual	1/8/2026 8:18:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 198	Building C Room C10 Soffit	Manual	1/8/2026 8:22:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 190	Building C Room C10 Storage	Manual	1/6/2026 3:47:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 160	Building C Room C1A	Manual	1/7/2026 3:30:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 165	Building C Room C1A Foyer	Manual	1/5/2026 6:55:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 166	Building C Room C1A Storage	Manual	1/5/2026 6:56:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 167	Building C Room C1B	Manual	1/5/2026 6:59:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 168	Building C Room C2	Manual	1/5/2026 7:01:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 169	Building C Room C2	Manual	1/5/2026 7:01:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 195	Building C Room C2 Chase	Manual	1/8/2026 8:22:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 170	Building C Room C3	Manual	1/5/2026 7:02:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 171	Building C Room C3	Manual	1/5/2026 7:04:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 196	Building C Room C3 Chase	Manual	1/8/2026 8:22:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 172	Building C Room C4	Manual	1/5/2026 5:33:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 173	Building C Room C4	Manual	1/5/2026 7:05:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 197	Building C Room C4 Chase	Manual	1/8/2026 8:22:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-286 174	Building C Room C7	Manual	1/6/2026 3:41:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 175	Building C Room C7	Manual	1/6/2026 3:41:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382	Building C Room C7 Soffit	Manual	1/8/2026 8:22:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 178	Building C Room C8	Manual	1/6/2026 3:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 179	Building C Room C8	Manual	1/6/2026 3:44:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 176	Building C Room C8	Manual	1/6/2026 3:44:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 177	Building C Room C8	Manual	1/6/2026 3:44:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 181	Building C Room C8A Storage	Manual	1/6/2026 3:41:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 180	Building C Room C8A Storage	Manual	1/6/2026 3:44:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 183	Building C Room C9	Manual	1/6/2026 3:45:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 184	Building C Room C9	Manual	1/6/2026 3:46:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 185	Building C Room C9	Manual	1/6/2026 3:46:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 182	Building C Room C9	Manual	1/7/2026 5:31:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 193	Building C Womens Restroom	Manual	1/5/2026 4:55:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 219	Building D Electrical Room D7	Manual	1/5/2026 4:55:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 203	Building D Room D1	Manual	1/5/2026 4:51:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-291 204	Building D Room D1	Manual	1/5/2026 4:52:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 221	Building D Room D1 Chase	Manual	1/8/2026 8:23:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 205	Building D Room D2	Manual	1/5/2026 4:46:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 206	Building D Room D2	Manual	1/5/2026 4:48:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 208	Building D Room D2	Manual	1/7/2026 3:30:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 207	Building D Room D2	Manual	1/7/2026 3:30:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 209	Building D Room D3	Manual	1/5/2026 4:43:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 211	Building D Room D3	Manual	1/5/2026 4:43:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 212	Building D Room D3	Manual	1/5/2026 4:44:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 210	Building D Room D3	Manual	1/5/2026 4:44:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 213	Building D Room D4	Manual	1/5/2026 5:01:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 214	Building D Room D4	Manual	1/5/2026 5:02:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 222	Building D Room D4 Chase	Manual	1/8/2026 8:23:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 215	Building D Room D5	Manual	1/5/2026 4:58:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 216	Building D Room D5	Manual	1/5/2026 4:58:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 217	Building D Room D6	Manual	1/5/2026 4:57:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-303 218	Building D Room D6	Manual	1/5/2026 4:57:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 220	Building D Room D7A	Manual	1/5/2026 4:56:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-396 237	Building E Attic Room E1	Manual	1/8/2026 8:21:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-395 238	Building E Attic Room E2	Manual	1/8/2026 8:21:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-394 239	Building E Attic Room E3	Manual	1/8/2026 8:20:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-391 240	Building E Attic Room E4	Manual	1/8/2026 8:20:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-392 241	Building E Attic Room E5	Manual	1/8/2026 8:20:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-393 242	Building E Attic Room E6	Manual	1/8/2026 8:20:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 227	Building E Room E1	Manual	1/5/2026 4:26:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 228	Building E Room E1	Manual	1/5/2026 4:27:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-341 229	Building E Room E1	Manual	1/5/2026 4:28:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 230	Building E Room E2	Manual	1/5/2026 4:36:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-337 233	Building E Room E3	Manual	1/5/2026 4:37:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 231	Building E Room E3	Manual	1/5/2026 4:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336 232	Building E Room E3	Manual	1/5/2026 4:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-332 234	Building E Room E4	Manual	1/5/2026 4:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-333 235	Building E Room E5	Manual	1/5/2026 4:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 236	Building E Room E6	Manual	1/5/2026 4:41:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 265	Building F ADA Restroom F10	Manual	1/5/2026 5:10:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-361 266	Building F ADA Restroom F10	Manual	1/5/2026 7:04:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-362 264	Building F ADA RR F10 Entry	Manual	1/5/2026 5:09:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 275	Building F Attic ADA RR F10	Manual	1/8/2026 8:23:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 274	Building F Attic ADA RR F10	Manual	1/8/2026 8:23:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Non-restorable Line	2-381	Building F Attic Heat Rm F5A	Manual	1/8/2026 8:19:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 276	Building F Girls RR Chase	Manual	1/8/2026 8:22:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 267	Building F Mens Restroom	Manual	1/5/2026 5:38:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 268	Building F Mens Restroom	Manual	1/6/2026 3:51:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 248	Building F Room F1	Manual	1/5/2026 5:06:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 245	Building F Room F1	Manual	1/5/2026 5:06:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 246	Building F Room F1	Manual	1/5/2026 5:07:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 247	Building F Room F1	Manual	1/5/2026 5:07:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 249	Building F Room F1A Storage	Manual	1/5/2026 5:05:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-317 250	Building F Room F1B Storage	Manual	1/5/2026 5:04:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 251	Building F Room F2	Manual	1/5/2026 5:03:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 252	Building F Room F2	Manual	1/5/2026 5:03:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 254	Building F Room F2	Manual	1/5/2026 5:04:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 253	Building F Room F2	Manual	1/5/2026 5:04:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330 255	Building F Room F3	Manual	1/5/2026 5:14:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 256	Building F Room F3	Manual	1/5/2026 5:14:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-390 271	Building F Room F3 Soffit	Manual	1/8/2026 8:23:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328 257	Building F Room F4	Manual	1/5/2026 5:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329 258	Building F Room F4	Manual	1/5/2026 5:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-389 272	Building F Room F4 Soffit	Manual	1/8/2026 8:23:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 259	Building F Room F5	Manual	1/5/2026 5:11:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 261	Building F Room F5	Manual	1/5/2026 5:11:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-325 262	Building F Room F5	Manual	1/5/2026 5:12:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 260	Building F Room F5	Manual	1/6/2026 3:51:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 273	Building F Room F5 Soffit	Manual	1/8/2026 8:19:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-326 263	Building F Room F5A	Manual	1/6/2026 3:51:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 269	Building F Womens Restroom	Manual	1/6/2026 3:51:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 270	Building F Womens Restroom	Manual	1/6/2026 3:51:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-400 300	Building G Attic Room G7	Manual	1/8/2026 8:23:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-358 290	Building G Breakroom G4B	Manual	1/5/2026 5:23:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-357 289	Building G Conference Rm G4A	Manual	1/7/2026 3:30:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-344 296	Building G Copy Rm Storage G7A	Manual	1/8/2026 8:23:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-343 295	Building G Copy Room G7	Manual	1/5/2026 5:19:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-345 279	Building G Room G1	Manual	1/5/2026 5:18:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-346 280	Building G Room G1	Manual	1/5/2026 5:18:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-347 281	Building G Room G2	Manual	1/5/2026 5:16:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-348 282	Building G Room G2	Manual	1/5/2026 5:16:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-349 283	Building G Room G3	Manual	1/5/2026 5:15:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-350 284	Building G Room G3	Manual	1/5/2026 5:15:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-398 297	Building G Room G3 Chase	Manual	1/8/2026 8:23:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-359 287	Building G Room G4	Manual	1/5/2026 5:24:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-360 288	Building G Room G4	Manual	1/5/2026 5:25:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-356 286	Building G Room G4	Manual	1/5/2026 5:25:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-355 285	Building G Room G4	Manual	1/7/2026 3:30:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-353 291	Building G Room G5	Manual	1/5/2026 5:22:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-354 292	Building G Room G5	Manual	1/5/2026 5:22:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-399 298	Building G Room G5 Chase	Manual	1/8/2026 8:23:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-351 293	Building G Room G6	Manual	1/5/2026 5:21:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-352 294	Building G Room G6	Manual	1/5/2026 5:21:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-397 299	Building G Room G6 Chase	Manual	1/8/2026 8:23:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378 335	Building I Attic Room I-2	Manual	1/8/2026 8:22:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377 334	Building I Attic Room I-2	Manual	1/8/2026 8:22:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-380 336	Building I Attic Room I-2A	Manual	1/8/2026 8:22:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 338	Building I Attic Room I-3	Manual	1/8/2026 8:22:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-381 337	Building I Attic Room I-3	Manual	1/8/2026 8:22:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-254 305	Building I Room I-1	Manual	1/5/2026 5:42:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-252 303	Building I Room I-1	Manual	1/5/2026 5:42:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-253 304	Building I Room I-1	Manual	1/5/2026 5:43:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255 306	Building I Room I-1	Manual	1/5/2026 6:59:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376 332	Building I Room I-1 Soffit	Manual	1/8/2026 8:22:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-258 309	Building I Room I-2	Manual	1/5/2026 5:39:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-264 312	Building I Room I-2	Manual	1/5/2026 5:39:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259 310	Building I Room I-2	Manual	1/5/2026 5:40:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260 311	Building I Room I-2	Manual	1/5/2026 5:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257 308	Building I Room I-2	Manual	1/5/2026 5:40:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-256 307	Building I Room I-2	Manual	1/5/2026 5:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379 333	Building I Room I-2 Soffit	Manual	1/8/2026 8:22:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-261 313	Building I Room I-2A	Manual	1/5/2026 5:35:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262 314	Building I Room I-2A Window	Manual	1/7/2026 3:31:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267 315	Building I Room I-2A1	Manual	1/5/2026 7:06:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-263 316	Building I Room I-2A2	Manual	1/5/2026 5:36:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-269 319	Building I Room I-3	Manual	1/8/2026 8:22:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268 318	Building I Room I-3	Manual	1/5/2026 5:32:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-265 317	Building I Room I-3	Manual	1/5/2026 5:32:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270 320	Building I Room I-3	Manual	1/7/2026 3:30:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271 321	Building I Room I-3	Manual	1/7/2026 3:30:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272 322	Building I Room I-3	Manual	1/7/2026 3:30:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266 323	Building I Room I-3 Storage	Manual	1/5/2026 5:33:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279 326	Building I Room I-4	Manual	1/5/2026 5:30:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-280 327	Building I Room I-4	Manual	1/5/2026 5:30:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278 325	Building I Room I-4	Manual	1/5/2026 5:31:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-277 324	Building I Room I-4	Manual	1/5/2026 5:31:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-399 339	Building I Room I-4 Soffit	Manual	1/8/2026 8:22:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 329	Building I Room I-5	Manual	1/5/2026 5:28:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275 328	Building I Room I-5	Manual	1/5/2026 5:28:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274 331	Building I Room I-6	Manual	1/5/2026 5:26:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-273 330	Building I Room I-6	Manual	1/5/2026 5:26:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 340	Building I Room I-6 Chase	Manual	1/8/2026 8:22:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-397 341	Building I Room I-6 Soffit	Manual	1/8/2026 8:22:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-061 406	Building J Anatomy Room J10	Manual	1/6/2026 4:41:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-060 405	Building J Anatomy Room J10	Manual	1/6/2026 4:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-063 408	Building J Anatomy Room J10	Manual	1/6/2026 4:43:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-062 407	Building J Anatomy Room J10	Manual	1/6/2026 4:43:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-145 424	Building J Attic Boys RR J15	Manual	1/8/2026 8:18:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135 423	Building J Attic Data Room J1C	Manual	1/8/2026 8:23:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-065 410	Building J Biology Room J11	Manual	1/6/2026 4:47:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-066 411	Building J Biology Room J11	Manual	1/6/2026 4:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-067 412	Building J Biology Room J11	Manual	1/6/2026 4:49:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-068 413	Building J Biology Room J11	Manual	1/6/2026 4:49:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-073 417	Building J Biology Room J12	Manual	1/6/2026 4:53:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-074 418	Building J Biology Room J12	Manual	1/6/2026 4:53:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-071 415	Building J Biology Room J12	Manual	1/6/2026 4:53:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-072 416	Building J Biology Room J12	Manual	1/6/2026 4:54:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-040 369	Building J Biology Room J2	Manual	1/6/2026 3:54:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-041 370	Building J Biology Room J2	Manual	1/6/2026 3:54:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-042 371	Building J Biology Room J2	Manual	1/6/2026 3:56:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-043 377	Building J Biology Room J2	Manual	1/6/2026 3:56:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-036 373	Building J Biology Room J3	Manual	1/6/2026 3:59:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-037 374	Building J Biology Room J3	Manual	1/6/2026 3:59:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-038 375	Building J Biology Room J3	Manual	1/6/2026 4:00:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-039 376	Building J Biology Room J3	Manual	1/6/2026 4:00:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-032 381	Building J Biology Room J4	Manual	1/6/2026 4:03:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-033 382	Building J Biology Room J4	Manual	1/6/2026 4:04:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-030 379	Building J Biology Room J4	Manual	1/6/2026 4:04:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-031 380	Building J Biology Room J4	Manual	1/6/2026 4:05:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-046 421	Building J Boys Restroom J15	Manual	1/7/2026 3:31:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-050 395	Building J Chemistry Room J8	Manual	1/6/2026 4:34:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-051 396	Building J Chemistry Room J8	Manual	1/6/2026 4:35:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-052 397	Building J Chemistry Room J8	Manual	1/6/2026 4:35:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-053 398	Building J Chemistry Room J8	Manual	1/6/2026 4:35:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-058 402	Building J Chemistry Room J9	Manual	1/6/2026 4:38:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-059 403	Building J Chemistry Room J9	Manual	1/6/2026 4:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-056 400	Building J Chemistry Room J9	Manual	1/6/2026 4:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-057 401	Building J Chemistry Room J9	Manual	1/6/2026 4:39:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-075 422	Building J Custodial Closet J13	Manual	1/8/2026 8:23:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003 367	Building J Data Room J1C	Manual	1/6/2026 4:16:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018 393	Building J Drafting Room J7	Manual	1/6/2026 4:13:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-019 394	Building J Drafting Room J7	Manual	1/6/2026 4:14:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-045 366	Building J Electrical Room J1B	Manual	1/7/2026 3:31:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-023 392	Building J Engineering Rm J6	Manual	1/6/2026 4:10:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022 391	Building J Engineering Rm J6	Manual	1/6/2026 4:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021 390	Building J Engineering Rm J6	Manual	1/6/2026 4:11:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-020 389	Building J Engineering Rm J6	Manual	1/6/2026 4:12:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-048 420	Building J Girls Restroom J14	Manual	1/7/2026 3:31:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-017 360	Building J Maker Upper J1	Manual	1/5/2026 5:25:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-076 361	Building J Maker Upper J1	Manual	1/7/2026 3:30:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009 352	Building J Maker Upper J1	Manual	1/7/2026 3:30:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-079 364	Building J Maker Upper J1	Manual	1/7/2026 3:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-077 362	Building J Maker Upper J1	Manual	1/7/2026 3:30:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-008 351	Building J Maker Upper J1	Manual	1/7/2026 3:30:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 357	Building J Maker Upper J1	Manual	1/7/2026 3:31:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-007 350	Building J Maker Upper J1	Manual	1/7/2026 3:31:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012 355	Building J Maker Upper J1	Manual	1/7/2026 3:31:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 349	Building J Maker Upper J1	Manual	1/7/2026 3:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013 356	Building J Maker Upper J1	Manual	1/7/2026 3:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016 359	Building J Maker Upper J1	Manual	1/7/2026 3:31:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 354	Building J Maker Upper J1	Manual	1/7/2026 3:31:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010 353	Building J Maker Upper J1	Manual	1/7/2026 3:31:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015 358	Building J Maker Upper J1	Manual	1/7/2026 3:31:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-078 363	Building J Maker Upper J1	Manual	1/7/2026 3:31:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004 346	Building J North Entry J1	Manual	1/6/2026 4:21:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-138 429	Building J OS&Y Valve	Manual	1/8/2026 8:23:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-138	Building J OS&Y Valve	Manual	1/8/2026 8:23:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-138 430	Building J P.I.V.	Manual	1/8/2026 8:22:09 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026 384	Building J Physics Room J5	Manual	1/6/2026 4:06:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-027 385	Building J Physics Room J5	Manual	1/6/2026 4:07:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028 386	Building J Physics Room J5	Manual	1/6/2026 4:07:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-029 387	Building J Physics Room J5	Manual	1/6/2026 4:08:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-136 427	Building J Riser Room J1D	Manual	1/8/2026 8:22:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005 368	Building J Riser Room J1D	Manual	1/6/2026 4:17:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-137 428	Building J Riser Room J1D	Manual	1/8/2026 8:22:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-149 426	Building J Roof J11	Manual	1/8/2026 8:19:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-139 425	Building J Roof J6	Manual	1/8/2026 8:19:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-044 347	Building J South Entry Room J1	Manual	1/6/2026 4:01:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-049 348	Building J South Entry Room J1	Manual	1/6/2026 4:46:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-047 365	Building J Staff Room J1A	Manual	1/7/2026 3:31:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-064 409	Building J Storage Room J10A	Manual	1/6/2026 4:44:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-070 414	Building J Storage Room J11A	Manual	1/6/2026 4:50:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-069 419	Building J Storage Room J12A	Manual	1/6/2026 4:51:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-034 372	Building J Storage Room J2A	Manual	1/6/2026 3:57:17 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3-035 378	Building J Storage Room J3A	Manual	1/6/2026 3:58:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024 383	Building J Storage Room J4A	Manual	1/6/2026 4:05:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-025 388	Building J Storage Room J5A	Manual	1/6/2026 4:06:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-054 399	Building J Storage Room J8A	Manual	1/6/2026 4:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-055 404	Building J Storage Room J9A	Manual	1/6/2026 4:37:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-286 441	Building L Custodial Room	Manual	1/8/2026 8:20:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285 439	Building L Mens Restroom	Manual	1/6/2026 5:01:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283 435	Building L Room L1	Manual	1/6/2026 4:56:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284 436	Building L Room L1	Manual	1/6/2026 4:56:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385 442	Building L Room L1 Soffit	Manual	1/8/2026 8:18:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-282 438	Building L Room L2	Manual	1/6/2026 4:59:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-281 437	Building L Room L2	Manual	1/6/2026 5:00:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 443	Building L Room L2 Soffit	Manual	1/8/2026 8:18:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287 440	Building L Womens Restroom	Manual	1/6/2026 5:04:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-387 466	Building M Attic Room M2	Manual	1/8/2026 8:18:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-388 467	Building M Attic Room M2	Manual	1/8/2026 8:20:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-300 463	Building M Custodial Room	Manual	1/6/2026 5:16:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-294 464	Building M Kiln Room	Manual	1/6/2026 5:09:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-386 465	Building M Outside Kiln	Manual	1/8/2026 8:20:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-291 448	Building M Room M1	Manual	1/6/2026 5:06:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289 446	Building M Room M1	Manual	1/6/2026 5:07:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-288 445	Building M Room M1	Manual	1/6/2026 5:07:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-290 447	Building M Room M1	Manual	1/7/2026 3:31:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-293 450	Building M Room M1 N Storage	Manual	1/6/2026 5:08:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-292 449	Building M Room M1 S Storage	Manual	1/6/2026 5:06:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-296 452	Building M Room M2	Manual	1/6/2026 5:11:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-297 453	Building M Room M2	Manual	1/6/2026 5:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-299 455	Building M Room M2	Manual	1/6/2026 5:12:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-298 454	Building M Room M2	Manual	1/6/2026 5:12:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-295 451	Building M Room M2	Manual	1/7/2026 3:31:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-301 456	Building M Room M2 Office	Manual	1/6/2026 5:13:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-302 457	Building M Room M2 Storage	Manual	1/6/2026 5:14:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-305 460	Building M Room M4	Manual	1/6/2026 5:18:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-306 461	Building M Room M4	Manual	1/6/2026 5:19:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-304 459	Building M Room M4	Manual	1/6/2026 5:20:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-303 458	Building M Room M4	Manual	1/6/2026 5:20:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-307 462	Building M Room M4 Storage	Manual	1/7/2026 3:31:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-389 471	Building N Boiler Room N1	Manual	1/8/2026 8:18:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-308 469	Building N Room N1	Manual	1/6/2026 5:22:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-309 470	Building N Room N1	Manual	1/6/2026 5:22:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-312 497	Building O Annex Storage O5A	Manual	1/5/2026 5:48:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-398 518	Building O Attic Girls Locker Rm	Manual	1/8/2026 8:20:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-392 515	Building O East Entry	Manual	1/8/2026 8:18:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-348 513	Building O Girls Lock N RR	Manual	1/8/2026 8:21:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-347 512	Building O Girls Lock NW Entry	Manual	1/8/2026 8:20:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-324 509	Building O Girls Lock Off RR	Manual	1/7/2026 5:17:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-349 514	Building O Girls Lock S RR	Manual	1/8/2026 8:20:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-325 510	Building O Girls Locker Off Ice	Manual	1/7/2026 5:17:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-322 507	Building O Girls Locker Off Ice	Manual	1/7/2026 5:17:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-323 508	Building O Girls Locker Off Ice	Manual	1/7/2026 5:17:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-320 505	Building O Girls Locker Office	Manual	1/7/2026 5:18:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-410 522	Building O Girls Locker Rm E	Manual	1/8/2026 8:19:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-408 520	Building O Girls Locker Rm N	Manual	1/8/2026 8:20:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-409 521	Building O Girls Locker Rm S	Manual	1/8/2026 8:20:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-394 517	Building O Girls Locker Rm SW	Manual	1/8/2026 8:20:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-411 523	Building O Girls Locker Rm W	Manual	1/8/2026 8:19:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390 516	Building O Girls Locker Room	Manual	1/8/2026 8:21:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:17 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:18 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390	Building O Girls Locker Room	Manual	1/8/2026 8:21:20 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-311 496	Building O Girls Locker Storage	Manual	1/7/2026 5:17:50 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-310 495	Building O Girls Locker Storage	Manual	1/7/2026 5:17:51 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-354	Building O Girls Locker Toilet	Manual	1/7/2026 5:17:52 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-391 519	Building O Pool Equip O4 NE	Manual	1/8/2026 8:20:49 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-331 479	Building O Small Gym	Manual	1/7/2026 5:18:02 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-336 484	Building O Small Gym	Manual	1/7/2026 5:18:05 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-341 489	Building O Small Gym	Manual	1/7/2026 5:18:06 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-346 494	Building O Small Gym	Manual	1/7/2026 5:18:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-345 493	Building O Small Gym	Manual	1/7/2026 5:18:09 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-340 488	Building O Small Gym	Manual	1/7/2026 5:18:11 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-335 483	Building O Small Gym	Manual	1/7/2026 5:18:12 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-330 478	Building O Small Gym	Manual	1/7/2026 5:18:14 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-329 477	Building O Small Gym	Manual	1/7/2026 5:18:17 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-334 482	Building O Small Gym	Manual	1/7/2026 5:18:18 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-339 487	Building O Small Gym	Manual	1/7/2026 5:18:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-344 492	Building O Small Gym	Manual	1/7/2026 5:18:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-343 491	Building O Small Gym	Manual	1/7/2026 5:18:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-338 486	Building O Small Gym	Manual	1/7/2026 5:18:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-333 481	Building O Small Gym	Manual	1/7/2026 5:18:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-328 476	Building O Small Gym	Manual	1/7/2026 5:18:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-327 475	Building O Small Gym	Manual	1/7/2026 5:18:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-332 480	Building O Small Gym	Manual	1/7/2026 5:18:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-337 485	Building O Small Gym	Manual	1/7/2026 5:18:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-342 490	Building O Small Gym	Manual	1/7/2026 5:18:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-316 501	Building O Small Gym Annex O5	Manual	1/5/2026 5:47:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-313 498	Building O Small Gym Annex O5	Manual	1/5/2026 5:47:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-314 499	Building O Small Gym Annex O5	Manual	1/5/2026 5:47:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-315 500	Building O Small Gym Annex O5	Manual	1/5/2026 5:47:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-326 511	Building O Small Gym Boys RR	Manual	1/7/2026 5:18:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-319 504	Building O Small Gym Girls RR	Manual	1/7/2026 5:18:38 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Manual Pull Station	3-393 472	Building O Small Gym South	Manual	1/8/2026 8:18:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-396 474	Building O Small Gym Southwest	Manual	1/8/2026 8:18:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-395 473	Building O Small Gym Southwest	Manual	1/8/2026 8:18:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-321 506	Building O Small Gym Storage	Manual	1/7/2026 5:18:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-317 502	Building O South Entry	Manual	1/7/2026 3:30:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-318 503	Building O Storage	Manual	1/7/2026 5:18:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-385 608	Building P Attic Room P4A	Manual	1/8/2026 8:19:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 605	Building P Attic Snack Room	Manual	1/8/2026 8:19:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-387 613	Building P Boys Locker North	Manual	1/8/2026 8:20:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 606	Building P Boys Locker Room	Manual	1/8/2026 8:21:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:21:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:21:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:21:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:21:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:21:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:21:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:21:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379	Building P Boys Locker Room	Manual	1/8/2026 8:22:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-388 614	Building P Boys Locker South	Manual	1/8/2026 8:20:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-319 596	Building P Exercise Room	Manual	1/7/2026 3:56:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-384 528	Building P Large Gym P9	Manual	1/8/2026 8:22:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-381 527	Building P Large Gym P9	Manual	1/8/2026 8:22:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-382 611	Building P Large Gym P9	Manual	1/8/2026 8:19:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-383 612	Building P Large Gym P9	Manual	1/8/2026 8:20:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-286 563	Building P Large Gym P9	Manual	1/6/2026 3:45:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-277 554	Building P Large Gym P9	Manual	1/6/2026 5:07:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-280 557	Building P Large Gym P9	Manual	1/6/2026 5:07:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-281 558	Building P Large Gym P9	Manual	1/6/2026 5:07:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-282 559	Building P Large Gym P9	Manual	1/6/2026 5:07:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-288 565	Building P Large Gym P9	Manual	1/6/2026 5:07:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-287 564	Building P Large Gym P9	Manual	1/6/2026 5:07:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-285 562	Building P Large Gym P9	Manual	1/6/2026 5:07:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-284 561	Building P Large Gym P9	Manual	1/6/2026 5:07:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-306 583	Building P Large Gym P9	Manual	1/6/2026 5:07:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-283 560	Building P Large Gym P9	Manual	1/6/2026 5:07:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-292 569	Building P Large Gym P9	Manual	1/6/2026 5:07:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-294 571	Building P Large Gym P9	Manual	1/6/2026 5:07:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-304 581	Building P Large Gym P9	Manual	1/6/2026 5:07:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-291 568	Building P Large Gym P9	Manual	1/6/2026 5:07:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-293 570	Building P Large Gym P9	Manual	1/6/2026 5:07:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-289 566	Building P Large Gym P9	Manual	1/6/2026 5:07:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-290 567	Building P Large Gym P9	Manual	1/6/2026 5:07:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-300 577	Building P Large Gym P9	Manual	1/6/2026 5:07:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-299 576	Building P Large Gym P9	Manual	1/6/2026 5:07:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-298 575	Building P Large Gym P9	Manual	1/6/2026 5:07:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-297 574	Building P Large Gym P9	Manual	1/6/2026 5:07:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-296 573	Building P Large Gym P9	Manual	1/6/2026 5:08:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-295 572	Building P Large Gym P9	Manual	1/6/2026 5:08:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-301 578	Building P Large Gym P9	Manual	1/6/2026 5:08:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-302 579	Building P Large Gym P9	Manual	1/6/2026 5:08:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-303 580	Building P Large Gym P9	Manual	1/6/2026 5:08:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-305 582	Building P Large Gym P9	Manual	1/6/2026 5:08:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-310 587	Building P Large Gym P9	Manual	1/6/2026 5:08:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-312 589	Building P Large Gym P9	Manual	1/6/2026 5:08:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-309 586	Building P Large Gym P9	Manual	1/6/2026 5:08:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-308 585	Building P Large Gym P9	Manual	1/6/2026 5:08:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-307 584	Building P Large Gym P9	Manual	1/6/2026 5:08:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-311 588	Building P Large Gym P9	Manual	1/6/2026 5:08:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-279 556	Building P Large Gym P9	Manual	1/6/2026 5:08:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-278 555	Building P Large Gym P9	Manual	1/6/2026 5:08:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-327 604	Building P Locker North Hall	Manual	1/8/2026 8:21:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-326 545	Building P Locker North Hall	Manual	1/7/2026 3:55:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-274 551	Building P Locker Restroom	Manual	1/8/2026 8:22:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 607	Building P Locker Soffit	Manual	1/8/2026 8:20:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-268 603	Building P Locker South Hall	Manual	1/7/2026 3:56:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-376 526	Building P P1 Entry	Manual	1/8/2026 8:22:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-377 610	Building P P1 Entry	Manual	1/8/2026 8:19:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-258 535	Building P P1 Entry Hall	Manual	1/5/2026 6:56:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-261 538	Building P P1 Lobby	Manual	1/7/2026 3:55:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-260 537	Building P P1 Lobby	Manual	1/7/2026 3:56:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-259 536	Building P P1 Lobby	Manual	1/7/2026 3:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-321 598	Building P P3-B Locker Room	Manual	1/7/2026 3:56:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-322 599	Building P P3-B Locker Room	Manual	1/7/2026 3:56:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-320 597	Building P P3-B Storage	Manual	1/7/2026 3:56:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-386 609	Building P P4 Attic Weight Room	Manual	1/8/2026 8:19:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-324 601	Building P P4 Weight Room	Manual	1/7/2026 3:56:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-325 602	Building P P4 Weight Room	Manual	1/7/2026 3:56:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-315 592	Building P P7 Storage	Manual	1/7/2026 3:56:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-317 594	Building P P8 Hallway	Manual	1/7/2026 3:56:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-313 590	Building P P8 Hallway	Manual	1/7/2026 3:56:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-314 591	Building P P8 Storage	Manual	1/7/2026 3:56:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-316 593	Building P P8-B Storage	Manual	1/7/2026 3:56:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-252 529	Building P Room P1-E Storage	Manual	1/7/2026 3:56:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-271 548	Building P Room P3A	Manual	1/7/2026 3:56:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-269 546	Building P Room P3A Office	Manual	1/7/2026 3:56:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-270 547	Building P Room P3A Office	Manual	1/7/2026 3:56:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-273 550	Building P Room P3A Restroom	Manual	1/8/2026 8:21:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-272 549	Building P Room P3A Shower	Manual	1/7/2026 3:56:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-254 531	Building P S Custodial Closet	Manual	1/7/2026 3:56:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-263 540	Building P Snack P10	Manual	1/7/2026 3:55:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-262 539	Building P Snack Room	Manual	1/8/2026 8:18:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-256 533	Building P South Boys Restroom	Manual	1/7/2026 3:55:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-257 534	Building P South Girls Restroom	Manual	1/7/2026 3:55:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-253 530	Building P South Hallway	Manual	1/7/2026 3:56:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-255 532	Building P South Storage	Manual	1/7/2026 3:55:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-318 595	Building P Storage	Manual	1/7/2026 3:55:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-276 553	Building P Storage P3C	Manual	1/7/2026 3:56:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-275 552	Building P Storage P3D	Manual	1/7/2026 3:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-323 600	Building P Weight Rm Storage P4A	Manual	1/7/2026 3:56:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-264 541	Building P Wrestling P2	Manual	1/7/2026 3:56:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-267 544	Building P Wrestling P2	Manual	1/7/2026 3:56:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-265 542	Building P Wrestling P2	Manual	1/7/2026 3:56:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-266 543	Building P Wrestling P2	Manual	1/7/2026 3:56:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128	Building Q Attic Heat Cafeteria N.W.	Manual	1/8/2026 8:19:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-130 707	Building Q Attic Kitchen	Manual	1/8/2026 8:19:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-146 716	Building Q Attic Kitchen Walk-In	Manual	1/8/2026 8:18:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-134 710	Building Q Attic Room Q1B	Manual	1/8/2026 8:19:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-142 715	Building Q Attic Room Q6	Manual	1/8/2026 8:23:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-138 712	Building Q Attic Room Q7	Manual	1/8/2026 8:23:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-133 709	Building Q Attic Room Q7 Entry	Manual	1/8/2026 8:19:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-140 713	Building Q Attic Room Q8	Manual	1/8/2026 8:19:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-135 711	Building Q Attic Stage	Manual	1/8/2026 8:19:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-005 692	Building Q Boys Restroom	Manual	1/7/2026 5:19:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012 690	Building Q Boys RR Entry	Manual	1/7/2026 5:19:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-004 691	Building Q Boys RR Entry	Manual	1/7/2026 5:19:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-030 698	Building Q Cafeteria	Manual	1/8/2026 8:22:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-027 640	Building Q Cafeteria	Manual	1/7/2026 5:19:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-026 639	Building Q Cafeteria	Manual	1/7/2026 5:19:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-025 638	Building Q Cafeteria	Manual	1/7/2026 5:19:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-023 637	Building Q Cafeteria	Manual	1/7/2026 5:19:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-018 632	Building Q Cafeteria	Manual	1/7/2026 5:19:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019 633	Building Q Cafeteria	Manual	1/7/2026 5:19:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-020 634	Building Q Cafeteria	Manual	1/7/2026 5:19:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021 635	Building Q Cafeteria	Manual	1/7/2026 5:19:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022 636	Building Q Cafeteria	Manual	1/7/2026 5:19:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 631	Building Q Cafeteria	Manual	1/7/2026 5:19:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-016 630	Building Q Cafeteria	Manual	1/7/2026 5:19:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-014 628	Building Q Cafeteria	Manual	1/7/2026 5:19:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-013 627	Building Q Cafeteria	Manual	1/7/2026 5:19:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 621	Building Q Cafeteria	Manual	1/7/2026 5:19:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007 622	Building Q Cafeteria	Manual	1/7/2026 5:19:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 623	Building Q Cafeteria	Manual	1/7/2026 5:19:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011 626	Building Q Cafeteria	Manual	1/7/2026 5:20:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009 624	Building Q Cafeteria	Manual	1/7/2026 5:20:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010 625	Building Q Cafeteria	Manual	1/7/2026 5:20:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-015 629	Building Q Cafeteria	Manual	1/7/2026 5:20:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-127 620	Building Q Cafeteria Northwest	Manual	1/8/2026 8:23:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-144 718	Building Q Cafeteria Northwest	Manual	1/8/2026 8:19:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 706	Building Q Cafeteria Southwest	Manual	1/8/2026 8:19:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-126 619	Building Q Cafeteria Southwest	Manual	1/8/2026 8:19:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-143 717	Building Q Cafeteria Southwest	Manual	1/8/2026 8:19:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-029 642	Building Q Cafeteria Storage	Manual	1/7/2026 5:19:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-024 641	Building Q Cafeteria Storage	Manual	1/7/2026 5:19:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-028 693	Building Q Girls Restroom	Manual	1/5/2026 6:52:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-037 705	Building Q Kitchen	Manual	1/8/2026 8:18:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-034 702	Building Q Kitchen	Manual	1/8/2026 8:18:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-036 704	Building Q Kitchen	Manual	1/8/2026 8:18:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-035 703	Building Q Kitchen	Manual	1/8/2026 8:18:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-033 701	Building Q Kitchen	Manual	1/8/2026 8:22:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-031 699	Building Q Kitchen Office	Manual	1/8/2026 8:19:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-085 696	Building Q Kitchen Restroom	Manual	1/7/2026 5:20:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-032 700	Building Q Kitchen SE Entry	Manual	1/7/2026 5:20:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-083 694	Building Q Mens Restroom	Manual	1/7/2026 5:20:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-045 689	Building Q North Restroom	Manual	1/7/2026 5:19:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-065 660	Building Q Room Q1A	Manual	1/7/2026 5:20:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-053 661	Building Q Room Q1B	Manual	1/7/2026 5:20:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-042 667	Building Q Room Q3 North Hall	Manual	1/7/2026 5:19:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-044 669	Building Q Room Q3 Restroom	Manual	1/7/2026 5:19:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-039 664	Building Q Room Q3 Stairs	Manual	1/7/2026 5:19:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-038 663	Building Q Room Q3 Storage	Manual	1/7/2026 5:19:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-040 665	Building Q Room Q3 Storage	Manual	1/7/2026 5:19:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-041 666	Building Q Room Q3 Storage	Manual	1/7/2026 5:19:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-043 668	Building Q Room Q3 Storage	Manual	1/7/2026 5:19:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-073 672	Building Q Room Q4	Manual	1/7/2026 5:18:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-072 671	Building Q Room Q4	Manual	1/7/2026 5:18:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-071 670	Building Q Room Q4	Manual	1/7/2026 5:18:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-074 673	Building Q Room Q4	Manual	1/7/2026 5:20:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-075 674	Building Q Room Q5	Manual	1/7/2026 5:18:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-076 675	Building Q Room Q6	Manual	1/7/2026 5:18:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-139 720	Building Q Room Q7	Manual	1/8/2026 8:19:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-066 677	Building Q Room Q7	Manual	1/7/2026 5:19:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-078 681	Building Q Room Q7	Manual	1/7/2026 5:19:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-079 682	Building Q Room Q7	Manual	1/7/2026 5:19:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-067 678	Building Q Room Q7	Manual	1/7/2026 5:19:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-068 679	Building Q Room Q7	Manual	1/7/2026 5:19:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-077 680	Building Q Room Q7	Manual	1/7/2026 5:19:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	4-145 719	Building Q Room Q7 Entry	Manual	1/8/2026 8:19:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-046 676	Building Q Room Q7 Entry Hall	Manual	1/7/2026 5:19:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-069 683	Building Q Room Q7 Office	Manual	1/7/2026 5:18:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-070 684	Building Q Room Q7 Office	Manual	1/7/2026 5:18:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-087 688	Building Q Room Q8	Manual	1/5/2026 4:10:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-082 687	Building Q Room Q8	Manual	1/7/2026 5:20:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-080 685	Building Q Room Q8	Manual	1/7/2026 5:20:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-081 686	Building Q Room Q8	Manual	1/7/2026 5:20:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-131 708	Building Q Southeast Storage	Manual	1/8/2026 8:18:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-086 697	Building Q Staff Restroom	Manual	1/7/2026 5:20:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	4-136 721	Building Q Stage	Manual	1/8/2026 8:23:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-055 650	Building Q Stage	Manual	1/7/2026 5:19:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-059 654	Building Q Stage	Manual	1/7/2026 5:19:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-063 657	Building Q Stage	Manual	1/7/2026 5:20:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-058 653	Building Q Stage	Manual	1/7/2026 5:20:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-062 656	Building Q Stage	Manual	1/7/2026 5:20:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-057 652	Building Q Stage	Manual	1/7/2026 5:20:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-056 651	Building Q Stage	Manual	1/7/2026 5:20:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-061 655	Building Q Stage	Manual	1/7/2026 5:20:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-054 649	Building Q Stage	Manual	1/7/2026 5:20:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-051 647	Building Q Stage	Manual	1/7/2026 5:20:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-052 648	Building Q Stage	Manual	1/7/2026 5:20:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-050 646	Building Q Stage	Manual	1/7/2026 5:20:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-049 645	Building Q Stage	Manual	1/7/2026 5:20:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-048 644	Building Q Stage	Manual	1/7/2026 5:20:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	4-137 722	Building Q Stage	Manual	1/8/2026 8:22:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-047 643	Building Q Stage Hall	Manual	1/7/2026 5:19:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-060 658	Building Q Stage Stairs	Manual	1/7/2026 5:19:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-064 659	Building Q Stage Stairs	Manual	1/7/2026 5:20:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-003 662	Building Q Storage Q1H	Manual	1/7/2026 5:20:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-141 714	Building Q Under Stage	Manual	1/8/2026 8:19:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-084 695	Building Q Womens Restroom	Manual	1/7/2026 5:20:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	1/6/2026 2:47:03 PM
Fusible Links	Fusible Links 450 x 3		Manual	1/6/2026 2:47:00 PM
Range Hood	Hood		Manual	1/6/2026 2:47:09 PM
Range Suppression	Suppression System		Manual	1/6/2026 2:47:05 PM
Range Suppression Tank	WHDR400S Cylinder		Manual	1/6/2026 2:47:12 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
	Entire Campus				
Audible And Visible					
	Entire Campus				
Visible					
	Entire Campus				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Admin Office				
NAC Power Extender Panel					
085	Admin Building IDF Room A1E1 BPS A				
150	Building B Electrical Room BPS - B				
151	Building B Electrical Room BPS - C				
223	Building D Electrical Room D7 - BPS D				
224	Building D Electrical Room D7 - BPS E				
301	Building G Room G7 BPS G				
431	Building J Data Room J1C BPS F				
432	Building J Data Room J1C BPS I				
615	Building P Large Gym P9				
723	Building Q Storage Q3A BPS K				
724	Building Q Storage Q3A BPS L				
	Building N Room N1 BPS H				
	Building N Room N1 BPS J				

Fire Alarm Panel

152	Building B Electrical Room				
-----	----------------------------	--	--	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-150 002	Admin Building Admin Office				
3-393 472	Building O Small Gym South				
3-395 473	Building O Small Gym Southwest				
3-396 474	Building O Small Gym Southwest				
4-376 526	Building P P1 Entry				
4-381 527	Building P Large Gym P9				
4-384 528	Building P Large Gym P9				
4-126 619	Building Q Cafeteria Southwest				
4-127 620	Building Q Cafeteria Northwest				
Smoke Detector - General					
2-083 003	Admin Building Lobby				
2-058 004	Admin Building Room A1A				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-068 005	Admin Building Restroom A1B East				
2-070 006	Admin Building Room A1C				
2-071 007	Admin Building A1C Open Office				
2-069 008	Admin Building Room A1C Closet				
2-072 009	Admin Building Room A1D				
2-061 010	Admin Building Room A1E				
2-073 011	Admin Building Room A1F				
2-074 012	Admin Building Room A1G				
2-064 013	Admin Building Room A1H				
2-075 014	Admin Building Room A1J				
2-076 015	Admin Building Room A1K				
2-077 016	Admin Building Room A1L				
2-078 017	Admin Building A1L2 Storage				
2-082 018	Admin Building A1L Hallway				
2-081 019	Admin Building A1M Restroom				
2-079 020	Admin Building A1N Conference Rm				
2-080 021	Admin Building A1N Conference Rm				
2-085 022	Admin Building A1P Mechanical Room				
2-086 023	Admin Building A1P Mech Storage				
2-051 024	Admin Building Room A1Q				
2-052 025	Admin Building Room A1R				
2-054 026	Admin Building Room A1S				
2-062 027	Admin Building Room A1T				
2-056 028	Admin Building Room A1U				
2-067 029	Admin Building VP Sec Open Office				
2-065 030	Admin Building VP Secretary Closet				
2-053 031	Admin Building Hallway				
2-055 032	Admin Building Hallway				
2-057 033	Admin Building Hallway				
2-059 034	Admin Building Hallway				
2-063 035	Admin Building Hallway South				
2-066 036	Admin Building Hallway Closet				
2-060 037	Admin Building IDF Room				
2-087 038	Admin Building Room A2				
2-088 039	Admin Building Room A2				
2-089 040	Admin Building Room A3				
2-090 041	Admin Building Room A3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-091 042	Admin Building Room A4				
2-092 043	Admin Building Room A4				
2-093 044	Admin Building Room A5				
2-094 045	Admin Building Room A5				
2-095 046	Admin Building Room A6				
2-096 047	Admin Building Room A6				
2-097 048	Admin Building Room A7				
2-099 049	Admin Building Room A7A				
2-098 050	Admin Building Room A8				
2-100 051	Admin Building Room A8				
2-101 052	Admin Building Room A9				
2-102 053	Admin Building Room A9				
2-103 054	Admin Building Room A10				
2-104 055	Admin Building Room A10				
2-084 056	Admin Building A10 Mechanical Room				
2-105 057	Admin Building Room A11				
2-106 058	Admin Building Room A11				
2-110 059	Admin Building Room A12				
2-107 060	Admin Building Room A13A				
2-108 061	Admin Building Room 13				
2-109 062	Admin Building Room 13A				
2-111 063	Admin Building Room A14				
2-112 064	Admin Building Room A14				
2-113 065	Admin Building Room A14				
2-114 066	Admin Building Room A14				
2-032 089	Building B Attend Office B1				
2-029 090	Building B Attend Office B1-B1				
2-028 091	Building B Attend Office B1A				
2-030 092	Building B Attend Office B1B				
2-031 093	Building B Attend Office B1C				
2-033 094	Building B Attend Office B1D				
2-034 095	Building B Attend Office B1E				
2-035 096	Building B Attend B1 Hall				
2-011 097	Building B Room B2				
2-015 098	Building B B2A Lounge				
2-014 099	Building B B2A Storage				
2-016 100	Building B B2A Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-018 101	Building B Conference Rm B2A1				
2-012 102	Building B Room B2-A4 RR				
2-013 103	Building B Room B2-A4 Conf Rm				
2-017 104	Building B B2-B1 Restroom				
2-010 105	Building B Room B3 Office				
2-008 106	Building B Room B4				
2-009 107	Building B Room B4				
2-006 108	Building B Room B5				
2-007 109	Building B Room B5				
2-003 110	Building B ADA Restroom B6				
2-021 111	Building B Room B9				
2-022 112	Building B Room B9				
2-019 113	Building B Room B10				
2-020 114	Building B Room B10				
2-023 115	Building B Library B11				
2-024 116	Building B Library B11				
2-026 117	Building B Library B11				
2-027 118	Building B Library B11				
2-036 119	Building B Library B11				
2-037 120	Building B Library B11				
2-025 121	Building B Library Office B11A				
2-038 122	Building B Room B12				
2-039 123	Building B Room B12				
2-040 124	Building B Room B13				
2-041 125	Building B Room B13				
2-042 126	Building B Room B14				
2-043 127	Building B Room B14				
2-044 128	Building B Room B15				
2-045 129	Building B Room B15				
2-046 130	Building B Room B16				
2-047 131	Building B Room B16				
2-048 132	Building B Room B16A				
2-049 133	Building B Mens Restroom				
2-005 134	Building B Girls Restroom				
2-050 135	Building B Womens Restroom				
2-002 136	Building B Above FACP				
2-004 137	Building B Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-251 157	Building C Room C1				
2-252 158	Building C Room C1				
2-255 159	Building C Room C1				
2-253 160	Building C Room C1A				
2-258 161	Building C Photo Lab C1A				
2-259 162	Building C Photo Lab C1A				
2-260 163	Building C Photo Pic C1A				
2-261 164	Building C Photo Pic C1A				
2-256 165	Building C Room C1A Foyer				
2-257 166	Building C Room C1A Storage				
2-254 167	Building C Room C1B				
2-262 168	Building C Room C2				
2-263 169	Building C Room C2				
2-264 170	Building C Room C3				
2-265 171	Building C Room C3				
2-266 172	Building C Room C4				
2-268 173	Building C Room C4				
2-286 174	Building C Room C7				
2-287 175	Building C Room C7				
2-280 176	Building C Room C8				
2-281 177	Building C Room C8				
2-283 178	Building C Room C8				
2-284 179	Building C Room C8				
2-282 180	Building C Room C8A Storage				
2-285 181	Building C Room C8A Storage				
2-276 182	Building C Room C9				
2-277 183	Building C Room C9				
2-278 184	Building C Room C9				
2-279 185	Building C Room C9				
2-270 186	Building C Room C10				
2-271 187	Building C Room C10				
2-272 188	Building C Room C10				
2-273 189	Building C Room C10				
2-274 190	Building C Room C10 Storage				
2-267 192	Building C Mens Restroom				
2-269 193	Building C Womens Restroom				
2-290 203	Building D Room D1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-291 204	Building D Room D1				
2-292 205	Building D Room D2				
2-293 206	Building D Room D2				
2-294 207	Building D Room D2				
2-295 208	Building D Room D2				
2-296 209	Building D Room D3				
2-297 210	Building D Room D3				
2-298 211	Building D Room D3				
2-299 212	Building D Room D3				
2-306 213	Building D Room D4				
2-307 214	Building D Room D4				
2-304 215	Building D Room D5				
2-305 216	Building D Room D5				
2-301 217	Building D Room D6				
2-303 218	Building D Room D6				
2-300 219	Building D Electrical Room D7				
2-302 220	Building D Room D7A				
2-339 227	Building E Room E1				
2-340 228	Building E Room E1				
2-341 229	Building E Room E1				
2-338 230	Building E Room E2				
2-335 231	Building E Room E3				
2-336 232	Building E Room E3				
2-337 233	Building E Room E3				
2-332 234	Building E Room E4				
2-333 235	Building E Room E5				
2-334 236	Building E Room E6				
2-312 245	Building F Room F1				
2-313 246	Building F Room F1				
2-314 247	Building F Room F1				
2-315 248	Building F Room F1				
2-316 249	Building F Room F1A Storage				
2-317 250	Building F Room F1B Storage				
2-318 251	Building F Room F2				
2-319 252	Building F Room F2				
2-320 253	Building F Room F2				
2-321 254	Building F Room F2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-330 255	Building F Room F3				
2-331 256	Building F Room F3				
2-328 257	Building F Room F4				
2-329 258	Building F Room F4				
2-322 259	Building F Room F5				
2-323 260	Building F Room F5				
2-324 261	Building F Room F5				
2-325 262	Building F Room F5				
2-326 263	Building F Room F5A				
2-362 264	Building F ADA RR F10 Entry				
2-327 265	Building F ADA Restroom F10				
2-361 266	Building F ADA Restroom F10				
2-308 267	Building F Mens Restroom				
2-309 268	Building F Mens Restroom				
2-310 269	Building F Womens Restroom				
2-311 270	Building F Womens Restroom				
2-345 279	Building G Room G1				
2-346 280	Building G Room G1				
2-347 281	Building G Room G2				
2-348 282	Building G Room G2				
2-349 283	Building G Room G3				
2-350 284	Building G Room G3				
2-355 285	Building G Room G4				
2-356 286	Building G Room G4				
2-359 287	Building G Room G4				
2-360 288	Building G Room G4				
2-357 289	Building G Conference Rm G4A				
2-358 290	Building G Breakroom G4B				
2-353 291	Building G Room G5				
2-354 292	Building G Room G5				
2-351 293	Building G Room G6				
2-352 294	Building G Room G6				
2-343 295	Building G Copy Room G7				
3-252 303	Building I Room I-1				
3-253 304	Building I Room I-1				
3-254 305	Building I Room I-1				
3-255 306	Building I Room I-1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-256 307	Building I Room I-2				
3-257 308	Building I Room I-2				
3-258 309	Building I Room I-2				
3-259 310	Building I Room I-2				
3-260 311	Building I Room I-2				
3-264 312	Building I Room I-2				
3-261 313	Building I Room I-2A				
3-262 314	Building I Room I-2A Window				
3-267 315	Building I Room I-2A1				
3-263 316	Building I Room I-2A2				
3-265 317	Building I Room I-3				
3-268 318	Building I Room I-3				
3-270 320	Building I Room I-3				
3-271 321	Building I Room I-3				
3-272 322	Building I Room I-3				
3-266 323	Building I Room I-3 Storage				
3-277 324	Building I Room I-4				
3-278 325	Building I Room I-4				
3-279 326	Building I Room I-4				
3-280 327	Building I Room I-4				
3-275 328	Building I Room I-5				
3-276 329	Building I Room I-5				
3-273 330	Building I Room I-6				
3-274 331	Building I Room I-6				
3-004 346	Building J North Entry J1				
3-044 347	Building J South Entry Room J1				
3-049 348	Building J South Entry Room J1				
3-006 349	Building J Maker Upper J1				
3-007 350	Building J Maker Upper J1				
3-008 351	Building J Maker Upper J1				
3-009 352	Building J Maker Upper J1				
3-010 353	Building J Maker Upper J1				
3-011 354	Building J Maker Upper J1				
3-012 355	Building J Maker Upper J1				
3-013 356	Building J Maker Upper J1				
3-014 357	Building J Maker Upper J1				
3-015 358	Building J Maker Upper J1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-016 359	Building J Maker Upper J1				
3-017 360	Building J Maker Upper J1				
3-076 361	Building J Maker Upper J1				
3-077 362	Building J Maker Upper J1				
3-078 363	Building J Maker Upper J1				
3-079 364	Building J Maker Upper J1				
3-047 365	Building J Staff Room J1A				
3-045 366	Building J Electrical Room J1B				
3-003 367	Building J Data Room J1C				
3-005 368	Building J Riser Room J1D				
3-040 369	Building J Biology Room J2				
3-041 370	Building J Biology Room J2				
3-042 371	Building J Biology Room J2				
3-034 372	Building J Storage Room J2A				
3-036 373	Building J Biology Room J3				
3-037 374	Building J Biology Room J3				
3-038 375	Building J Biology Room J3				
3-039 376	Building J Biology Room J3				
3-043 377	Building J Biology Room J2				
3-035 378	Building J Storage Room J3A				
3-030 379	Building J Biology Room J4				
3-031 380	Building J Biology Room J4				
3-032 381	Building J Biology Room J4				
3-033 382	Building J Biology Room J4				
3-024 383	Building J Storage Room J4A				
3-026 384	Building J Physics Room J5				
3-027 385	Building J Physics Room J5				
3-028 386	Building J Physics Room J5				
3-029 387	Building J Physics Room J5				
3-025 388	Building J Storage Room J5A				
3-020 389	Building J Engineering Rm J6				
3-021 390	Building J Engineering Rm J6				
3-022 391	Building J Engineering Rm J6				
3-023 392	Building J Engineering Rm J6				
3-018 393	Building J Drafting Room J7				
3-019 394	Building J Drafting Room J7				
3-050 395	Building J Chemistry Room J8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-051 396	Building J Chemistry Room J8				
3-052 397	Building J Chemistry Room J8				
3-053 398	Building J Chemistry Room J8				
3-054 399	Building J Storage Room J8A				
3-056 400	Building J Chemistry Room J9				
3-057 401	Building J Chemistry Room J9				
3-058 402	Building J Chemistry Room J9				
3-059 403	Building J Chemistry Room J9				
3-055 404	Building J Storage Room J9A				
3-060 405	Building J Anatomy Room J10				
3-061 406	Building J Anatomy Room J10				
3-062 407	Building J Anatomy Room J10				
3-063 408	Building J Anatomy Room J10				
3-064 409	Building J Storage Room J10A				
3-065 410	Building J Biology Room J11				
3-066 411	Building J Biology Room J11				
3-067 412	Building J Biology Room J11				
3-068 413	Building J Biology Room J11				
3-070 414	Building J Storage Room J11A				
3-071 415	Building J Biology Room J12				
3-072 416	Building J Biology Room J12				
3-073 417	Building J Biology Room J12				
3-074 418	Building J Biology Room J12				
3-069 419	Building J Storage Room J12A				
3-048 420	Building J Girls Restroom J14				
3-046 421	Building J Boys Restroom J15				
3-283 435	Building L Room L1				
3-284 436	Building L Room L1				
3-281 437	Building L Room L2				
3-282 438	Building L Room L2				
3-285 439	Building L Mens Restroom				
3-287 440	Building L Womens Restroom				
3-288 445	Building M Room M1				
3-289 446	Building M Room M1				
3-290 447	Building M Room M1				
3-291 448	Building M Room M1				
3-292 449	Building M Room M1 S Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-293 450	Building M Room M1 N Storage				
3-295 451	Building M Room M2				
3-296 452	Building M Room M2				
3-297 453	Building M Room M2				
3-298 454	Building M Room M2				
3-299 455	Building M Room M2				
3-301 456	Building M Room M2 Office				
3-302 457	Building M Room M2 Storage				
3-303 458	Building M Room M4				
3-304 459	Building M Room M4				
3-305 460	Building M Room M4				
3-306 461	Building M Room M4				
3-307 462	Building M Room M4 Storage				
3-300 463	Building M Custodial Room				
3-294 464	Building M Kiln Room				
3-308 469	Building N Room N1				
3-309 470	Building N Room N1				
3-327 475	Building O Small Gym				
3-328 476	Building O Small Gym				
3-329 477	Building O Small Gym				
3-330 478	Building O Small Gym				
3-331 479	Building O Small Gym				
3-332 480	Building O Small Gym				
3-333 481	Building O Small Gym				
3-334 482	Building O Small Gym				
3-335 483	Building O Small Gym				
3-336 484	Building O Small Gym				
3-337 485	Building O Small Gym				
3-338 486	Building O Small Gym				
3-339 487	Building O Small Gym				
3-340 488	Building O Small Gym				
3-341 489	Building O Small Gym				
3-342 490	Building O Small Gym				
3-343 491	Building O Small Gym				
3-344 492	Building O Small Gym				
3-345 493	Building O Small Gym				
3-346 494	Building O Small Gym				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-310 495	Building O Girls Locker Storage				
3-311 496	Building O Girls Locker Storage				
3-312 497	Building O Annex Storage O5A				
3-313 498	Building O Small Gym Annex O5				
3-314 499	Building O Small Gym Annex O5				
3-315 500	Building O Small Gym Annex O5				
3-316 501	Building O Small Gym Annex O5				
3-317 502	Building O South Entry				
3-318 503	Building O Storage				
3-319 504	Building O Small Gym Girls RR				
3-320 505	Building O Girls Locker Office				
3-321 506	Building O Small Gym Storage				
3-322 507	Building O Girls Locker Off Ice				
3-323 508	Building O Girls Locker Off Ice				
3-324 509	Building O Girls Lock Off RR				
3-325 510	Building O Girls Locker Off Ice				
3-326 511	Building O Small Gym Boys RR				
4-252 529	Building P Room P1-E Storage				
4-253 530	Building P South Hallway				
4-254 531	Building P S Custodial Closet				
4-255 532	Building P South Storage				
4-256 533	Building P South Boys Restroom				
4-257 534	Building P South Girls Restroom				
4-258 535	Building P P1 Entry Hall				
4-259 536	Building P P1 Lobby				
4-260 537	Building P P1 Lobby				
4-261 538	Building P P1 Lobby				
4-263 540	Building P Snack P10				
4-264 541	Building P Wrestling P2				
4-265 542	Building P Wrestling P2				
4-266 543	Building P Wrestling P2				
4-267 544	Building P Wrestling P2				
4-326 545	Building P Locker North Hall				
4-269 546	Building P Room P3A Office				
4-270 547	Building P Room P3A Office				
4-271 548	Building P Room P3A				
4-272 549	Building P Room P3A Shower				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-275 552	Building P Storage P3D				
4-276 553	Building P Storage P3C				
4-277 554	Building P Large Gym P9				
4-278 555	Building P Large Gym P9				
4-279 556	Building P Large Gym P9				
4-280 557	Building P Large Gym P9				
4-281 558	Building P Large Gym P9				
4-282 559	Building P Large Gym P9				
4-283 560	Building P Large Gym P9				
4-284 561	Building P Large Gym P9				
4-285 562	Building P Large Gym P9				
4-286 563	Building P Large Gym P9				
4-287 564	Building P Large Gym P9				
4-288 565	Building P Large Gym P9				
4-289 566	Building P Large Gym P9				
4-290 567	Building P Large Gym P9				
4-291 568	Building P Large Gym P9				
4-292 569	Building P Large Gym P9				
4-293 570	Building P Large Gym P9				
4-294 571	Building P Large Gym P9				
4-295 572	Building P Large Gym P9				
4-296 573	Building P Large Gym P9				
4-297 574	Building P Large Gym P9				
4-298 575	Building P Large Gym P9				
4-299 576	Building P Large Gym P9				
4-300 577	Building P Large Gym P9				
4-301 578	Building P Large Gym P9				
4-302 579	Building P Large Gym P9				
4-303 580	Building P Large Gym P9				
4-304 581	Building P Large Gym P9				
4-305 582	Building P Large Gym P9				
4-306 583	Building P Large Gym P9				
4-307 584	Building P Large Gym P9				
4-308 585	Building P Large Gym P9				
4-309 586	Building P Large Gym P9				
4-310 587	Building P Large Gym P9				
4-311 588	Building P Large Gym P9				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-312 589	Building P Large Gym P9				
4-313 590	Building P P8 Hallway				
4-314 591	Building P P8 Storage				
4-315 592	Building P P7 Storage				
4-316 593	Building P P8-B Storage				
4-317 594	Building P P8 Hallway				
4-318 595	Building P Storage				
4-319 596	Building P Exercise Room				
4-320 597	Building P P3-B Storage				
4-321 598	Building P P3-B Locker Room				
4-322 599	Building P P3-B Locker Room				
4-323 600	Building P Weight Rm Storage P4A				
4-324 601	Building P P4 Weight Room				
4-325 602	Building P P4 Weight Room				
4-268 603	Building P Locker South Hall				
4-006 621	Building Q Cafeteria				
4-007 622	Building Q Cafeteria				
4-008 623	Building Q Cafeteria				
4-009 624	Building Q Cafeteria				
4-010 625	Building Q Cafeteria				
4-011 626	Building Q Cafeteria				
4-013 627	Building Q Cafeteria				
4-014 628	Building Q Cafeteria				
4-015 629	Building Q Cafeteria				
4-016 630	Building Q Cafeteria				
4-017 631	Building Q Cafeteria				
4-018 632	Building Q Cafeteria				
4-019 633	Building Q Cafeteria				
4-020 634	Building Q Cafeteria				
4-021 635	Building Q Cafeteria				
4-022 636	Building Q Cafeteria				
4-023 637	Building Q Cafeteria				
4-025 638	Building Q Cafeteria				
4-026 639	Building Q Cafeteria				
4-027 640	Building Q Cafeteria				
4-024 641	Building Q Cafeteria Storage				
4-029 642	Building Q Cafeteria Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-047 643	Building Q Stage Hall				
4-048 644	Building Q Stage				
4-049 645	Building Q Stage				
4-050 646	Building Q Stage				
4-051 647	Building Q Stage				
4-052 648	Building Q Stage				
4-054 649	Building Q Stage				
4-055 650	Building Q Stage				
4-056 651	Building Q Stage				
4-057 652	Building Q Stage				
4-058 653	Building Q Stage				
4-059 654	Building Q Stage				
4-061 655	Building Q Stage				
4-062 656	Building Q Stage				
4-063 657	Building Q Stage				
4-060 658	Building Q Stage Stairs				
4-064 659	Building Q Stage Stairs				
4-065 660	Building Q Room Q1A				
4-053 661	Building Q Room Q1B				
4-003 662	Building Q Storage Q1H				
4-038 663	Building Q Room Q3 Storage				
4-039 664	Building Q Room Q3 Stairs				
4-040 665	Building Q Room Q3 Storage				
4-041 666	Building Q Room Q3 Storage				
4-042 667	Building Q Room Q3 North Hall				
4-043 668	Building Q Room Q3 Storage				
4-044 669	Building Q Room Q3 Restroom				
4-071 670	Building Q Room Q4				
4-072 671	Building Q Room Q4				
4-073 672	Building Q Room Q4				
4-074 673	Building Q Room Q4				
4-075 674	Building Q Room Q5				
4-076 675	Building Q Room Q6				
4-046 676	Building Q Room Q7 Entry Hall				
4-066 677	Building Q Room Q7				
4-067 678	Building Q Room Q7				
4-068 679	Building Q Room Q7				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-077 680	Building Q Room Q7				
4-078 681	Building Q Room Q7				
4-079 682	Building Q Room Q7				
4-069 683	Building Q Room Q7 Office				
4-070 684	Building Q Room Q7 Office				
4-080 685	Building Q Room Q8				
4-081 686	Building Q Room Q8				
4-082 687	Building Q Room Q8				
4-087 688	Building Q Room Q8				
4-045 689	Building Q North Restroom				
4-012 690	Building Q Boys RR Entry				
4-004 691	Building Q Boys RR Entry				
4-005 692	Building Q Boys Restroom				
4-028 693	Building Q Girls Restroom				
4-083 694	Building Q Mens Restroom				
4-084 695	Building Q Womens Restroom				
4-085 696	Building Q Kitchen Restroom				
4-086 697	Building Q Staff Restroom				
4-032 700	Building Q Kitchen SE Entry				
3-354	Building O Girls Locker Toilet				
Heat Detector - Restorable Spot					
2-156 067	Admin Building Attic Admin Bldg				
2-146 068	Admin Building Attic Room A1Q				
2-147 069	Admin Building Attic Room A1R				
2-148 070	Admin Building Attic Room A1S				
2-149 071	Admin Building Attic Room A1U				
2-157 072	Admin Building Room A2 Soffit				
2-158 073	Admin Building Room A3 Soffit				
2-159 074	Admin Building Room A4 Soffit				
2-160 075	Admin Building Room A5 Soffit				
2-161 076	Admin Building Room A6 Soffit				
2-209 077	Admin Building Attic Room A7				
2-162 078	Admin Building Room A8 Soffit				
2-163 079	Admin Building Room A9 Soffit				
2-164 080	Admin Building Room A10 Soffit				
2-155 081	Admin Building Attic A10 Mech Rm				
2-165 082	Admin Building Room A11 Soffit				
2-166 083	Admin Building Room A13 Soffit				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-167 084	Admin Building Room A14 Soffit				
2-135 138	Building B Attic ADA RR B6				
2-136 139	Building B B7 Plumbing Chase				
2-137 140	Building B Women's RR Plumbing Chase				
2-138 141	Building B Room B5 Chase				
2-139 142	Building B Attic Room B3-B2 (located B2-A4)				
2-140 143	Building B Attic Library				
2-141 144	Building B Attic Attend Off B1				
2-142 145	Building B Room B12 Chase				
2-143 146	Building B Room B13 Chase				
2-144 147	Building B Room B14 Soffit				
2-145 148	Building B Mens RR Chase				
2-204 149	Building B Exterior Electrical Room				
2-275 191	Building C Room C10 Breakroom				
2-376 194	Building C Room C10 Chase				
2-377 195	Building C Room C2 Chase				
2-378 196	Building C Room C3 Chase				
2-379 197	Building C Room C4 Chase				
2-380 198	Building C Room C10 Soffit				
2-383 221	Building D Room D1 Chase				
2-384 222	Building D Room D4 Chase				
2-396 237	Building E Attic Room E1				
2-395 238	Building E Attic Room E2				
2-394 239	Building E Attic Room E3				
2-391 240	Building E Attic Room E4				
2-392 241	Building E Attic Room E5				
2-393 242	Building E Attic Room E6				
2-390 271	Building F Room F3 Soffit				
2-389 272	Building F Room F4 Soffit				
2-388 273	Building F Room F5 Soffit				
2-386 274	Building F Attic ADA RR F10				
2-387 275	Building F Attic ADA RR F10				
2-385 276	Building F Girls RR Chase				
2-344 296	Building G Copy Rm Storage G7A				
2-398 297	Building G Room G3 Chase				
2-399 298	Building G Room G5 Chase				
2-397 299	Building G Room G6 Chase				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-400 300	Building G Attic Room G7				
3-269 319	Building I Room I-3				
3-376 332	Building I Room I-1 Soffit				
3-379 333	Building I Room I-2 Soffit				
3-377 334	Building I Attic Room I-2				
3-378 335	Building I Attic Room I-2				
3-380 336	Building I Attic Room I-2A				
3-381 337	Building I Attic Room I-3				
3-382 338	Building I Attic Room I-3				
3-399 339	Building I Room I-4 Soffit				
3-383 340	Building I Room I-6 Chase				
3-397 341	Building I Room I-6 Soffit				
3-075 422	Building J Custodial Closet J13				
3-135 423	Building J Attic Data Room J1C				
3-145 424	Building J Attic Boys RR J15				
3-286 441	Building L Custodial Room				
3-385 442	Building L Room L1 Soffit				
3-384 443	Building L Room L2 Soffit				
3-386 465	Building M Outside Kiln				
3-387 466	Building M Attic Room M2				
3-388 467	Building M Attic Room M2				
3-389 471	Building N Boiler Room N1				
3-347 512	Building O Girls Lock NW Entry				
3-348 513	Building O Girls Lock N RR				
3-349 514	Building O Girls Lock S RR				
3-392 515	Building O East Entry				
3-390 516	Building O Girls Locker Room				
3-394 517	Building O Girls Locker Rm SW				
3-398 518	Building O Attic Girls Locker Rm				
3-391 519	Building O Pool Equip O4 NE				
4-262 539	Building P Snack Room				
4-273 550	Building P Room P3A Restroom				
4-274 551	Building P Locker Restroom				
4-327 604	Building P Locker North Hall				
4-378 605	Building P Attic Snack Room				
4-379 606	Building P Boys Locker Room				
4-380 607	Building P Locker Soffit				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-408 520	Building O Girls Locker Rm N				
3-409 521	Building O Girls Locker Rm S				
3-410 522	Building O Girls Locker Rm E				
3-411 523	Building O Girls Locker Rm W				
4-377 610	Building P P1 Entry				
4-382 611	Building P Large Gym P9				
4-383 612	Building P Large Gym P9				
4-387 613	Building P Boys Locker North				
4-388 614	Building P Boys Locker South				
4-143 717	Building Q Cafeteria Southwest				
4-144 718	Building Q Cafeteria Northwest				
4-145 719	Building Q Room Q7 Entry				
4-139 720	Building Q Room Q7				

Mechanical, Electrosonic, or Pressure Waterflow Device

3-136 427	Building J Riser Room J1D				
4-136 721	Building Q Stage				

Valve Tamper Switch

3-137 428	Building J Riser Room J1D				
3-138 429	Building J OS&Y Valve				
3-138 430	Building J P.I.V.				
4-137 722	Building Q Stage				
3-138	Building J OS&Y Valve				

Heat Detector - Non-restorable Line

2-381	Building F Attic Heat Rm F5A				
-------	------------------------------	--	--	--	--

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	WHDR400S Cylinder				01/01/2020
Range Hood					
	Hood				01/01/2020
Range Suppression					
	Suppression System				01/01/2020
Cooking Equipment					
	Appliances				01/01/2020
Fusible Links					
	Fusible Links 450 x 3				09/01/2025