

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

WILL ROGERS

4924 DEWEY DR
FAIR OAKS, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Thursday, July 31, 2025

Test Session :29 Jul 2025 06:20 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	WILL ROGERS	CONTACT
ADDRESS	4924 DEWEY DR	PHONE
CITY/STATE/ZIP	FAIR?OAKS, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	139	139(100%)	139(100%)	0(0%)
Fire Control Panel	12	12(100%)	12(100%)	0(0%)
Initiating Device	365	354(97%)	351(96%)	3(1%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 31, 2025

ACCEPTED BY 07/31/2025

Building Representative


TESTED BY 07/31/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Admin Area Telecom Closet
MANUFACTURER	Notifier	S/W VERSION	
MODEL	NFS-3030	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 2 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Valve Tamper Switch	3-388 510	Weight Room Bldg OSY Valve
	Created By:	Riley Goyet
	Creation Date:	07/29/2025
	Corrective Action:	Did not report to panel
	Proposed Solution:	
	Manufacturer:	
	Model:	
Valve Tamper Switch	3-388 511	Weight Room Bldg OSY Valve
	Created By:	Riley Goyet
	Creation Date:	07/29/2025
	Corrective Action:	Did not report to panel
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	057	Admin Area Courtyard	Manual	7/29/2025 7:29:13 AM
		Visual inspection	Passed (Manual)	
Audible	058	Admin Area Courtyard	Manual	7/29/2025 7:29:15 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	064	Admin Area East Corridor	Manual	7/29/2025 7:30:47 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	063	Admin Area East Corridor	Manual	7/29/2025 7:30:49 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	061	Admin Area Library	Manual	7/29/2025 7:26:55 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	062	Admin Area Library	Manual	7/29/2025 7:30:51 AM
		Visual inspection	Passed (Manual)	
Visible	067	Admin Area Office Restroom	Manual	7/29/2025 7:30:42 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	059	Admin Area Reception	Manual	7/29/2025 7:29:16 AM
		Visual inspection	Passed (Manual)	
Visible	068	Admin Area Reception	Manual	7/29/2025 7:30:41 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	060	Admin Area Storage	Manual	7/29/2025 7:28:04 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	066	Admin Area West Corridor	Manual	7/29/2025 7:30:44 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	065	Admin Area West Corridor	Manual	7/29/2025 7:30:46 AM
		Visual inspection	Passed (Manual)	
Visible	495	Locker Room Bldg Boys Locker Rm RR	Manual	7/29/2025 7:29:03 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	492	Locker Room Bldg Boys Locker Room	Manual	7/29/2025 7:28:58 AM
		Visual inspection	Passed (Manual)	
Visible	494	Locker Room Bldg Boys Locker Room	Manual	7/29/2025 7:29:01 AM
		Visual inspection	Passed (Manual)	
Audible	491	Locker Room Bldg East Exterior	Manual	7/29/2025 7:28:56 AM
		Visual inspection	Passed (Manual)	
Visible	497	Locker Room Bldg Girls Locker Rm RR	Manual	7/29/2025 7:29:06 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	498	Locker Room Bldg Girls Locker Rm RR	Manual	7/29/2025 7:29:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	493	Locker Room Bldg Girls Locker Room	Manual	7/29/2025 7:28:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	496	Locker Room Bldg Girls Locker Room	Manual	7/29/2025 7:29:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	490	Locker Room Bldg North Exterior	Manual	7/29/2025 7:28:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	467	Multi-Purpose Bldg Band Rm 1 Practice	Manual	7/29/2025 7:28:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	456	Multi-Purpose Bldg Band Room 1	Manual	7/29/2025 7:28:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	457	Multi-Purpose Bldg Band Room 2	Manual	7/29/2025 7:28:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	462	Multi-Purpose Bldg Custodial Office	Manual	7/29/2025 7:28:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	465	Multi-Purpose Bldg East Stage Corridor	Manual	7/29/2025 7:28:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	460	Multi-Purpose Bldg Kitchen	Manual	7/29/2025 7:28:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	458	Multi-Purpose Bldg Kitchen Corridor	Manual	7/29/2025 7:28:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	459	Multi-Purpose Bldg Kitchen Corridor	Manual	7/29/2025 7:28:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	461	Multi-Purpose Bldg Kitchen Inner Corridor	Manual	7/29/2025 7:28:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	470	Multi-Purpose Bldg Kitchen Mens RR	Manual	7/29/2025 7:28:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	468	Multi-Purpose Bldg Kitchen RR Corridor	Manual	7/29/2025 7:28:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	469	Multi-Purpose Bldg Kitchen Womens RR	Manual	7/29/2025 7:28:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	452	Multi-Purpose Bldg Locker Rm Corridor	Manual	7/29/2025 7:28:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	453	Multi-Purpose Bldg Locker Rm Corridor	Manual	7/29/2025 7:28:21 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	450	Multi-Purpose Bldg MP Room	Manual	7/29/2025 7:28:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	451	Multi-Purpose Bldg MP Room	Manual	7/29/2025 7:28:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	463	Multi-Purpose Bldg MP Room	Manual	7/29/2025 7:28:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	464	Multi-Purpose Bldg MP Room	Manual	7/29/2025 7:28:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	445	Multi-Purpose Bldg North Exterior	Manual	7/29/2025 7:28:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	446	Multi-Purpose Bldg North Exterior	Manual	7/29/2025 7:28:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	447	Multi-Purpose Bldg South Exterior	Manual	7/29/2025 7:28:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	448	Multi-Purpose Bldg South Exterior	Manual	7/29/2025 7:28:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	454	Multi-Purpose Bldg Stage	Manual	7/29/2025 7:28:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	455	Multi-Purpose Bldg Stage	Manual	7/29/2025 7:28:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	449	Multi-Purpose Bldg West Exterior	Manual	7/29/2025 7:28:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	466	Multi-Purpose Bldg West Stage Corridor	Manual	7/29/2025 7:28:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	388	Portables Room P1	Manual	7/29/2025 7:28:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	389	Portables Room P2	Manual	7/29/2025 7:28:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	390	Portables Room P3	Manual	7/29/2025 7:28:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	206	Rooms 10-18 Area Boys RR Southwest	Manual	7/29/2025 7:29:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	207	Rooms 10-18 Area Boys RR Southwest	Manual	7/29/2025 7:29:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	202	Rooms 10-18 Area Corridor	Manual	7/29/2025 7:29:39 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible And Visible	201	Rooms 10-18 Area Corridor	Manual	7/29/2025 7:29:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	200	Rooms 10-18 Area Corridor	Manual	7/29/2025 7:29:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	199	Rooms 10-18 Area Corridor	Manual	7/29/2025 7:29:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	208	Rooms 10-18 Area Mens RR SW Corridor	Manual	7/29/2025 7:29:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	192	Rooms 10-18 Area Room 10	Manual	7/29/2025 7:29:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	203	Rooms 10-18 Area Room 10B Office	Manual	7/29/2025 7:29:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	193	Rooms 10-18 Area Room 11	Manual	7/29/2025 7:29:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	204	Rooms 10-18 Area Room 11A Storage	Manual	7/29/2025 7:29:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	194	Rooms 10-18 Area Room 14	Manual	7/29/2025 7:29:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	195	Rooms 10-18 Area Room 15	Manual	7/29/2025 7:29:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	196	Rooms 10-18 Area Room 16	Manual	7/29/2025 7:29:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	197	Rooms 10-18 Area Room 17	Manual	7/29/2025 7:29:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	198	Rooms 10-18 Area Room 18	Manual	7/29/2025 7:29:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	191	Rooms 10-18 Area South Exterior	Manual	7/29/2025 7:29:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	190	Rooms 10-18 Area South Exterior	Manual	7/29/2025 7:29:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	205	Rooms 10-18 Area Work Rm by Rm 11	Manual	7/29/2025 7:29:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	134	Rooms 1-9 Area Corridor	Manual	7/29/2025 7:30:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	Rooms 1-9 Area Corridor	Manual	7/29/2025 7:30:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	132	Rooms 1-9 Area Corridor	Manual	7/29/2025 7:30:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	Rooms 1-9 Area Corridor	Manual	7/29/2025 7:30:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	139	Rooms 1-9 Area Girls Restroom	Manual	7/29/2025 7:30:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	138	Rooms 1-9 Area Girls Restroom	Manual	7/29/2025 7:30:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	121	Rooms 1-9 Area North Exterior	Manual	7/29/2025 7:30:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	120	Rooms 1-9 Area North Exterior	Manual	7/29/2025 7:30:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	124	Rooms 1-9 Area Room 1	Manual	7/29/2025 7:30:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	125	Rooms 1-9 Area Room 2	Manual	7/29/2025 7:30:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	126	Rooms 1-9 Area Room 3	Manual	7/29/2025 7:30:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	127	Rooms 1-9 Area Room 4	Manual	7/29/2025 7:30:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	128	Rooms 1-9 Area Room 5	Manual	7/29/2025 7:30:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	129	Rooms 1-9 Area Room 8	Manual	7/29/2025 7:30:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	135	Rooms 1-9 Area Room 8A Storage	Manual	7/29/2025 7:30:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	130	Rooms 1-9 Area Room 9	Manual	7/29/2025 7:30:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	137	Rooms 1-9 Area Room 9 Office	Manual	7/29/2025 7:30:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	123	Rooms 1-9 Area South Exterior	Manual	7/29/2025 7:30:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	122	Rooms 1-9 Area South Exterior	Manual	7/29/2025 7:30:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	140	Rooms 1-9 Area Womens Restroom	Manual	7/29/2025 7:30:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	136	Rooms 1-9 Area Work Rm by Rm 8	Manual	7/29/2025 7:30:06 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	234	Rooms 19-22 Area East Corridor	Manual	7/29/2025 7:29:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	237	Rooms 19-22 Area Room 19	Manual	7/29/2025 7:29:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	236	Rooms 19-22 Area Room 19	Manual	7/29/2025 7:29:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	238	Rooms 19-22 Area Room 20	Manual	7/29/2025 7:29:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	239	Rooms 19-22 Area Room 21	Manual	7/29/2025 7:29:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	240	Rooms 19-22 Area Room 22	Manual	7/29/2025 7:29:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	241	Rooms 19-22 Area South Corridor	Manual	7/29/2025 7:26:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	233	Rooms 19-22 Area South Exterior	Manual	7/29/2025 7:29:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	235	Rooms 19-22 Area West Corridor	Manual	7/29/2025 7:29:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	307	Rooms 30-38 Area Boys RR E Corrd Strg	Manual	7/29/2025 7:27:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	308	Rooms 30-38 Area Boys RR E Corrd Strg	Manual	7/29/2025 7:27:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300	Rooms 30-38 Area Corridor	Manual	7/29/2025 7:27:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	301	Rooms 30-38 Area Corridor	Manual	7/29/2025 7:27:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	302	Rooms 30-38 Area Corridor	Manual	7/29/2025 7:27:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	303	Rooms 30-38 Area Corridor	Manual	7/29/2025 7:27:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	291	Rooms 30-38 Area East Exterior	Manual	7/29/2025 7:27:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	309	Rooms 30-38 Area Mens RR E Corridor	Manual	7/29/2025 7:27:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	290	Rooms 30-38 Area North Exterior	Manual	7/29/2025 7:26:53 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	293	Rooms 30-38 Area Room 30	Manual	7/29/2025 7:27:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	294	Rooms 30-38 Area Room 31	Manual	7/29/2025 7:27:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	295	Rooms 30-38 Area Room 32	Manual	7/29/2025 7:27:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	296	Rooms 30-38 Area Room 33	Manual	7/29/2025 7:27:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	297	Rooms 30-38 Area Room 34	Manual	7/29/2025 6:56:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	298	Rooms 30-38 Area Room 37	Manual	7/29/2025 7:27:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	304	Rooms 30-38 Area Room 37A Storage	Manual	7/29/2025 7:27:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	299	Rooms 30-38 Area Room 38	Manual	7/29/2025 7:27:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	306	Rooms 30-38 Area Room 38B Office	Manual	7/29/2025 7:27:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	292	Rooms 30-38 Area South Exterior	Manual	7/29/2025 7:27:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	305	Rooms 30-38 Area Work Rm by Rm 37	Manual	7/29/2025 7:27:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	365	Rooms 39-47 Area Corridor	Manual	7/29/2025 7:27:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	366	Rooms 39-47 Area Corridor	Manual	7/29/2025 7:27:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	364	Rooms 39-47 Area Corridor	Manual	7/29/2025 7:27:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	367	Rooms 39-47 Area Corridor	Manual	7/29/2025 7:27:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	369	Rooms 39-47 Area Girls Restroom	Manual	7/29/2025 7:27:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	370	Rooms 39-47 Area Girls Restroom	Manual	7/29/2025 7:27:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	357	Rooms 39-47 Area Room 39	Manual	7/29/2025 7:27:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	358	Rooms 39-47 Area Room 40	Manual	7/29/2025 7:27:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	359	Rooms 39-47 Area Room 43	Manual	7/29/2025 7:27:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	360	Rooms 39-47 Area Room 44	Manual	7/29/2025 7:27:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	361	Rooms 39-47 Area Room 45	Manual	7/29/2025 7:27:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	362	Rooms 39-47 Area Room 46	Manual	7/29/2025 6:55:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	363	Rooms 39-47 Area Room 47	Manual	7/29/2025 7:27:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	356	Rooms 39-47 Area South Exterior	Manual	7/29/2025 7:27:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	372	Rooms 39-47 Area Speech Room	Manual	7/29/2025 7:27:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	371	Rooms 39-47 Area Womens Restroom	Manual	7/29/2025 7:27:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	368	Rooms 39-47 Area Work Rm by Rm 37	Manual	7/29/2025 7:27:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	513	Weight Room Bldg Weight Room	Manual	7/29/2025 7:29:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	512	Weight Room Bldg Weight Room	Manual	7/29/2025 7:29:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	514	Weight Room Bldg West Exterior	Manual	7/29/2025 7:29:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Area Reception	Manual	7/29/2025 7:40:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Admin Area Telecom Closet	Manual	7/29/2025 7:40:11 AM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	071	Admin Area Telecom Closet	Manual	7/29/2025 8:29:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	070	Admin Area Telecom Closet	Manual	7/29/2025 8:29:43 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
NAC Power Extender Panel	069	Admin Area Telecom Closet	Manual	7/29/2025 8:29:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	472	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:43:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	471	Multi-Purpose Bldg West Stage Storage	Manual	7/29/2025 8:43:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	209	Rooms 10-18 Area Work Rm by Rm 8	Manual	7/29/2025 8:43:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	141	Rooms 1-9 Area Work Rm by Rm 8	Manual	7/29/2025 8:43:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	310	Rooms 30-38 Area Work Rm by Rm 37	Manual	7/29/2025 8:43:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	373	Rooms 39-47 Area Work Rm by Rm 40	Manual	7/29/2025 8:43:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	515	Weight Room Bldg Weight Room Closet	Manual	7/29/2025 8:31:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-131 048	Admin Area Attic East Corridor	Manual	7/29/2025 6:52:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 047	Admin Area Attic East Corridor	Manual	7/29/2025 6:52:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 046	Admin Area Attic East Corridor	Manual	7/29/2025 6:53:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 045	Admin Area Attic East Corridor	Manual	7/29/2025 6:53:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 044	Admin Area Attic East Corridor	Manual	7/29/2025 6:53:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 056	Admin Area Attic West Corridor	Manual	7/29/2025 6:27:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 055	Admin Area Attic West Corridor	Manual	7/29/2025 6:27:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 054	Admin Area Attic West Corridor	Manual	7/29/2025 6:28:00 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 053	Admin Area Attic West Corridor	Manual	7/29/2025 6:28:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 052	Admin Area Attic West Corridor	Manual	7/29/2025 6:28:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 051	Admin Area Attic West Corridor	Manual	7/29/2025 6:28:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 050	Admin Area Attic West Corridor	Manual	7/29/2025 6:28:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 049	Admin Area Attic West Corridor	Manual	7/29/2025 6:28:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 013	Admin Area Conference Room	Manual	7/29/2025 9:13:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 005	Admin Area Copy Room	Manual	7/29/2025 6:24:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 016	Admin Area Counselor Office 23B	Manual	7/29/2025 7:14:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 037	Admin Area East Corridor	Manual	7/29/2025 6:25:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 036	Admin Area East Corridor	Manual	7/29/2025 6:38:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 035	Admin Area East Corridor	Manual	7/29/2025 6:38:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 034	Admin Area East Corridor	Manual	7/29/2025 6:38:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 025	Admin Area Library	Manual	7/29/2025 6:38:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 022	Admin Area Library	Manual	7/29/2025 6:38:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 021	Admin Area Library	Manual	7/29/2025 6:38:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 018	Admin Area Library	Manual	7/29/2025 6:39:12 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-021 019	Admin Area Library	Manual	7/29/2025 6:39:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 020	Admin Area Library	Manual	7/29/2025 6:39:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 023	Admin Area Library	Manual	7/29/2025 6:39:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 024	Admin Area Library	Manual	7/29/2025 6:39:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 026	Admin Area North Corridor	Manual	7/29/2025 6:25:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 029	Admin Area North Corridor	Manual	7/29/2025 7:16:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 027	Admin Area North Corridor	Manual	7/29/2025 9:13:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 028	Admin Area North Corridor	Manual	7/29/2025 9:13:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 017	Admin Area Nurse Office Rm 24	Manual	7/29/2025 7:14:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 004	Admin Area Office Restroom	Manual	7/29/2025 6:24:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 011	Admin Area Principal Office	Manual	7/29/2025 6:23:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-136 002	Admin Area Reception	Manual	7/29/2025 9:23:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 006	Admin Area Reception	Manual	7/29/2025 6:23:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 009	Admin Area Reception	Manual	7/29/2025 6:23:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 010	Admin Area Reception	Manual	7/29/2025 6:23:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 015	Admin Area Room 23A	Manual	7/29/2025 7:14:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-017 014	Admin Area Storage	Manual	7/29/2025 6:41:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 012	Admin Area Supply Storage	Manual	7/29/2025 6:23:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-002 038	Admin Area Telecom Closet	Manual	7/29/2025 6:39:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 003	Admin Area Telecom Closet	Manual	7/29/2025 6:26:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 008	Admin Area Vice Principal Office	Manual	7/29/2025 6:24:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 007	Admin Area Vice Principal Office	Manual	7/29/2025 9:13:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 033	Admin Area West Corridor	Manual	7/29/2025 7:13:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 032	Admin Area West Corridor	Manual	7/29/2025 7:14:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 031	Admin Area West Corridor	Manual	7/29/2025 7:14:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-125 030	Admin Area West Corridor	Manual	7/29/2025 7:15:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-331 476	Locker Room Bldg Boys Locker Foyer	Manual	7/29/2025 8:19:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-330 477	Locker Room Bldg Boys Locker Office	Manual	7/29/2025 8:19:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-332 478	Locker Room Bldg Boys Locker Rm RR	Manual	7/29/2025 8:14:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-334 485	Locker Room Bldg Boys Locker Room	Manual	7/29/2025 8:14:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-335 484	Locker Room Bldg Boys Locker Room	Manual	7/29/2025 8:14:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-333 479	Locker Room Bldg Boys Locker Storage	Manual	7/29/2025 8:19:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-339 480	Locker Room Bldg Girls Locker Foyer	Manual	7/29/2025 8:16:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-338 481	Locker Room Bldg Girls Locker Office	Manual	7/29/2025 8:16:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-340 482	Locker Room Bldg Girls Locker Rm RR	Manual	7/29/2025 8:14:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-343 487	Locker Room Bldg Girls Locker Room	Manual	7/29/2025 8:20:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-342 486	Locker Room Bldg Girls Locker Room	Manual	7/29/2025 8:21:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-341 483	Locker Room Bldg Girls Locker Storage	Manual	7/29/2025 8:16:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-329 473	Locker Room Bldg Locker Rm Corridor	Manual	7/29/2025 8:31:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-328 474	Locker Room Bldg Locker Rm Corridor	Manual	7/29/2025 8:31:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-327 475	Locker Room Bldg Locker Rm Corridor	Manual	7/29/2025 8:32:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-336 489	Locker Room Bldg Locker Rm E Storage	Manual	7/29/2025 8:17:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-337 488	Locker Room Bldg Locker Rm E Storage	Manual	7/29/2025 8:18:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-319 416	Multi-Purpose Bldg Band Rm 1 Practice	Manual	7/29/2025 8:09:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-320 415	Multi-Purpose Bldg Band Rm 1 Storage	Manual	7/29/2025 7:07:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-318 417	Multi-Purpose Bldg Band Rm 1-2 Storage	Manual	7/29/2025 8:10:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-313 414	Multi-Purpose Bldg Band Room 1	Manual	7/29/2025 6:59:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-312 409	Multi-Purpose Bldg Band Room 1	Manual	7/29/2025 7:03:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-314 410	Multi-Purpose Bldg Band Room 1	Manual	7/29/2025 8:08:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-315 413	Multi-Purpose Bldg Band Room 1	Manual	7/29/2025 8:08:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-316 411	Multi-Purpose Bldg Band Room 1	Manual	7/29/2025 8:08:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-317 412	Multi-Purpose Bldg Band Room 1	Manual	7/29/2025 8:09:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-321 420	Multi-Purpose Bldg Band Room 2	Manual	7/29/2025 8:10:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-323 418	Multi-Purpose Bldg Band Room 2	Manual	7/29/2025 8:10:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-324 419	Multi-Purpose Bldg Band Room 2	Manual	7/29/2025 8:11:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-322 421	Multi-Purpose Bldg Band Room 2	Manual	7/29/2025 8:11:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-282 432	Multi-Purpose Bldg Custodial Office	Manual	7/29/2025 7:58:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283 433	Multi-Purpose Bldg Custodial Office	Manual	7/29/2025 7:58:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-325 398	Multi-Purpose Bldg East Stage Corridor	Manual	7/29/2025 8:11:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-326 397	Multi-Purpose Bldg East Stage Storage	Manual	7/29/2025 8:32:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-280 434	Multi-Purpose Bldg Kitchen	Manual	7/29/2025 7:51:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-281 435	Multi-Purpose Bldg Kitchen	Manual	7/29/2025 7:51:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-148 396	Multi-Purpose Bldg Kitchen	Manual	7/29/2025 8:01:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 424	Multi-Purpose Bldg Kitchen Corridor	Manual	7/29/2025 7:58:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-275 423	Multi-Purpose Bldg Kitchen Corridor	Manual	7/29/2025 7:58:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274 422	Multi-Purpose Bldg Kitchen Corridor	Manual	7/29/2025 7:58:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284 429	Multi-Purpose Bldg Kitchen Inner Corridor	Manual	7/29/2025 8:00:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285 428	Multi-Purpose Bldg Kitchen Inner Corridor	Manual	7/29/2025 8:02:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279 427	Multi-Purpose Bldg Kitchen Mens RR	Manual	7/29/2025 8:05:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-288 430	Multi-Purpose Bldg Kitchen Storage	Manual	7/29/2025 8:02:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287 431	Multi-Purpose Bldg Kitchen Storage	Manual	7/29/2025 8:27:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-286 436	Multi-Purpose Bldg Kitchen Telco Room	Manual	7/29/2025 7:54:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278 426	Multi-Purpose Bldg Kitchen Womens RR	Manual	7/29/2025 8:04:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-277 425	Multi-Purpose Bldg Mechanical Room	Manual	7/29/2025 7:59:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	3-427 443	Multi-Purpose Bldg MP Rm NW Beam	Manual	7/29/2025 8:03:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	3-425 444	Multi-Purpose Bldg MP Rm SW Beam	Manual	7/29/2025 8:03:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-151 395	Multi-Purpose Bldg MP Room Center	Manual	7/29/2025 8:29:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-146 392	Multi-Purpose Bldg MP Room Northeast	Manual	7/29/2025 8:13:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-147 393	Multi-Purpose Bldg MP Room Northwest	Manual	7/29/2025 8:05:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-150 391	Multi-Purpose Bldg MP Room Southeast	Manual	7/29/2025 8:14:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-149 394	Multi-Purpose Bldg MP Room Southwest	Manual	7/29/2025 8:28:07 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-299 399	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:06:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-295 400	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:07:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-298 401	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:07:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-294 402	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:08:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-297 403	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:08:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-293 404	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:08:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-292 406	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:09:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-296 405	Multi-Purpose Bldg Stage	Manual	7/29/2025 8:09:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-272 407	Multi-Purpose Bldg West Stage Corridor	Manual	7/29/2025 8:07:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-273 408	Multi-Purpose Bldg West Stage Storage	Manual	7/29/2025 8:06:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 382	Portables Attic Room P1	Manual	7/29/2025 7:45:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 383	Portables Attic Room P1	Manual	7/29/2025 7:45:16 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-379 384	Portables Attic Room P2	Manual	7/29/2025 7:42:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-379 385	Portables Attic Room P2	Manual	7/29/2025 7:42:37 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-378 386	Portables Attic Room P3	Manual	7/29/2025 7:40:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-378 387	Portables Attic Room P3	Manual	7/29/2025 7:40:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-360 377	Portables Room P1	Manual	7/29/2025 8:54:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-359 375	Portables Room P1	Manual	7/29/2025 8:54:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-361 376	Portables Room P1	Manual	7/29/2025 8:54:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-358 374	Portables Room P1	Manual	7/29/2025 9:11:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-356 378	Portables Room P2	Manual	7/29/2025 8:54:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-357 379	Portables Room P2	Manual	7/29/2025 8:54:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-354 381	Portables Room P3	Manual	7/29/2025 8:54:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-355 380	Portables Room P3	Manual	7/29/2025 8:54:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 185	Rooms 10-18 Area Attic Room 10B Office	Manual	7/29/2025 7:35:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 186	Rooms 10-18 Area Attic Room 11A	Manual	7/29/2025 6:44:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 189	Rooms 10-18 Area Attic SW Corridor	Manual	7/29/2025 6:44:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 188	Rooms 10-18 Area Attic SW Corridor	Manual	7/29/2025 6:44:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 187	Rooms 10-18 Area Attic Wrk Rm by rm 11	Manual	7/29/2025 6:44:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-349 174	Rooms 10-18 Area Boys RR Southwest	Manual	7/29/2025 6:57:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-348 175	Rooms 10-18 Area Boys RR Southwest	Manual	7/29/2025 6:58:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-325 184	Rooms 10-18 Area Hall by Room 14	Manual	7/29/2025 7:05:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 183	Rooms 10-18 Area Hall by Room 14	Manual	7/29/2025 7:06:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-350 177	Rooms 10-18 Area Janitor Storage	Manual	7/29/2025 7:00:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 176	Rooms 10-18 Area Mens RR SW Corridor	Manual	7/29/2025 8:08:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 145	Rooms 10-18 Area Room 10	Manual	7/29/2025 7:02:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 144	Rooms 10-18 Area Room 10	Manual	7/29/2025 7:02:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 143	Rooms 10-18 Area Room 10	Manual	7/29/2025 7:03:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 142	Rooms 10-18 Area Room 10	Manual	7/29/2025 7:03:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 146	Rooms 10-18 Area Room 10A Office	Manual	7/29/2025 7:03:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 147	Rooms 10-18 Area Room 10B Office	Manual	7/29/2025 7:03:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 150	Rooms 10-18 Area Room 11	Manual	7/29/2025 7:06:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 149	Rooms 10-18 Area Room 11	Manual	7/29/2025 7:07:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 148	Rooms 10-18 Area Room 11	Manual	7/29/2025 7:07:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 151	Rooms 10-18 Area Room 11	Manual	7/29/2025 9:20:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 152	Rooms 10-18 Area Room 11A Storage	Manual	7/29/2025 7:11:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-332 157	Rooms 10-18 Area Room 14	Manual	7/29/2025 7:08:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-330 154	Rooms 10-18 Area Room 14	Manual	7/29/2025 7:08:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329 155	Rooms 10-18 Area Room 14	Manual	7/29/2025 7:09:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 156	Rooms 10-18 Area Room 14	Manual	7/29/2025 7:09:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336 161	Rooms 10-18 Area Room 15	Manual	7/29/2025 7:10:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 159	Rooms 10-18 Area Room 15	Manual	7/29/2025 7:10:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-333 158	Rooms 10-18 Area Room 15	Manual	7/29/2025 7:11:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 160	Rooms 10-18 Area Room 15	Manual	7/29/2025 7:11:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-370 162	Rooms 10-18 Area Room 16	Manual	7/29/2025 7:07:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-337 163	Rooms 10-18 Area Room 16	Manual	7/29/2025 7:07:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 165	Rooms 10-18 Area Room 16	Manual	7/29/2025 8:16:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 164	Rooms 10-18 Area Room 16	Manual	7/29/2025 8:16:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-343 169	Rooms 10-18 Area Room 17	Manual	7/29/2025 7:04:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-341 167	Rooms 10-18 Area Room 17	Manual	7/29/2025 7:04:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-342 168	Rooms 10-18 Area Room 17	Manual	7/29/2025 7:05:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 166	Rooms 10-18 Area Room 17	Manual	7/29/2025 7:05:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-347 173	Rooms 10-18 Area Room 18	Manual	7/29/2025 7:01:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-345 171	Rooms 10-18 Area Room 18	Manual	7/29/2025 7:01:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-344 170	Rooms 10-18 Area Room 18	Manual	7/29/2025 7:01:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-346 172	Rooms 10-18 Area Room 18	Manual	7/29/2025 7:01:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328 180	Rooms 10-18 Area Southwest Corridor	Manual	7/29/2025 7:01:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 181	Rooms 10-18 Area Southwest Corridor	Manual	7/29/2025 7:06:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-326 182	Rooms 10-18 Area Southwest Corridor	Manual	7/29/2025 7:06:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 179	Rooms 10-18 Area Southwest Corridor	Manual	7/29/2025 9:23:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-351 178	Rooms 10-18 Area Water Heater Closet	Manual	7/29/2025 7:00:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 153	Rooms 10-18 Area Work Rm by Rm 11	Manual	7/29/2025 7:08:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 118	Rooms 1-9 Area Attic NW Corridor	Manual	7/29/2025 7:19:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 119	Rooms 1-9 Area Attic NW Corridor	Manual	7/29/2025 7:19:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 116	Rooms 1-9 Area Attic Room 8A	Manual	7/29/2025 7:19:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 117	Rooms 1-9 Area Attic Wrk Rm by Rm 8	Manual	7/29/2025 7:19:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 105	Rooms 1-9 Area Girls Restroom	Manual	7/29/2025 7:18:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 106	Rooms 1-9 Area Girls Restroom	Manual	7/29/2025 7:19:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-372 107	Rooms 1-9 Area Girls RR W Corr Strg	Manual	7/29/2025 9:21:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-279 114	Rooms 1-9 Area Hallby Room 5	Manual	7/29/2025 7:16:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 115	Rooms 1-9 Area Hallby Room 5	Manual	7/29/2025 7:17:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 103	Rooms 1-9 Area Janitor Storage	Manual	7/29/2025 7:16:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 110	Rooms 1-9 Area Northwest Corridor	Manual	7/29/2025 7:15:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 111	Rooms 1-9 Area Northwest Corridor	Manual	7/29/2025 7:15:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 112	Rooms 1-9 Area Northwest Corridor	Manual	7/29/2025 7:16:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 113	Rooms 1-9 Area Northwest Corridor	Manual	7/29/2025 7:16:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 075	Rooms 1-9 Area Room 1	Manual	7/29/2025 7:19:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 074	Rooms 1-9 Area Room 1	Manual	7/29/2025 7:19:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 073	Rooms 1-9 Area Room 1	Manual	7/29/2025 7:20:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 072	Rooms 1-9 Area Room 1	Manual	7/29/2025 7:20:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 078	Rooms 1-9 Area Room 2	Manual	7/29/2025 7:20:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 077	Rooms 1-9 Area Room 2	Manual	7/29/2025 7:21:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 076	Rooms 1-9 Area Room 2	Manual	7/29/2025 7:21:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 079	Rooms 1-9 Area Room 2	Manual	7/29/2025 7:21:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 083	Rooms 1-9 Area Room 3	Manual	7/29/2025 7:24:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 082	Rooms 1-9 Area Room 3	Manual	7/29/2025 7:24:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 081	Rooms 1-9 Area Room 3	Manual	7/29/2025 7:25:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 080	Rooms 1-9 Area Room 3	Manual	7/29/2025 7:25:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 084	Rooms 1-9 Area Room 4	Manual	7/29/2025 7:24:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 087	Rooms 1-9 Area Room 4	Manual	7/29/2025 7:54:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 085	Rooms 1-9 Area Room 4	Manual	7/29/2025 7:54:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 086	Rooms 1-9 Area Room 4	Manual	7/29/2025 7:55:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 091	Rooms 1-9 Area Room 5	Manual	7/29/2025 7:22:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 089	Rooms 1-9 Area Room 5	Manual	7/29/2025 7:23:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 088	Rooms 1-9 Area Room 5	Manual	7/29/2025 7:23:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 090	Rooms 1-9 Area Room 5	Manual	7/29/2025 7:23:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 094	Rooms 1-9 Area Room 8	Manual	7/29/2025 7:20:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 093	Rooms 1-9 Area Room 8	Manual	7/29/2025 7:20:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 092	Rooms 1-9 Area Room 8	Manual	7/29/2025 7:20:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 095	Rooms 1-9 Area Room 8	Manual	7/29/2025 7:53:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 096	Rooms 1-9 Area Room 8A Storage	Manual	7/29/2025 7:54:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-291 100	Rooms 1-9 Area Room 9	Manual	7/29/2025 7:22:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 101	Rooms 1-9 Area Room 9	Manual	7/29/2025 7:22:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 099	Rooms 1-9 Area Room 9	Manual	7/29/2025 7:22:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 098	Rooms 1-9 Area Room 9	Manual	7/29/2025 7:22:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 102	Rooms 1-9 Area Room 9 Office	Manual	7/29/2025 7:23:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 104	Rooms 1-9 Area Water Heater Closet	Manual	7/29/2025 9:18:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 108	Rooms 1-9 Area Womens Restroom	Manual	7/29/2025 7:15:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 109	Rooms 1-9 Area Womens Restroom	Manual	7/29/2025 7:15:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 097	Rooms 1-9 Area Work Rm by Rm 8	Manual	7/29/2025 7:22:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 228	Rooms 19-22 Area East Corridor	Manual	7/29/2025 6:39:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 227	Rooms 19-22 Area East Corridor	Manual	7/29/2025 6:39:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-367 212	Rooms 19-22 Area Room 19	Manual	7/29/2025 6:54:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-366 213	Rooms 19-22 Area Room 19	Manual	7/29/2025 6:54:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-365 211	Rooms 19-22 Area Room 19	Manual	7/29/2025 6:54:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-364 214	Rooms 19-22 Area Room 19	Manual	7/29/2025 6:55:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-362 215	Rooms 19-22 Area Room 19	Manual	7/29/2025 6:55:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-363 210	Rooms 19-22 Area Room 19	Manual	7/29/2025 6:55:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-371 216	Rooms 19-22 Area Room 19A Office	Manual	7/29/2025 6:55:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 217	Rooms 19-22 Area Room 20	Manual	7/29/2025 7:00:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 218	Rooms 19-22 Area Room 20	Manual	7/29/2025 7:00:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 220	Rooms 19-22 Area Room 20	Manual	7/29/2025 7:01:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 219	Rooms 19-22 Area Room 20	Manual	7/29/2025 7:02:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 221	Rooms 19-22 Area Room 21	Manual	7/29/2025 6:55:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 222	Rooms 19-22 Area Room 21	Manual	7/29/2025 6:55:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 224	Rooms 19-22 Area Room 21	Manual	7/29/2025 9:12:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 223	Rooms 19-22 Area Room 21	Manual	7/29/2025 9:12:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-368 225	Rooms 19-22 Area Room 22	Manual	7/29/2025 6:53:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-369 226	Rooms 19-22 Area Room 22	Manual	7/29/2025 6:54:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 230	Rooms 19-22 Area South Corridor	Manual	7/29/2025 6:41:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 229	Rooms 19-22 Area South Corridor	Manual	7/29/2025 6:41:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 232	Rooms 19-22 Area West Corridor	Manual	7/29/2025 6:55:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 231	Rooms 19-22 Area West Corridor	Manual	7/29/2025 6:56:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-133 288	Rooms 30-38 Area Attic NE Corridor	Manual	7/29/2025 7:01:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 289	Rooms 30-38 Area Attic NE Corridor	Manual	7/29/2025 7:01:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 286	Rooms 30-38 Area Attic Room 38B Office	Manual	7/29/2025 7:53:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 287	Rooms 30-38 Area Attic Wrk Rm by rm 37	Manual	7/29/2025 7:01:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 276	Rooms 30-38 Area Boys RR E Corrd Strg	Manual	7/29/2025 9:12:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-043 275	Rooms 30-38 Area E Corridor Boys RR	Manual	7/29/2025 9:20:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 274	Rooms 30-38 Area E Corridor Boys RR	Manual	7/29/2025 9:12:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 278	Rooms 30-38 Area E Corridor Cust Strg	Manual	7/29/2025 6:26:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 284	Rooms 30-38 Area Hall by Room 34	Manual	7/29/2025 6:29:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 285	Rooms 30-38 Area Hall by Room 34	Manual	7/29/2025 6:29:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 277	Rooms 30-38 Area Mens RR E Corridor	Manual	7/29/2025 9:12:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 280	Rooms 30-38 Area Northeast Corridor	Manual	7/29/2025 6:25:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 281	Rooms 30-38 Area Northeast Corridor	Manual	7/29/2025 6:27:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 282	Rooms 30-38 Area Northeast Corridor	Manual	7/29/2025 6:28:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 283	Rooms 30-38 Area Northeast Corridor	Manual	7/29/2025 6:28:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 245	Rooms 30-38 Area Room 30	Manual	7/29/2025 6:28:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-046 243	Rooms 30-38 Area Room 30	Manual	7/29/2025 6:28:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 242	Rooms 30-38 Area Room 30	Manual	7/29/2025 6:28:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 244	Rooms 30-38 Area Room 30	Manual	7/29/2025 6:28:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 247	Rooms 30-38 Area Room 31	Manual	7/29/2025 6:31:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 249	Rooms 30-38 Area Room 31	Manual	7/29/2025 6:32:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 246	Rooms 30-38 Area Room 31	Manual	7/29/2025 6:32:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 248	Rooms 30-38 Area Room 31	Manual	7/29/2025 6:32:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 253	Rooms 30-38 Area Room 32	Manual	7/29/2025 6:33:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 250	Rooms 30-38 Area Room 32	Manual	7/29/2025 6:34:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 251	Rooms 30-38 Area Room 32	Manual	7/29/2025 6:34:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 252	Rooms 30-38 Area Room 32	Manual	7/29/2025 6:35:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 256	Rooms 30-38 Area Room 33	Manual	7/29/2025 6:35:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 254	Rooms 30-38 Area Room 33	Manual	7/29/2025 6:36:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 255	Rooms 30-38 Area Room 33	Manual	7/29/2025 6:36:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 257	Rooms 30-38 Area Room 33	Manual	7/29/2025 6:36:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 261	Rooms 30-38 Area Room 34	Manual	7/29/2025 6:34:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-061 260	Rooms 30-38 Area Room 34	Manual	7/29/2025 6:35:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 258	Rooms 30-38 Area Room 34	Manual	7/29/2025 6:35:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 259	Rooms 30-38 Area Room 34	Manual	7/29/2025 6:36:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 265	Rooms 30-38 Area Room 37	Manual	7/29/2025 6:32:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 264	Rooms 30-38 Area Room 37	Manual	7/29/2025 6:32:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 263	Rooms 30-38 Area Room 37	Manual	7/29/2025 6:32:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 262	Rooms 30-38 Area Room 37	Manual	7/29/2025 6:32:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 266	Rooms 30-38 Area Room 37A Storage	Manual	7/29/2025 6:33:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 271	Rooms 30-38 Area Room 38	Manual	7/29/2025 6:29:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 270	Rooms 30-38 Area Room 38	Manual	7/29/2025 6:29:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 269	Rooms 30-38 Area Room 38	Manual	7/29/2025 6:29:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 268	Rooms 30-38 Area Room 38	Manual	7/29/2025 6:29:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 272	Rooms 30-38 Area Room 38A Office	Manual	7/29/2025 9:16:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 273	Rooms 30-38 Area Room 38B Office	Manual	7/29/2025 6:30:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 279	Rooms 30-38 Area Water Heater Closet	Manual	7/29/2025 9:12:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 267	Rooms 30-38 Area Work Rm by Rm 37	Manual	7/29/2025 6:34:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-134 355	Rooms 39-47 Area Attic SE Corridor	Manual	7/29/2025 7:05:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 354	Rooms 39-47 Area Attic SE Corridor	Manual	7/29/2025 7:05:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 353	Rooms 39-47 Area Attic Wrkrm by Rm 40	Manual	7/29/2025 7:05:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-121 345	Rooms 39-47 Area Cust Strg SE Corrid	Manual	7/29/2025 6:42:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-123 341	Rooms 39-47 Area Girls Restroom	Manual	7/29/2025 6:44:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-124 342	Rooms 39-47 Area Girls Restroom	Manual	7/29/2025 6:44:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 351	Rooms 39-47 Area Hall by Room 43	Manual	7/29/2025 6:43:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 352	Rooms 39-47 Area Hall by Room 43	Manual	7/29/2025 6:43:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 313	Rooms 39-47 Area Room 39	Manual	7/29/2025 6:45:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 311	Rooms 39-47 Area Room 39	Manual	7/29/2025 6:45:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 312	Rooms 39-47 Area Room 39	Manual	7/29/2025 6:46:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 314	Rooms 39-47 Area Room 39	Manual	7/29/2025 9:12:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 316	Rooms 39-47 Area Room 40	Manual	7/29/2025 6:52:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 318	Rooms 39-47 Area Room 40	Manual	7/29/2025 6:52:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 315	Rooms 39-47 Area Room 40	Manual	7/29/2025 6:52:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 317	Rooms 39-47 Area Room 40	Manual	7/29/2025 6:52:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-095 319	Rooms 39-47 Area Room 40A Storage	Manual	7/29/2025 6:51:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 324	Rooms 39-47 Area Room 43	Manual	7/29/2025 6:50:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 323	Rooms 39-47 Area Room 43	Manual	7/29/2025 6:50:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 321	Rooms 39-47 Area Room 43	Manual	7/29/2025 6:50:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 322	Rooms 39-47 Area Room 43	Manual	7/29/2025 6:50:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 328	Rooms 39-47 Area Room 44	Manual	7/29/2025 6:50:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 326	Rooms 39-47 Area Room 44	Manual	7/29/2025 6:50:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 325	Rooms 39-47 Area Room 44	Manual	7/29/2025 6:50:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 327	Rooms 39-47 Area Room 44	Manual	7/29/2025 6:51:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-112 332	Rooms 39-47 Area Room 45	Manual	7/29/2025 6:48:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 330	Rooms 39-47 Area Room 45	Manual	7/29/2025 6:49:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 331	Rooms 39-47 Area Room 45	Manual	7/29/2025 6:49:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 329	Rooms 39-47 Area Room 45	Manual	7/29/2025 6:49:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 336	Rooms 39-47 Area Room 46	Manual	7/29/2025 6:45:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-115 335	Rooms 39-47 Area Room 46	Manual	7/29/2025 6:45:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-113 333	Rooms 39-47 Area Room 46	Manual	7/29/2025 6:46:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-114 334	Rooms 39-47 Area Room 46	Manual	7/29/2025 6:46:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-120 340	Rooms 39-47 Area Room 47	Manual	7/29/2025 6:48:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-118 338	Rooms 39-47 Area Room 47	Manual	7/29/2025 6:48:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-117 337	Rooms 39-47 Area Room 47	Manual	7/29/2025 6:48:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-119 339	Rooms 39-47 Area Room 47	Manual	7/29/2025 6:49:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 347	Rooms 39-47 Area Southeast Corridor	Manual	7/29/2025 6:39:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 348	Rooms 39-47 Area Southeast Corridor	Manual	7/29/2025 6:42:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 349	Rooms 39-47 Area Southeast Corridor	Manual	7/29/2025 6:43:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 350	Rooms 39-47 Area Southeast Corridor	Manual	7/29/2025 6:43:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 344	Rooms 39-47 Area Speech Room	Manual	7/29/2025 9:12:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-122 346	Rooms 39-47 Area Water Heater Closet	Manual	7/29/2025 6:43:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 343	Rooms 39-47 Area Womens Restroom	Manual	7/29/2025 6:41:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 320	Rooms 39-47 Area Work Rm by Rm 40	Manual	7/29/2025 6:48:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-390 509	Weight Room Bldg Butterfly Valve	Manual	7/29/2025 9:11:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-420 506	Weight Room Bldg Weight Rm Mech Rm	Manual	7/29/2025 8:08:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-420 507	Weight Room Bldg Weight Rm Mech Rm	Manual	7/29/2025 8:08:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-301 500	Weight Room Bldg Weight Room	Manual	7/29/2025 8:21:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-306 499	Weight Room Bldg Weight Room	Manual	7/29/2025 8:21:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-303 501	Weight Room Bldg Weight Room	Manual	7/29/2025 8:22:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-302 504	Weight Room Bldg Weight Room	Manual	7/29/2025 8:22:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-304 503	Weight Room Bldg Weight Room	Manual	7/29/2025 8:22:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-300 505	Weight Room Bldg Weight Room Closet	Manual	7/29/2025 6:41:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-389 508	Weight Room Bldg West Exterior	Manual	7/29/2025 8:23:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-130 040	Admin Area Attic Office Area	Manual	7/29/2025 7:51:12 AM
Heat Detector - Restorable Spot	2-130 039	Admin Area Attic Office Area	Manual	7/29/2025 7:51:15 AM
Heat Detector - Restorable Spot	2-130 041	Admin Area Attic Office Area	Manual	7/29/2025 7:51:17 AM
Heat Detector - Restorable Spot	2-130 043	Admin Area Attic Office Area	Manual	7/29/2025 7:51:20 AM
Heat Detector - Restorable Spot	2-130 042	Admin Area Attic Office Area	Manual	7/29/2025 7:51:23 AM
Heat Detector - Restorable Spot	3-424 440	Multi-Purpose Bldg Attic Band Rooms	Manual	7/29/2025 8:02:01 AM
	Comment:	Out of reach		
Heat Detector - Restorable Spot	3-424 441	Multi-Purpose Bldg Attic Band Rooms	Manual	7/29/2025 8:02:14 AM
	Comment:	Out of reach		
Heat Detector - Restorable Spot	3-424 442	Multi-Purpose Bldg Attic Band Rooms	Manual	7/29/2025 8:02:23 AM
	Comment:	Out of reach		
Heat Detector - Restorable Spot	3-429 437	Multi-Purpose Bldg Attic Stage	Manual	7/29/2025 8:26:24 AM
	Comment:	Out of reach		
Heat Detector - Restorable Spot	3-429 438	Multi-Purpose Bldg Attic Stage	Manual	7/29/2025 8:26:33 AM
	Comment:	Out of reach		
Heat Detector - Restorable Spot	3-429 439	Multi-Purpose Bldg Attic Stage	Manual	7/29/2025 8:26:44 AM
	Comment:	Out of reach		

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Valve Tamper Switch	3-388 510	Weight Room Bldg OSY Valve	Manual	7/29/2025 9:11:15 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Valve Tamper Switch	3-388 511	Weight Room Bldg OSY Valve	Manual	7/29/2025 9:11:34 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Smoke Detector - General	3-305 502	Weight Room Bldg Weight Room	Manual	7/29/2025 8:22:34 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
062	Admin Area Library				
063	Admin Area East Corridor				
064	Admin Area East Corridor				
065	Admin Area West Corridor				
066	Admin Area West Corridor				
124	Rooms 1-9 Area Room 1				
125	Rooms 1-9 Area Room 2				
126	Rooms 1-9 Area Room 3				
127	Rooms 1-9 Area Room 4				
128	Rooms 1-9 Area Room 5				
129	Rooms 1-9 Area Room 8				
130	Rooms 1-9 Area Room 9				
131	Rooms 1-9 Area Corridor				
132	Rooms 1-9 Area Corridor				
133	Rooms 1-9 Area Corridor				
134	Rooms 1-9 Area Corridor				
192	Rooms 10-18 Area Room 10				
193	Rooms 10-18 Area Room 11				
194	Rooms 10-18 Area Room 14				
195	Rooms 10-18 Area Room 15				
196	Rooms 10-18 Area Room 16				
197	Rooms 10-18 Area Room 17				
198	Rooms 10-18 Area Room 18				
199	Rooms 10-18 Area Corridor				
200	Rooms 10-18 Area Corridor				
201	Rooms 10-18 Area Corridor				
202	Rooms 10-18 Area Corridor				
234	Rooms 19-22 Area East Corridor				
235	Rooms 19-22 Area West Corridor				
236	Rooms 19-22 Area Room 19				
237	Rooms 19-22 Area Room 19				
238	Rooms 19-22 Area Room 20				
239	Rooms 19-22 Area Room 21				
240	Rooms 19-22 Area Room 22				
293	Rooms 30-38 Area Room 30				
294	Rooms 30-38 Area Room 31				
295	Rooms 30-38 Area Room 32				
296	Rooms 30-38 Area Room 33				
297	Rooms 30-38 Area Room 34				
298	Rooms 30-38 Area Room 37				
299	Rooms 30-38 Area Room 38				
300	Rooms 30-38 Area Corridor				
301	Rooms 30-38 Area Corridor				
302	Rooms 30-38 Area Corridor				
303	Rooms 30-38 Area Corridor				
357	Rooms 39-47 Area Room 39				
358	Rooms 39-47 Area Room 40				
359	Rooms 39-47 Area Room 43				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
360	Rooms 39-47 Area Room 44				
361	Rooms 39-47 Area Room 45				
362	Rooms 39-47 Area Room 46				
363	Rooms 39-47 Area Room 47				
364	Rooms 39-47 Area Corridor				
365	Rooms 39-47 Area Corridor				
366	Rooms 39-47 Area Corridor				
367	Rooms 39-47 Area Corridor				
388	Portables Room P1				
389	Portables Room P2				
390	Portables Room P3				
450	Multi-Purpose Bldg MP Room				
451	Multi-Purpose Bldg MP Room				
452	Multi-Purpose Bldg Locker Rm Corridor				
453	Multi-Purpose Bldg Locker Rm Corridor				
454	Multi-Purpose Bldg Stage				
455	Multi-Purpose Bldg Stage				
456	Multi-Purpose Bldg Band Room 1				
457	Multi-Purpose Bldg Band Room 2				
458	Multi-Purpose Bldg Kitchen Corridor				
459	Multi-Purpose Bldg Kitchen Corridor				
460	Multi-Purpose Bldg Kitchen				
461	Multi-Purpose Bldg Kitchen Inner Corridor				
462	Multi-Purpose Bldg Custodial Office				
492	Locker Room Bldg Boys Locker Room				
493	Locker Room Bldg Girls Locker Room				
512	Weight Room Bldg Weight Room				
513	Weight Room Bldg Weight Room				
059	Admin Area Reception				
060	Admin Area Storage				
061	Admin Area Library				
Visible					
067	Admin Area Office Restroom				
068	Admin Area Reception				
135	Rooms 1-9 Area Room 8A Storage				
136	Rooms 1-9 Area Work Rm by Rm 8				
137	Rooms 1-9 Area Room 9 Office				
138	Rooms 1-9 Area Girls Restroom				
139	Rooms 1-9 Area Girls Restroom				
140	Rooms 1-9 Area Womens Restroom				
203	Rooms 10-18 Area Room 10B Office				
204	Rooms 10-18 Area Room 11A Storage				
205	Rooms 10-18 Area Work Rm by Rm 11				
206	Rooms 10-18 Area Boys RR Southwest				
207	Rooms 10-18 Area Boys RR Southwest				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
208	Rooms 10-18 Area Mens RR SW Corridor				
241	Rooms 19-22 Area South Corridor				
304	Rooms 30-38 Area Room 37A Storage				
305	Rooms 30-38 Area Work Rm by Rm 37				
306	Rooms 30-38 Area Room 38B Office				
307	Rooms 30-38 Area Boys RR E Corrd Strg				
308	Rooms 30-38 Area Boys RR E Corrd Strg				
309	Rooms 30-38 Area Mens RR E Corridor				
368	Rooms 39-47 Area Work Rm by Rm 37				
369	Rooms 39-47 Area Girls Restroom				
370	Rooms 39-47 Area Girls Restroom				
371	Rooms 39-47 Area Womens Restroom				
372	Rooms 39-47 Area Speech Room				
463	Multi-Purpose Bldg MP Room				
464	Multi-Purpose Bldg MP Room				
465	Multi-Purpose Bldg East Stage Corridor				
466	Multi-Purpose Bldg West Stage Corridor				
467	Multi-Purpose Bldg Band Rm 1 Practice				
468	Multi-Purpose Bldg Kitchen RR Corridor				
469	Multi-Purpose Bldg Kitchen Womens RR				
470	Multi-Purpose Bldg Kitchen Mens RR				
494	Locker Room Bldg Boys Locker Room				
495	Locker Room Bldg Boys Locker Rm RR				
496	Locker Room Bldg Girls Locker Room				
497	Locker Room Bldg Girls Locker Rm RR				
498	Locker Room Bldg Girls Locker Rm RR				
Audible					
120	Rooms 1-9 Area North Exterior				
121	Rooms 1-9 Area North Exterior				
122	Rooms 1-9 Area South Exterior				
123	Rooms 1-9 Area South Exterior				
190	Rooms 10-18 Area South Exterior				
191	Rooms 10-18 Area South Exterior				
233	Rooms 19-22 Area South Exterior				
290	Rooms 30-38 Area North Exterior				
291	Rooms 30-38 Area East Exterior				
292	Rooms 30-38 Area South Exterior				
356	Rooms 39-47 Area South Exterior				
445	Multi-Purpose Bldg North Exterior				
446	Multi-Purpose Bldg North Exterior				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
447	Multi-Purpose Bldg South Exterior				
448	Multi-Purpose Bldg South Exterior				
449	Multi-Purpose Bldg West Exterior				
490	Locker Room Bldg North Exterior				
491	Locker Room Bldg East Exterior				
514	Weight Room Bldg West Exterior				
057	Admin Area Courtyard				
058	Admin Area Courtyard				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
069	Admin Area Telecom Closet				
070	Admin Area Telecom Closet				
071	Admin Area Telecom Closet				
141	Rooms 1-9 Area Work Rm by Rm 8				
209	Rooms 10-18 Area Work Rm by Rm 8				
310	Rooms 30-38 Area Work Rm by Rm 37				
373	Rooms 39-47 Area Work Rm by Rm 40				
471	Multi-Purpose Bldg West Stage Storage				
472	Multi-Purpose Bldg Stage				
515	Weight Room Bldg Weight Room Closet				

Remote Annunciator

001	Admin Area Reception				
-----	----------------------	--	--	--	--

Fire Alarm Panel

	Admin Area Telecom Closet	Notifier	NFS-3030		
--	---------------------------	----------	----------	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2-259 072	Rooms 1-9 Area Room 1				
2-257 073	Rooms 1-9 Area Room 1				
2-258 074	Rooms 1-9 Area Room 1				
2-260 075	Rooms 1-9 Area Room 1				
2-263 076	Rooms 1-9 Area Room 2				
2-262 077	Rooms 1-9 Area Room 2				
2-264 078	Rooms 1-9 Area Room 2				
2-261 079	Rooms 1-9 Area Room 2				
2-267 080	Rooms 1-9 Area Room 3				
2-265 081	Rooms 1-9 Area Room 3				
2-266 082	Rooms 1-9 Area Room 3				
2-268 083	Rooms 1-9 Area Room 3				
2-269 084	Rooms 1-9 Area Room 4				
2-270 085	Rooms 1-9 Area Room 4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-271 086	Rooms 1-9 Area Room 4				
2-272 087	Rooms 1-9 Area Room 4				
2-273 088	Rooms 1-9 Area Room 5				
2-274 089	Rooms 1-9 Area Room 5				
2-275 090	Rooms 1-9 Area Room 5				
2-276 091	Rooms 1-9 Area Room 5				
2-286 092	Rooms 1-9 Area Room 8				
2-284 093	Rooms 1-9 Area Room 8				
2-285 094	Rooms 1-9 Area Room 8				
2-287 095	Rooms 1-9 Area Room 8				
2-278 096	Rooms 1-9 Area Room 8A Storage				
2-277 097	Rooms 1-9 Area Work Rm by Rm 8				
2-288 098	Rooms 1-9 Area Room 9				
2-289 099	Rooms 1-9 Area Room 9				
2-291 100	Rooms 1-9 Area Room 9				
2-290 101	Rooms 1-9 Area Room 9				
2-292 102	Rooms 1-9 Area Room 9 Office				
2-254 103	Rooms 1-9 Area Janitor Storage				
2-255 104	Rooms 1-9 Area Water Heater Closet				
2-253 105	Rooms 1-9 Area Girls Restroom				
2-256 106	Rooms 1-9 Area Girls Restroom				
2-372 107	Rooms 1-9 Area Girls RR W Corr Strg				
2-293 108	Rooms 1-9 Area Womens Restroom				
2-294 109	Rooms 1-9 Area Womens Restroom				
2-030 110	Rooms 1-9 Area Northwest Corridor				
2-283 111	Rooms 1-9 Area Northwest Corridor				
2-282 112	Rooms 1-9 Area Northwest Corridor				
2-281 113	Rooms 1-9 Area Northwest Corridor				
2-279 114	Rooms 1-9 Area Hallby Room 5				
2-280 115	Rooms 1-9 Area Hallby Room 5				
2-316 142	Rooms 10-18 Area Room 10				
2-315 143	Rooms 10-18 Area Room 10				
2-314 144	Rooms 10-18 Area Room 10				
2-317 145	Rooms 10-18 Area Room 10				
2-311 146	Rooms 10-18 Area Room 10A Office				
2-312 147	Rooms 10-18 Area Room 10B Office				
2-318 148	Rooms 10-18 Area Room 11				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-320 149	Rooms 10-18 Area Room 11				
2-321 150	Rooms 10-18 Area Room 11				
2-319 151	Rooms 10-18 Area Room 11				
2-323 152	Rooms 10-18 Area Room 11A Storage				
2-322 153	Rooms 10-18 Area Work Rm by Rm 11				
2-330 154	Rooms 10-18 Area Room 14				
2-329 155	Rooms 10-18 Area Room 14				
2-331 156	Rooms 10-18 Area Room 14				
2-332 157	Rooms 10-18 Area Room 14				
2-333 158	Rooms 10-18 Area Room 15				
2-334 159	Rooms 10-18 Area Room 15				
2-335 160	Rooms 10-18 Area Room 15				
2-336 161	Rooms 10-18 Area Room 15				
2-370 162	Rooms 10-18 Area Room 16				
2-337 163	Rooms 10-18 Area Room 16				
2-338 164	Rooms 10-18 Area Room 16				
2-339 165	Rooms 10-18 Area Room 16				
2-340 166	Rooms 10-18 Area Room 17				
2-341 167	Rooms 10-18 Area Room 17				
2-342 168	Rooms 10-18 Area Room 17				
2-343 169	Rooms 10-18 Area Room 17				
2-344 170	Rooms 10-18 Area Room 18				
2-345 171	Rooms 10-18 Area Room 18				
2-346 172	Rooms 10-18 Area Room 18				
2-347 173	Rooms 10-18 Area Room 18				
2-349 174	Rooms 10-18 Area Boys RR Southwest				
2-348 175	Rooms 10-18 Area Boys RR Southwest				
2-313 176	Rooms 10-18 Area Mens RR SW Corridor				
2-350 177	Rooms 10-18 Area Janitor Storage				
2-351 178	Rooms 10-18 Area Water Heater Closet				
2-309 179	Rooms 10-18 Area Southwest Corridor				
2-328 180	Rooms 10-18 Area Southwest Corridor				
2-327 181	Rooms 10-18 Area Southwest Corridor				
2-326 182	Rooms 10-18 Area Southwest Corridor				
2-324 183	Rooms 10-18 Area Hall by Room 14				
2-325 184	Rooms 10-18 Area Hall by Room 14				
2-363 210	Rooms 19-22 Area Room 19				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-365 211	Rooms 19-22 Area Room 19				
2-367 212	Rooms 19-22 Area Room 19				
2-366 213	Rooms 19-22 Area Room 19				
2-364 214	Rooms 19-22 Area Room 19				
2-362 215	Rooms 19-22 Area Room 19				
2-371 216	Rooms 19-22 Area Room 19A Office				
2-307 217	Rooms 19-22 Area Room 20				
2-308 218	Rooms 19-22 Area Room 20				
2-305 219	Rooms 19-22 Area Room 20				
2-306 220	Rooms 19-22 Area Room 20				
2-303 221	Rooms 19-22 Area Room 21				
2-304 222	Rooms 19-22 Area Room 21				
2-301 223	Rooms 19-22 Area Room 21				
2-302 224	Rooms 19-22 Area Room 21				
2-368 225	Rooms 19-22 Area Room 22				
2-369 226	Rooms 19-22 Area Room 22				
2-038 227	Rooms 19-22 Area East Corridor				
2-036 228	Rooms 19-22 Area East Corridor				
2-300 229	Rooms 19-22 Area South Corridor				
2-039 230	Rooms 19-22 Area South Corridor				
2-297 231	Rooms 19-22 Area West Corridor				
2-299 232	Rooms 19-22 Area West Corridor				
2-044 242	Rooms 30-38 Area Room 30				
2-046 243	Rooms 30-38 Area Room 30				
2-045 244	Rooms 30-38 Area Room 30				
2-047 245	Rooms 30-38 Area Room 30				
2-049 246	Rooms 30-38 Area Room 31				
2-048 247	Rooms 30-38 Area Room 31				
2-050 248	Rooms 30-38 Area Room 31				
2-051 249	Rooms 30-38 Area Room 31				
2-052 250	Rooms 30-38 Area Room 32				
2-053 251	Rooms 30-38 Area Room 32				
2-055 252	Rooms 30-38 Area Room 32				
2-054 253	Rooms 30-38 Area Room 32				
2-056 254	Rooms 30-38 Area Room 33				
2-058 255	Rooms 30-38 Area Room 33				
2-057 256	Rooms 30-38 Area Room 33				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-059 257	Rooms 30-38 Area Room 33				
2-060 258	Rooms 30-38 Area Room 34				
2-062 259	Rooms 30-38 Area Room 34				
2-061 260	Rooms 30-38 Area Room 34				
2-063 261	Rooms 30-38 Area Room 34				
2-074 262	Rooms 30-38 Area Room 37				
2-072 263	Rooms 30-38 Area Room 37				
2-073 264	Rooms 30-38 Area Room 37				
2-075 265	Rooms 30-38 Area Room 37				
2-066 266	Rooms 30-38 Area Room 37A Storage				
2-065 267	Rooms 30-38 Area Work Rm by Rm 37				
2-079 268	Rooms 30-38 Area Room 38				
2-078 269	Rooms 30-38 Area Room 38				
2-076 270	Rooms 30-38 Area Room 38				
2-077 271	Rooms 30-38 Area Room 38				
2-080 272	Rooms 30-38 Area Room 38A Office				
2-081 273	Rooms 30-38 Area Room 38B Office				
2-040 274	Rooms 30-38 Area E Corridor Boys RR				
2-001 276	Rooms 30-38 Area Boys RR E Corrd Strg				
2-082 277	Rooms 30-38 Area Mens RR E Corridor				
2-041 278	Rooms 30-38 Area E Corridor Cust Strg				
2-042 279	Rooms 30-38 Area Water Heater Closet				
2-032 280	Rooms 30-38 Area Northeast Corridor				
2-071 281	Rooms 30-38 Area Northeast Corridor				
2-070 282	Rooms 30-38 Area Northeast Corridor				
2-069 283	Rooms 30-38 Area Northeast Corridor				
2-068 284	Rooms 30-38 Area Hall by Room 34				
2-067 285	Rooms 30-38 Area Hall by Room 34				
2-085 311	Rooms 39-47 Area Room 39				
2-086 312	Rooms 39-47 Area Room 39				
2-087 313	Rooms 39-47 Area Room 39				
2-088 314	Rooms 39-47 Area Room 39				
2-089 315	Rooms 39-47 Area Room 40				
2-090 316	Rooms 39-47 Area Room 40				
2-091 317	Rooms 39-47 Area Room 40				
2-092 318	Rooms 39-47 Area Room 40				
2-095 319	Rooms 39-47 Area Room 40A Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-094 320	Rooms 39-47 Area Work Rm by Rm 40				
2-101 321	Rooms 39-47 Area Room 43				
2-102 322	Rooms 39-47 Area Room 43				
2-103 323	Rooms 39-47 Area Room 43				
2-104 324	Rooms 39-47 Area Room 43				
2-105 325	Rooms 39-47 Area Room 44				
2-106 326	Rooms 39-47 Area Room 44				
2-107 327	Rooms 39-47 Area Room 44				
2-108 328	Rooms 39-47 Area Room 44				
2-109 329	Rooms 39-47 Area Room 45				
2-110 330	Rooms 39-47 Area Room 45				
2-111 331	Rooms 39-47 Area Room 45				
2-112 332	Rooms 39-47 Area Room 45				
2-113 333	Rooms 39-47 Area Room 46				
2-114 334	Rooms 39-47 Area Room 46				
2-115 335	Rooms 39-47 Area Room 46				
2-116 336	Rooms 39-47 Area Room 46				
2-117 337	Rooms 39-47 Area Room 47				
2-118 338	Rooms 39-47 Area Room 47				
2-119 339	Rooms 39-47 Area Room 47				
2-120 340	Rooms 39-47 Area Room 47				
2-123 341	Rooms 39-47 Area Girls Restroom				
2-124 342	Rooms 39-47 Area Girls Restroom				
2-084 343	Rooms 39-47 Area Womens Restroom				
2-083 344	Rooms 39-47 Area Speech Room				
2-121 345	Rooms 39-47 Area Cust Strg SE Corrid				
2-122 346	Rooms 39-47 Area Water Heater Closet				
2-037 347	Rooms 39-47 Area Southeast Corridor				
2-100 348	Rooms 39-47 Area Southeast Corridor				
2-099 349	Rooms 39-47 Area Southeast Corridor				
2-098 350	Rooms 39-47 Area Southeast Corridor				
2-096 351	Rooms 39-47 Area Hall by Room 43				
2-097 352	Rooms 39-47 Area Hall by Room 43				
2-358 374	Portables Room P1				
2-359 375	Portables Room P1				
2-361 376	Portables Room P1				
2-360 377	Portables Room P1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-356 378	Portables Room P2				
2-357 379	Portables Room P2				
2-355 380	Portables Room P3				
2-354 381	Portables Room P3				
3-326 397	Multi-Purpose Bldg East Stage Storage				
3-325 398	Multi-Purpose Bldg East Stage Corridor				
3-299 399	Multi-Purpose Bldg Stage				
3-295 400	Multi-Purpose Bldg Stage				
3-298 401	Multi-Purpose Bldg Stage				
3-294 402	Multi-Purpose Bldg Stage				
3-297 403	Multi-Purpose Bldg Stage				
3-293 404	Multi-Purpose Bldg Stage				
3-296 405	Multi-Purpose Bldg Stage				
3-292 406	Multi-Purpose Bldg Stage				
3-272 407	Multi-Purpose Bldg West Stage Corridor				
3-273 408	Multi-Purpose Bldg West Stage Storage				
3-312 409	Multi-Purpose Bldg Band Room 1				
3-314 410	Multi-Purpose Bldg Band Room 1				
3-316 411	Multi-Purpose Bldg Band Room 1				
3-317 412	Multi-Purpose Bldg Band Room 1				
3-315 413	Multi-Purpose Bldg Band Room 1				
3-313 414	Multi-Purpose Bldg Band Room 1				
3-320 415	Multi-Purpose Bldg Band Rm 1 Storage				
3-319 416	Multi-Purpose Bldg Band Rm 1 Practice				
3-318 417	Multi-Purpose Bldg Band Rm 1-2 Storage				
3-323 418	Multi-Purpose Bldg Band Room 2				
3-324 419	Multi-Purpose Bldg Band Room 2				
3-321 420	Multi-Purpose Bldg Band Room 2				
3-322 421	Multi-Purpose Bldg Band Room 2				
3-274 422	Multi-Purpose Bldg Kitchen Corridor				
3-275 423	Multi-Purpose Bldg Kitchen Corridor				
3-276 424	Multi-Purpose Bldg Kitchen Corridor				
3-277 425	Multi-Purpose Bldg Mechanical Room				
3-278 426	Multi-Purpose Bldg Kitchen Womens RR				
3-279 427	Multi-Purpose Bldg Kitchen Mens RR				
3-285 428	Multi-Purpose Bldg Kitchen Inner Corridor				
3-284 429	Multi-Purpose Bldg Kitchen Inner Corridor				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-288 430	Multi-Purpose Bldg Kitchen Storage				
3-287 431	Multi-Purpose Bldg Kitchen Storage				
3-282 432	Multi-Purpose Bldg Custodial Office				
3-283 433	Multi-Purpose Bldg Custodial Office				
3-329 473	Locker Room Bldg Locker Rm Corridor				
3-328 474	Locker Room Bldg Locker Rm Corridor				
3-327 475	Locker Room Bldg Locker Rm Corridor				
3-331 476	Locker Room Bldg Boys Locker Foyer				
2-003 003	Admin Area Telecom Closet				
2-004 004	Admin Area Office Restroom				
2-005 005	Admin Area Copy Room				
2-009 006	Admin Area Reception				
2-013 007	Admin Area Vice Principal Office				
2-014 008	Admin Area Vice Principal Office				
2-010 009	Admin Area Reception				
2-011 010	Admin Area Reception				
2-015 011	Admin Area Principal Office				
2-012 012	Admin Area Supply Storage				
2-016 013	Admin Area Conference Room				
2-017 014	Admin Area Storage				
2-006 015	Admin Area Room 23A				
2-007 016	Admin Area Counselor Office 23B				
2-008 017	Admin Area Nurse Office Rm 24				
2-025 018	Admin Area Library				
2-021 019	Admin Area Library				
2-020 020	Admin Area Library				
2-024 021	Admin Area Library				
2-023 022	Admin Area Library				
2-019 023	Admin Area Library				
2-018 024	Admin Area Library				
2-022 025	Admin Area Library				
2-026 026	Admin Area North Corridor				
2-027 027	Admin Area North Corridor				
2-028 028	Admin Area North Corridor				
2-029 029	Admin Area North Corridor				
2-125 030	Admin Area West Corridor				
2-295 031	Admin Area West Corridor				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-296 032	Admin Area West Corridor				
2-298 033	Admin Area West Corridor				
2-035 034	Admin Area East Corridor				
2-034 035	Admin Area East Corridor				
2-033 036	Admin Area East Corridor				
2-031 037	Admin Area East Corridor				
3-330 477	Locker Room Bldg Boys Locker Office				
3-332 478	Locker Room Bldg Boys Locker Rm RR				
3-333 479	Locker Room Bldg Boys Locker Storage				
3-339 480	Locker Room Bldg Girls Locker Foyer				
3-338 481	Locker Room Bldg Girls Locker Office				
3-340 482	Locker Room Bldg Girls Locker Rm RR				
3-341 483	Locker Room Bldg Girls Locker Storage				
3-306 499	Weight Room Bldg Weight Room				
3-301 500	Weight Room Bldg Weight Room				
3-303 501	Weight Room Bldg Weight Room				
3-305 502	Weight Room Bldg Weight Room				
3-304 503	Weight Room Bldg Weight Room				
3-302 504	Weight Room Bldg Weight Room				
3-300 505	Weight Room Bldg Weight Room Closet				
Heat Detector - Restorable Spot					
2-376 116	Rooms 1-9 Area Attic Room 8A				
2-376 117	Rooms 1-9 Area Attic Wrk Rm by Rm 8				
2-376 118	Rooms 1-9 Area Attic NW Corridor				
2-376 119	Rooms 1-9 Area Attic NW Corridor				
2-381 185	Rooms 10-18 Area Attic Room 10B Office				
2-377 186	Rooms 10-18 Area Attic Room 11A				
2-377 187	Rooms 10-18 Area Attic Wrk Rm by rm 11				
2-377 188	Rooms 10-18 Area Attic SW Corridor				
2-377 189	Rooms 10-18 Area Attic SW Corridor				
2-043 275	Rooms 30-38 Area E Corridor Boys RR				
2-137 286	Rooms 30-38 Area Attic Room 38B Office				
2-133 287	Rooms 30-38 Area Attic Wrk Rm by rm 37				
2-133 288	Rooms 30-38 Area Attic NE Corridor				
2-133 289	Rooms 30-38 Area Attic NE Corridor				
2-134 353	Rooms 39-47 Area Attic Wrkrm by Rm 40				
2-134 354	Rooms 39-47 Area Attic SE Corridor				
2-134 355	Rooms 39-47 Area Attic SE Corridor				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-380 382	Portables Attic Room P1				
2-380 383	Portables Attic Room P1				
2-379 384	Portables Attic Room P2				
2-379 385	Portables Attic Room P2				
2-378 386	Portables Attic Room P3				
2-378 387	Portables Attic Room P3				
3-280 434	Multi-Purpose Bldg Kitchen				
3-281 435	Multi-Purpose Bldg Kitchen				
3-286 436	Multi-Purpose Bldg Kitchen Telco Room				
3-429 437	Multi-Purpose Bldg Attic Stage				
3-429 438	Multi-Purpose Bldg Attic Stage				
3-429 439	Multi-Purpose Bldg Attic Stage				
3-424 440	Multi-Purpose Bldg Attic Band Rooms				
3-424 441	Multi-Purpose Bldg Attic Band Rooms				
3-424 442	Multi-Purpose Bldg Attic Band Rooms				
2-002 038	Admin Area Telecom Closet				
2-130 039	Admin Area Attic Office Area				
2-130 040	Admin Area Attic Office Area				
2-130 041	Admin Area Attic Office Area				
2-130 042	Admin Area Attic Office Area				
2-130 043	Admin Area Attic Office Area				
2-131 044	Admin Area Attic East Corridor				
2-131 045	Admin Area Attic East Corridor				
2-131 046	Admin Area Attic East Corridor				
2-131 047	Admin Area Attic East Corridor				
3-335 484	Locker Room Bldg Boys Locker Room				
3-334 485	Locker Room Bldg Boys Locker Room				
3-342 486	Locker Room Bldg Girls Locker Room				
3-343 487	Locker Room Bldg Girls Locker Room				
3-337 488	Locker Room Bldg Locker Rm E Storage				
3-336 489	Locker Room Bldg Locker Rm E Storage				
3-420 506	Weight Room Bldg Weight Rm Mech Rm				
3-420 507	Weight Room Bldg Weight Rm Mech Rm				
2-131 048	Admin Area Attic East Corridor				
2-132 049	Admin Area Attic West Corridor				
2-132 050	Admin Area Attic West Corridor				
2-132 051	Admin Area Attic West Corridor				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-132 052	Admin Area Attic West Corridor				
2-132 053	Admin Area Attic West Corridor				
2-132 054	Admin Area Attic West Corridor				
2-132 055	Admin Area Attic West Corridor				
2-132 056	Admin Area Attic West Corridor				
Manual Pull Station					
2-150 391	Multi-Purpose Bldg MP Room Southeast				
2-146 392	Multi-Purpose Bldg MP Room Northeast				
2-147 393	Multi-Purpose Bldg MP Room Northwest				
2-149 394	Multi-Purpose Bldg MP Room Southwest				
2-151 395	Multi-Purpose Bldg MP Room Center				
2-148 396	Multi-Purpose Bldg Kitchen				
2-136 002	Admin Area Reception				
Smoke Detector - Projected Beam					
3-427 443	Multi-Purpose Bldg MP Rm NW Beam				
3-425 444	Multi-Purpose Bldg MP Rm SW Beam				
Mechanical, Electrosonic, or Pressure Waterflow Device					
3-389 508	Weight Room Bldg West Exterior				
Valve Tamper Switch					
3-390 509	Weight Room Bldg Butterfly Valve				
3-388 510	Weight Room Bldg OSY Valve				
3-388 511	Weight Room Bldg OSY Valve				