

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

ARCADE MIDDLE SCHOOL

3500 EDISON AVE
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Thursday, July 31, 2025

Test Session :28 Jul 2025 06:34

Test Plans : Fire Alarm - Annual

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	ARCADE MIDDLE SCHOOL	CONTACT
ADDRESS	3500 EDISON AVE	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Power Supplies	5	5(100%)	3(60%)	2(40%)
Initiating Device	254	254(100%)	251(99%)	3(1%)
Fire Control Panel	1	1(100%)	1(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 31, 2025

ACCEPTED BY 07/31/2025

Building Representative

Riley
TESTED BY 07/31/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Bldg A MDF Room A105 FACP (2) 12v55ah
MANUFACTURER	Edwards	S/W VERSION	
MODEL	EST-3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	07/27/2025		

Secondary Power

Open Corrective Action & Solution Summary

The following 4 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
BPS - Booster Power Supply	1.2.142	BPS D1 IDF Room D10 (2)12v18ah
	Created By:	Brian Brown
	Creation Date:	07/28/2025
	Corrective Action:	Left battery- Low voltage. Replace (2) 12 v / 18 ah batteries. Power Sonic PS-12180 F2
	Proposed Solution:	
	Manufacturer:	
	Model:	

Duct Detector	1.3.126	Duct Actvi Comm B14 PHP B10
	Created By:	Chris Spencer
	Creation Date:	07/28/2025
	Corrective Action:	Device failed to activate during test
	Proposed Solution:	
	Manufacturer:	
	Model:	



Duct Detector	1.3.128	Duct Actvi Comm B14 PHP B9
	Created By:	Chris Spencer
	Creation Date:	07/28/2025
	Corrective Action:	Device failed to activate during test
	Proposed Solution:	
	Manufacturer:	
	Model:	



Duct Detector	1.3.130	Duct Actvi Comm B14 PHP B8
	Created By:	Chris Spencer
	Creation Date:	07/28/2025
	Corrective Action:	Device failed to activate during test
	Proposed Solution:	
	Manufacturer:	
	Model:	



Testing Details

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel		Bldg A MDF Room A105 FACP (2) 12v55ah	Manual	7/28/2025 2:39:07 PM
	Comment:	Battery # 1- 12 v / 55 ah Manufacture date- NA Load test- 100% Pass/ fail- Pass		
		Battery # 2- 12 v / 55 ah Manufacture date- NA Load test- 100% Pass/ fail- Pass		
		Make- Duracell		
		Model- DURA12-55C/FR		
		Manufacturer	Edwards	
		Model	EST-3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	1.2.382	Bldg A Admin A101 Pullstation	Manual	7/28/2025 9:33:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.2.380	Bldg A Attic Restroom A111	Manual	7/28/2025 9:38:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.280	Bldg A Conference Room A102	Manual	7/28/2025 8:18:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.269	Bldg A Conference Room A109.7	Manual	7/28/2025 8:24:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.276	Bldg A Counseling Office A113	Manual	7/28/2025 8:22:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.258	Bldg A Custodial Room A108.2	Manual	7/28/2025 8:16:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.256	Bldg A Electrical Room A106	Manual	7/28/2025 8:32:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.255	Bldg A FACP/MDF A105	Manual	7/28/2025 8:32:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.257	Bldg A Fire Riser Room A107	Manual	7/28/2025 8:31:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.271	Bldg A Hallway A109.A	Manual	7/28/2025 8:23:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.2.267	Bldg A Hallway A109.A	Manual	7/28/2025 8:25:53 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.275	Bldg A Hallway A110	Manual	7/28/2025 8:20:36 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.279	Bldg A Lobby A101	Manual	7/28/2025 8:19:37 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.259	Bldg A Lounge A108.1	Manual	7/28/2025 8:16:05 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.282	Bldg A Nurses Office A104	Manual	7/28/2025 8:17:14 AM
		Visual inspection	Passed (Manual)	
Supervisory - Control Valve	1.2.378	Bldg A PIV N.E. Riser Room A107	Manual	7/28/2025 1:23:34 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.263	Bldg A Principals Office A109.5	Manual	7/28/2025 8:30:18 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.283	Bldg A Restroom A104.1	Manual	7/28/2025 8:17:44 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.273	Bldg A Restroom A111	Manual	7/28/2025 8:16:43 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.281	Bldg A Shared Spaces A103	Manual	7/28/2025 8:18:17 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.261	Bldg A Storage A109.6	Manual	7/28/2025 8:30:50 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.262	Bldg A Storage Closet A108.3	Manual	7/28/2025 8:16:01 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.270	Bldg A Student Services 2 A109.2	Manual	7/28/2025 8:24:52 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.274	Bldg A Student Services A109.1	Manual	7/28/2025 8:23:12 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.268	Bldg A Vice Principal A109.3	Manual	7/28/2025 8:25:27 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.266	Bldg A Vice Principal A109.4	Manual	7/28/2025 8:26:19 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.277	Bldg A Vice Principal Office A113	Manual	7/28/2025 8:21:22 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.264	Bldg A Waiting Room A109.8	Manual	7/28/2025 8:26:53 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.260	Bldg A Workroom A108	Manual	7/28/2025 8:16:07 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.013	Bldg B Activity Commons B14.E	Manual	7/28/2025 8:37:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.012	Bldg B Activity Commons B14.E	Manual	7/28/2025 8:38:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.011	Bldg B Activity Commons B14.E	Manual	7/28/2025 8:39:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.010	Bldg B Activity Commons B14.W	Manual	7/28/2025 8:41:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.008	Bldg B Activity Commons B14.W	Manual	7/28/2025 8:45:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.009	Bldg B Activity Commons B14.W	Manual	7/28/2025 8:46:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.006	Bldg B Classroom B01	Manual	7/28/2025 8:46:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.007	Bldg B Classroom B01	Manual	7/28/2025 8:47:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.014	Bldg B Classroom B02	Manual	7/28/2025 8:48:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.015	Bldg B Classroom B02	Manual	7/28/2025 8:49:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.023	Bldg B Classroom B03	Manual	7/28/2025 8:47:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.022	Bldg B Classroom B03	Manual	7/28/2025 8:48:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.025	Bldg B Classroom B04	Manual	7/28/2025 8:33:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.024	Bldg B Classroom B04	Manual	7/28/2025 8:34:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.026	Bldg B Classroom B05	Manual	7/28/2025 8:38:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.027	Bldg B Classroom B05	Manual	7/28/2025 8:38:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.028	Bldg B Classroom B06	Manual	7/28/2025 8:45:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.029	Bldg B Classroom B06	Manual	7/28/2025 8:46:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.3.030	Bldg B Classroom B07	Manual	7/28/2025 8:47:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.031	Bldg B Classroom B07	Manual	7/28/2025 8:49:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.032	Bldg B Classroom B08	Manual	7/28/2025 8:51:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.033	Bldg B Classroom B08	Manual	7/28/2025 8:52:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.034	Bldg B Classroom B09	Manual	7/28/2025 8:48:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.035	Bldg B Classroom B09	Manual	7/28/2025 8:49:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.018	Bldg B Corridor B14	Manual	7/28/2025 8:39:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.036	Bldg B Electrical Room B10	Manual	7/28/2025 8:58:31 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.021	Bldg B Fire Riser Room B15	Manual	7/28/2025 8:55:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.05	Bldg B IDF Room B13	Manual	7/28/2025 8:56:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.017	Bldg B Office B14.3	Manual	7/28/2025 8:53:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1.3.150	Bldg B Plumbing Chase Restroom B11	Manual	7/28/2025 9:36:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1.3.141	Bldg B Plumbing Chase Restroom B14.1	Manual	7/28/2025 9:35:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1.3.136	Bldg B Plumbing Chase Restroom B14.4	Manual	7/28/2025 9:35:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.037	Bldg B Restroom B11	Manual	7/28/2025 8:57:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.038	Bldg B Restroom B11	Manual	7/28/2025 8:57:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.020	Bldg B Restroom B14.2	Manual	7/28/2025 8:52:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.019	Bldg B Restroom B14.2	Manual	7/28/2025 8:54:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.3.016	Bldg B Room B02.1	Manual	7/28/2025 8:51:29 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.040	Bldg B Room B14.4	Manual	7/28/2025 8:53:52 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.259	Bldg C Activity Common C14 East	Manual	7/28/2025 2:23:44 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.258	Bldg C Activity Common C14 East	Manual	7/28/2025 2:24:13 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.260	Bldg C Activity Common C14 East	Manual	7/28/2025 2:24:46 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.261	Bldg C Activity Common C14 West	Manual	7/28/2025 2:27:25 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.262	Bldg C Activity Common C14 West	Manual	7/28/2025 2:35:49 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.263	Bldg C Activity Common C14 West	Manual	7/28/2025 2:36:07 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.257	Bldg C Classroom C01	Manual	7/28/2025 2:22:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.256	Bldg C Classroom C01	Manual	7/28/2025 2:22:22 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.274	Bldg C Classroom C03	Manual	7/28/2025 2:29:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.273	Bldg C Classroom C03	Manual	7/28/2025 2:30:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.276	Bldg C Classroom C04	Manual	7/28/2025 2:37:04 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.275	Bldg C Classroom C04	Manual	7/28/2025 2:37:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.278	Bldg C Classroom C05	Manual	7/28/2025 2:36:27 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.277	Bldg C Classroom C05	Manual	7/28/2025 2:36:44 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.279	Bldg C Classroom C06	Manual	7/28/2025 2:33:09 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.280	Bldg C Classroom C06	Manual	7/28/2025 2:35:10 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.282	Bldg C Classroom C07	Manual	7/28/2025 2:27:45 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.281	Bldg C Classroom C07	Manual	7/28/2025 2:27:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.283	Bldg C Classroom C08	Manual	7/28/2025 2:26:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.284	Bldg C Classroom C08	Manual	7/28/2025 2:26:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.286	Bldg C Classroom C09	Manual	7/28/2025 2:22:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.285	Bldg C Classroom C09	Manual	7/28/2025 2:22:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.269	Bldg C Corridor C14	Manual	7/28/2025 2:30:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.267	Bldg C Cust/Storage Room C14.3	Manual	7/28/2025 2:31:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.255	Bldg C IDF Room C13	Manual	7/28/2025 2:21:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.264	Bldg C ILS Classroom C02	Manual	7/28/2025 2:25:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.265	Bldg C ILS Classroom C02	Manual	7/28/2025 2:25:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.266	Bldg C ILS Classroom C02	Manual	7/28/2025 2:25:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	1.3.402	Bldg C PIV Riser Room C12	Manual	7/28/2025 12:39:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.3.390	Bldg C Plumbing Chase Restroom C02.1	Manual	7/28/2025 3:56:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.3.401	Bldg C Plumbing Chase Restroom C12	Manual	7/28/2025 3:57:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.3.393	Bldg C Plumbing Chase Restroom C14.1	Manual	7/28/2025 3:56:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.268	Bldg C Restroom C02.1	Manual	7/28/2025 2:26:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.290	Bldg C Restroom C12	Manual	7/28/2025 2:57:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.270	Bldg C Restroom C14.1	Manual	7/28/2025 2:34:44 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.271	Bldg C Restroom C14.2	Manual	7/28/2025 2:32:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.035	Bldg D Art Storage D04.1	Manual	7/28/2025 9:11:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.028	Bldg D Book Storage D12.2	Manual	7/28/2025 9:13:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.029	Bldg D Book Storage D12.2	Manual	7/28/2025 9:13:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.048	Bldg D Classroom D01 N.E.	Manual	7/28/2025 9:08:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.047	Bldg D Classroom D01 N.W.	Manual	7/28/2025 9:05:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.050	Bldg D Classroom D01 S.E.	Manual	7/28/2025 9:07:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.049	Bldg D Classroom D01 S.W.	Manual	7/28/2025 9:06:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.044	Bldg D Classroom D02 N.E.	Manual	7/28/2025 8:59:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.043	Bldg D Classroom D02 N.W.	Manual	7/28/2025 9:01:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.046	Bldg D Classroom D02 S.E.	Manual	7/28/2025 9:00:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.045	Bldg D Classroom D02 S.W.	Manual	7/28/2025 9:00:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.032	Bldg D Classroom D04 N.E.	Manual	7/28/2025 9:09:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.031	Bldg D Classroom D04 N.W.	Manual	7/28/2025 9:10:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.034	Bldg D Classroom D04 S.E.	Manual	7/28/2025 9:09:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.033	Bldg D Classroom D04 S.W.	Manual	7/28/2025 9:12:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.021	Bldg D Classroom D05 N.E.	Manual	7/28/2025 9:17:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.020	Bldg D Classroom D05 N.W.	Manual	7/28/2025 9:18:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.4.023	Bldg D Classroom D05 S.E.	Manual	7/28/2025 9:17:26 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.022	Bldg D Classroom D05 S.W.	Manual	7/28/2025 9:18:11 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.019	Bldg D Classroom D06 N.E.	Manual	7/28/2025 9:20:52 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.008	Bldg D Classroom D06 N.W.	Manual	7/28/2025 9:20:25 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.017	Bldg D Classroom D06 S.E.	Manual	7/28/2025 9:21:19 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.016	Bldg D Classroom D06 S.W.	Manual	7/28/2025 9:19:21 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.015	Bldg D Classroom D07 N.E.	Manual	7/28/2025 9:28:51 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.014	Bldg D Classroom D07 N.W.	Manual	7/28/2025 9:29:20 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.013	Bldg D Classroom D07 S.E.	Manual	7/28/2025 9:26:51 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.012	Bldg D Classroom D07 S.W.	Manual	7/28/2025 9:31:09 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.008	Bldg D Classroom D08 N.E.	Manual	7/28/2025 9:23:44 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.009	Bldg D Classroom D08 N.W.	Manual	7/28/2025 9:27:34 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.011	Bldg D Classroom D08 S.E.	Manual	7/28/2025 9:26:13 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.010	Bldg D Classroom D08 S.W.	Manual	7/28/2025 9:24:42 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.037	Bldg D Clean Room D14	Manual	7/28/2025 9:08:33 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.042	Bldg D Control Room D02.1	Manual	7/28/2025 9:02:28 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.006	Bldg D Electrical Room D09	Manual	7/28/2025 9:28:19 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.030	Bldg D Fire Riser Room D13	Manual	7/28/2025 9:31:49 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.005	Bldg D IDF Room D10	Manual	7/28/2025 9:30:11 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.036	Bldg D Kiln Room D04.2	Manual	7/28/2025 9:12:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.027	Bldg D Library D12 N.E.	Manual	7/28/2025 9:14:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.025	Bldg D Library D12 N.W.	Manual	7/28/2025 9:14:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.026	Bldg D Library D12 S.E.	Manual	7/28/2025 9:15:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.024	Bldg D Library D12 W.	Manual	7/28/2025 9:15:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.038	Bldg D Recording Studio D02.1	Manual	7/28/2025 9:05:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.007	Bldg D Resource Room D11	Manual	7/28/2025 9:19:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.154	Bldg D Restroom D15	Manual	7/28/2025 9:37:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.041	Bldg D Restroom D15	Manual	7/28/2025 9:32:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.392	Bldg M Attic Restroom M101.2	Manual	7/28/2025 4:00:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.267	Bldg M Boys Locker Restroom M113	Manual	7/28/2025 2:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.266	Bldg M Boys Locker Restroom M113.1	Manual	7/28/2025 2:40:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.265	Bldg M Boys Locker Restroom M113.2	Manual	7/28/2025 2:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.271	Bldg M Boys Locker Room M112 N.W.	Manual	7/28/2025 2:42:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.272	Bldg M Boys Locker Room M112 North	Manual	7/28/2025 2:39:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.274	Bldg M Boys Locker Room M112 South	Manual	7/28/2025 2:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.278	Bldg M Boys Restroom M109	Manual	7/28/2025 3:51:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.317	Bldg M Dish Washing M119.6	Manual	7/28/2025 3:58:15 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.318	Bldg M Dry Storage M119.3	Manual	7/28/2025 3:38:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.255	Bldg M Electrical Room M118	Manual	7/28/2025 3:53:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.269	Bldg M Girls Locker Office Ice M114.1	Manual	7/28/2025 2:53:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.264	Bldg M Girls Locker Restroom M115	Manual	7/28/2025 2:54:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.262	Bldg M Girls Locker Restroom M115.1	Manual	7/28/2025 2:55:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.263	Bldg M Girls Locker Restroom M115.2	Manual	7/28/2025 2:55:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.259	Bldg M Girls Locker Room M114 N.E.	Manual	7/28/2025 2:54:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.258	Bldg M Girls Locker Room M114 N.W.	Manual	7/28/2025 2:52:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.260	Bldg M Girls Locker Room M114 North	Manual	7/28/2025 2:53:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.261	Bldg M Girls Locker Room M114 South	Manual	7/28/2025 2:51:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.279	Bldg M Girls Restroom M110	Manual	7/28/2025 3:51:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.282	Bldg M Gym East M102	Manual	7/28/2025 3:26:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.285	Bldg M Gym East M102	Manual	7/28/2025 3:26:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.288	Bldg M Gym East M102	Manual	7/28/2025 3:26:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.291	Bldg M Gym East M102	Manual	7/28/2025 3:27:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.294	Bldg M Gym East M102	Manual	7/28/2025 3:27:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.297	Bldg M Gym East M102	Manual	7/28/2025 3:27:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.300	Bldg M Gym East M102	Manual	7/28/2025 3:28:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.4.289	Bldg M Gym East M102	Manual	7/28/2025 3:33:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.299	Bldg M Gym Middle M102	Manual	7/28/2025 3:23:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.296	Bldg M Gym Middle M102	Manual	7/28/2025 3:23:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.293	Bldg M Gym Middle M102	Manual	7/28/2025 3:23:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.290	Bldg M Gym Middle M102	Manual	7/28/2025 3:24:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.287	Bldg M Gym Middle M102	Manual	7/28/2025 3:24:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.284	Bldg M Gym Middle M102	Manual	7/28/2025 3:24:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.281	Bldg M Gym Middle M102	Manual	7/28/2025 3:25:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.314	Bldg M Gym Restroom M101.1	Manual	7/28/2025 3:40:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.315	Bldg M Gym Restroom M101.2	Manual	7/28/2025 3:38:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.313	Bldg M Gym Vestibule M101	Manual	7/28/2025 3:39:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1.4.391	Bldg M Gym Vestibule M101 Pullstation	Manual	7/28/2025 4:01:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.393	Bldg M Gym Vestibule M102	Manual	7/28/2025 3:39:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.298	Bldg M Gym West M102	Manual	7/28/2025 3:29:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.295	Bldg M Gym West M102	Manual	7/28/2025 3:32:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.292	Bldg M Gym West M102	Manual	7/28/2025 3:33:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.286	Bldg M Gym West M102	Manual	7/28/2025 3:34:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.283	Bldg M Gym West M102	Manual	7/28/2025 3:34:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.280	Bldg M Gym West M102	Manual	7/28/2025 3:35:03 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.256	Bldg M IDF Room M117	Manual	7/28/2025 3:54:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.401	Bldg M Kitchen Chase M119.2	Manual	7/28/2025 3:59:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.319	Bldg M Kitchen M119.2	Manual	7/28/2025 3:58:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.304	Bldg M Music Classroom M105	Manual	7/28/2025 3:45:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.303	Bldg M Music Classroom M105	Manual	7/28/2025 3:46:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.270	Bldg M Office M112.1	Manual	7/28/2025 2:42:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.305	Bldg M PE Classroom M106	Manual	7/28/2025 3:47:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.306	Bldg M PE Classroom M106	Manual	7/28/2025 3:48:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.310	Bldg M Platform M103	Manual	7/28/2025 3:42:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.311	Bldg M Platform M103	Manual	7/28/2025 3:43:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.309	Bldg M Platform Ramp M102.2	Manual	7/28/2025 3:43:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.308	Bldg M Platform Ramp M102.2 South	Manual	7/28/2025 3:44:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.307	Bldg M Practice Room M105.1	Manual	7/28/2025 3:46:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.277	Bldg M Restroom M107	Manual	7/28/2025 3:50:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.320	Bldg M Serving Area M119	Manual	7/28/2025 2:56:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.321	Bldg M Serving Area M119	Manual	7/28/2025 3:22:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.301	Bldg M Stage IDF/Storage M103.1	Manual	7/28/2025 3:44:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.276	Bldg M Storage M111	Manual	7/28/2025 3:52:17 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1.4.312	Bldg M Table Storage M102.1	Manual	7/28/2025 3:41:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.134	Duct Actvi Comm B14 PHP B6	Manual	7/28/2025 7:55:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.132	Duct Actvi Comm B14 PHP B7	Manual	7/28/2025 7:55:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.384	Duct C14 East PHP C10	Manual	7/28/2025 12:34:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.380	Duct C14 East PHP C8	Manual	7/28/2025 12:42:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.382	Duct C14 East PHP C9	Manual	7/28/2025 12:34:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.376	Duct C14 West PHP C6	Manual	7/28/2025 12:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.378	Duct C14 West PHP C7	Manual	7/28/2025 12:46:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.146	Duct Clean Room D14 PHP D4	Manual	7/28/2025 7:56:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.148	Duct Clean Room D14 PHP D5	Manual	7/28/2025 7:56:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.144	Duct Corridor B14 PHP B4	Manual	7/28/2025 7:55:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.142	Duct Corridor B14 PHP B5	Manual	7/28/2025 7:55:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.398	Duct Hall M119.1 PHP M2	Manual	7/28/2025 1:00:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.394	Duct Hall M119.6 PHP M3	Manual	7/28/2025 12:59:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.402	Duct Kitchen M119.2 PHP M1	Manual	7/28/2025 1:05:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.139	Duct Library D12 PHP D3	Manual	7/28/2025 7:56:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.137	Duct Library D12 PHP D6	Manual	7/28/2025 7:56:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.135	Duct Library D12 PHP D7	Manual	7/28/2025 7:56:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Duct Detector	1.4.129	Duct Resource Room D11 PHP D1	Manual	7/28/2025 7:56:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.127	Duct Resource Room D11 PHP D9	Manual	7/28/2025 7:56:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.396	Duct RF Area M119.4 MAU M1	Manual	7/28/2025 1:00:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.137	Duct Room B02.1 PHP B2	Manual	7/28/2025 7:55:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.139	Duct Room B14.3 PHP B1	Manual	7/28/2025 7:55:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.388	Duct Room C02 PHP C5	Manual	7/28/2025 12:42:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.391	Duct Room C03 PHP C1	Manual	7/28/2025 12:36:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.394	Duct Room C03 PHP C2	Manual	7/28/2025 12:36:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.386	Duct Room C13.3 PHP C4	Manual	7/28/2025 12:40:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.396	Duct Room C14 PHP C3	Manual	7/28/2025 12:37:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	1.4.404	OS&Y Edison N.W. M117	Manual	7/28/2025 1:29:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	1.2.377	Room A107 Riser Tamper	Manual	7/28/2025 7:55:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	1.2.376	Room A107 Riser Waterflow	Manual	7/28/2025 8:00:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	1.3.147	Room B15 Riser Tamper	Manual	7/28/2025 7:55:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	1.3.146	Room B15 Riser Waterflow	Manual	7/28/2025 7:59:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	1.3.399	Room C12 Riser Tamper	Manual	7/28/2025 12:35:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	1.3.398	Room C12 Riser Waterflow	Manual	7/28/2025 12:37:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	1.4.143	Room D13 Riser Tamper	Manual	7/28/2025 7:55:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Mechanical, Electrosonic, or Pressure Waterflow Device	1.4.142	Room D13 Riser Waterflow	Manual	7/28/2025 7:59:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	1.4.379	Room M116 Riser Tamper	Manual	7/28/2025 1:30:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	1.4.378	Room M116 Riser Waterflow	Manual	7/28/2025 1:31:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Duct Detector	1.3.126	Duct Actvi Comm B14 PHP B10	Manual	7/28/2025 9:42:43 AM
		Functional Inspection	Failed	
Duct Detector	1.3.130	Duct Actvi Comm B14 PHP B8	Manual	7/28/2025 9:43:48 AM
		Functional Inspection	Failed	
Duct Detector	1.3.128	Duct Actvi Comm B14 PHP B9	Manual	7/28/2025 9:43:25 AM
		Functional Inspection	Failed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply	1.2.130	BPS B1 IDF Room B13 (2)12v18ah	Manual	7/28/2025 1:50:01 PM
	Comment:	Battery # 1- 12 v / 18ah Manufacture date- 3/20/24 Load test- 90% Pass/ fail- Pass		
		Battery # 2- 12 v / 18ah Manufacture date- 3/20/24 Load test- 90% Pass/ fail- Pass		
		Make- Power Sonic		
		Model- PS-12180 F2		
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
BPS - Booster Power Supply	1.2.136	BPS C1 IDF Room C13 (2)12v18ah	Manual	7/28/2025 2:21:51 PM
	Comment:	Battery # 1- 12 v / 18ah Manufacture date- 3/20/24 Load test- 80% Pass/ fail- Pass		
		Battery # 2- 12 v / 18ah Manufacture date- 3/20/24 Load test- 80% Pass/ fail- Pass		
		Make- Power Sonic		
		Model- PS-12180 F2		
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply	1.2.148	BPS M1 IDF Room M117 (2)12v18ah	Manual	7/28/2025 2:14:14 PM
	Comment:	Battery # 1- 12 v / 18ah Manufacture date- 3/20/24 Load test- 80% Pass/ fail- Pass		
		Battery # 2- 12 v / 18ah Manufacture date- 3/20/24 Load test- 80% Pass/ fail- Pass		
		Make- Power Sonic		
		Model- PS-12180 F2		
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply	1.2.126	BPS A1 FACP Room A107 (2)12v7ah	Manual	7/28/2025 2:28:37 PM
	Comment:	Battery # 1- 12 v / 7 ah Manufacture date- 12/13/23 Load test- 10% Pass/ fail- Pass		
		Battery # 2- 12 v / 7 ah Manufacture date- 12/13/23 Load test- 100% Pass/ fail- Pass		
		Make- Power Sonic		
		Model- PS-1270F1		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

BPS - Booster Power Supply	1.2.142	BPS D1 IDF Room D10 (2)12v18ah	Manual	7/28/2025 2:07:54 PM
	Comment:	Battery # 1- 12 v / 18ah Manufacture date- 3/20/24 Load test- 40% Pass/ fail- Fail		
		Battery # 2- 12 v / 18ah Manufacture date- 3/20/24 Load test- 90% Pass/ fail- Pass		
		Make- Power Sonic		
		Model- PS-12180 F2		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Device/Equipment Details

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Control Panel					
	Bldg A MDF Room A105 FACP (2)12v55ah	Edwards	EST-3		07/28/2025

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Duct Detector					
1.3.137	Duct Room B02.1 PHP B2				07/28/2025
1.3.139	Duct Room B14.3 PHP B1				07/28/2025
1.3.142	Duct Corridor B14 PHP B5				07/28/2025
1.3.144	Duct Corridor B14 PHP B4				07/28/2025
1.3.132	Duct Actvi Comm B14 PHP B7				07/28/2025
1.3.134	Duct Actvi Comm B14 PHP B6				07/28/2025
1.4.146	Duct Clean Room D14 PHP D4				07/28/2025
1.4.148	Duct Clean Room D14 PHP D5				07/28/2025
1.3.126	Duct Actvi Comm B14 PHP B10				07/28/2025
1.3.128	Duct Actvi Comm B14 PHP B9				07/28/2025
1.3.130	Duct Actvi Comm B14 PHP B8				07/28/2025
1.4.135	Duct Library D12 PHP D7				07/28/2025
1.4.137	Duct Library D12 PHP D6				07/28/2025
1.4.139	Duct Library D12 PHP D3				07/28/2025
1.4.129	Duct Resource Room D11 PHP D1				07/28/2025
1.4.127	Duct Resource Room D11 PHP D9				07/28/2025
1.3.384	Duct C14 East PHP C10				07/28/2025
1.3.382	Duct C14 East PHP C9				07/28/2025
1.3.394	Duct Room C03 PHP C2				07/28/2025
1.3.391	Duct Room C03 PHP C1				07/28/2025
1.3.396	Duct Room C14 PHP C3				07/28/2025
1.3.386	Duct Room C13.3 PHP C4				07/28/2025
1.3.380	Duct C14 East PHP C8				07/28/2025
1.3.388	Duct Room C02 PHP C5				07/28/2025
1.3.378	Duct C14 West PHP C7				07/28/2025
1.3.376	Duct C14 West PHP C6				07/28/2025
1.4.394	Duct Hall M119.6 PHP M3				07/28/2025
1.4.396	Duct RF Area M119.4 MAU M1				07/28/2025
1.4.398	Duct Hall M119.1 PHP M2				07/28/2025
1.4.402	Duct Kitchen M119.2 PHP M1				07/28/2025
Supervisory - Control Valve					
1.3.147	Room B15 Riser Tamper				07/28/2025
1.4.143	Room D13 Riser Tamper				07/28/2025
1.2.377	Room A107 Riser Tamper				07/28/2025
1.3.399	Room C12 Riser Tamper				07/28/2025
1.3.402	Bldg C PIV Riser Room C12				07/28/2025
1.2.378	Bldg A PIV N.E. Riser Room A107				07/28/2025
1.4.404	OS&Y Edison N.W. M117				07/28/2025
1.4.379	Room M116 Riser Tamper				07/28/2025
Mechanical, Electrosonic, or Pressure Waterflow Device					
1.2.376	Room A107 Riser Waterflow				07/28/2025
1.3.146	Room B15 Riser Waterflow				07/28/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.4.142	Room D13 Riser Waterflow				07/28/2025
1.3.398	Room C12 Riser Waterflow				07/28/2025
1.4.378	Room M116 Riser Waterflow				07/28/2025
Smoke Detector - General					
1.2.258	Bldg A Custodial Room A108.2				07/28/2025
1.2.260	Bldg A Workroom A108				07/28/2025
1.2.259	Bldg A Lounge A108.1				07/28/2025
1.2.262	Bldg A Storage Closet A108.3				07/28/2025
1.2.273	Bldg A Restroom A111				07/28/2025
1.2.282	Bldg A Nurses Office A104				07/28/2025
1.2.283	Bldg A Restroom A104.1				07/28/2025
1.2.281	Bldg A Shared Spaces A103				07/28/2025
1.2.280	Bldg A Conference Room A102				07/28/2025
1.2.279	Bldg A Lobby A101				07/28/2025
1.2.275	Bldg A Hallway A110				07/28/2025
1.2.277	Bldg A Vice Principal Office A113				07/28/2025
1.2.276	Bldg A Counseling Office A113				07/28/2025
1.2.274	Bldg A Student Services A109.1				07/28/2025
1.2.271	Bldg A Hallway A109.A				07/28/2025
1.2.269	Bldg A Conference Room A109.7				07/28/2025
1.2.270	Bldg A Student Services 2 A109.2				07/28/2025
1.2.268	Bldg A Vice Principal A109.3				07/28/2025
1.2.267	Bldg A Hallway A109.A				07/28/2025
1.2.266	Bldg A Vice Principal A109.4				07/28/2025
1.2.264	Bldg A Waiting Room A109.8				07/28/2025
1.2.263	Bldg A Principals Office A109.5				07/28/2025
1.2.261	Bldg A Storage A109.6				07/28/2025
1.2.257	Bldg A Fire Riser Room A107				07/28/2025
1.2.256	Bldg A Electrical Room A106				07/28/2025
1.2.255	Bldg A FACP/MDF A105				07/28/2025
1.3.025	Bldg B Classroom B04				07/28/2025
1.3.024	Bldg B Classroom B04				07/28/2025
1.3.013	Bldg B Activity Commons B14.E				07/28/2025
1.3.026	Bldg B Classroom B05				07/28/2025
1.3.012	Bldg B Activity Commons B14.E				07/28/2025
1.3.027	Bldg B Classroom B05				07/28/2025
1.3.011	Bldg B Activity Commons B14.E				07/28/2025
1.3.018	Bldg B Corridor B14				07/28/2025
1.3.010	Bldg B Activity Commons B14.W				07/28/2025
1.3.028	Bldg B Classroom B06				07/28/2025
1.3.008	Bldg B Activity Commons B14.W				07/28/2025
1.3.029	Bldg B Classroom B06				07/28/2025
1.3.009	Bldg B Activity Commons B14.W				07/28/2025
1.3.006	Bldg B Classroom B01				07/28/2025
1.3.023	Bldg B Classroom B03				07/28/2025
1.3.030	Bldg B Classroom B07				07/28/2025
1.3.007	Bldg B Classroom B01				07/28/2025
1.3.022	Bldg B Classroom B03				07/28/2025
1.3.034	Bldg B Classroom B09				07/28/2025
1.3.014	Bldg B Classroom B02				07/28/2025
1.3.031	Bldg B Classroom B07				07/28/2025
1.3.035	Bldg B Classroom B09				07/28/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.3.015	Bldg B Classroom B02				07/28/2025
1.3.016	Bldg B Room B02.1				07/28/2025
1.3.032	Bldg B Classroom B08				07/28/2025
1.3.033	Bldg B Classroom B08				07/28/2025
1.3.020	Bldg B Restroom B14.2				07/28/2025
1.3.017	Bldg B Office B14.3				07/28/2025
1.3.040	Bldg B Room B14.4				07/28/2025
1.3.019	Bldg B Restroom B14.2				07/28/2025
1.3.021	Bldg B Fire Riser Room B15				07/28/2025
1.3.05	Bldg B IDF Room B13				07/28/2025
1.3.037	Bldg B Restroom B11				07/28/2025
1.3.038	Bldg B Restroom B11				07/28/2025
1.3.036	Bldg B Electrical Room B10				07/28/2025
1.4.044	Bldg D Classroom D02 N.E.				07/28/2025
1.4.046	Bldg D Classroom D02 S.E.				07/28/2025
1.4.045	Bldg D Classroom D02 S.W.				07/28/2025
1.4.043	Bldg D Classroom D02 N.W.				07/28/2025
1.4.042	Bldg D Control Room D02.1				07/28/2025
1.4.038	Bldg D Recording Studio D02.1				07/28/2025
1.4.047	Bldg D Classroom D01 N.W.				07/28/2025
1.4.049	Bldg D Classroom D01 S.W.				07/28/2025
1.4.050	Bldg D Classroom D01 S.E.				07/28/2025
1.4.048	Bldg D Classroom D01 N.E.				07/28/2025
1.4.037	Bldg D Clean Room D14				07/28/2025
1.4.032	Bldg D Classroom D04 N.E.				07/28/2025
1.4.034	Bldg D Classroom D04 S.E.				07/28/2025
1.4.031	Bldg D Classroom D04 N.W.				07/28/2025
1.4.035	Bldg D Art Storage D04.1				07/28/2025
1.4.036	Bldg D Kiln Room D04.2				07/28/2025
1.4.033	Bldg D Classroom D04 S.W.				07/28/2025
1.4.028	Bldg D Book Storage D12.2				07/28/2025
1.4.029	Bldg D Book Storage D12.2				07/28/2025
1.4.027	Bldg D Library D12 N.E.				07/28/2025
1.4.025	Bldg D Library D12 N.W.				07/28/2025
1.4.024	Bldg D Library D12 W.				07/28/2025
1.4.026	Bldg D Library D12 S.E.				07/28/2025
1.4.021	Bldg D Classroom D05 N.E.				07/28/2025
1.4.023	Bldg D Classroom D05 S.E.				07/28/2025
1.4.022	Bldg D Classroom D05 S.W.				07/28/2025
1.4.020	Bldg D Classroom D05 N.W.				07/28/2025
1.4.016	Bldg D Classroom D06 S.W.				07/28/2025
1.4.007	Bldg D Resource Room D11				07/28/2025
1.4.008	Bldg D Classroom D06 N.W.				07/28/2025
1.4.019	Bldg D Classroom D06 N.E.				07/28/2025
1.4.017	Bldg D Classroom D06 S.E.				07/28/2025
1.4.008	Bldg D Classroom D08 N.E.				07/28/2025
1.4.010	Bldg D Classroom D08 S.W.				07/28/2025
1.4.011	Bldg D Classroom D08 S.E.				07/28/2025
1.4.013	Bldg D Classroom D07 S.E.				07/28/2025
1.4.009	Bldg D Classroom D08 N.W.				07/28/2025
1.4.006	Bldg D Electrical Room D09				07/28/2025
1.4.015	Bldg D Classroom D07 N.E.				07/28/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.4.014	Bldg D Classroom D07 N.W.				07/28/2025
1.4.005	Bldg D IDF Room D10				07/28/2025
1.4.012	Bldg D Classroom D07 S.W.				07/28/2025
1.4.030	Bldg D Fire Riser Room D13				07/28/2025
1.4.041	Bldg D Restroom D15				07/28/2025
1.3.255	Bldg C IDF Room C13				07/28/2025
1.3.257	Bldg C Classroom C01				07/28/2025
1.3.256	Bldg C Classroom C01				07/28/2025
1.3.286	Bldg C Classroom C09				07/28/2025
1.3.285	Bldg C Classroom C09				07/28/2025
1.3.259	Bldg C Activity Common C14 East				07/28/2025
1.3.258	Bldg C Activity Common C14 East				07/28/2025
1.3.260	Bldg C Activity Common C14 East				07/28/2025
1.3.264	Bldg C ILS Classroom C02				07/28/2025
1.3.265	Bldg C ILS Classroom C02				07/28/2025
1.3.266	Bldg C ILS Classroom C02				07/28/2025
1.3.283	Bldg C Classroom C08				07/28/2025
1.3.268	Bldg C Restroom C02.1				07/28/2025
1.3.284	Bldg C Classroom C08				07/28/2025
1.3.261	Bldg C Activity Common C14 West				07/28/2025
1.3.282	Bldg C Classroom C07				07/28/2025
1.3.281	Bldg C Classroom C07				07/28/2025
1.3.274	Bldg C Classroom C03				07/28/2025
1.3.273	Bldg C Classroom C03				07/28/2025
1.3.269	Bldg C Corridor C14				07/28/2025
1.3.267	Bldg C Cust/Storage Room C14.3				07/28/2025
1.3.271	Bldg C Restroom C14.2				07/28/2025
1.3.279	Bldg C Classroom C06				07/28/2025
1.3.270	Bldg C Restroom C14.1				07/28/2025
1.3.280	Bldg C Classroom C06				07/28/2025
1.3.262	Bldg C Activity Common C14 West				07/28/2025
1.3.263	Bldg C Activity Common C14 West				07/28/2025
1.3.278	Bldg C Classroom C05				07/28/2025
1.3.277	Bldg C Classroom C05				07/28/2025
1.3.276	Bldg C Classroom C04				07/28/2025
1.3.275	Bldg C Classroom C04				07/28/2025
1.4.274	Bldg M Boys Locker Room M112 South				07/28/2025
1.4.272	Bldg M Boys Locker Room M112 North				07/28/2025
1.4.265	Bldg M Boys Locker Restroom M113.2				07/28/2025
1.4.266	Bldg M Boys Locker Restroom M113.1				07/28/2025
1.4.267	Bldg M Boys Locker Restroom M113				07/28/2025
1.4.271	Bldg M Boys Locker Room M112 N.W.				07/28/2025
1.4.270	Bldg M Office M112.1				07/28/2025
1.4.261	Bldg M Girls Locker Room M114 South				07/28/2025
1.4.258	Bldg M Girls Locker Room M114 N.W.				07/28/2025
1.4.269	Bldg M Girls Locker Office Ice M114.1				07/28/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.4.260	Bldg M Girls Locker Room M114 North				07/28/2025
1.4.259	Bldg M Girls Locker Room M114 N.E.				07/28/2025
1.4.264	Bldg M Girls Locker Restroom M115				07/28/2025
1.4.262	Bldg M Girls Locker Restroom M115.1				07/28/2025
1.4.263	Bldg M Girls Locker Restroom M115.2				07/28/2025
1.4.320	Bldg M Serving Area M119				07/28/2025
1.3.290	Bldg C Restroom C12				07/28/2025
1.4.321	Bldg M Serving Area M119				07/28/2025
1.4.299	Bldg M Gym Middle M102				07/28/2025
1.4.296	Bldg M Gym Middle M102				07/28/2025
1.4.293	Bldg M Gym Middle M102				07/28/2025
1.4.290	Bldg M Gym Middle M102				07/28/2025
1.4.287	Bldg M Gym Middle M102				07/28/2025
1.4.284	Bldg M Gym Middle M102				07/28/2025
1.4.281	Bldg M Gym Middle M102				07/28/2025
1.4.282	Bldg M Gym East M102				07/28/2025
1.4.285	Bldg M Gym East M102				07/28/2025
1.4.288	Bldg M Gym East M102				07/28/2025
1.4.291	Bldg M Gym East M102				07/28/2025
1.4.294	Bldg M Gym East M102				07/28/2025
1.4.297	Bldg M Gym East M102				07/28/2025
1.4.300	Bldg M Gym East M102				07/28/2025
1.4.298	Bldg M Gym West M102				07/28/2025
1.4.295	Bldg M Gym West M102				07/28/2025
1.4.292	Bldg M Gym West M102				07/28/2025
1.4.289	Bldg M Gym East M102				07/28/2025
1.4.286	Bldg M Gym West M102				07/28/2025
1.4.283	Bldg M Gym West M102				07/28/2025
1.4.280	Bldg M Gym West M102				07/28/2025
1.4.318	Bldg M Dry Storage M119.3				07/28/2025
1.4.315	Bldg M Gym Restroom M101.2				07/28/2025
1.4.313	Bldg M Gym Vestibule M101				07/28/2025
1.4.393	Bldg M Gym Vestibule M102				07/28/2025
1.4.314	Bldg M Gym Restroom M101.1				07/28/2025
1.4.312	Bldg M Table Storage M102.1				07/28/2025
1.4.310	Bldg M Platform M103				07/28/2025
1.4.311	Bldg M Platform M103				07/28/2025
1.4.309	Bldg M Platform Ramp M102.2				07/28/2025
1.4.301	Bldg M Stage IDF/Storage M103.1				07/28/2025
1.4.308	Bldg M Platform Ramp M102.2 South				07/28/2025
1.4.304	Bldg M Music Classroom M105				07/28/2025
1.4.303	Bldg M Music Classroom M105				07/28/2025
1.4.307	Bldg M Practice Room M105.1				07/28/2025
1.4.305	Bldg M PE Classroom M106				07/28/2025
1.4.306	Bldg M PE Classroom M106				07/28/2025
1.4.277	Bldg M Restroom M107				07/28/2025
1.4.278	Bldg M Boys Restroom M109				07/28/2025
1.4.279	Bldg M Girls Restroom M110				07/28/2025
1.4.276	Bldg M Storage M111				07/28/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.4.255	Bldg M Electrical Room M118				07/28/2025
1.4.256	Bldg M IDF Room M117				07/28/2025
Manual Pull Station					
1.2.382	Bldg A Admin A101 Pullstation				07/28/2025
1.4.391	Bldg M Gym Vestibule M101 Pullstation				07/28/2025
Heat Detector - Restorable Spot					
1.3.136	Bldg B Plumbing Chase Restroom B14.4				07/28/2025
1.3.141	Bldg B Plumbing Chase Restroom B14.1				07/28/2025
1.3.150	Bldg B Plumbing Chase Restroom B11				07/28/2025
1.4.154	Bldg D Restroom D15				07/28/2025
1.2.380	Bldg A Attic Restroom A111				07/28/2025
1.3.393	Bldg C Plumbing Chase Restroom C14.1				07/28/2025
1.3.390	Bldg C Plumbing Chase Restroom C02.1				07/28/2025
1.3.401	Bldg C Plumbing Chase Restroom C12				07/28/2025
1.4.317	Bldg M Dish Washing M119.6				07/28/2025
1.4.319	Bldg M Kitchen M119.2				07/28/2025
1.4.401	Bldg M Kitchen Chase M119.2				07/28/2025
1.4.392	Bldg M Attic Restroom M101.2				07/28/2025

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
BPS - Booster Power Supply					
1.2.148	BPS M1 IDF Room M117 (2) 12v18ah				07/28/2025
1.2.142	BPS D1 IDF Room D10 (2) 12v18ah				07/28/2025
1.2.126	BPS A1 FACP Room A107 (2) 12v7ah				07/28/2025
1.2.130	BPS B1 IDF Room B13 (2) 12v18ah				07/28/2025
1.2.136	BPS C1 IDF Room C13 (2) 12v18ah				07/28/2025