

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

Katherine Johnson Middle School

2641 Kent Drive  
Sacramento, California 95821  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Thursday, July 31, 2025

Test Session :23 Jul 2025 11:15

Test Plans : Fire Alarm - Annual

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	Katherine Johnson Middle School	CONTACT
ADDRESS	2641 Kent Drive	PHONE
CITY/STATE/ZIP	Sacramento, California 95821	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Initiating Device	199	199(100%)	199(100%)	0(0%)
Fire Control Panel	1	1(100%)	1(100%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 31, 2025

ACCEPTED BY 07/31/2025

Building Representative

*Riley*  
TESTED BY 07/31/2025  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS / SCAN ADDRESS	DESCRIPTION	FACU - A105 MDF (2)12v 55ah
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE	07/22/2025	

# Testing Details

## Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel		FACU - A105 MDF (2)12v 55ah	Manual	7/31/2025 7:23:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

## Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.4.035	Art Storage D04.1	Manual	7/23/2025 12:44:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.028	Book Storage D12.2	Manual	7/23/2025 12:46:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.029	Book Storage D12.2	Manual	7/23/2025 12:46:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.272	Boys Locker Room M112	Manual	7/23/2025 1:44:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.274	Boys Locker Room M112	Manual	7/23/2025 1:45:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.271	Boys Locker Room M112	Manual	7/23/2025 1:46:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.275	Boys Locker Room M112	Manual	7/23/2025 1:46:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.267	Boys Locker Room M113	Manual	7/23/2025 1:45:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.3.150	Boys Restroom Attic B11	Manual	7/23/2025 1:54:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.381	Boys Restroom Attic M109	Manual	7/23/2025 1:57:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.036	Boys Restroom B11	Manual	7/23/2025 1:30:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.037	Boys Restroom B11	Manual	7/23/2025 1:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.278	Boys Restroom M109	Manual	7/23/2025 1:49:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.388	Claaroom C02 PHP C5	Manual	7/23/2025 2:05:38 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1.3.006	Classroom B01	Manual	7/23/2025 1:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.007	Classroom B01	Manual	7/23/2025 1:30:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.014	Classroom B02	Manual	7/23/2025 1:26:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.015	Classroom B02	Manual	7/23/2025 1:26:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.023	Classroom B03	Manual	7/23/2025 1:22:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.022	Classroom B03	Manual	7/23/2025 1:22:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.024	Classroom B04	Manual	7/23/2025 1:18:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.025	Classroom B04	Manual	7/23/2025 1:19:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.026	Classroom B05	Manual	7/23/2025 1:20:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.040	Classroom B05	Manual	7/23/2025 1:20:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.027	Classroom B06	Manual	7/23/2025 1:21:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.028	Classroom B06	Manual	7/23/2025 1:21:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.029	Classroom B07	Manual	7/23/2025 1:22:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.030	Classroom B07	Manual	7/23/2025 1:23:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.031	Classroom B08	Manual	7/23/2025 1:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.032	Classroom B08	Manual	7/23/2025 1:28:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.033	Classroom B09	Manual	7/23/2025 1:29:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.034	Classroom B09	Manual	7/23/2025 1:29:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.3.257	Classroom C01	Manual	7/23/2025 1:15:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.256	Classroom C01	Manual	7/23/2025 1:17:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.266	Classroom C02	Manual	7/23/2025 1:08:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.264	Classroom C02	Manual	7/23/2025 1:09:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.265	Classroom C02	Manual	7/23/2025 1:10:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.273	Classroom C03	Manual	7/23/2025 1:02:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.274	Classroom C03	Manual	7/23/2025 1:02:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.276	Classroom C04	Manual	7/23/2025 1:00:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.275	Classroom C04	Manual	7/23/2025 1:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.278	Classroom C05	Manual	7/23/2025 12:59:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.277	Classroom C05	Manual	7/23/2025 1:00:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.279	Classroom C06	Manual	7/23/2025 1:03:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.281	Classroom C07	Manual	7/23/2025 1:04:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.282	Classroom C07	Manual	7/23/2025 1:04:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.283	Classroom C08	Manual	7/23/2025 1:10:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.284	Classroom C08	Manual	7/23/2025 1:11:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.286	Classroom C09	Manual	7/23/2025 1:14:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.285	Classroom C09	Manual	7/23/2025 1:18:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.048	Classroom D01	Manual	7/23/2025 12:39:25 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.050	Classroom D01	Manual	7/23/2025 12:39:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.049	Classroom D01	Manual	7/23/2025 12:39:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.047	Classroom D01	Manual	7/23/2025 12:40:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.045	Classroom D02	Manual	7/23/2025 12:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.043	Classroom D02	Manual	7/23/2025 12:41:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.044	Classroom D02	Manual	7/23/2025 12:41:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.046	Classroom D02	Manual	7/23/2025 12:42:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.032	Classroom D04	Manual	7/23/2025 12:43:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.034	Classroom D04	Manual	7/23/2025 12:43:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.031	Classroom D04	Manual	7/23/2025 12:45:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.033	Classroom D04	Manual	7/23/2025 12:45:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.020	Classroom D05	Manual	7/23/2025 12:48:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.022	Classroom D05	Manual	7/23/2025 12:48:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.021	Classroom D05	Manual	7/23/2025 12:48:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.023	Classroom D05	Manual	7/23/2025 12:50:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.016	Classroom D06	Manual	7/23/2025 12:51:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.018	Classroom D06	Manual	7/23/2025 12:51:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.019	Classroom D06	Manual	7/23/2025 12:52:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.4.017	Classroom D06	Manual	7/23/2025 12:52:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.013	Classroom D07	Manual	7/23/2025 12:52:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.012	Classroom D07	Manual	7/23/2025 12:53:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.014	Classroom D07	Manual	7/23/2025 12:53:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.015	Classroom D07	Manual	7/23/2025 12:53:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.008	Classroom D08	Manual	7/23/2025 12:55:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.011	Classroom D08	Manual	7/23/2025 12:56:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.009	Classroom D08	Manual	7/23/2025 12:56:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.010	Classroom D08	Manual	7/23/2025 12:57:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.305	Classroom M106	Manual	7/23/2025 1:47:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.306	Classroom M106	Manual	7/23/2025 1:48:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.037	Clean Room D14	Manual	7/23/2025 12:40:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.4.148	Clean Room D14 PHP D4	Manual	7/23/2025 1:59:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.4.146	Clean Room D14 PHP D5	Manual	7/23/2025 2:00:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.2.278	Clerical A115	Manual	7/23/2025 12:28:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.2.280	Conference Room A102	Manual	7/23/2025 12:36:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.042	Control Room D02.1	Manual	7/23/2025 12:43:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.018	Corridor B14	Manual	7/23/2025 1:24:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.144	Corridor B14 PHP B4	Manual	7/23/2025 2:06:49 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.142	Corridor B14 PHP B5	Manual	7/23/2025 2:07:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.269	Corridor C14	Manual	7/23/2025 1:05:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.386	Cust Room C14.3 PHP C4	Manual	7/23/2025 2:05:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.258	Custodial Room A108.2	Manual	7/23/2025 12:30:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.267	Custodial Room C14.3	Manual	7/23/2025 1:07:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.317	Dishwashing Heat M119.6	Manual	7/23/2025 1:55:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.318	Dry Storage M119.3	Manual	7/23/2025 1:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.259	Girls Locker Room M114	Manual	7/23/2025 1:40:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.260	Girls Locker Room M114	Manual	7/23/2025 1:40:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.261	Girls Locker Room M114	Manual	7/23/2025 1:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.258	Girls Locker Room M114	Manual	7/23/2025 1:43:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.382	Girls Restroom Attic M110	Manual	7/23/2025 1:57:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.288	Girls Restroom C11	Manual	7/23/2025 1:49:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.289	Girls Restroom C11	Manual	7/23/2025 1:50:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.279	Girls Restroom M110	Manual	7/23/2025 1:48:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.264	Girls Restroom M115	Manual	7/23/2025 1:41:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1.4.383	Gym Pull	Manual	7/23/2025 2:13:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1.4.384	Gym Pull	Manual	7/23/2025 2:14:19 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Manual Pull Station	1.4.391	Gym Vestibule Pull M101	Manual	7/23/2025 2:13:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1.4.393	Gym Vestibule Pull M101	Manual	7/23/2025 2:14:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.275	Hallway A110	Manual	7/23/2025 11:22:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.271	Hallway A110	Manual	7/23/2025 12:26:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.267	Hallway A110	Manual	7/23/2025 12:26:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.401	Hallway Attic Heat M119.1	Manual	7/23/2025 1:56:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.396	Hallway M119.1 MAU M1	Manual	7/23/2025 2:11:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.402	Hallway M119.1 PHP M1	Manual	7/23/2025 2:12:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.398	Hallway M119.1 PHP M2	Manual	7/23/2025 2:11:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.394	Hallway M119.1 PHP M3	Manual	7/23/2025 2:10:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.036	Kiln Room D04.2	Manual	7/23/2025 1:52:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.319	Kitchen Heat M119.2	Manual	7/23/2025 1:55:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.268	Laundry/Storage M112.2	Manual	7/23/2025 1:42:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.027	Library D12	Manual	7/23/2025 12:47:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.024	Library D12	Manual	7/23/2025 12:47:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.025	Library D12	Manual	7/23/2025 12:47:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.133	Library D12 PHP D2	Manual	7/23/2025 2:02:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.139	Library D12 PHP D3	Manual	7/23/2025 2:01:07 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Duct Detector	1.4.137	Library D12 PHP D6	Manual	7/23/2025 2:01:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.135	Library D12 PHP D7	Manual	7/23/2025 2:01:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.131	Library D12 PHP D8	Manual	7/23/2025 2:02:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.279	Lobby A101	Manual	7/23/2025 12:37:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1.2.382	Lobby Pull A101	Manual	7/23/2025 2:12:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.259	Lounge Room A108.1	Manual	7/23/2025 12:28:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.017	MTSS Room B14.3	Manual	7/23/2025 1:25:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.4.385	Music M105 PHP M5	Manual	7/23/2025 2:10:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.303	Music Room M105	Manual	7/23/2025 1:32:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.304	Music Room M105	Manual	7/23/2025 1:32:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.282	Nurses Room A104	Manual	7/23/2025 12:29:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.270	Office M112.1	Manual	7/23/2025 1:46:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.269	Office M114.1	Manual	7/23/2025 1:43:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.310	Platform M103	Manual	7/23/2025 1:33:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.311	Platform M103	Manual	7/23/2025 1:34:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.308	Platform Ramp M102.2	Manual	7/23/2025 1:33:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.309	Platform Ramp M102.2	Manual	7/23/2025 1:34:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.307	Practice Room M105.1	Manual	7/23/2025 1:35:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.2.263	Principal Office A109.5	Manual	7/23/2025 12:34:54 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.016	Quiet Room B02.1	Manual	7/23/2025 1:27:23 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.016	Functional Inspection	Passed	
Duct Detector	1.3.137	Quiet Room B02.1 PHP B2	Manual	7/23/2025 2:09:12 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.038	Record Studio D02.2	Manual	7/23/2025 12:42:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.038	Functional Inspection	Passed	
Smoke Detector - General	1.4.007	Resource Room D11	Manual	7/23/2025 12:50:58 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.007	Functional Inspection	Passed	
Smoke Detector - General	1.2.283	Restroom A104.1	Manual	7/23/2025 12:30:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.283	Functional Inspection	Passed	
Smoke Detector - General	1.2.273	Restroom A111	Manual	7/23/2025 12:37:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.273	Functional Inspection	Passed	
Smoke Detector - General	1.2.272	Restroom A112	Manual	7/23/2025 12:27:43 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.2.272	Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.2.383	Restroom Attic A104.1	Manual	7/23/2025 1:52:18 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	1.2.383	Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.2.380	Restroom Attic A111	Manual	7/23/2025 1:51:44 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	1.2.380	Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.3.141	Restroom Attic B14.1	Manual	7/23/2025 1:53:43 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	1.3.141	Functional Inspection	Passed	
Heat Detector - Restorable Spot	1.4.150	Restroom Attic D15	Manual	7/23/2025 1:58:14 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	1.4.150	Functional Inspection	Passed	
Smoke Detector - General	1.3.019	Restroom B14.2	Manual	7/23/2025 1:25:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.019	Functional Inspection	Passed	
Smoke Detector - General	1.3.268	Restroom C02.1	Manual	7/23/2025 1:08:27 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.268	Functional Inspection	Passed	
Smoke Detector - General	1.3.270	Restroom C14.1	Manual	7/23/2025 1:05:52 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.270	Functional Inspection	Passed	
Smoke Detector - General	1.3.271	Restroom C14.2	Manual	7/23/2025 1:06:21 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.3.271	Functional Inspection	Passed	
Smoke Detector - General	1.4.041	Restroom D15	Manual	7/23/2025 1:50:34 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.041	Functional Inspection	Passed	
Smoke Detector - General	1.4.314	Restroom M101.1	Manual	7/23/2025 1:37:09 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	1.4.314	Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.4.315	Restroom M101.2	Manual	7/23/2025 1:37:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.4.277	Restroom M107	Manual	7/23/2025 1:47:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1.4.380	Restroom Stall Attic M115.1	Manual	7/23/2025 1:56:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.013	Room B14	Manual	7/23/2025 1:19:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.012	Room B14	Manual	7/23/2025 1:20:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.011	Room B14	Manual	7/23/2025 1:23:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.010	Room B14	Manual	7/23/2025 1:26:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.008	Room B14	Manual	7/23/2025 1:28:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.009	Room B14	Manual	7/23/2025 1:28:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.126	Room B14 PHP B10	Manual	7/23/2025 2:09:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.134	Room B14 PHP B6	Manual	7/23/2025 2:07:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.132	Room B14 PHP B7	Manual	7/23/2025 2:08:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.130	Room B14 PHP B8	Manual	7/23/2025 2:08:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.128	Room B14 PHP B9	Manual	7/23/2025 2:08:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.391	Room C03 PHP C1	Manual	7/23/2025 2:03:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Duct Detector	1.3.394	Room C03 PHP C2	Manual	7/23/2025 2:04:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.263	Room C14	Manual	7/23/2025 1:01:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.262	Room C14	Manual	7/23/2025 1:02:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1.3.260	Room C14	Manual	7/23/2025 1:07:56 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.258	Room C14	Manual	7/23/2025 1:12:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.3.259	Room C14	Manual	7/23/2025 1:13:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.384	Room C14 PHP C10	Manual	7/23/2025 2:03:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.378	Room C14 PHP C7	Manual	7/23/2025 2:06:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.380	Room C14 PHP C8	Manual	7/23/2025 2:04:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Duct Detector	1.3.382	Room C14 PHP C9	Manual	7/23/2025 2:03:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.269	Secretary Office A109.7	Manual	7/23/2025 12:33:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.321	Serving M119	Manual	7/23/2025 1:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.320	Serving M119	Manual	7/23/2025 1:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.281	Shared Space A103	Manual	7/23/2025 12:36:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.301	Stage Storage/IDF M103.1	Manual	7/23/2025 1:35:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.262	Storage Room A108.3	Manual	7/23/2025 12:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.261	Storage Room A109.6	Manual	7/23/2025 12:35:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.266	Student Services A109.4	Manual	7/23/2025 12:34:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.312	Table Storage M102.1	Manual	7/23/2025 1:36:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.4.313	Vestibule M101	Manual	7/23/2025 1:36:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.277	Vice Principal Office A113	Manual	7/23/2025 12:31:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.276	Vice Principal Office A114	Manual	7/23/2025 12:32:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1.2.264	Waiting Room A109.8	Manual	7/23/2025 12:27:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1.2.260	Work Room A108	Manual	7/23/2025 12:38:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

# Device/Equipment Details

## Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Control Panel					
	FACU - A105 MDF (2)12v 55ah				07/23/2025

## Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
1.2.275	Hallway A110				07/23/2025
1.2.271	Hallway A110				07/23/2025
1.2.267	Hallway A110				07/23/2025
1.2.264	Waiting Room A109.8				07/23/2025
1.2.272	Restroom A112				07/23/2025
1.2.259	Lounge Room A108.1				07/23/2025
1.2.278	Clerical A115				07/23/2025
1.2.282	Nurses Room A104				07/23/2025
1.2.283	Restroom A104.1				07/23/2025
1.2.258	Custodial Room A108.2				07/23/2025
1.2.277	Vice Principal Office A113				07/23/2025
1.2.276	Vice Principal Office A114				07/23/2025
1.2.269	Secretary Office A109.7				07/23/2025
1.2.266	Student Services A109.4				07/23/2025
1.2.263	Principal Office A109.5				07/23/2025
1.2.261	Storage Room A109.6				07/23/2025
1.2.281	Shared Space A103				07/23/2025
1.2.280	Conference Room A102				07/23/2025
1.2.279	Lobby A101				07/23/2025
1.2.273	Restroom A111				07/23/2025
1.2.260	Work Room A108				07/23/2025
1.2.262	Storage Room A108.3				07/23/2025
1.4.048	Classroom D01				07/23/2025
1.4.050	Classroom D01				07/23/2025
1.4.049	Classroom D01				07/23/2025
1.4.047	Classroom D01				07/23/2025
1.4.037	Clean Room D14				07/23/2025
1.4.045	Classroom D02				07/23/2025
1.4.043	Classroom D02				07/23/2025
1.4.044	Classroom D02				07/23/2025
1.4.046	Classroom D02				07/23/2025
1.4.038	Record Studio D02.2				07/23/2025
1.4.042	Control Room D02.1				07/23/2025
1.4.032	Classroom D04				07/23/2025
1.4.034	Classroom D04				07/23/2025
1.4.035	Art Storage D04.1				07/23/2025
1.4.031	Classroom D04				07/23/2025
1.4.033	Classroom D04				07/23/2025
1.4.028	Book Storage D12.2				07/23/2025
1.4.029	Book Storage D12.2				07/23/2025
1.4.027	Library D12				07/23/2025
1.4.024	Library D12				07/23/2025
1.4.025	Library D12				07/23/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.4.020	Classroom D05				07/23/2025
1.4.022	Classroom D05				07/23/2025
1.4.021	Classroom D05				07/23/2025
1.4.023	Classroom D05				07/23/2025
1.4.007	Resource Room D11				07/23/2025
1.4.016	Classroom D06				07/23/2025
1.4.018	Classroom D06				07/23/2025
1.4.019	Classroom D06				07/23/2025
1.4.017	Classroom D06				07/23/2025
1.4.013	Classroom D07				07/23/2025
1.4.012	Classroom D07				07/23/2025
1.4.014	Classroom D07				07/23/2025
1.4.015	Classroom D07				07/23/2025
1.4.008	Classroom D08				07/23/2025
1.4.011	Classroom D08				07/23/2025
1.4.009	Classroom D08				07/23/2025
1.4.010	Classroom D08				07/23/2025
1.3.278	Classroom C05				07/23/2025
1.3.277	Classroom C05				07/23/2025
1.3.276	Classroom C04				07/23/2025
1.3.263	Room C14				07/23/2025
1.3.275	Classroom C04				07/23/2025
1.3.273	Classroom C03				07/23/2025
1.3.262	Room C14				07/23/2025
1.3.274	Classroom C03				07/23/2025
1.3.279	Classroom C06				07/23/2025
1.3.281	Classroom C07				07/23/2025
1.3.282	Classroom C07				07/23/2025
1.3.269	Corridor C14				07/23/2025
1.3.270	Restroom C14.1				07/23/2025
1.3.271	Restroom C14.2				07/23/2025
1.3.267	Custodial Room C14.3				07/23/2025
1.3.260	Room C14				07/23/2025
1.3.268	Restroom C02.1				07/23/2025
1.3.266	Classroom C02				07/23/2025
1.3.264	Classroom C02				07/23/2025
1.3.265	Classroom C02				07/23/2025
1.3.283	Classroom C08				07/23/2025
1.3.284	Classroom C08				07/23/2025
1.3.258	Room C14				07/23/2025
1.3.259	Room C14				07/23/2025
1.3.286	Classroom C09				07/23/2025
1.3.257	Classroom C01				07/23/2025
1.3.256	Classroom C01				07/23/2025
1.3.285	Classroom C09				07/23/2025
1.3.024	Classroom B04				07/23/2025
1.3.025	Classroom B04				07/23/2025
1.3.013	Room B14				07/23/2025
1.3.026	Classroom B05				07/23/2025
1.3.040	Classroom B05				07/23/2025
1.3.012	Room B14				07/23/2025
1.3.027	Classroom B06				07/23/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.3.028	Classroom B06				07/23/2025
1.3.023	Classroom B03				07/23/2025
1.3.022	Classroom B03				07/23/2025
1.3.029	Classroom B07				07/23/2025
1.3.030	Classroom B07				07/23/2025
1.3.011	Room B14				07/23/2025
1.3.018	Corridor B14				07/23/2025
1.3.019	Restroom B14.2				07/23/2025
1.3.017	MTSS Room B14.3				07/23/2025
1.3.010	Room B14				07/23/2025
1.3.014	Classroom B02				07/23/2025
1.3.015	Classroom B02				07/23/2025
1.3.016	Quiet Room B02.1				07/23/2025
1.3.031	Classroom B08				07/23/2025
1.3.032	Classroom B08				07/23/2025
1.3.008	Room B14				07/23/2025
1.3.009	Room B14				07/23/2025
1.3.033	Classroom B09				07/23/2025
1.3.034	Classroom B09				07/23/2025
1.3.006	Classroom B01				07/23/2025
1.3.007	Classroom B01				07/23/2025
1.3.036	Boys Restroom B11				07/23/2025
1.3.037	Boys Restroom B11				07/23/2025
1.4.303	Music Room M105				07/23/2025
1.4.304	Music Room M105				07/23/2025
1.4.308	Platform Ramp M102.2				07/23/2025
1.4.310	Platform M103				07/23/2025
1.4.311	Platform M103				07/23/2025
1.4.309	Platform Ramp M102.2				07/23/2025
1.4.301	Stage Storage/IDF M103.1				07/23/2025
1.4.307	Practice Room M105.1				07/23/2025
1.4.312	Table Storage M102.1				07/23/2025
1.4.313	Vestibule M101				07/23/2025
1.4.314	Restroom M101.1				07/23/2025
1.4.315	Restroom M101.2				07/23/2025
1.4.321	Serving M119				07/23/2025
1.4.320	Serving M119				07/23/2025
1.4.318	Dry Storage M119.3				07/23/2025
1.4.259	Girls Locker Room M114				07/23/2025
1.4.260	Girls Locker Room M114				07/23/2025
1.4.261	Girls Locker Room M114				07/23/2025
1.4.264	Girls Restroom M115				07/23/2025
1.4.268	Laundry/Storage M112.2				07/23/2025
1.4.258	Girls Locker Room M114				07/23/2025
1.4.269	Office M114.1				07/23/2025
1.4.272	Boys Locker Room M112				07/23/2025
1.4.267	Boys Locker Room M113				07/23/2025
1.4.274	Boys Locker Room M112				07/23/2025
1.4.270	Office M112.1				07/23/2025
1.4.271	Boys Locker Room M112				07/23/2025
1.4.275	Boys Locker Room M112				07/23/2025
1.4.277	Restroom M107				07/23/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.4.305	Classroom M106				07/23/2025
1.4.306	Classroom M106				07/23/2025
1.4.279	Girls Restroom M110				07/23/2025
1.4.278	Boys Restroom M109				07/23/2025
1.3.288	Girls Restroom C11				07/23/2025
1.3.289	Girls Restroom C11				07/23/2025
1.4.041	Restroom D15				07/23/2025
<b>Heat Detector - Restorable Spot</b>					
1.2.380	Restroom Attic A111				07/23/2025
1.2.383	Restroom Attic A104.1				07/23/2025
1.4.036	Kiln Room D04.2				07/23/2025
1.3.141	Restroom Attic B14.1				07/23/2025
1.3.150	Boys Restroom Attic B11				07/23/2025
1.4.317	Dishwashing Heat M119.6				07/23/2025
1.4.319	Kitchen Heat M119.2				07/23/2025
1.4.401	Hallway Attic Heat M119.1				07/23/2025
1.4.380	Restroom Stall Attic M115.1				07/23/2025
1.4.381	Boys Restroom Attic M109				07/23/2025
1.4.382	Girls Restroom Attic M110				07/23/2025
1.4.150	Restroom Attic D15				07/23/2025
<b>Duct Detector</b>					
1.4.148	Clean Room D14 PHP D4				07/23/2025
1.4.146	Clean Room D14 PHP D5				07/23/2025
1.4.139	Library D12 PHP D3				07/23/2025
1.4.137	Library D12 PHP D6				07/23/2025
1.4.135	Library D12 PHP D7				07/23/2025
1.4.133	Library D12 PHP D2				07/23/2025
1.4.131	Library D12 PHP D8				07/23/2025
1.3.384	Room C14 PHP C10				07/23/2025
1.3.382	Room C14 PHP C9				07/23/2025
1.3.391	Room C03 PHP C1				07/23/2025
1.3.394	Room C03 PHP C2				07/23/2025
1.3.380	Room C14 PHP C8				07/23/2025
1.3.386	Cust Room C14.3 PHP C4				07/23/2025
1.3.388	Claroom C02 PHP C5				07/23/2025
1.3.378	Room C14 PHP C7				07/23/2025
1.3.144	Corridor B14 PHP B4				07/23/2025
1.3.142	Corridor B14 PHP B5				07/23/2025
1.3.134	Room B14 PHP B6				07/23/2025
1.3.132	Room B14 PHP B7				07/23/2025
1.3.130	Room B14 PHP B8				07/23/2025
1.3.128	Room B14 PHP B9				07/23/2025
1.3.137	Quiet Room B02.1 PHP B2				07/23/2025
1.3.126	Room B14 PHP B10				07/23/2025
1.4.385	Music M105 PHP M5				07/23/2025
1.4.394	Hallway M119.1 PHP M3				07/23/2025
1.4.396	Hallway M119.1 MAU M1				07/23/2025
1.4.398	Hallway M119.1 PHP M2				07/23/2025
1.4.402	Hallway M119.1 PHP M1				07/23/2025
<b>Manual Pull Station</b>					
1.2.382	Lobby Pull A101				07/23/2025
1.4.383	Gym Pull				07/23/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1.4.391	Gym Vestibule Pull M101				07/23/2025
1.4.393	Gym Vestibule Pull M101				07/23/2025
1.4.384	Gym Pull				07/23/2025