

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

DYER KELLY ELEMENTARY

2236 EDISON AVE  
SACRAMENTO, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, July 31, 2025

Test Session :30 Jul 2025 05:56

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	DYER KELLY ELEMENTARY	CONTACT
ADDRESS	2236 EDISON AVE	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Power Supplies	8	8(100%)	1(13%)	7(88%)
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Fire Control Panel	2	2(100%)	1(50%)	1(50%)
Initiating Device	236	232(98%)	231(98%)	1(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 31, 2025

ACCEPTED BY      07/31/2025  
  
Building Representative

TESTED BY        
07/31/2025  
Riley Goyet  
Technician

## System Details

### Control Units

ADDRESS / SCAN ADDRESS	FACP Room A110 (2)12v55ah	DESCRIPTION
MANUFACTURER		S/W VERSION
MODEL		LAST UPDATE
SERIAL NUMBER		S/W LOCATION
INSTALL DATE	11/06/2024	

### Secondary Power

# Open Corrective Action & Solution Summary

The following 9 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	2.016	Strg A113
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Device was sticking on panel. Removed smoke and the back is corroded needs replaced. The metal prongs on the seat are damaged as well.
	Proposed Solution:	
	Manufacturer:	
	Model:	
		
Fire Alarm Control Panel	FACP Room A110 (2) 12v55ah	
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
BPS - Booster Power Supply		BPS-A Room A110 (2)12v7ah
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
BPS - Booster Power Supply		BPS-B Room A110 (2)12v7ah
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
BPS - Booster Power Supply		BPS-D Room A110 (2)12v7ah
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
BPS - Booster Power Supply		BPS-H Room A110 (2)12v7ah
	Created By:	Chris Spencer
	Creation Date:	07/30/2025

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
	Corrective Action: Proposed Solution: Manufacturer: Model:	Both 12v 7ah batteries over 5 years old and need replaced
BPS - Booster Power Supply	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	BPS-C Room M101.5 (2)12v26ah  Chris Spencer 07/30/2025 Both 12v 26ah batteries over 5 years old and need replaced
BPS - Booster Power Supply	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	BPS-E Room A113 (2)12v7ah  Chris Spencer 07/30/2025 Both 12v 7ah batteries over 5 years old and need replaced
BPS - Booster Power Supply	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	BPS-G Room B201.1 (2)12v7ah  Chris Spencer 07/30/2025 Both 12v 7ah batteries over 5 years old and need replaced

# Testing Details

## Fire Control Panel

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Area Reception	Manual	7/30/2025 9:44:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel	FACP Room A110 (2) 12v55ah Comment:	08/01/2019		7/30/2025 9:08:57 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

## Initiating Device

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Mechanical, Electrosonic, or Pressure Waterflow Device	2.474	1st Riser C115 (ITV in Kitchen M104.5)	Manual	7/30/2025 11:29:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	2.475	1st Riser Tamper C115	Manual	7/30/2025 11:50:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.378	2nd Riser C115 (ITV in Kitchen M104.5)	Manual	7/30/2025 11:29:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	2.379	2nd Riser Tamper C115	Manual	7/30/2025 11:50:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.006	Admin A104	Manual	7/30/2025 6:50:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.018	Admin A104	Manual	7/30/2025 6:52:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.015	Admin A104	Manual	7/30/2025 9:18:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.007	Admin Recpt A111	Manual	7/30/2025 6:50:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.014	Admin Recpt A111	Manual	7/30/2025 6:50:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.314	Boys RR B102	Manual	7/30/2025 8:23:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.283	Boys RR C101	Manual	7/30/2025 9:44:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.277	Boys RR C201	Manual	7/30/2025 9:12:12 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.315	Boys RR k209	Manual	7/30/2025 9:42:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.032	Bridges M101.4	Manual	7/30/2025 8:03:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.261	Classr, C203	Manual	7/30/2025 9:12:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.309	Classrm ab205	Manual	7/30/2025 8:25:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.310	Classrm B205	Manual	7/30/2025 8:25:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.305	Classrm B206.A	Manual	7/30/2025 8:24:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.306	Classrm B206.A	Manual	7/30/2025 8:25:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.308	Classrm B206.B	Manual	7/30/2025 8:25:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.307	Classrm B206B	Manual	7/30/2025 8:25:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.304	Classrm B207	Manual	7/30/2025 8:24:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.303	Classrm B207	Manual	7/30/2025 8:24:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.298	Classrm B208	Manual	7/30/2025 8:24:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.299	Classrm B208	Manual	7/30/2025 10:08:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.295	Classrm B209	Manual	7/30/2025 8:25:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.296	Classrm B209	Manual	7/30/2025 8:25:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.292	Classrm B210	Manual	7/30/2025 8:26:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.293	Classrm B293	Manual	7/30/2025 8:26:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.281	Classrm C106	Manual	7/30/2025 7:33:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.282	Classrm C106	Manual	7/30/2025 7:33:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.279	Classrm C107	Manual	7/30/2025 7:25:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.280	Classrm C107	Manual	7/30/2025 7:26:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.277	Classrm C108	Manual	7/30/2025 7:25:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.267	Classrm C112	Manual	7/30/2025 7:23:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.265	Classrm C113	Manual	7/30/2025 7:22:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.263	Classrm C113	Manual	7/30/2025 7:22:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.257	Classrm C114	Manual	7/30/2025 7:22:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.256	Classrm C114	Manual	7/30/2025 7:22:16 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.258	Classrm C114	Manual	7/30/2025 7:22:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.259	Classrm C114	Manual	7/30/2025 7:22:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.257	Classrm C203	Manual	7/30/2025 9:12:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.260	Classrm C203	Manual	7/30/2025 9:12:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.276	Classrm C205	Manual	7/30/2025 9:45:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.275	Classrm C205	Manual	7/30/2025 9:45:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.274	Classrm C206	Manual	7/30/2025 9:45:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.273	Classrm C206	Manual	7/30/2025 9:45:57 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.272	Classrm C207	Manual	7/30/2025 9:46:07 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.271	Classrm C207	Manual	7/30/2025 9:46:10 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.266	Classrm C208	Manual	7/30/2025 9:46:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.265	Classrm C208	Manual	7/30/2025 9:46:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.263	Classrm C209	Manual	7/30/2025 9:47:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.262	Classrm C209	Manual	7/30/2025 9:47:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.259	Classrm C210	Manual	7/30/2025 9:12:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.258	Classrm C210	Manual	7/30/2025 9:12:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.256	Classrm C212	Manual	7/30/2025 9:42:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.063	Classrm K102	Manual	7/30/2025 6:54:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.066	Classrm K102	Manual	7/30/2025 6:54:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.065	Classrm K102	Manual	7/30/2025 6:54:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.069	Classrm K103	Manual	7/30/2025 7:21:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.067	Classrm K103	Manual	7/30/2025 7:21:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.068	Classrm K103	Manual	7/30/2025 7:21:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.070	Classrm K103	Manual	7/30/2025 7:21:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.071	Classrm K103	Manual	7/30/2025 7:21:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.074	Classrm K104	Manual	7/30/2025 7:21:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.076	Classrm K104	Manual	7/30/2025 7:21:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.077	Classrm K104	Manual	7/30/2025 7:21:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.075	Classrm K104	Manual	7/30/2025 7:21:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.320	Classrm K202	Manual	7/30/2025 9:42:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.321	Classrm K202	Manual	7/30/2025 9:42:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.326	Classrm K203	Manual	7/30/2025 9:41:57 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.331	Classrm K204	Manual	7/30/2025 9:41:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.332	Classrm K204	Manual	7/30/2025 9:41:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.329	Classrm K206	Manual	7/30/2025 9:41:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.330	Classrm K206	Manual	7/30/2025 9:41:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.323	Classrm K207	Manual	7/30/2025 9:41:39 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.324	Classrm K207	Manual	7/30/2025 9:41:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.318	Classrm K208	Manual	7/30/2025 9:42:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.319	Classrm K208	Manual	7/30/2025 9:42:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.325	Classrm K325	Manual	7/30/2025 9:41:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.312	Classroom B105	Manual	7/30/2025 7:40:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.310	Classroom B106	Manual	7/30/2025 7:39:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.308	Classroom B107	Manual	7/30/2025 7:39:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.304	Classroom B109	Manual	7/30/2025 7:36:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.301	Classroom B110	Manual	7/30/2025 7:34:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.298	Classroom B111	Manual	7/30/2025 7:34:31 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.276	Classroom C109	Manual	7/30/2025 7:25:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.271	Classroom C111	Manual	7/30/2025 7:23:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.269	Classroom C111	Manual	7/30/2025 7:23:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.270	Classroom C111	Manual	7/30/2025 7:26:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.313	CO Classroom B105	Manual	7/30/2025 7:40:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.311	CO Classroom B106	Manual	7/30/2025 9:49:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.309	CO Classroom B107	Manual	7/30/2025 7:38:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.303	CO Classroom B109	Manual	7/30/2025 7:35:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.300	CO Classroom B110	Manual	7/30/2025 7:34:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.297	CO Classroom B111	Manual	7/30/2025 7:34:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.048	CO Serving M104	Manual	7/30/2025 8:04:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036	CO Stage M106	Manual	7/30/2025 8:04:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.279	Comp Lab A201	Manual	7/30/2025 9:44:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.017	Comp Lab A201	Manual	7/30/2025 9:44:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.016	Comp Lab A201	Manual	7/30/2025 9:44:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.015	Comp Lab A201	Manual	7/30/2025 9:44:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.014	Comp Lab A201	Manual	7/30/2025 9:44:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.018	Comp Lab A201	Manual	7/30/2025 9:44:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.019	Comp Lab A201	Manual	7/30/2025 9:44:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.020	Comp Lab A201	Manual	7/30/2025 9:45:03 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.021	Comp Lab A201	Manual	7/30/2025 9:45:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.022	Conf A106	Manual	7/30/2025 6:52:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.030	Conf A115.1	Manual	7/30/2025 8:03:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.272	Corr C104	Manual	7/30/2025 7:25:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.260	Corr C104	Manual	7/30/2025 7:32:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.255	Corr C104	Manual	7/30/2025 7:33:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.266	Corr C104	Manual	7/30/2025 9:43:56 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.286	Corridor 211	Manual	7/30/2025 9:06:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.285	Corridor A211	Manual	7/30/2025 9:11:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.284	Corridor A211	Manual	7/30/2025 9:11:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.283	Corridor A211	Manual	7/30/2025 9:11:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.282	Corridor A211	Manual	7/30/2025 9:12:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.280	Corridor A211	Manual	7/30/2025 9:43:03 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.281	Corridor A211	Manual	7/30/2025 9:45:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.293	Corridor B103	Manual	7/30/2025 7:34:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.299	Corridor B103	Manual	7/30/2025 7:34:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.305	Corridor B103	Manual	7/30/2025 7:36:36 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.302	Corridor B103	Manual	7/30/2025 8:23:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.300	Corridor B203	Manual	7/30/2025 8:24:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.297	Corridor B203	Manual	7/30/2025 8:24:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.294	Corridor B203	Manual	7/30/2025 8:25:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.291	Corridor B203	Manual	7/30/2025 8:26:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.287	Corridor B203	Manual	7/30/2025 8:26:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.264	Corridor C203	Manual	7/30/2025 7:22:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.333	Corridor K201	Manual	7/30/2025 9:41:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.328	Corridor K201	Manual	7/30/2025 9:41:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.327	Corridor K201	Manual	7/30/2025 9:41:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.322	Corridor K201	Manual	7/30/2025 9:42:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.317	Corridor K201	Manual	7/30/2025 9:42:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.307	Custodial B108	Manual	7/30/2025 7:37:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.255	Custodial C211	Manual	7/30/2025 9:47:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.273	Custodial C273	Manual	7/30/2025 7:23:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.044	Custodial M104.5	Manual	7/30/2025 8:05:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.040	Custodial M105	Manual	7/30/2025 8:04:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.039	Custodial M105	Manual	7/30/2025 8:04:40 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3.289	CustodialB212	Manual	7/30/2025 9:11:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.046	Dry Strg M104.7	Manual	7/30/2025 8:23:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.315	Girls RR B101	Manual	7/30/2025 8:23:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.294	Girls RR B114	Manual	7/30/2025 8:03:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.288	Girls RR B213	Manual	7/30/2025 9:11:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.316	Girls RR K210	Manual	7/30/2025 9:42:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.008	IDF A203.1	Manual	7/30/2025 9:44:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.296	IDF B113	Manual	7/30/2025 7:33:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.313	IDF B201.1	Manual	7/30/2025 8:36:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.031	IDF M101.5	Manual	7/30/2025 8:03:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.041	Kitchen Dish M104.8	Manual	7/30/2025 8:04:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.043	Kitchen Dish M104.8	Manual	7/30/2025 8:08:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.049	Kitchen M104.1	Manual	7/30/2025 8:23:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.029	Library A115	Manual	7/30/2025 8:03:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.023	Lobby A118	Manual	7/30/2025 9:12:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.022	Lobby A118	Manual	7/30/2025 9:41:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.287	Lobby Corr A126	Manual	7/30/2025 7:33:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.286	Lobby Corr A126	Manual	7/30/2025 7:33:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.289	Lobby Corr A126	Manual	7/30/2025 7:33:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.373	Lobby Corr A126	Manual	7/30/2025 7:33:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.290	Lobby Corr A126	Manual	7/30/2025 7:34:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.291	Lobby Corr A126	Manual	7/30/2025 7:34:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.149	MP Rm M101	Manual	7/30/2025 8:03:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.161	MP Rm M101	Manual	7/30/2025 8:04:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.148	MP Rm M101	Manual	7/30/2025 8:09:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3.148	MP Rm M101	Manual	7/30/2025 10:08:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.162	MP Rm M101	Manual	7/30/2025 10:08:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.052	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.053	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.054	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.055	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.056	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.057	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.058	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.059	MP Room Gym Ceiling M101	Manual	7/30/2025 11:49:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.292	MP Vestbl A127	Manual	7/30/2025 7:34:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.013	Nurse A111	Manual	7/30/2025 6:54:17 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.021	Office A107	Manual	7/30/2025 6:52:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.011	Office A202.1	Manual	7/30/2025 10:02:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	2.380	OS&Y	Manual	7/30/2025 11:50:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023	Parnt Res A105	Manual	7/30/2025 6:52:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.051	PE Office M102	Manual	7/30/2025 8:23:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	2.381	PIV	Manual	7/30/2025 11:50:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.019	Principals A109	Manual	7/30/2025 6:52:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.013	Prop Dev A202	Manual	7/30/2025 10:02:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.012	Prop Dev A202	Manual	7/30/2025 10:02:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.027	Restroom A102	Manual	7/30/2025 9:18:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.011	Restroom A111.2	Manual	7/30/2025 6:54:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.278	RR C107.1	Manual	7/30/2025 7:26:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.268	RR C111.1	Manual	7/30/2025 7:23:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.262	RR C113.1	Manual	7/30/2025 7:22:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.261	RR C114.1	Manual	7/30/2025 7:22:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.064	RR K102.1	Manual	7/30/2025 6:55:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.061	RR K102.1	Manual	7/30/2025 7:27:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.072	RR K103.1	Manual	7/30/2025 7:21:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.073	RR K104.1	Manual	7/30/2025 7:22:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.047	Serving M104	Manual	7/30/2025 8:04:45 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.009	Staff Lounge A203	Manual	7/30/2025 9:44:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.010	Staff Lounge A203	Manual	7/30/2025 9:44:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.012	Staff RR A112	Manual	7/30/2025 6:54:37 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.010	Staff RR A116.1	Manual	7/30/2025 6:54:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.005	Staff RR A203.3	Manual	7/30/2025 9:43:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.295	Staff RR B112	Manual	7/30/2025 7:33:32 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.311	Staff RR B202	Manual	7/30/2025 10:02:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.290	Staff RR B211	Manual	7/30/2025 9:11:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.006	Staff RR Lounge A203	Manual	7/30/2025 11:50:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.042	Staff RR M104.4	Manual	7/30/2025 8:08:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.035	Stage M106	Manual	7/30/2025 8:04:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.038	Stage Stair M101.1	Manual	7/30/2025 8:04:29 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.306	Stair 2 B104	Manual	7/30/2025 7:36:59 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.302	Stair 2 B204	Manual	7/30/2025 8:24:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.301	Stair 2 B204	Manual	7/30/2025 8:24:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.274	Stair 3 C105	Manual	7/30/2025 7:23:59 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.078	Stair 4 K106	Manual	7/30/2025 9:42:32 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.334	Stair K205	Manual	7/30/2025 9:42:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.335	Stair K205	Manual	7/30/2025 9:50:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034	Stair M101.2	Manual	7/30/2025 8:04:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.029	Storage A204	Manual	7/30/2025 9:10:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.314	Storage B205.1	Manual	7/30/2025 11:50:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.278	Storage C202	Manual	7/30/2025 10:08:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.062	Storage K101	Manual	7/30/2025 6:54:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.017	Strg A114	Manual	7/30/2025 6:54:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.028	Strg A204	Manual	7/30/2025 9:11:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.033	Strg M101.3	Manual	7/30/2025 8:04:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.037	Strg M106.1	Manual	7/30/2025 8:04:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.144	Vestibule	Manual	7/30/2025 9:06:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.024	Vestibule A101	Manual	7/30/2025 9:11:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.025	Vestibule A101	Manual	7/30/2025 9:18:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.020	Vice Principal A108	Manual	7/30/2025 6:52:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.008	Workroom A116	Manual	7/30/2025 6:53:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.288	Alt Elev Lobby A126	Manual	7/30/2025 9:09:25 AM
	Comment:	Test during elevator inspection		

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2.060	Elev Rm K105	Manual	7/30/2025 9:09:42 AM
	Comment:	Test during elevator inspection		
Smoke Detector - General	3.336	Pri Elev Corr A211	Manual	7/30/2025 9:09:49 AM
	Comment:	Test during elevator inspection		
Smoke Detector - General	3.007	Staff RR A203.3	Manual	7/30/2025 9:38:56 AM
	Comment:	No access RR out of order could not unlock door		

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.016	Strg A113	Manual	7/30/2025 11:47:55 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply		BPS-C Room A203.1 (2)12v7ah	Manual	7/30/2025 8:02:57 AM
	Comment:	03/21/2024 Left 100% Right 100%		
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply		BPS-A Room A110 (2)12v7ah	Manual	7/30/2025 8:09:50 AM
	Comment:	06/14/2019		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-B Room A110 (2)12v7ah	Manual	7/30/2025 8:10:29 AM
	Comment:	06/14/2109		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-C Room M101.5 (2)12v26ah	Manual	7/30/2025 7:45:19 AM
	Comment:	09/01/2019		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-D Room A110 (2)12v7ah	Manual	7/30/2025 8:10:52 AM
	Comment:	07/05/2019		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-E Room A113 (2)12v7ah	Manual	7/30/2025 7:52:37 AM
	Comment:	2016		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-G Room B201.1 (2)12v7ah	Manual	7/30/2025 7:55:43 AM
	Comment:	08/2/2019		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-H Room A110 (2)12v7ah	Manual	7/30/2025 8:11:16 AM
	Comment:	06/14/2019		
		Visual inspection	Passed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Hood And Appliances		Manual	7/30/2025 6:57:25 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Ansul	
		Model	R102	
Fusible Links	Qty-4 450 Degree Fusible Links		Manual	7/30/2025 6:57:36 AM
		Manufacturer	Ansul	
		Model	R102	
Range Suppression	Fire Suppression		Manual	7/30/2025 6:57:32 AM
		Manufacturer	Ansul	
		Model	R102	
Range Suppression	101-20 Cartridge		Manual	7/30/2025 6:57:44 AM
		Manufacturer	Ansul	
		Model	R102	
Range Suppression Tank	3 Gal Ansul Cylinder		Manual	7/30/2025 6:57:47 AM
		Manufacturer	Ansul	
		Model	R102	

# Device/Equipment Details

## Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Area Reception				
Fire Alarm Control Panel					
FACP Room A110 (2) 12v55ah					11/07/2024

## Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Heat Detector - Restorable Spot					
3.255	Custodial C211				08/29/2024
2.042	Staff RR M104.4				08/29/2024
2.049	Kitchen M104.1				08/29/2024
2.060	Elev Rm K105				08/29/2024
2.307	Custodial B108				08/29/2024
Smoke Detector - General					
2.006	Admin A104				08/29/2024
2.019	Principals A109				08/29/2024
2.007	Admin Recpt A111				08/29/2024
2.020	Vice Principal A108				08/29/2024
2.021	Office A107				08/29/2024
2.014	Admin Recpt A111				08/29/2024
2.022	Conf A106				08/29/2024
2.023	Parnt Res A105				08/29/2024
2.018	Admin A104				08/29/2024
2.013	Nurse A111				08/29/2024
2.011	Restroom A111.2				08/29/2024
2.008	Workroom A116				08/29/2024
2.017	Strg A114				08/29/2024
2.015	Admin A104				08/29/2024
2.012	Staff RR A112				08/29/2024
2.016	Strg A113				08/29/2024
2.024	Vestibule A101				08/29/2024
2.025	Vestibule A101				08/29/2024
2.027	Restroom A102				08/29/2024
2.032	Bridges M101.4				08/29/2024
2.031	IDF M101.5				08/29/2024
2.033	Strg M101.3				08/29/2024
2.034	Stair M101.2				08/29/2024
2.035	Stage M106				08/29/2024
2.036	CO Stage M106				08/29/2024
2.037	Strg M106.1				08/29/2024
2.038	Stage Stair M101.1				08/29/2024
2.040	Custodial M105				08/29/2024
2.039	Custodial M105				08/29/2024
2.047	Serving M104				08/29/2024
2.048	CO Serving M104				08/29/2024
2.046	Dry Strg M104.7				08/29/2024
2.044	Custodial M104.5				08/29/2024
2.041	Kitchen Dish M104.8				08/29/2024
2.051	PE Office M102				08/29/2024

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.292	MP Vestbl A127				08/29/2024
2.314	Boys RR B102				08/29/2024
2.315	Girls RR B101				08/29/2024
2.293	Corridor B103				08/29/2024
2.299	Corridor B103				08/29/2024
2.302	Corridor B103				08/29/2024
2.305	Corridor B103				08/29/2024
2.306	Stair 2 B104				08/29/2024
2.309	CO Classroom B107				08/29/2024
2.308	Classroom B107				08/29/2024
2.303	CO Classroom B109				08/29/2024
2.304	Classroom B109				08/29/2024
2.310	Classroom B106				08/29/2024
2.311	CO Classroom B106				08/29/2024
2.301	Classroom B110				08/29/2024
2.300	CO Classroom B110				08/29/2024
2.312	Classroom B105				08/29/2024
2.313	CO Classroom B105				08/29/2024
2.298	Classroom B111				08/29/2024
2.297	CO Classroom B111				08/29/2024
2.291	Lobby Corr A126				08/29/2024
2.294	Girls RR B114				08/29/2024
2.373	Lobby Corr A126				08/29/2024
2.296	IDF B113				08/29/2024
2.295	Staff RR B112				08/29/2024
2.289	Lobby Corr A126				08/29/2024
2.290	Lobby Corr A126				08/29/2024
2.029	Library A115				08/29/2024
2.030	Conf A115.1				08/29/2024
2.288	Alt Elev Lobby A126				08/29/2024
2.283	Boys RR C101				08/29/2024
2.287	Lobby Corr A126				08/29/2024
2.255	Corr C104				08/29/2024
2.260	Corr C104				08/29/2024
2.266	Corr C104				08/29/2024
2.272	Corr C104				08/29/2024
2.274	Stair 3 C105				08/29/2024
2.271	Classroom C111				08/29/2024
2.269	Classroom C111				08/29/2024
2.268	RR C111.1				08/29/2024
2.276	Classroom C109				08/29/2024
2.277	Classrm C108				08/29/2024
2.279	Classrm C107				08/29/2024
2.280	Classrm C107				08/29/2024
2.278	RR C107.1				08/29/2024
2.262	RR C113.1				08/29/2024
2.263	Classrm C113				08/29/2024
2.267	Classrm C112				08/29/2024
2.265	Classrm C113				08/29/2024
2.281	Classrm C106				08/29/2024
2.282	Classrm C106				08/29/2024
2.259	Classrm C114				08/29/2024

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.258	Classrm C114				08/29/2024
2.256	Classrm C114				08/29/2024
2.257	Classrm C114				08/29/2024
2.261	RR C114.1				08/29/2024
2.286	Lobby Corr A126				08/29/2024
2.062	Storage K101				08/29/2024
2.063	Classrm K102				08/29/2024
2.066	Classrm K102				08/29/2024
2.065	Classrm K102				08/29/2024
2.064	RR K102.1				08/29/2024
2.069	Classrm K103				08/29/2024
2.067	Classrm K103				08/29/2024
2.068	Classrm K103				08/29/2024
2.070	Classrm K103				08/29/2024
2.072	RR K103.1				08/29/2024
2.071	Classrm K103				08/29/2024
2.077	Classrm K104				08/29/2024
2.075	Classrm K104				08/29/2024
2.073	RR K104.1				08/29/2024
2.076	Classrm K104				08/29/2024
2.074	Classrm K104				08/29/2024
2.078	Stair 4 K106				08/29/2024
2.264	Corridor C203				08/29/2024
3.265	Classrm C208				08/29/2024
3.266	Classrm C208				08/29/2024
3.271	Classrm C207				08/29/2024
3.272	Classrm C207				08/29/2024
3.273	Classrm C206				08/29/2024
3.274	Classrm C206				08/29/2024
3.262	Classrm C209				08/29/2024
3.263	Classrm C209				08/29/2024
3.258	Classrm C210				08/29/2024
3.259	Classrm C210				08/29/2024
3.275	Classrm C205				08/29/2024
3.276	Classrm C205				08/29/2024
3.261	Classr, C203				08/29/2024
3.260	Classrm C203				08/29/2024
3.257	Classrm C203				08/29/2024
3.256	Classrm C212				08/29/2024
3.280	Corridor A211				08/29/2024
3.315	Boys RR k209				08/29/2024
3.316	Girls RR K210				08/29/2024
3.317	Corridor K201				08/29/2024
3.322	Corridor K201				08/29/2024
3.327	Corridor K201				08/29/2024
3.328	Corridor K201				08/29/2024
3.333	Corridor K201				08/29/2024
3.335	Stair K205				08/29/2024
3.334	Stair K205				08/29/2024
3.330	Classrm K206				08/29/2024
3.329	Classrm K206				08/29/2024
3.332	Classrm K204				08/29/2024

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.331	Classrm K204				08/29/2024
3.324	Classrm K207				08/29/2024
3.323	Classrm K207				08/29/2024
3.326	Classrm K203				08/29/2024
3.325	Classrm K325				08/29/2024
3.319	Classrm K208				08/29/2024
3.318	Classrm K208				08/29/2024
3.321	Classrm K202				08/29/2024
3.320	Classrm K202				08/29/2024
3.279	Comp Lab A201				08/29/2024
3.014	Comp Lab A201				08/29/2024
3.015	Comp Lab A201				08/29/2024
3.016	Comp Lab A201				08/29/2024
3.017	Comp Lab A201				08/29/2024
3.281	Corridor A211				08/29/2024
3.021	Comp Lab A201				08/29/2024
3.020	Comp Lab A201				08/29/2024
3.019	Comp Lab A201				08/29/2024
3.018	Comp Lab A201				08/29/2024
3.010	Staff Lounge A203				08/29/2024
3.009	Staff Lounge A203				08/29/2024
3.008	IDF A203.1				08/29/2024
3.007	Staff RR A203.3				08/29/2024
3.005	Staff RR A203.3				08/29/2024
3.013	Prop Dev A202				08/29/2024
3.012	Prop Dev A202				08/29/2024
3.011	Office A202.1				08/29/2024
3.023	Lobby A118				08/29/2024
3.022	Lobby A118				08/29/2024
3.282	Corridor A211				08/29/2024
3.277	Boys RR C201				08/29/2024
3.336	Pri Elev Corr A211				08/29/2024
3.278	Storage C202				08/29/2024
3.290	Staff RR B211				08/29/2024
3.283	Corridor A211				08/29/2024
3.289	CustodialB212				08/29/2024
3.284	Corridor A211				08/29/2024
3.288	Girls RR B213				08/29/2024
3.285	Corridor A211				08/29/2024
3.286	Corridor 211				08/29/2024
3.029	Storage A204				08/29/2024
3.028	Strg A204				08/29/2024
3.287	Corridor B203				08/29/2024
3.291	Corridor B203				08/29/2024
3.294	Corridor B203				08/29/2024
3.297	Corridor B203				08/29/2024
3.300	Corridor B203				08/29/2024
3.301	Stair 2 B204				08/29/2024
3.302	Stair 2 B204				08/29/2024
3.298	Classrm B208				08/29/2024
3.299	Classrm B208				08/29/2024
3.303	Classrm B207				08/29/2024

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.304	Classrm B207				08/29/2024
3.295	Classrm B209				08/29/2024
3.296	Classrm B209				08/29/2024
3.305	Classrm B206.A				08/29/2024
3.307	Classrm B206B				08/29/2024
3.306	Classrm B206.A				08/29/2024
3.308	Classrm B206.B				08/29/2024
3.309	Classrm ab205				08/29/2024
3.310	Classrm B205				08/29/2024
3.292	Classrm B210				08/29/2024
3.293	Classrm B293				08/29/2024
3.311	Staff RR B202				08/29/2024
3.313	IDF B201.1				08/29/2024
2.162	MP Rm M101				08/29/2024
2.273	Custodial C273				08/29/2024
2.010	Staff RR A116.1				08/29/2024
2.270	Classroom C111				08/29/2024
2.061	RR K102.1				08/29/2024
2.043	Kitchen Dish M104.8				08/29/2024
2.058	MP Room Gym Ceiling M101				08/29/2024
2.056	MP Room Gym Ceiling M101				08/29/2024
2.054	MP Room Gym Ceiling M101				08/29/2024
2.052	MP Room Gym Ceiling M101				08/29/2024
2.053	MP Room Gym Ceiling M101				08/29/2024
2.055	MP Room Gym Ceiling M101				08/29/2024
2.057	MP Room Gym Ceiling M101				08/29/2024
2.059	MP Room Gym Ceiling M101				08/29/2024
3.006	Staff RR Lounge A203				08/29/2024
3.314	Storage B205.1				08/29/2024

**Manual Pull Station**

2.144	Vestibule				08/29/2024
2.161	MP Rm M101				08/29/2024
2.149	MP Rm M101				08/29/2024
3.148	MP Rm M101				08/29/2024
2.148	MP Rm M101				08/29/2024

**Mechanical, Electrosonic, or Pressure Waterflow Device**

2.474	1st Riser C115 (ITV in Kitchen M104.5)				08/29/2024
2.378	2nd Riser C115 (ITV in Kitchen M104.5)				08/29/2024

**Supervisory - Control Valve**

2.381	PIV				07/30/2025
2.380	OS&Y				07/30/2025
2.379	2nd Riser Tamper C115				07/30/2025
2.475	1st Riser Tamper C115				07/30/2025

**Power Supplies**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
<b>BPS - Booster Power Supply</b>					
	BPS-A Room A110 (2)12v7ah				07/30/2025
	BPS-B Room A110 (2)12v7ah				07/30/2025
	BPS-D Room A110 (2)12v7ah				07/30/2025
	BPS-H Room A110 (2)12v7ah				07/30/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	BPS-C Room M101.5 (2) 12v26ah				07/30/2025
	BPS-E Room A113 (2)12v7ah				07/30/2025
	BPS-G Room B201.1 (2)12v7ah				07/30/2025
	BPS-C Room A203.1 (2)12v7ah				07/30/2025

**Ventilation and Cooking Equipment**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	3 Gal Ansul Cylinder	Ansul	R102		01/22/2019
Range Suppression					
	101-20 Cartridge	Ansul	R102		01/22/2019
	Fire Suppression	Ansul	R102		01/22/2019
Fusible Links					
	Qty-4 450 Degree Fusible Links	Ansul	R102		01/22/2019
Cooking Equipment					
	Hood And Appliances	Ansul	R102		01/22/2019