

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

Del Paso Manor CURRENT 2024

2700 Maryal Drive
SACRAMENTO, California 95821
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Thursday, July 31, 2025

Test Session :073025 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	Del Paso Manor CURRENT 2024	CONTACT
ADDRESS	2700 Maryal Drive	PHONE
CITY/STATE/ZIP	SACRAMENTO, California 95821	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	1	1(100%)	1(100%)	0(0%)
Power Supplies	4	4(100%)	0(0%)	4(100%)
Ventilation and Cooking Equipment	6	0(0%)	0(0%)	0(0%)
Fire Control Panel	1	1(100%)	0(0%)	1(100%)
Initiating Device	157	156(99%)	156(99%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 31, 2025

ACCEPTED BY 07/31/2025

Building Representative


TESTED BY 07/31/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS	DESCRIPTION	FACP IDF Room A13.1 (2)12v55ah
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE	07/29/2025	

Secondary Power

Open Corrective Action & Solution Summary

The following 5 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
BPS - Booster Power Supply		BPS-D Room D3
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries are over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
BPS - Booster Power Supply		BPS-C IDF Room C21.1
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries are over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
BPS - Booster Power Supply		BPS-A IDF Room A13.1 (2)12v7ah
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries are over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
BPS - Booster Power Supply		BPS-B IDF Room B06.1
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 7ah batteries are over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Control Panel		FACP IDF Room A13.1 (2)12v55ah
	Created By:	Chris Spencer
	Creation Date:	07/30/2025
	Corrective Action:	Both 12v 55ah batteries are over 5 years old and need replaced
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	all audible visibles		Manual	7/30/2025 1:54:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel		FACP IDF Room A13.1 (2)12v55ah	Manual	7/30/2025 2:02:09 PM
	Comment:	06/20/2025		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.042	Bldg A Boys RR A14	Manual	7/30/2025 12:52:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.041	Bldg A Custodial A15	Manual	7/30/2025 12:54:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.126	Bldg A Custodian Rm A15	Manual	7/30/2025 1:27:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2.127	Bldg A Custodian Rm A15	Manual	7/30/2025 1:02:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.020	Bldg A ECE Rm A09	Manual	7/30/2025 12:53:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.019	Bldg A ECE Rm A09	Manual	7/30/2025 12:53:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.021	Bldg A ECE Rm A09	Manual	7/30/2025 12:53:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.022	Bldg A ECE Rm A09	Manual	7/30/2025 12:53:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.002	Bldg A Elect Rm A13	Manual	7/30/2025 12:51:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.040	Bldg A Girls RR A16	Manual	7/30/2025 12:54:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.001	Bldg A IDF Rm	Manual	7/30/2025 12:52:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.038	Bldg A Rm A01	Manual	7/30/2025 12:55:02 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.037	Bldg A Rm A01	Manual	7/30/2025 12:55:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.035	Bldg A Rm A02	Manual	7/30/2025 12:53:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036	Bldg A Rm A02	Manual	7/30/2025 12:53:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034	Bldg A Rm A03	Manual	7/30/2025 12:53:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.033	Bldg A Rm A03	Manual	7/30/2025 12:53:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.032	Bldg A Rm A04	Manual	7/30/2025 12:54:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.031	Bldg A Rm A04	Manual	7/30/2025 12:54:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.030	Bldg A Rm A05	Manual	7/30/2025 12:54:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.029	Bldg A Rm A05	Manual	7/30/2025 12:54:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.027	Bldg A Rm A06	Manual	7/30/2025 12:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.028	Bldg A Rm A06	Manual	7/30/2025 12:54:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.026	Bldg A Rm A07	Manual	7/30/2025 12:54:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.025	Bldg A Rm A07	Manual	7/30/2025 12:54:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023	Bldg A Rm A08	Manual	7/30/2025 12:54:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.024	Bldg A Rm A08	Manual	7/30/2025 12:54:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.013	Bldg A Rm A10	Manual	7/30/2025 12:52:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.014	Bldg A Rm A10	Manual	7/30/2025 12:52:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.015	Bldg A Rm A10	Manual	7/30/2025 12:53:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.016	Bldg A Rm A10	Manual	7/30/2025 12:53:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.009	Bldg A Rm A11	Manual	7/30/2025 12:52:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.012	Bldg A Rm A11	Manual	7/30/2025 12:52:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.011	Bldg A Rm A11	Manual	7/30/2025 12:52:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.010	Bldg A Rm A11	Manual	7/30/2025 12:52:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.003	Bldg A Rm A12	Manual	7/30/2025 12:50:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.004	Bldg A Rm A12	Manual	7/30/2025 12:51:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.005	Bldg A Rm A12	Manual	7/30/2025 12:51:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.006	Bldg A Rm A12	Manual	7/30/2025 12:51:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.017	Bldg A RR A09	Manual	7/30/2025 12:53:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.018	Bldg A RR A10	Manual	7/30/2025 12:53:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.007	Bldg A RR A11	Manual	7/30/2025 12:52:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.008	Bldg A RR A12	Manual	7/30/2025 12:52:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2.138	Bldg B Admin Lobby	Manual	7/30/2025 1:34:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.053	Bldg B Admin Lobby B01	Manual	7/30/2025 1:27:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.052	Bldg B Admin Lobby B01	Manual	7/30/2025 1:27:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.051	Bldg B Admin Lobby B01	Manual	7/30/2025 1:28:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.058	Bldg B Admin Lobby B01	Manual	7/30/2025 1:29:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.045	Bldg B Assistant Principal B04	Manual	7/30/2025 1:29:03 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.087	Bldg B Boys RR B18	Manual	7/30/2025 1:34:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.075	Bldg B Bridges B13	Manual	7/30/2025 1:00:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.066	Bldg B Comp Lab B13	Manual	7/30/2025 12:59:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.067	Bldg B Comp Lab B13	Manual	7/30/2025 12:59:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.056	Bldg B Conf Rm B08	Manual	7/30/2025 1:29:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.076	Bldg B Cook Prep B15	Manual	7/30/2025 1:33:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.047	Bldg B Counsel B05	Manual	7/30/2025 1:29:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.133	Bldg B Cust B15.3	Manual	7/30/2025 1:33:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2.134	Bldg B Cust B15.3	Manual	7/30/2025 1:02:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.073	Bldg B Cust Off B14	Manual	7/30/2025 12:58:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.074	Bldg B Cust Strg B14	Manual	7/30/2025 12:58:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.055	Bldg B Custodial B07	Manual	7/30/2025 1:28:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.080	Bldg B Custodial B15	Manual	7/30/2025 1:32:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.088	Bldg B Custodial B16	Manual	7/30/2025 12:55:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.081	Bldg B Dishwash	Manual	7/30/2025 1:33:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.077	Bldg B Dry Strg B15	Manual	7/30/2025 1:33:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.046	Bldg B Elect Rm B06	Manual	7/30/2025 1:34:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.100	Bldg B Elect Rm B20	Manual	7/30/2025 12:57:53 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.065	Bldg B General Strg B13	Manual	7/30/2025 1:00:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.098	Bldg B General Strg B16	Manual	7/30/2025 12:56:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.086	Bldg B Girls RR B17	Manual	7/30/2025 12:55:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.049	Bldg B Health Office B02	Manual	7/30/2025 1:28:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.048	Bldg B Health RR	Manual	7/30/2025 1:28:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.050	Bldg B Health St Rm B02	Manual	7/30/2025 1:28:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.043	Bldg B IDF Rm B06	Manual	7/30/2025 1:34:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.079	Bldg B Kitch RR B15.2	Manual	7/30/2025 12:57:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.078	Bldg B Kitchen Hall	Manual	7/30/2025 12:57:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.064	Bldg B Library St B13	Manual	7/30/2025 12:58:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.083	Bldg B MP Rm B16	Manual	7/30/2025 1:31:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.085	Bldg B MP Rm B16	Manual	7/30/2025 1:31:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.084	Bldg B MP Rm B16	Manual	7/30/2025 1:31:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.094	Bldg B MP Rm B16	Manual	7/30/2025 1:32:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.095	Bldg B MP Rm B16	Manual	7/30/2025 1:32:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.096	Bldg B MP Rm B16	Manual	7/30/2025 1:32:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.059	Bldg B Parent Work B11	Manual	7/30/2025 1:49:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.097	Bldg B PE Office B16	Manual	7/30/2025 12:56:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.099	Bldg B PE Strg B19	Manual	7/30/2025 1:34:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.060	Bldg B Principal B10	Manual	7/30/2025 1:29:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.044	Bldg B Psyche B03	Manual	7/30/2025 1:28:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.070	Bldg B Read Lnge B13	Manual	7/30/2025 12:58:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.069	Bldg B Read Lnge B13	Manual	7/30/2025 12:58:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.071	Bldg B Read Lnge B13	Manual	7/30/2025 12:59:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.072	Bldg B Read Lnge B13	Manual	7/30/2025 12:59:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.068	Bldg B Reading Lnge B13	Manual	7/30/2025 12:59:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.063	Bldg B Secure St B07	Manual	7/30/2025 1:28:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.082	Bldg B Servery B15	Manual	7/30/2025 12:57:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.054	Bldg B Staff Rm B07	Manual	7/30/2025 1:27:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.061	Bldg B Staff Rm B12	Manual	7/30/2025 1:00:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.062	Bldg B Staff Rm B12	Manual	7/30/2025 1:00:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.057	Bldg B Staff RR B09	Manual	7/30/2025 1:31:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.090	Bldg B Stage B16	Manual	7/30/2025 12:56:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.091	Bldg B Stage B16	Manual	7/30/2025 12:56:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.092	Bldg B Stage Hall	Manual	7/30/2025 12:56:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.089	Bldg B Stage Hall Rt	Manual	7/30/2025 12:55:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.093	Bldg B Stage St B16	Manual	7/30/2025 12:56:37 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.271	Bldg C Boys RR C18	Manual	7/30/2025 12:57:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.291	Bldg C Custodial C22	Manual	7/30/2025 1:01:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2.377	Bldg C Custodial C22	Manual	7/30/2025 1:02:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.376	Bldg C Custodial Rm C22	Manual	7/30/2025 1:01:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.255	Bldg C ELD C06	Manual	7/30/2025 1:00:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.256	Bldg C ELD C06	Manual	7/30/2025 1:00:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.252	Bldg C Elect Rm C24	Manual	7/30/2025 1:01:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.272	Bldg C Girls RR C19	Manual	7/30/2025 12:57:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.251	Bldg C IDF Rm C21	Manual	7/30/2025 1:01:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.282	Bldg C Rm C01	Manual	7/30/2025 1:26:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.281	Bldg C Rm C01	Manual	7/30/2025 1:27:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.284	Bldg C Rm C02	Manual	7/30/2025 1:26:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.283	Bldg C Rm C02	Manual	7/30/2025 1:26:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.285	Bldg C Rm C03	Manual	7/30/2025 1:26:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.286	Bldg C Rm C03	Manual	7/30/2025 1:26:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.287	Bldg C Rm C04	Manual	7/30/2025 12:55:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.288	Bldg C Rm C04	Manual	7/30/2025 1:26:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.257	Bldg C Rm C07	Manual	7/30/2025 1:00:27 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2.258	Bldg C Rm C07	Manual	7/30/2025 1:00:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.259	Bldg C Rm C08	Manual	7/30/2025 1:00:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.260	Bldg C Rm C08	Manual	7/30/2025 1:00:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.261	Bldg C Rm C09	Manual	7/30/2025 12:59:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.262	Bldg C Rm C09	Manual	7/30/2025 12:59:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.264	Bldg C Rm C10	Manual	7/30/2025 12:59:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.263	Bldg C Rm C10	Manual	7/30/2025 12:59:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.265	Bldg C Rm C11	Manual	7/30/2025 12:58:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.266	Bldg C Rm C11	Manual	7/30/2025 12:58:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.268	Bldg C Rm C12	Manual	7/30/2025 12:58:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.267	Bldg C Rm C12	Manual	7/30/2025 12:58:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.269	Bldg C Rm C13	Manual	7/30/2025 12:58:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.270	Bldg C Rm C13	Manual	7/30/2025 12:58:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.274	Bldg C Rm C14	Manual	7/30/2025 12:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.273	Bldg C Rm C14	Manual	7/30/2025 12:56:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.275	Bldg C Rm C15	Manual	7/30/2025 12:56:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.276	Bldg C Rm C15	Manual	7/30/2025 12:56:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.277	Bldg C Rm C16	Manual	7/30/2025 12:55:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.278	Bldg C Rm C16	Manual	7/30/2025 12:55:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.279	Bldg C Rm C17	Manual	7/30/2025 12:55:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.280	Bldg C Rm C17	Manual	7/30/2025 12:55:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.253	Bldg C RSP C05	Manual	7/30/2025 1:01:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.254	Bldg C RSP C05	Manual	7/30/2025 1:01:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.289	Bldg C Speech C20	Manual	7/30/2025 1:01:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.292	Bldg C Staff RR C23	Manual	7/30/2025 1:01:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.290	Bldg C Strg C21	Manual	7/30/2025 1:01:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.317	Bldg D D1	Manual	7/30/2025 1:31:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.318	Bldg D D1	Manual	7/30/2025 1:31:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.315	Bldg D D2	Manual	7/30/2025 1:29:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.316	Bldg D D2	Manual	7/30/2025 1:29:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.314	Bldg D D3	Manual	7/30/2025 1:28:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.313	Bldg D D3	Manual	7/30/2025 1:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.311	Bldg D D4	Manual	7/30/2025 1:27:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.312	Bldg D D4	Manual	7/30/2025 1:27:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.039	Bldg A RR A17	Manual	7/30/2025 1:48:21 PM
	Comment:	No access door is locked		

Power Supplies

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply		BPS-A IDF Room A13.1 (2)12v7ah	Manual	7/30/2025 2:03:41 PM
	Comment:	05/22/2020		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-B IDF Room B06.1	Manual	7/30/2025 2:52:29 PM
	Comment:	05/2020		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-C IDF Room C21.1	Manual	7/30/2025 2:52:48 PM
	Comment:	05/2020		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
BPS - Booster Power Supply		BPS-D Room D3	Manual	7/30/2025 2:53:06 PM
	Comment:	05/2020		
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	7/30/2025 12:15:15 PM
Fusible Links	Fusible Links 450 x 3		Manual	7/30/2025 12:15:24 PM
Range Hood	Hood		Manual	7/30/2025 12:15:21 PM
Range Suppression	101-20 Cartridge		Manual	7/30/2025 12:15:07 PM
Range Suppression	Suppression		Manual	7/30/2025 12:15:18 PM
Range Suppression Tank	R102 3 Gallon Cylinder		Manual	7/30/2025 12:15:12 PM

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
	all audible visibles				03/05/2024

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Control Panel					
	FACP IDF Room A13.1 (2) 12v55ah				07/30/2025

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2.001	Bldg A IDF Rm				02/29/2024
2.002	Bldg A Elect Rm A13				02/29/2024
2.003	Bldg A Rm A12				02/29/2024
2.004	Bldg A Rm A12				02/29/2024
2.005	Bldg A Rm A12				02/29/2024
2.006	Bldg A Rm A12				02/29/2024
2.007	Bldg A RR A11				02/29/2024
2.008	Bldg A RR A12				02/29/2024
2.009	Bldg A Rm A11				02/29/2024
2.010	Bldg A Rm A11				02/29/2024
2.011	Bldg A Rm A11				02/29/2024
2.012	Bldg A Rm A11				02/29/2024
2.013	Bldg A Rm A10				02/29/2024
2.014	Bldg A Rm A10				02/29/2024
2.015	Bldg A Rm A10				02/29/2024
2.016	Bldg A Rm A10				02/29/2024
2.017	Bldg A RR A09				02/29/2024
2.018	Bldg A RR A10				02/29/2024
2.019	Bldg A ECE Rm A09				02/29/2024
2.020	Bldg A ECE Rm A09				02/29/2024
2.021	Bldg A ECE Rm A09				02/29/2024
2.022	Bldg A ECE Rm A09				02/29/2024
2.023	Bldg A Rm A08				02/29/2024
2.024	Bldg A Rm A08				02/29/2024
2.025	Bldg A Rm A07				02/29/2024
2.026	Bldg A Rm A07				02/29/2024
2.027	Bldg A Rm A06				02/29/2024
2.028	Bldg A Rm A06				02/29/2024
2.029	Bldg A Rm A05				02/29/2024
2.030	Bldg A Rm A05				02/29/2024
2.031	Bldg A Rm A04				02/29/2024
2.032	Bldg A Rm A04				02/29/2024
2.033	Bldg A Rm A03				02/29/2024
2.034	Bldg A Rm A03				02/29/2024
2.035	Bldg A Rm A02				02/29/2024
2.036	Bldg A Rm A02				02/29/2024
2.037	Bldg A Rm A01				02/29/2024
2.038	Bldg A Rm A01				02/29/2024
2.039	Bldg A RR A17				02/29/2024

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.040	Bldg A Girls RR A16				02/29/2024
2.041	Bldg A Custodial A15				02/29/2024
2.042	Bldg A Boys RR A14				02/29/2024
2.043	Bldg B IDF Rm B06				02/29/2024
2.044	Bldg B Psyche B03				02/29/2024
2.045	Bldg B Assistant Principal B04				02/29/2024
2.046	Bldg B Elect Rm B06				02/29/2024
2.047	Bldg B Counsel B05				02/29/2024
2.048	Bldg B Health RR				02/29/2024
2.049	Bldg B Health Office B02				02/29/2024
2.050	Bldg B Health St Rm B02				02/29/2024
2.051	Bldg B Admin Lobby B01				02/29/2024
2.052	Bldg B Admin Lobby B01				02/29/2024
2.053	Bldg B Admin Lobby B01				02/29/2024
2.054	Bldg B Staff Rm B07				02/29/2024
2.055	Bldg B Custodial B07				02/29/2024
2.056	Bldg B Conf Rm B08				02/29/2024
2.057	Bldg B Staff RR B09				02/29/2024
2.058	Bldg B Admin Lobby B01				02/29/2024
2.059	Bldg B Parent Work B11				02/29/2024
2.060	Bldg B Principal B10				02/29/2024
2.061	Bldg B Staff Rm B12				02/29/2024
2.062	Bldg B Staff Rm B12				02/29/2024
2.063	Bldg B Secure St B07				02/29/2024
2.064	Bldg B Library St B13				02/29/2024
2.065	Bldg B General Strg B13				02/29/2024
2.066	Bldg B Comp Lab B13				02/29/2024
2.067	Bldg B Comp Lab B13				02/29/2024
2.068	Bldg B Reading Lnge B13				02/29/2024
2.069	Bldg B Read Lnge B13				02/29/2024
2.070	Bldg B Read Lnge B13				02/29/2024
2.071	Bldg B Read Lnge B13				02/29/2024
2.072	Bldg B Read Lnge B13				02/29/2024
2.073	Bldg B Cust Off B14				02/29/2024
2.074	Bldg B Cust Strg B14				02/29/2024
2.075	Bldg B Bridges B13				02/29/2024
2.077	Bldg B Dry Strg B15				02/29/2024
2.078	Bldg B Kitchen Hall				02/29/2024
2.080	Bldg B Custodial B15				02/29/2024
2.082	Bldg B Servery B15				02/29/2024
2.083	Bldg B MP Rm B16				02/29/2024
2.084	Bldg B MP Rm B16				02/29/2024
2.085	Bldg B MP Rm B16				02/29/2024
2.086	Bldg B Girls RR B17				02/29/2024
2.087	Bldg B Boys RR B18				02/29/2024
2.088	Bldg B Custodial B16				02/29/2024
2.089	Bldg B Stage Hall Rt				02/29/2024
2.090	Bldg B Stage B16				02/29/2024
2.091	Bldg B Stage B16				02/29/2024
2.092	Bldg B Stage Hall				02/29/2024
2.093	Bldg B Stage St B16				02/29/2024
2.094	Bldg B MP Rm B16				02/29/2024

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.095	Bldg B MP Rm B16				02/29/2024
2.096	Bldg B MP Rm B16				02/29/2024
2.097	Bldg B PE Office B16				02/29/2024
2.098	Bldg B General Strg B16				02/29/2024
2.099	Bldg B PE Strg B19				02/29/2024
2.100	Bldg B Elect Rm B20				02/29/2024
2.251	Bldg C IDF Rm C21				02/29/2024
2.252	Bldg C Elect Rm C24				02/29/2024
2.253	Bldg C RSP C05				02/29/2024
2.254	Bldg C RSP C05				02/29/2024
2.255	Bldg C ELD C06				02/29/2024
2.256	Bldg C ELD C06				02/29/2024
2.257	Bldg C Rm C07				02/29/2024
2.258	Bldg C Rm C07				02/29/2024
2.259	Bldg C Rm C08				02/29/2024
2.260	Bldg C Rm C08				02/29/2024
2.261	Bldg C Rm C09				02/29/2024
2.262	Bldg C Rm C09				02/29/2024
2.263	Bldg C Rm C10				02/29/2024
2.264	Bldg C Rm C10				02/29/2024
2.265	Bldg C Rm C11				02/29/2024
2.266	Bldg C Rm C11				02/29/2024
2.267	Bldg C Rm C12				02/29/2024
2.268	Bldg C Rm C12				02/29/2024
2.269	Bldg C Rm C13				02/29/2024
2.270	Bldg C Rm C13				02/29/2024
2.271	Bldg C Boys RR C18				02/29/2024
2.272	Bldg C Girls RR C19				02/29/2024
2.273	Bldg C Rm C14				02/29/2024
2.274	Bldg C Rm C14				02/29/2024
2.275	Bldg C Rm C15				02/29/2024
2.276	Bldg C Rm C15				02/29/2024
2.277	Bldg C Rm C16				02/29/2024
2.278	Bldg C Rm C16				02/29/2024
2.279	Bldg C Rm C17				02/29/2024
2.280	Bldg C Rm C17				02/29/2024
2.281	Bldg C Rm C01				02/29/2024
2.282	Bldg C Rm C01				02/29/2024
2.283	Bldg C Rm C02				02/29/2024
2.284	Bldg C Rm C02				02/29/2024
2.285	Bldg C Rm C03				02/29/2024
2.286	Bldg C Rm C03				02/29/2024
2.287	Bldg C Rm C04				02/29/2024
2.288	Bldg C Rm C04				02/29/2024
2.289	Bldg C Speech C20				02/29/2024
2.290	Bldg C Strg C21				02/29/2024
2.291	Bldg C Custodial C22				02/29/2024
2.292	Bldg C Staff RR C23				02/29/2024
2.079	Bldg B Kitch RR B15.2				08/28/2024
2.317	Bldg D D1				08/28/2024
2.318	Bldg D D1				08/28/2024
2.315	Bldg D D2				08/28/2024

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.316	Bldg D D2				08/28/2024
2.314	Bldg D D3				08/28/2024
2.313	Bldg D D3				08/28/2024
2.311	Bldg D D4				08/28/2024
2.312	Bldg D D4				08/28/2024

Manual Pull Station

2.138	Bldg B Admin Lobby				02/29/2024
-------	--------------------	--	--	--	------------

Heat Detector - Restorable Spot

2.076	Bldg B Cook Prep B15				02/29/2024
2.081	Bldg B Dishwash				02/29/2024

Mechanical, Electrosonic, or Pressure Waterflow Device

2.126	Bldg A Custodian Rm A15				02/29/2024
2.376	Bldg C Custodial Rm C22				02/29/2024
2.133	Bldg B Cust B15.3				08/28/2024

Valve Tamper Switch

2.127	Bldg A Custodian Rm A15				02/29/2024
2.377	Bldg C Custodial C22				02/29/2024
2.134	Bldg B Cust B15.3				08/28/2024

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
BPS - Booster Power Supply					
	BPS-D Room D3				07/30/2025
	BPS-C IDF Room C21.1				07/30/2025
	BPS-A IDF Room A13.1 (2) 12v7ah				07/30/2025
	BPS-B IDF Room B06.1				07/30/2025

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fusible Links					
	Fusible Links 450 x 3				07/28/2025
Range Hood					
	Hood				07/28/2025
Range Suppression					
	Suppression				07/28/2025
	101-20 Cartridge				01/28/2020
Cooking Equipment					
	Appliances				07/28/2025
Range Suppression Tank					
	R102 3 Gallon Cylinder				01/28/2020