

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

MARIEMONT ELEMNTARY

1401 CORTA WAY
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, July 22, 2025

Test Session :22 Jul 2025 06:00 RJ5311 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	MARIEMONT ELELEMENTARY	CONTACT
ADDRESS	1401 CORTA WAY	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Ventilation and Cooking Equipment	1	1(100%)	1(100%)	0(0%)
Alarm Notification Appliance	86	86(100%)	86(100%)	0(0%)
Fire Control Panel	8	8(100%)	8(100%)	0(0%)
Initiating Device	188	183(97%)	181(96%)	2(1%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, July 22, 2025

ACCEPTED BY 07/22/2025

Building Representative


TESTED BY 07/22/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Building J J2 Custodial Room
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			
ADDRESS / SCAN ADDRESS		DESCRIPTION	Building J J2 Custodial Room - Voice/EVAC Panel
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	2-287 059	Building C C3 Kitchen Restroom
	Created By:	Riley Goyet
	Creation Date:	07/21/2025
	Corrective Action:	Covered with tape
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	2-059 152	Building E Staff RR Entry
	Created By:	Riley Goyet
	Creation Date:	07/21/2025
	Corrective Action:	Covered in tape
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Building J J2 Custodial Room - Voice/EVAC Panel
	Created By:	Riley Goyet
	Creation Date:	07/21/2025
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	020	Building A A1 Hallway	Manual	9/24/2024 3:07:36 PM
		Visual inspection	Passed (Manual)	
Visible	026	Building A A1 North Exit	Manual	9/24/2024 3:08:31 PM
		Visual inspection	Passed (Manual)	
Visible	029	Building A A1A Admin Office	Manual	9/24/2024 3:08:36 PM
		Functional Inspection	Passed	
Visible	027	Building A A1A Admin Restroom	Manual	9/24/2024 3:08:32 PM
		Visual inspection	Passed (Manual)	
Visible	028	Building A A1A Admin Restroom	Manual	9/24/2024 3:08:34 PM
		Functional Inspection	Passed	
Visible	024	Building A A1C Admin Office	Manual	9/24/2024 3:08:28 PM
		Visual inspection	Passed (Manual)	
Visible	025	Building A A1C Admin Restroom	Manual	9/24/2024 3:08:30 PM
		Functional Inspection	Passed	
Audible And Visible	021	Building A A1D Admin Office	Manual	9/24/2024 3:07:39 PM
		Visual inspection	Passed (Manual)	
Visible	030	Building A A2 Admin Office	Manual	9/24/2024 3:08:37 PM
		Functional Inspection	Passed	
Audible And Visible	022	Building A A3 Library	Manual	9/24/2024 3:07:37 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	023	Building A A3 Library	Manual	9/24/2024 3:07:40 PM
		Functional Inspection	Passed	
Audible	019	Building A East Exterior	Manual	9/24/2024 3:07:06 PM
		Visual inspection	Passed (Manual)	
Visible	258	Building A L1 Staff RR Near Admin	Manual	9/24/2024 3:09:06 PM
		Functional Inspection	Passed	
Visible	259	Building A L2 Staff Restroom Near Admin	Manual	9/24/2024 3:09:07 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	045	Building B Classroom B1	Manual	9/24/2024 3:07:41 PM
		Functional Inspection	Passed	
Visible	047	Building B Classroom B1 RR	Manual	9/24/2024 3:08:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	046	Building B Classroom B2	Manual	9/24/2024 3:07:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	048	Building B Classroom B2 RR	Manual	9/24/2024 3:08:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	044	Building B East Exterior	Manual	9/24/2024 3:07:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	043	Building B South Exterior	Manual	9/24/2024 3:07:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	092	Building C C2A Kitchen	Manual	9/24/2024 3:08:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	089	Building C C2B Kitchen	Manual	9/24/2024 3:07:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	093	Building C C3 Kitchen Hallway	Manual	9/24/2024 3:08:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	094	Building C C3 Kitchen Restroom	Manual	9/24/2024 3:08:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	095	Building C C3 Kitchen Restroom	Manual	9/24/2024 3:08:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	096	Building C C3A MP Cust Room	Manual	9/24/2024 3:08:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	087	Building C C4 MP Room	Manual	9/24/2024 3:07:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	088	Building C C4 MP Room	Manual	9/24/2024 3:07:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	090	Building C C4 MP Room Stage	Manual	9/24/2024 3:07:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	091	Building C C4 MP Room Stage	Manual	9/24/2024 3:07:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	086	Building C Classroom C2A	Manual	9/24/2024 3:07:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	084	Building C East Exterior	Manual	9/24/2024 3:07:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	083	Building C South Exterior	Manual	9/24/2024 3:07:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	085	Building C West Exterior	Manual	9/24/2024 3:07:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	122	Building D Classroom D1	Manual	9/24/2024 3:07:48 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	123	Building D Classroom D2	Manual	9/24/2024 3:07:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	124	Building D Classroom D3	Manual	9/24/2024 3:07:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	125	Building D Classroom D4	Manual	9/24/2024 3:07:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	126	Building D Classroom D5	Manual	9/24/2024 3:07:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	127	Building D Classroom D6	Manual	9/24/2024 3:07:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	121	Building D East Exterior	Manual	9/24/2024 3:07:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	157	Building E Classroom E1	Manual	9/24/2024 3:08:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	158	Building E Classroom E2	Manual	9/24/2024 3:08:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	159	Building E Classroom E3	Manual	9/24/2024 3:08:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	160	Building E Classroom E4	Manual	9/24/2024 3:08:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	161	Building E Classroom E5	Manual	9/24/2024 3:08:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	162	Building E Classroom E6	Manual	9/24/2024 3:08:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	155	Building E North Exterior	Manual	9/24/2024 3:07:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	164	Building E Staff Restroom	Manual	9/24/2024 3:08:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	163	Building E Staff RR Entry	Manual	9/24/2024 3:08:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	156	Building E West Exterior	Manual	9/24/2024 3:07:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	193	Building F Classroom F1	Manual	9/24/2024 3:08:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	194	Building F Classroom F2	Manual	9/24/2024 3:08:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	195	Building F Classroom F3	Manual	9/24/2024 3:08:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	196	Building F Classroom F4	Manual	9/24/2024 3:08:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	197	Building F Classroom F5	Manual	9/24/2024 3:08:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	198	Building F Classroom F6	Manual	9/24/2024 3:08:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	189	Building F North Exterior	Manual	9/24/2024 3:07:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	190	Building F North Exterior	Manual	9/24/2024 3:07:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	191	Building F South Exterior	Manual	9/24/2024 3:07:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	192	Building F South Exterior	Manual	9/24/2024 3:07:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	210	Building G Classroom G1	Manual	9/24/2024 3:08:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	211	Building G Classroom G2	Manual	9/24/2024 3:08:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	209	Building G North Exterior	Manual	9/24/2024 3:07:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	222	Building H Classroom H1	Manual	9/24/2024 3:08:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	223	Building H Classroom H1 RR	Manual	9/24/2024 3:08:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	224	Building H Classroom H1 RR	Manual	9/24/2024 3:08:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	221	Building H West Exterior	Manual	9/24/2024 3:07:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	234	Building I Classroom I-1	Manual	9/24/2024 3:08:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	235	Building I Classroom I-1A RR	Manual	9/24/2024 3:08:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	236	Building I Classroom I-1B RR	Manual	9/24/2024 3:08:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	233	Building I South Exterior	Manual	9/24/2024 3:07:27 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	241	Building J East Exterior	Manual	9/24/2024 3:07:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	243	Building J J1 Boys Restroom	Manual	9/24/2024 3:08:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	244	Building J J3 Girls Restroom	Manual	9/24/2024 3:08:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	242	Building J West Exterior	Manual	9/24/2024 3:07:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	251	Building K East Exterior	Manual	9/24/2024 3:07:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	252	Building K K2 Girls Restroom	Manual	9/24/2024 3:09:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	253	Building K K2 Girls Restroom	Manual	9/24/2024 3:09:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	254	Building K K3 Boys Restroom	Manual	9/24/2024 3:09:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	255	Building K K3 Boys Restroom	Manual	9/24/2024 3:09:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building L Classroom L1	Manual	9/24/2024 3:08:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building L Classroom L2	Manual	9/24/2024 3:08:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building L Classroom L3	Manual	9/24/2024 3:08:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building L North Exterior	Manual	9/24/2024 3:07:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building L South Exterior	Manual	9/24/2024 3:07:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A A1 Reception	Manual	7/21/2025 8:33:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building C C3A MP Custodian Room - P.E. "C"	Manual	7/21/2025 9:50:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building J J2 Custodial Room	Manual	7/21/2025 9:50:31 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building J J2 Custodial Room - P.E. "B"	Manual	7/21/2025 9:50:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building J J2 Custodial Room - P.E. "E"	Manual	7/21/2025 9:49:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building J J2 Custodial Room - P.E. "F"	Manual	7/21/2025 9:49:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building J J2 Custodial Room - P.E. "Master"	Manual	7/21/2025 9:50:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building J J2 Custodial Room - Voice/EVAC Panel	Manual	7/21/2025 9:39:49 AM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Timer (s)	30_seconds	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	3-382	Admin A1 AC-A1	Manual	7/21/2025 7:59:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 003	Building A A1 Admin Entrance	Manual	7/21/2025 7:59:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 004	Building A A1 Hallway	Manual	7/21/2025 8:00:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-377 002	Building A A1 Reception	Manual	7/21/2025 7:59:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 011	Building A A1A Admin Office	Manual	7/21/2025 7:53:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 009	Building A A1A Admin Restroom	Manual	7/21/2025 7:54:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 010	Building A A1A Admin Restroom	Manual	7/21/2025 7:54:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 008	Building A A1B Admin Office	Manual	7/21/2025 8:02:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 013	Building A A1B Admin Office Storage	Manual	7/21/2025 8:02:32 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-257 007	Building A A1C Admin Office	Manual	7/21/2025 8:01:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 014	Building A A1C Admin Restroom	Manual	7/21/2025 8:00:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 005	Building A A1D Admin Office	Manual	7/21/2025 8:00:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 006	Building A A1D Admin Office	Manual	7/21/2025 8:03:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 012	Building A A2 Admin Office	Manual	7/21/2025 7:55:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 018	Building A A3 Library	Manual	7/21/2025 7:52:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 016	Building A A3 Library	Manual	7/21/2025 7:52:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 017	Building A A3 Library	Manual	7/21/2025 7:52:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 015	Building A A3 Library	Manual	7/21/2025 7:53:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 256	Building A L1 Staff RR Near Admin	Manual	7/21/2025 8:04:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 034	Building B Classroom B1	Manual	7/21/2025 8:21:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 033	Building B Classroom B1	Manual	7/21/2025 8:22:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 032	Building B Classroom B1	Manual	7/21/2025 8:22:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 031	Building B Classroom B1	Manual	7/21/2025 8:22:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 035	Building B Classroom B1 Strg	Manual	7/21/2025 9:26:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 038	Building B Classroom B2	Manual	7/21/2025 8:18:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-269 037	Building B Classroom B2	Manual	7/21/2025 8:19:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 040	Building B Classroom B2	Manual	7/21/2025 8:19:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 039	Building B Classroom B2	Manual	7/21/2025 8:20:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 041	Building B Classroom B2 RR	Manual	7/21/2025 8:20:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 042	Building B Room B3 O/S Strg	Manual	7/21/2025 9:29:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-308 080	Building C C2B Kitchen	Manual	7/21/2025 11:44:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 057	Building C C3 Kitchen Hallway	Manual	7/21/2025 8:15:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 058	Building C C3 Kitchen Restroom	Manual	7/21/2025 8:15:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-285 081	Building C C3A Kitchen O/S Strg	Manual	7/21/2025 11:45:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 061	Building C C3A MP Custodian Room	Manual	7/21/2025 8:15:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 062	Building C C4 MP Room	Manual	7/21/2025 8:11:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 063	Building C C4 MP Room	Manual	7/21/2025 8:11:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 064	Building C C4 MP Room	Manual	7/21/2025 8:11:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 065	Building C C4 MP Room	Manual	7/21/2025 8:11:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 066	Building C C4 MP Room	Manual	7/21/2025 8:11:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 067	Building C C4 MP Room	Manual	7/21/2025 8:11:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-301 068	Building C C4 MP Room	Manual	7/21/2025 8:12:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 069	Building C C4 MP Room	Manual	7/21/2025 8:12:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 077	Building C C4 MP Room	Manual	7/21/2025 8:12:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 070	Building C C4 MP Room	Manual	7/21/2025 8:12:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 072	Building C C4 MP Room	Manual	7/21/2025 8:12:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 071	Building C C4 MP Room	Manual	7/21/2025 8:12:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 074	Building C C4 MP Room	Manual	7/21/2025 8:13:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 075	Building C C4 MP Room	Manual	7/21/2025 8:13:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 076	Building C C4 MP Room	Manual	7/21/2025 8:13:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 073	Building C C4 MP Room	Manual	7/21/2025 8:13:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 079	Building C C4 MP Room Stage	Manual	7/21/2025 8:14:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 078	Building C C4 MP Room Stage	Manual	7/21/2025 8:14:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 082	Building C C5 MP O/S Storage	Manual	7/21/2025 11:46:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 056	Building C Classroom C2A/Kitchen	Manual	7/21/2025 8:16:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-140 050	Building C MP Room NW	Manual	7/21/2025 8:06:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 052	Building C MP Room South	Manual	7/21/2025 8:08:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-144 053	Building C MP Room Stage N	Manual	7/21/2025 8:09:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-143 054	Building C MP Room Stage S	Manual	7/21/2025 8:09:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-139 051	Building C MP Room SW	Manual	7/21/2025 8:06:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 055	Building C Room C2/MP Foyer	Manual	7/21/2025 8:17:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-141 049	Building C Room C2/North Hall	Manual	7/21/2025 8:07:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 097	Building D Classroom D1	Manual	7/21/2025 7:41:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 098	Building D Classroom D1	Manual	7/21/2025 7:42:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 099	Building D Classroom D1	Manual	7/21/2025 7:42:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 100	Building D Classroom D1	Manual	7/21/2025 7:42:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 104	Building D Classroom D2	Manual	7/21/2025 7:43:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 101	Building D Classroom D2	Manual	7/21/2025 7:43:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 102	Building D Classroom D2	Manual	7/21/2025 7:44:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 103	Building D Classroom D2	Manual	7/21/2025 7:44:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 108	Building D Classroom D3	Manual	7/21/2025 7:44:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 105	Building D Classroom D3	Manual	7/21/2025 7:45:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 106	Building D Classroom D3	Manual	7/21/2025 7:45:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-020 107	Building D Classroom D3	Manual	7/21/2025 7:45:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 109	Building D Classroom D4	Manual	7/21/2025 7:46:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 110	Building D Classroom D4	Manual	7/21/2025 7:46:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 111	Building D Classroom D4	Manual	7/21/2025 7:47:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 112	Building D Classroom D4	Manual	7/21/2025 7:47:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 114	Building D Classroom D5	Manual	7/21/2025 7:48:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 115	Building D Classroom D5	Manual	7/21/2025 7:48:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 116	Building D Classroom D5	Manual	7/21/2025 7:48:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 113	Building D Classroom D5	Manual	7/21/2025 7:48:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 117	Building D Classroom D6	Manual	7/21/2025 7:49:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 120	Building D Classroom D6	Manual	7/21/2025 7:50:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 119	Building D Classroom D6	Manual	7/21/2025 7:50:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 118	Building D Classroom D6	Manual	7/21/2025 7:50:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 131	Building E Classroom E1	Manual	7/21/2025 7:39:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 130	Building E Classroom E1	Manual	7/21/2025 7:39:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 129	Building E Classroom E1	Manual	7/21/2025 7:40:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-036 128	Building E Classroom E1	Manual	7/21/2025 7:40:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 135	Building E Classroom E2	Manual	7/21/2025 7:38:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 134	Building E Classroom E2	Manual	7/21/2025 7:38:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 133	Building E Classroom E2	Manual	7/21/2025 7:38:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 132	Building E Classroom E2	Manual	7/21/2025 7:38:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 136	Building E Classroom E3	Manual	7/21/2025 7:36:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 139	Building E Classroom E3	Manual	7/21/2025 7:36:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 137	Building E Classroom E3	Manual	7/21/2025 7:37:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 138	Building E Classroom E3	Manual	7/21/2025 7:37:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 140	Building E Classroom E4	Manual	7/21/2025 7:35:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 143	Building E Classroom E4	Manual	7/21/2025 7:35:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 142	Building E Classroom E4	Manual	7/21/2025 7:35:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 141	Building E Classroom E4	Manual	7/21/2025 7:35:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 144	Building E Classroom E5	Manual	7/21/2025 7:33:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 147	Building E Classroom E5	Manual	7/21/2025 7:33:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 146	Building E Classroom E5	Manual	7/21/2025 7:34:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-052 145	Building E Classroom E5	Manual	7/21/2025 7:34:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 151	Building E Classroom E6	Manual	7/21/2025 7:32:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 150	Building E Classroom E6	Manual	7/21/2025 7:32:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 149	Building E Classroom E6	Manual	7/21/2025 7:32:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 148	Building E Classroom E6	Manual	7/21/2025 7:32:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 153	Building E Staff Restroom	Manual	7/21/2025 8:43:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-061 154	Building E Storage	Manual	7/21/2025 11:57:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 168	Building F Classroom F1	Manual	7/21/2025 7:20:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 167	Building F Classroom F1	Manual	7/21/2025 7:20:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 166	Building F Classroom F1	Manual	7/21/2025 7:21:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 165	Building F Classroom F1	Manual	7/21/2025 7:21:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 172	Building F Classroom F2	Manual	7/21/2025 7:22:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 169	Building F Classroom F2	Manual	7/21/2025 7:22:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 170	Building F Classroom F2	Manual	7/21/2025 7:22:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 171	Building F Classroom F2	Manual	7/21/2025 7:22:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 173	Building F Classroom F3	Manual	7/21/2025 7:24:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-071 174	Building F Classroom F3	Manual	7/21/2025 7:25:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 175	Building F Classroom F3	Manual	7/21/2025 7:25:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 176	Building F Classroom F3	Manual	7/21/2025 7:25:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 180	Building F Classroom F4	Manual	7/21/2025 7:26:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 177	Building F Classroom F4	Manual	7/21/2025 7:26:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 179	Building F Classroom F4	Manual	7/21/2025 7:26:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 178	Building F Classroom F4	Manual	7/21/2025 7:26:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 184	Building F Classroom F5	Manual	7/21/2025 7:27:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 181	Building F Classroom F5	Manual	7/21/2025 7:27:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 183	Building F Classroom F5	Manual	7/21/2025 7:28:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 182	Building F Classroom F5	Manual	7/21/2025 7:28:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 187	Building F Classroom F6	Manual	7/21/2025 7:29:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 185	Building F Classroom F6	Manual	7/21/2025 7:30:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 186	Building F Classroom F6	Manual	7/21/2025 7:30:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 188	Building F Classroom F6	Manual	7/21/2025 7:31:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 204	Building G Attic Classroom G1	Manual	7/21/2025 10:46:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-133 203	Building G Attic Classroom G1	Manual	7/21/2025 10:46:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 205	Building G Attic Classroom G1	Manual	7/21/2025 10:47:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 206	Building G Attic Classroom G2	Manual	7/21/2025 11:12:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 207	Building G Attic Classroom G2	Manual	7/21/2025 11:12:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 208	Building G Attic Classroom G2	Manual	7/21/2025 11:12:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 199	Building G Classroom G1	Manual	7/21/2025 9:46:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 200	Building G Classroom G1	Manual	7/21/2025 9:46:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 201	Building G Classroom G2	Manual	7/21/2025 9:43:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 202	Building G Classroom G2	Manual	7/21/2025 9:43:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 218	Building H Attic Classroom H1	Manual	7/21/2025 11:29:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 219	Building H Attic Classroom H1	Manual	7/21/2025 11:29:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 220	Building H Attic Classroom H1	Manual	7/21/2025 11:29:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-108 217	Building H Classroom H1	Manual	7/21/2025 10:02:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 213	Building H Classroom H1	Manual	7/21/2025 9:41:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 212	Building H Classroom H1	Manual	7/21/2025 9:41:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 215	Building H Classroom H1 RR	Manual	7/21/2025 9:42:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-099 214	Building H Classroom H1 RR	Manual	7/21/2025 9:42:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 216	Building H Classroom H1 Storage	Manual	7/21/2025 9:41:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 232	Building I Attic Classroom I-1	Manual	7/21/2025 10:20:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 231	Building I Attic Classroom I-1	Manual	7/21/2025 10:20:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 230	Building I Attic Classroom I-1	Manual	7/21/2025 10:20:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 226	Building I Classroom I-1	Manual	7/21/2025 10:13:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 225	Building I Classroom I-1	Manual	7/21/2025 10:13:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 227	Building I Classroom I-1	Manual	7/21/2025 10:13:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 228	Building I Classroom I-1A RR	Manual	7/21/2025 10:14:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 229	Building I Classroom I-1B RR	Manual	7/21/2025 10:14:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 237	Building J J1 Boys Restroom	Manual	7/21/2025 9:15:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 240	Building J J2 Custodial Room	Manual	7/21/2025 11:57:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 238	Building J J2 Custodial Room	Manual	7/21/2025 11:36:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 239	Building J J3 Girls Restroom	Manual	7/21/2025 8:35:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 245	Building K K1 Storage	Manual	7/21/2025 8:29:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 246	Building K K2 Girls Restroom	Manual	7/21/2025 8:31:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-008 247	Building K K2 Girls Restroom	Manual	7/21/2025 9:16:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 248	Building K K3 Boys Restroom	Manual	7/21/2025 9:16:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 249	Building K K3 Boys Restroom	Manual	7/21/2025 9:16:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 250	Building K K4 Storage Room	Manual	7/21/2025 11:36:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382	Building L Electrical Room L7	Manual	7/21/2025 11:54:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-384	Lobby C2 AC-B2	Manual	7/21/2025 8:17:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272	Room L1	Manual	7/21/2025 9:41:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271	Room L1	Manual	7/21/2025 9:41:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269	Room L2	Manual	7/21/2025 8:26:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270	Room L2	Manual	7/21/2025 8:47:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267	Room L3	Manual	7/21/2025 8:26:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268	Room L3	Manual	7/21/2025 9:41:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-278 036	Building B Classroom B1 RR	Manual	7/21/2025 9:30:51 AM
	Comment:	No access		
Smoke Detector - General	2-283 060	Building C C2A Kitchen Storage	Manual	7/21/2025 8:35:55 AM
	Comment:	No access		
Heat Detector - Restorable Spot	2-381	Building L HVAC L4 Classroom L3	Manual	7/21/2025 11:55:02 AM
	Comment:	Out of reach		
Heat Detector - Restorable Spot	2-380	Building L HVAC L5 Classroom L2	Manual	7/21/2025 11:55:14 AM
	Comment:	Out of reach		
Heat Detector - Restorable Spot	2-379	Building L HVAC L6 Classroom L1	Manual	7/21/2025 11:55:22 AM
	Comment:	Out of reach		

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
----------------	---------	-------------	--------	-----------

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-287 059	Building C C3 Kitchen Restroom	Manual	7/21/2025 9:24:01 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Smoke Detector - General	2-059 152	Building E Staff RR Entry	Manual	7/21/2025 9:24:41 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Atrium Hatch	2-386	Stage Roof Hatch	Manual	7/21/2025 9:12:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
019	Building A East Exterior				
043	Building B South Exterior				
044	Building B East Exterior				
083	Building C South Exterior				
084	Building C East Exterior				
085	Building C West Exterior				
121	Building D East Exterior				
155	Building E North Exterior				
156	Building E West Exterior				
189	Building F North Exterior				
190	Building F North Exterior				
191	Building F South Exterior				
192	Building F South Exterior				
209	Building G North Exterior				
221	Building H West Exterior				
233	Building I South Exterior				
241	Building J East Exterior				
242	Building J West Exterior				
251	Building K East Exterior				
	Building L North Exterior				
	Building L South Exterior				
Audible And Visible					
020	Building A A1 Hallway				
021	Building A A1D Admin Office				
022	Building A A3 Library				
023	Building A A3 Library				
045	Building B Classroom B1				
046	Building B Classroom B2				
086	Building C Classroom C2A				
087	Building C C4 MP Room				
088	Building C C4 MP Room				
089	Building C C2B Kitchen				
090	Building C C4 MP Room Stage				
091	Building C C4 MP Room Stage				
122	Building D Classroom D1				
123	Building D Classroom D2				
124	Building D Classroom D3				
125	Building D Classroom D4				
126	Building D Classroom D5				
127	Building D Classroom D6				
157	Building E Classroom E1				
158	Building E Classroom E2				
159	Building E Classroom E3				
160	Building E Classroom E4				
161	Building E Classroom E5				
162	Building E Classroom E6				
193	Building F Classroom F1				
194	Building F Classroom F2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
195	Building F Classroom F3				
196	Building F Classroom F4				
197	Building F Classroom F5				
198	Building F Classroom F6				
210	Building G Classroom G1				
211	Building G Classroom G2				
222	Building H Classroom H1				
234	Building I Classroom I-1				
	Building L Classroom L1				
	Building L Classroom L2				
	Building L Classroom L3				
Visible					
024	Building A A1C Admin Office				
025	Building A A1C Admin Restroom				
026	Building A A1 North Exit				
027	Building A A1A Admin Restroom				
028	Building A A1A Admin Restroom				
029	Building A A1A Admin Office				
030	Building A A2 Admin Office				
047	Building B Classroom B1 RR				
048	Building B Classroom B2 RR				
092	Building C C2A Kitchen				
093	Building C C3 Kitchen Hallway				
094	Building C C3 Kitchen Restroom				
095	Building C C3 Kitchen Restroom				
096	Building C C3A MP Cust Room				
163	Building E Staff RR Entry				
164	Building E Staff Restroom				
223	Building H Classroom H1 RR				
224	Building H Classroom H1 RR				
235	Building I Classroom I-1A RR				
236	Building I Classroom I-1B RR				
243	Building J J1 Boys Restroom				
244	Building J J3 Girls Restroom				
252	Building K K2 Girls Restroom				
253	Building K K2 Girls Restroom				
254	Building K K3 Boys Restroom				
255	Building K K3 Boys Restroom				
258	Building A L1 Staff RR Near Admin				
259	Building A L2 Staff Restroom Near Admin				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Building A A1 Reception				
NAC Power Extender Panel					
	Building J J2 Custodial Room - P.E. "Master"				
	Building J J2 Custodial Room - P.E. "B"				
	Building J J2 Custodial Room - P.E. "E"				
	Building J J2 Custodial Room - P.E. "F"				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Building C C3A MP Custodian Room - P.E. "C"				
Fire Alarm Panel					
	Building J J2 Custodial Room	EST	3		
	Building J J2 Custodial Room - Voice/EVAC Panel	EST	3		

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-377 002	Building A A1 Reception				
2-141 049	Building C Room C2/North Hall				
2-140 050	Building C MP Room NW				
2-139 051	Building C MP Room SW				
2-142 052	Building C MP Room South				
2-144 053	Building C MP Room Stage N				
2-143 054	Building C MP Room Stage S				
Smoke Detector - General					
2-261 003	Building A A1 Admin Entrance				
2-256 004	Building A A1 Hallway				
2-259 005	Building A A1D Admin Office				
2-260 006	Building A A1D Admin Office				
2-257 007	Building A A1C Admin Office				
2-255 008	Building A A1B Admin Office				
2-263 009	Building A A1A Admin Restroom				
2-262 010	Building A A1A Admin Restroom				
2-264 011	Building A A1A Admin Office				
2-265 012	Building A A2 Admin Office				
2-254 013	Building AA1B Admin Office Storage				
2-258 014	Building A A1C Admin Restroom				
2-311 015	Building A A3 Library				
2-266 016	Building A A3 Library				
2-267 017	Building A A3 Library				
2-312 018	Building A A3 Library				
2-279 031	Building B Classroom B1				
2-280 032	Building B Classroom B1				
2-275 033	Building B Classroom B1				
2-276 034	Building B Classroom B1				
2-277 035	Building B Classroom B1 Strg				
2-278 036	Building B Classroom B1 RR				
2-269 037	Building B Classroom B2				
2-270 038	Building B Classroom B2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-271 039	Building B Classroom B2				
2-272 040	Building B Classroom B2				
2-274 041	Building B Classroom B2 RR				
2-273 042	Building B Room B3 O/S Strg				
2-309 055	Building C Room C2/MP Foyer				
2-282 056	Building C Classroom C2A/Kitchen				
2-284 057	Building C C3 Kitchen Hallway				
2-286 058	Building C C3 Kitchen Restroom				
2-287 059	Building C C3 Kitchen Restroom				
2-283 060	Building C C2A Kitchen Storage				
2-288 061	Building C C3A MP Custodian Room				
2-304 062	Building C C4 MP Room				
2-305 063	Building C C4 MP Room				
2-306 064	Building C C4 MP Room				
2-307 065	Building C C4 MP Room				
2-303 066	Building C C4 MP Room				
2-302 067	Building C C4 MP Room				
2-301 068	Building C C4 MP Room				
2-300 069	Building C C4 MP Room				
2-297 070	Building C C4 MP Room				
2-299 071	Building C C4 MP Room				
2-298 072	Building C C4 MP Room				
2-292 073	Building C C4 MP Room				
2-293 074	Building C C4 MP Room				
2-294 075	Building C C4 MP Room				
2-295 076	Building C C4 MP Room				
2-296 077	Building C C4 MP Room				
2-289 078	Building C C4 MP Room Stage				
2-291 079	Building C C4 MP Room Stage				
2-011 097	Building D Classroom D1				
2-013 098	Building D Classroom D1				
2-012 099	Building D Classroom D1				
2-010 100	Building D Classroom D1				
2-015 101	Building D Classroom D2				
2-017 102	Building D Classroom D2				
2-016 103	Building D Classroom D2				
2-014 104	Building D Classroom D2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-019 105	Building D Classroom D3				
2-021 106	Building D Classroom D3				
2-020 107	Building D Classroom D3				
2-018 108	Building D Classroom D3				
2-022 109	Building D Classroom D4				
2-024 110	Building D Classroom D4				
2-025 111	Building D Classroom D4				
2-023 112	Building D Classroom D4				
2-027 113	Building D Classroom D5				
2-026 114	Building D Classroom D5				
2-028 115	Building D Classroom D5				
2-029 116	Building D Classroom D5				
2-030 117	Building D Classroom D6				
2-031 118	Building D Classroom D6				
2-033 119	Building D Classroom D6				
2-032 120	Building D Classroom D6				
2-036 128	Building E Classroom E1				
2-035 129	Building E Classroom E1				
2-038 130	Building E Classroom E1				
2-037 131	Building E Classroom E1				
2-041 132	Building E Classroom E2				
2-042 133	Building E Classroom E2				
2-039 134	Building E Classroom E2				
2-040 135	Building E Classroom E2				
2-045 136	Building E Classroom E3				
2-044 137	Building E Classroom E3				
2-043 138	Building E Classroom E3				
2-046 139	Building E Classroom E3				
2-048 140	Building E Classroom E4				
2-049 141	Building E Classroom E4				
2-050 142	Building E Classroom E4				
2-047 143	Building E Classroom E4				
2-053 144	Building E Classroom E5				
2-052 145	Building E Classroom E5				
2-051 146	Building E Classroom E5				
2-054 147	Building E Classroom E5				
2-055 148	Building E Classroom E6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-058 149	Building E Classroom E6				
2-057 150	Building E Classroom E6				
2-056 151	Building E Classroom E6				
2-059 152	Building E Staff RR Entry				
2-060 153	Building E Staff Restroom				
2-065 165	Building F Classroom F1				
2-064 166	Building F Classroom F1				
2-063 167	Building F Classroom F1				
2-066 168	Building F Classroom F1				
2-068 169	Building F Classroom F2				
2-069 170	Building F Classroom F2				
2-070 171	Building F Classroom F2				
2-067 172	Building F Classroom F2				
2-074 173	Building F Classroom F3				
2-071 174	Building F Classroom F3				
2-072 175	Building F Classroom F3				
2-073 176	Building F Classroom F3				
2-076 177	Building F Classroom F4				
2-077 178	Building F Classroom F4				
2-078 179	Building F Classroom F4				
2-075 180	Building F Classroom F4				
2-081 181	Building F Classroom F5				
2-079 182	Building F Classroom F5				
2-080 183	Building F Classroom F5				
2-082 184	Building F Classroom F5				
2-086 185	Building F Classroom F6				
2-085 186	Building F Classroom F6				
2-083 187	Building F Classroom F6				
2-084 188	Building F Classroom F6				
2-092 199	Building G Classroom G1				
2-091 200	Building G Classroom G1				
2-090 201	Building G Classroom G2				
2-089 202	Building G Classroom G2				
2-096 212	Building H Classroom H1				
2-095 213	Building H Classroom H1				
2-099 214	Building H Classroom H1 RR				
2-098 215	Building H Classroom H1 RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-097 216	Building H Classroom H1 Storage				
2-102 225	Building I Classroom I-1				
2-103 226	Building I Classroom I-1				
2-109 227	Building I Classroom I-1				
2-104 228	Building I Classroom I-1A RR				
2-105 229	Building I Classroom I-1B RR				
2-005 237	Building J J1 Boys Restroom				
2-002 238	Building J J2 Custodial Room				
2-004 239	Building J J3 Girls Restroom				
2-007 245	Building K K1 Storage				
2-106 246	Building K K2 Girls Restroom				
2-008 247	Building K K2 Girls Restroom				
2-107 248	Building K K3 Boys Restroom				
2-006 249	Building K K3 Boys Restroom				
2-252 256	Building A L1 Staff RR Near Admin				
3-270	Room L2				07/21/2025
3-269	Room L2				07/21/2025
3-268	Room L3				07/21/2025
3-267	Room L3				07/21/2025
3-271	Room L1				07/21/2025
3-272	Room L1				07/21/2025
Heat Detector - Restorable Spot					
2-308 080	Building C C2B Kitchen				
2-285 081	Building C C3A Kitchen O/S Strg				
2-376 082	Building C C5 MP O/S Storage				
2-061 154	Building E Storage				
2-133 203	Building G Attic Classroom G1				
2-133 204	Building G Attic Classroom G1				
2-133 205	Building G Attic Classroom G1				
2-132 206	Building G Attic Classroom G2				
2-132 207	Building G Attic Classroom G2				
2-132 208	Building G Attic Classroom G2				
2-108 217	Building H Classroom H1				
2-134 218	Building H Attic Classroom H1				
2-134 219	Building H Attic Classroom H1				
2-134 220	Building H Attic Classroom H1				
2-130 230	Building I Attic Classroom I-1				
2-130 231	Building I Attic Classroom I-1				
2-130 232	Building I Attic Classroom I-1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-003 240	Building J J2 Custodial Room				
2-131 250	Building K K4 Storage Room				
2-379	Building L HVAC L6 Classroom L1				
2-380	Building L HVAC L5 Classroom L2				
2-381	Building L HVAC L4 Classroom L3				
2-382	Building L Electrical Room L7				
Smoke Detector - Duct					
3-382	Admin A1 AC-A1				07/21/2025
2-384	Lobby C2 AC-B2				07/21/2025

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Atrium Hatch					
2-386	Stage Roof Hatch				07/21/2025