

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

LA ENTRADA HIGH

5320 HEMLOCK ST
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, August 07, 2025

Test Session :05 Aug 2025 10:57 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	LA ENTRADA HIGH	CONTACT
ADDRESS	5320 HEMLOCK ST	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	48	48(100%)	48(100%)	0(0%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	121	116(96%)	116(96%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, August 07, 2025

ACCEPTED BY 08/07/2025

Building Representative


TESTED BY 08/07/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Admin Area Custodial Office Closet
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 8 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	027	Admin Area Custodial Office Closet - P.E. "Master"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	028	Admin Area Custodial Office Closet - P.E. "B"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	029	Admin Area Custodial Office Closet - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Admin Area Custodial Office Closet
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
	Manufacturer:	EST
	Model:	3

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	022	Admin Area Archives Front Desk	Manual	8/5/2025 10:59:32 AM
		Visual inspection	Passed (Manual)	
Visible	023	Admin Area Archives Office	Manual	8/5/2025 10:59:30 AM
		Visual inspection	Passed (Manual)	
Visible	024	Admin Area Archives Office RR	Manual	8/5/2025 10:59:28 AM
		Visual inspection	Passed (Manual)	
Visible	026	Admin Area Custodial Office	Manual	8/5/2025 10:59:26 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	020	Admin Area Office Hallway North	Manual	8/5/2025 10:59:45 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	021	Admin Area Office Hallway South	Manual	8/5/2025 10:59:41 AM
		Visual inspection	Passed (Manual)	
Visible	025	Admin Area Plan Dept Off N RR	Manual	8/5/2025 10:59:27 AM
		Visual inspection	Passed (Manual)	
Audible	019	Admin Area West Exterior	Manual	8/5/2025 10:59:57 AM
		Visual inspection	Passed (Manual)	
Visible	174	Multi-Purpose Bldg Boys RR MP Rm	Manual	8/5/2025 10:59:34 AM
		Visual inspection	Passed (Manual)	
Audible	169	Multi-Purpose Bldg East Exterior	Manual	8/5/2025 10:59:55 AM
		Visual inspection	Passed (Manual)	
Visible	173	Multi-Purpose Bldg Girls RR MP Rm	Manual	8/5/2025 10:59:35 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	172	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 11:00:28 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	171	Multi-Purpose Bldg Mp Room	Manual	8/5/2025 11:00:30 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	170	Multi-Purpose Bldg MP Room	Manual	8/5/2025 10:59:47 AM
		Visual inspection	Passed (Manual)	
Audible	168	Multi-Purpose Bldg South Exterior	Manual	8/5/2025 10:59:54 AM
		Visual inspection	Passed (Manual)	
Audible	040	Room 1 Building Northeast Exterior	Manual	8/5/2025 10:59:58 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	041	Room 1 Building Room 1	Manual	8/5/2025 10:59:44 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	042	Room 1 Building Room 1 Hall	Manual	8/5/2025 10:59:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	043	Room 1 Building Room 1 Restroom	Manual	8/5/2025 10:59:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	112	Rooms 11-14 Area Room 11	Manual	8/5/2025 11:00:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	Rooms 11-14 Area Room 12	Manual	8/5/2025 11:00:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	114	Rooms 11-14 Area Room 13	Manual	8/5/2025 11:00:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	115	Rooms 11-14 Area Room 14	Manual	8/5/2025 11:00:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	111	Rooms 11-14 Area West Ext/Boys RR	Manual	8/5/2025 10:59:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	136	Rooms 15-18 Area East Exterior	Manual	8/5/2025 10:59:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	139	Rooms 15-18 Area Room 15	Manual	8/5/2025 11:00:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	140	Rooms 15-18 Area Room 16	Manual	8/5/2025 11:00:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	144	Rooms 15-18 Area Room 16 South	Manual	8/5/2025 10:59:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	141	Rooms 15-18 Area Room 16A	Manual	8/5/2025 11:00:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	142	Rooms 15-18 Area Room 17	Manual	8/5/2025 11:00:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	143	Rooms 15-18 Area Room 18	Manual	8/5/2025 11:00:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	138	Rooms 15-18 Area South Exterior	Manual	8/5/2025 10:59:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	137	Rooms 15-18 Area West Exterior	Manual	8/5/2025 10:59:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	060	Rooms 2-5 Bldg North Exterior	Manual	8/5/2025 10:59:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	061	Rooms 2-5 Bldg North Exterior	Manual	8/5/2025 10:59:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	062	Rooms 2-5 Bldg Room 2	Manual	8/5/2025 11:00:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	063	Rooms 2-5 Bldg Room 3	Manual	8/5/2025 11:00:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	064	Rooms 2-5 Bldg Room 4	Manual	8/5/2025 11:00:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	065	Rooms 2-5 Bldg Room 5	Manual	8/5/2025 11:00:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	091	Rooms 6-10 Area Girls RR Rm 10	Manual	8/5/2025 10:59:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	090	Rooms 6-10 Area Room 10	Manual	8/5/2025 11:00:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	085	Rooms 6-10 Area Room 6	Manual	8/5/2025 11:00:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	086	Rooms 6-10 Area Room 6 Office	Manual	8/5/2025 11:00:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	087	Rooms 6-10 Area Room 7	Manual	8/5/2025 11:00:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	088	Rooms 6-10 Area Room 8	Manual	8/5/2025 11:00:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	089	Rooms 6-10 Area Room 9	Manual	8/5/2025 11:00:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	083	Rooms 6-10 Area South Exterior	Manual	8/5/2025 10:59:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	084	Rooms 6-10 Area West Exterior	Manual	8/5/2025 10:59:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Area Archives Front Desk	Manual	8/5/2025 11:26:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Admin Area Custodial Office Closet	Manual	8/5/2025 1:35:36 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	028	Admin Area Custodial Office Closet - P.E. "B"	Manual	8/5/2025 11:27:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	029	Admin Area Custodial Office Closet - P.E. "C"	Manual	8/5/2025 1:35:40 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	030	Admin Area Custodial Office Closet - P.E. "E"	Manual	8/5/2025 11:27:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	027	Admin Area Custodial Office Closet - P.E. "Master"	Manual	8/5/2025 1:35:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-026 006	Admin Area Archive Office Storage	Manual	8/5/2025 1:38:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-138 002	Admin Area Archives Front Desk	Manual	8/5/2025 1:37:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 003	Admin Area Archives Front Desk	Manual	8/5/2025 1:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 004	Admin Area Archives Office	Manual	8/5/2025 1:40:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 005	Admin Area Archives Office RR	Manual	8/5/2025 1:40:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-051 017	Admin Area Attic Arch Front Desk	Manual	8/5/2025 2:16:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 018	Admin Area Attic Office Hall Soffit	Manual	8/5/2025 2:16:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 015	Admin Area Custodial Office	Manual	8/5/2025 2:14:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 016	Admin Area Custodial Office Closet	Manual	8/5/2025 2:14:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 014	Admin Area Office Hallway Middle	Manual	8/5/2025 2:14:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 013	Admin Area Office Hallway North	Manual	8/5/2025 2:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 012	Admin Area Office Hallway South	Manual	8/5/2025 12:50:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 011	Admin Area Plan Dept Off. N RR	Manual	8/5/2025 2:33:22 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 010	Admin Area Planning Dept Office N.	Manual	8/5/2025 12:49:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 009	Admin Area Planning Dept Office S.	Manual	8/5/2025 12:49:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 008	Admin Area Planning Dept Recpt	Manual	8/5/2025 12:49:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-127 167	Multi-Purpose Bldg Bldg B Duct Det	Manual	8/5/2025 1:58:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 163	Multi-Purpose Bldg Boys RR MP Rm	Manual	8/5/2025 11:40:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 162	Multi-Purpose Bldg Girls RR MP Rm	Manual	8/5/2025 11:41:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-107 165	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 11:36:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-106 164	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 11:37:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 146	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 155	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 156	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 157	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 154	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 147	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 148	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 158	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:56 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-098 153	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:28:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 159	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:29:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 152	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:29:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 149	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:29:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 150	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:30:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 151	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:30:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 160	Multi-Purpose Bldg MP Room	Manual	8/5/2025 11:30:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-145 145	Multi-Purpose Bldg MP Room SE Exit	Manual	8/5/2025 11:24:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 161	Multi-Purpose Bldg MP Room Storage	Manual	8/5/2025 11:29:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 039	Room 1 Building Exterior Closet SW	Manual	8/5/2025 2:33:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 031	Room 1 Building Room 1	Manual	8/5/2025 12:53:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 032	Room 1 Building Room 1	Manual	8/5/2025 12:53:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 037	Room 1 Building Room 1 Closet East	Manual	8/5/2025 12:55:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 038	Room 1 Building Room 1 Closet West	Manual	8/5/2025 2:33:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 034	Room 1 Building Room 1 Hall	Manual	8/5/2025 12:55:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 033	Room 1 Building Room 1 Kitchen	Manual	8/5/2025 12:53:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-078 036	Room 1 Building Room 1 Office	Manual	8/5/2025 12:53:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 035	Room 1 Building Room 1 Restroom	Manual	8/5/2025 12:54:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 106	Rooms 11-14 Area Boys RR Rm 14	Manual	8/5/2025 12:32:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 107	Rooms 11-14 Area Custodial Closet by Rm 14	Manual	8/5/2025 12:33:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 094	Rooms 11-14 Area Room 11	Manual	8/5/2025 2:03:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 093	Rooms 11-14 Area Room 11	Manual	8/5/2025 2:03:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 095	Rooms 11-14 Area Room 11	Manual	8/5/2025 2:03:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 092	Rooms 11-14 Area Room 11	Manual	8/5/2025 2:03:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-126 109	Rooms 11-14 Area Room 11 Duct Det	Manual	8/5/2025 1:58:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 096	Rooms 11-14 Area Room 11 Storage	Manual	8/5/2025 2:33:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 097	Rooms 11-14 Area Room 12	Manual	8/5/2025 1:58:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 098	Rooms 11-14 Area Room 12	Manual	8/5/2025 1:58:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 099	Rooms 11-14 Area Room 13	Manual	8/5/2025 1:55:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 100	Rooms 11-14 Area Room 13	Manual	8/5/2025 1:55:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 104	Rooms 11-14 Area Room 14	Manual	8/5/2025 12:01:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 101	Rooms 11-14 Area Room 14	Manual	8/5/2025 12:02:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-018 102	Rooms 11-14 Area Room 14	Manual	8/5/2025 1:48:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 103	Rooms 11-14 Area Room 14	Manual	8/5/2025 1:48:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016	Rooms 11-14 Area Room 14	Manual	8/5/2025 1:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 125	Rooms 15-18 Area Attic Room 15	Manual	8/5/2025 11:57:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 126	Rooms 15-18 Area Attic Room 15	Manual	8/5/2025 11:57:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 128	Rooms 15-18 Area Attic Room 16	Manual	8/5/2025 12:04:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 127	Rooms 15-18 Area Attic Room 16	Manual	8/5/2025 12:04:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 129	Rooms 15-18 Area Attic Room 16	Manual	8/5/2025 12:04:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 130	Rooms 15-18 Area Attic Room 16A	Manual	8/5/2025 12:04:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 131	Rooms 15-18 Area Attic Room 16A	Manual	8/5/2025 12:04:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 132	Rooms 15-18 Area Attic Room 17	Manual	8/5/2025 11:50:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 133	Rooms 15-18 Area Attic Room 17	Manual	8/5/2025 11:50:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 135	Rooms 15-18 Area Attic Room 18	Manual	8/5/2025 11:52:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 134	Rooms 15-18 Area Attic Room 18	Manual	8/5/2025 11:52:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 116	Rooms 15-18 Area Room 15	Manual	8/5/2025 11:56:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 118	Rooms 15-18 Area Room 16 North	Manual	8/5/2025 12:02:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 117	Rooms 15-18 Area Room 16 South	Manual	8/5/2025 1:00:46 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 119	Rooms 15-18 Area Room 16 Storage	Manual	8/5/2025 12:06:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 120	Rooms 15-18 Area Room 16A	Manual	8/5/2025 12:11:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 121	Rooms 15-18 Area Room 17	Manual	8/5/2025 11:45:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 122	Rooms 15-18 Area Room 17	Manual	8/5/2025 11:45:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 123	Rooms 15-18 Area Room 18	Manual	8/5/2025 11:53:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 124	Rooms 15-18 Area Room 18	Manual	8/5/2025 11:53:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 053	Rooms 2-5 Bldg Attic Room 2	Manual	8/5/2025 1:26:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 052	Rooms 2-5 Bldg Attic Room 2	Manual	8/5/2025 1:26:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 054	Rooms 2-5 Bldg Attic Room 3	Manual	8/5/2025 2:40:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 055	Rooms 2-5 Bldg Attic Room 3	Manual	8/5/2025 2:40:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 057	Rooms 2-5 Bldg Attic Room 4	Manual	8/5/2025 2:27:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 056	Rooms 2-5 Bldg Attic Room 4	Manual	8/5/2025 2:27:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 059	Rooms 2-5 Bldg Attic Room 5	Manual	8/5/2025 1:33:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 058	Rooms 2-5 Bldg Attic Room 5	Manual	8/5/2025 1:33:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 044	Rooms 2-5 Bldg Room 2	Manual	8/5/2025 1:15:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 045	Rooms 2-5 Bldg Room 2	Manual	8/5/2025 1:15:46 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-082 047	Rooms 2-5 Bldg Room 3	Manual	8/5/2025 1:18:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 046	Rooms 2-5 Bldg Room 3	Manual	8/5/2025 1:18:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 048	Rooms 2-5 Bldg Room 4	Manual	8/5/2025 1:18:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 049	Rooms 2-5 Bldg Room 4	Manual	8/5/2025 1:18:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 050	Rooms 2-5 Bldg Room 5	Manual	8/5/2025 1:30:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 051	Rooms 2-5 Bldg Room 5	Manual	8/5/2025 1:31:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-047 081	Rooms 6-10 Area Boiler Rm Rm 10	Manual	8/5/2025 12:27:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 080	Rooms 6-10 Area Cust Closet by Rm 10	Manual	8/5/2025 12:30:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 079	Rooms 6-10 Area Girls RR by Rm 10	Manual	8/5/2025 12:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 078	Rooms 6-10 Area Room 10	Manual	8/5/2025 12:38:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 077	Rooms 6-10 Area Room 10	Manual	8/5/2025 12:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 067	Rooms 6-10 Area Room 6	Manual	8/5/2025 12:46:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 066	Rooms 6-10 Area Room 6	Manual	8/5/2025 2:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 068	Rooms 6-10 Area Room 6 Office	Manual	8/5/2025 12:47:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 069	Rooms 6-10 Area Room 6 Office	Manual	8/5/2025 12:48:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 071	Rooms 6-10 Area Room 7	Manual	8/5/2025 12:45:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-036 070	Rooms 6-10 Area Room 7	Manual	8/5/2025 12:45:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 072	Rooms 6-10 Area Room 7 Storage	Manual	8/5/2025 12:46:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 073	Rooms 6-10 Area Room 8	Manual	8/5/2025 12:42:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 074	Rooms 6-10 Area Room 8	Manual	8/5/2025 12:43:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 075	Rooms 6-10 Area Room 9	Manual	8/5/2025 12:40:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 076	Rooms 6-10 Area Room 9	Manual	8/5/2025 12:41:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-034 007	Admin Area Arch Off. Storage Closet	Manual	8/5/2025 2:15:51 PM
Heat Detector - Restorable Spot	2-108 166	Multi-Purpose Bldg Kitchen Storage	Manual	8/5/2025 1:00:51 PM
Smoke Detector - Duct	2-132 110	Rooms 11-14 Area Room 14 Duct Det	Manual	8/5/2025 1:58:17 PM
Heat Detector - Restorable Spot	2-048 108	Rooms 11-14 Area RR Plumbing Chase by Rm 14	Manual	8/5/2025 1:36:25 PM
Heat Detector - Restorable Spot	2-045 082	Rooms 6-10 Area RR Plumbing Chase by Rm 10	Manual	8/5/2025 1:36:22 PM

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
060	Rooms 2-5 Bldg North Exterior				
061	Rooms 2-5 Bldg North Exterior				
083	Rooms 6-10 Area South Exterior				
084	Rooms 6-10 Area West Exterior				
111	Rooms 11-14 Area West Ext/Boys RR				
136	Rooms 15-18 Area East Exterior				
137	Rooms 15-18 Area West Exterior				
138	Rooms 15-18 Area South Exterior				
168	Multi-Purpose Bldg South Exterior				
169	Multi-Purpose Bldg East Exterior				
019	Admin Area West Exterior				
040	Room 1 Building Northeast Exterior				
Audible And Visible					
062	Rooms 2-5 Bldg Room 2				
063	Rooms 2-5 Bldg Room 3				
064	Rooms 2-5 Bldg Room 4				
065	Rooms 2-5 Bldg Room 5				
085	Rooms 6-10 Area Room 6				
086	Rooms 6-10 Area Room 6 Office				
087	Rooms 6-10 Area Room 7				
088	Rooms 6-10 Area Room 8				
089	Rooms 6-10 Area Room 9				
090	Rooms 6-10 Area Room 10				
112	Rooms 11-14 Area Room 11				
113	Rooms 11-14 Area Room 12				
114	Rooms 11-14 Area Room 13				
115	Rooms 11-14 Area Room 14				
139	Rooms 15-18 Area Room 15				
140	Rooms 15-18 Area Room 16				
141	Rooms 15-18 Area Room 16A				
142	Rooms 15-18 Area Room 17				
143	Rooms 15-18 Area Room 18				
170	Multi-Purpose Bldg MP Room				
171	Multi-Purpose Bldg Mp Room				
172	Multi-Purpose Bldg Kitchen				
020	Admin Area Office Hallway North				
021	Admin Area Office Hallway South				
041	Room 1 Building Room 1				
042	Room 1 Building Room 1 Hall				
Visible					
091	Rooms 6-10 Area Girls RR Rm 10				
144	Rooms 15-18 Area Room 16 South				
173	Multi-Purpose Bldg Girls RR MP Rm				
174	Multi-Purpose Bldg Boys RR MP Rm				
022	Admin Area Archives Front Desk				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
023	Admin Area Archives Office				
024	Admin Area Archives Office RR				
025	Admin Area Plan Dept Off N RR				
026	Admin Area Custodial Office				
043	Room 1 Building Room 1 Restroom				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Area Archives Front Desk				
NAC Power Extender Panel					
027	Admin Area Custodial Office Closet - P.E. "Master"				
028	Admin Area Custodial Office Closet - P.E. "B"				
029	Admin Area Custodial Office Closet - P.E. "C"				
030	Admin Area Custodial Office Closet - P.E. "E"				

Fire Alarm Panel

	Admin Area Custodial Office Closet	EST	3		
--	------------------------------------	-----	---	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Heat Detector - Restorable Spot					
2-133 052	Rooms 2-5 Bldg Attic Room 2				
2-133 053	Rooms 2-5 Bldg Attic Room 2				
2-134 054	Rooms 2-5 Bldg Attic Room 3				
2-134 055	Rooms 2-5 Bldg Attic Room 3				
2-135 056	Rooms 2-5 Bldg Attic Room 4				
2-135 057	Rooms 2-5 Bldg Attic Room 4				
2-136 058	Rooms 2-5 Bldg Attic Room 5				
2-136 059	Rooms 2-5 Bldg Attic Room 5				
2-047 081	Rooms 6-10 Area Boiler Rm Rm 10				
2-045 082	Rooms 6-10 Area RR Plumbing Chase by Rm 10				
2-048 108	Rooms 11-14 Area RR Plumbing Chase by Rm 14				
2-128 125	Rooms 15-18 Area Attic Room 15				
2-128 126	Rooms 15-18 Area Attic Room 15				
2-129 127	Rooms 15-18 Area Attic Room 16				
2-129 128	Rooms 15-18 Area Attic Room 16				
2-129 129	Rooms 15-18 Area Attic Room 16				
2-129 130	Rooms 15-18 Area Attic Room 16A				
2-129 131	Rooms 15-18 Area Attic Room 16A				
2-131 132	Rooms 15-18 Area Attic Room 17				
2-131 133	Rooms 15-18 Area Attic Room 17				
2-130 134	Rooms 15-18 Area Attic Room 18				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-130 135	Rooms 15-18 Area Attic Room 18				
2-106 164	Multi-Purpose Bldg Kitchen				
2-107 165	Multi-Purpose Bldg Kitchen				
2-108 166	Multi-Purpose Bldg Kitchen Storage				
2-051 017	Admin Area Attic Arch Front Desk				
2-137 018	Admin Area Attic Office Hall Soffit				
Smoke Detector - General					
2-030 066	Rooms 6-10 Area Room 6				
2-031 067	Rooms 6-10 Area Room 6				
2-032 068	Rooms 6-10 Area Room 6 Office				
2-033 069	Rooms 6-10 Area Room 6 Office				
2-036 070	Rooms 6-10 Area Room 7				
2-037 071	Rooms 6-10 Area Room 7				
2-035 072	Rooms 6-10 Area Room 7 Storage				
2-038 073	Rooms 6-10 Area Room 8				
2-039 074	Rooms 6-10 Area Room 8				
2-040 075	Rooms 6-10 Area Room 9				
2-041 076	Rooms 6-10 Area Room 9				
2-042 077	Rooms 6-10 Area Room 10				
2-043 078	Rooms 6-10 Area Room 10				
2-044 079	Rooms 6-10 Area Girls RR by Rm 10				
2-046 080	Rooms 6-10 Area Cust Closet by Rm 10				
2-006 092	Rooms 11-14 Area Room 11				
2-008 093	Rooms 11-14 Area Room 11				
2-009 094	Rooms 11-14 Area Room 11				
2-007 095	Rooms 11-14 Area Room 11				
2-005 096	Rooms 11-14 Area Room 11 Storage				
2-011 097	Rooms 11-14 Area Room 12				
2-010 098	Rooms 11-14 Area Room 12				
2-013 099	Rooms 11-14 Area Room 13				
2-012 100	Rooms 11-14 Area Room 13				
2-015 101	Rooms 11-14 Area Room 14				
2-018 102	Rooms 11-14 Area Room 14				
2-019 103	Rooms 11-14 Area Room 14				
2-017 104	Rooms 11-14 Area Room 14				
2-049 106	Rooms 11-14 Area Boys RR Rm 14				
2-050 107	Rooms 11-14 Area Custodial Closet by Rm 14				
2-055 116	Rooms 15-18 Area Room 15				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-014 117	Rooms 15-18 Area Room 16 South				
2-057 118	Rooms 15-18 Area Room 16 North				
2-056 119	Rooms 15-18 Area Room 16 Storage				
2-058 120	Rooms 15-18 Area Room 16A				
2-063 121	Rooms 15-18 Area Room 17				
2-062 122	Rooms 15-18 Area Room 17				
2-061 123	Rooms 15-18 Area Room 18				
2-060 124	Rooms 15-18 Area Room 18				
2-093 146	Multi-Purpose Bldg MP Room				
2-096 147	Multi-Purpose Bldg MP Room				
2-099 148	Multi-Purpose Bldg MP Room				
2-102 149	Multi-Purpose Bldg MP Room				
2-105 150	Multi-Purpose Bldg MP Room				
2-104 151	Multi-Purpose Bldg MP Room				
2-101 152	Multi-Purpose Bldg MP Room				
2-098 153	Multi-Purpose Bldg MP Room				
2-095 154	Multi-Purpose Bldg MP Room				
2-092 155	Multi-Purpose Bldg MP Room				
2-091 156	Multi-Purpose Bldg MP Room				
2-094 157	Multi-Purpose Bldg MP Room				
2-097 158	Multi-Purpose Bldg MP Room				
2-100 159	Multi-Purpose Bldg MP Room				
2-103 160	Multi-Purpose Bldg MP Room				
2-090 161	Multi-Purpose Bldg MP Room Storage				
2-003 162	Multi-Purpose Bldg Girls RR MP Rm				
2-004 163	Multi-Purpose Bldg Boys RR MP Rm				
2-027 003	Admin Area Archives Front Desk				
2-029 004	Admin Area Archives Office				
2-028 005	Admin Area Archives Office RR				
2-026 006	Admin Area Archive Office Storage				
2-034 007	Admin Area Arch Off. Storage Closet				
2-025 008	Admin Area Planning Dept Recpt				
2-024 009	Admin Area Planning Dept Office S.				
2-023 010	Admin Area Planning Dept Office N.				
2-022 011	Admin Area Plan Dept Off. N RR				
2-021 012	Admin Area Office Hallway South				
2-020 013	Admin Area Office Hallway North				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-052 014	Admin Area Office Hallway Middle				
2-002 015	Admin Area Custodial Office				
2-001 016	Admin Area Custodial Office Closet				
2-071 031	Room 1 Building Room 1				
2-072 032	Room 1 Building Room 1				
2-070 033	Room 1 Building Room 1 Kitchen				
2-076 034	Room 1 Building Room 1 Hall				
2-077 035	Room 1 Building Room 1 Restroom				
2-078 036	Room 1 Building Room 1 Office				
2-075 037	Room 1 Building Room 1 Closet East				
2-074 038	Room 1 Building Room 1 Closet West				
2-073 039	Room 1 Building Exterior Closet SW				
2-080 044	Rooms 2-5 Bldg Room 2				
2-079 045	Rooms 2-5 Bldg Room 2				
2-081 046	Rooms 2-5 Bldg Room 3				
2-082 047	Rooms 2-5 Bldg Room 3				
2-084 048	Rooms 2-5 Bldg Room 4				
2-083 049	Rooms 2-5 Bldg Room 4				
2-086 050	Rooms 2-5 Bldg Room 5				
2-085 051	Rooms 2-5 Bldg Room 5				
2-016	Rooms 11-14 Area Room 14				
Smoke Detector - Duct					
2-126 109	Rooms 11-14 Area Room 11 Duct Det				
2-132 110	Rooms 11-14 Area Room 14 Duct Det				
2-127 167	Multi-Purpose Bldg Bldg B Duct Det				
Manual Pull Station					
2-145 145	Multi-Purpose Bldg MP Room SE Exit				
2-138 002	Admin Area Archives Front Desk				