

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

CASA ROBLES HIGH

9151 OAK AVE
ORANGEVALE, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, September 11, 2025

Test Session: 18 Aug 2025 15:38 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	CASA ROBLES HIGH	CONTACT
ADDRESS	9151 OAK AVE	PHONE
CITY/STATE	ORANGEVALE, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Alarm Notification Appliance	149	149(100%)	149(100%)	0(0%)
Fire Control Panel	10	10(100%)	10(100%)	0(0%)
Initiating Device	748	693(93%)	692(93%)	1(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, September 11, 2025

ACCEPTED BY 09/11/2025

Building Representative

TESTED BY 09/11/2025
Riley Goyet
Technician



System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Head End Building
MANUFACTURER	EST-3	S/W VERSION	
MODEL		LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	06/29/2020		

Open Corrective Action & Solution Summary

The following 14 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	348	Building C Classroom C11 Strg
	Created By:	Riley Goyet
	Creation Date:	08/20/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	2-273 377	Building F Classroom F5
	Created By:	Riley Goyet
	Creation Date:	09/11/2024
	Corrective Action:	Smoke detector is hanging from ceiling.
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	450	Building F Hallway Storage
	Created By:	Riley Goyet
	Creation Date:	08/20/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - Projected Beam	572	Small Gym North
	Created By:	Riley Goyet
	Creation Date:	06/17/2021
	Corrective Action:	Detector did not trip
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	05/12/2022
	Corrective Action:	Did not activate
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	588	Small Gym Northwest Storage
	Created By:	Riley Goyet
	Creation Date:	08/20/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	671	Locker Room Bldg Girls Office
	Created By:	Riley Goyet
	Creation Date:	08/20/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

NAC Power Extender Panel		Building D Classroom D8
	Created By:	Riley Goyet
	Creation Date:	08/20/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

NAC Power Extender Panel		Cafeteria E/F Copy Rm Strg
	Created By:	Riley Goyet
	Creation Date:	08/20/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Range Suppression		Suppression System
	Created By:	Casey Smith
	Creation Date:	07/29/2025
	Corrective Action:	Suppression system is non UL300 compliant.
	Proposed Solution:	Replace Automan, cylinders, cartridge, and fix gas valve.
	Manufacturer:	
	Model:	

[Other]		Gas Valve
	Created By:	Casey Smith
	Creation Date:	07/29/2025
	Corrective Action:	Corner pulley is broken to the gas valve
	Proposed Solution:	Replace corner pulley
	Manufacturer:	
	Model:	



Range Suppression Tank		3 Gallon Cylinder #1
	Created By:	Casey Smith
	Creation Date:	07/29/2025
	Corrective Action:	Cylinder is pre UL300 from 1982. UL300 standards started in 1994.
	Proposed Solution:	Replace with R102 UL300 3 gallon cylinder
	Manufacturer:	
	Model:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------



Range Suppression Tank	3 Gallon Cylinder #2	
------------------------	----------------------	--

Created By: Casey Smith
 Creation Date: 07/29/2025
 Corrective Action: Cylinder is pre UL300 and from 1982. UL300 standards started in 1994.
 Proposed Solution: Replace with R102 UL300 3 gallon cylinder
 Manufacturer:
 Model:



[Other]	Automan	
---------	---------	--

Created By: Casey Smith
 Creation Date: 07/29/2025
 Corrective Action: Automan is pre UL300
 Proposed Solution: Replace Automan with new UL300 compliant Automan
 Manufacturer:
 Model:



Resolved Corrective Action & Solution Summary

The following 1 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	8-022 608	Locker Room Bldg Girls Locker Strg E
	Created By:	Riley Goyet
	Creation Date:	09/10/2024
	Corrective Action:	Smoke head is taped.
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	09/11/2025
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	128	Building A Classroom A1	Manual	8/18/2025 5:37:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	137	Building A Classroom A10	Manual	8/18/2025 5:37:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	138	Building A Classroom A11	Manual	8/18/2025 5:37:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	139	Building A Classroom A12	Manual	8/18/2025 5:38:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	140	Building A Classroom A13	Manual	8/18/2025 5:38:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	129	Building A Classroom A2	Manual	8/18/2025 5:37:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	130	Building A Classroom A3	Manual	8/18/2025 5:37:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	Building A Classroom A4	Manual	8/18/2025 5:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	132	Building A Classroom A5	Manual	8/18/2025 5:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	Building A Classroom A6	Manual	8/18/2025 5:37:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	134	Building A Classroom A7	Manual	8/18/2025 5:37:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	135	Building A Classroom A8	Manual	8/18/2025 5:37:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	136	Building A Classroom A9	Manual	8/18/2025 5:37:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	123	Building A East Exterior	Manual	8/18/2025 5:35:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	124	Building A East Exterior	Manual	8/18/2025 5:35:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	141	Building A Hallway	Manual	8/18/2025 5:38:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	144	Building A Hallway	Manual	8/18/2025 5:38:09 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	121	Building A North Exterior	Manual	8/18/2025 5:35:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	122	Building A North Exterior	Manual	8/18/2025 5:35:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	142	Building A Room A5 Office 1	Manual	8/18/2025 5:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	143	Building A Room A5 Office 2	Manual	8/18/2025 5:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	125	Building A South Exterior	Manual	8/18/2025 5:35:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	126	Building A South Exterior	Manual	8/18/2025 5:35:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	127	Building A West Exterior	Manual	8/18/2025 5:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	145	Building A Womens Staff RR	Manual	8/18/2025 5:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	235	Building B B8 Mens Restroom	Manual	8/18/2025 5:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	222	Building B Classroom B1	Manual	8/18/2025 5:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	231	Building B Classroom B10	Manual	8/18/2025 5:38:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	232	Building B Classroom B11	Manual	8/18/2025 5:38:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	233	Building B Classroom B12	Manual	8/18/2025 5:38:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	223	Building B Classroom B2	Manual	8/18/2025 5:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	224	Building B Classroom B3	Manual	8/18/2025 5:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	225	Building B Classroom B4	Manual	8/18/2025 5:38:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	226	Building B Classroom B5	Manual	8/18/2025 5:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	227	Building B Classroom B6	Manual	8/18/2025 5:38:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	228	Building B Classroom B7	Manual	8/18/2025 5:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	229	Building B Classroom B8	Manual	8/18/2025 5:38:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	230	Building B Classroom B9	Manual	8/18/2025 5:38:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	215	Building B East Exterior	Manual	8/18/2025 5:38:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	216	Building B East Exterior	Manual	8/18/2025 5:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	234	Building B Hallway	Manual	8/18/2025 5:38:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	237	Building B Hallway	Manual	8/18/2025 5:38:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	213	Building B North Exterior	Manual	8/18/2025 5:38:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	214	Building B North Exterior	Manual	8/18/2025 5:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	236	Building B Room B9 Storage	Manual	8/18/2025 5:38:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	217	Building B South Exterior	Manual	8/18/2025 5:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	218	Building B South Exterior	Manual	8/18/2025 5:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	219	Building B South Exterior	Manual	8/18/2025 5:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	220	Building B West Exterior	Manual	8/18/2025 5:38:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	221	Building B West Exterior	Manual	8/18/2025 5:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	343	Building C Art Room	Manual	8/18/2025 5:39:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	344	Building C Art Room Office	Manual	8/18/2025 5:39:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	339	Building C Classrm C9 Dark Rm	Manual	8/18/2025 5:39:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	346	Building C Classrm C9 Dark Rm	Manual	8/18/2025 5:39:41 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	330	Building C Classroom C1	Manual	8/18/2025 5:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	340	Building C Classroom C10	Manual	8/18/2025 5:39:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	341	Building C Classroom C11	Manual	8/18/2025 5:39:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	331	Building C Classroom C2	Manual	8/18/2025 5:39:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	332	Building C Classroom C3	Manual	8/18/2025 5:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	333	Building C Classroom C4	Manual	8/18/2025 5:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	334	Building C Classroom C5	Manual	8/18/2025 5:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	335	Building C Classroom C6	Manual	8/18/2025 5:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	336	Building C Classroom C7	Manual	8/18/2025 5:39:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	345	Building C Classroom C7	Manual	8/18/2025 5:39:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	337	Building C Classroom C8	Manual	8/18/2025 5:39:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	338	Building C Classroom C9	Manual	8/18/2025 5:39:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	326	Building C East Exterior	Manual	8/18/2025 5:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	342	Building C Kiln Room	Manual	8/18/2025 5:39:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	324	Building C North Exterior	Manual	8/18/2025 5:38:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	325	Building C North Exterior	Manual	8/18/2025 5:38:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	327	Building C South Exterior	Manual	8/18/2025 5:39:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	328	Building C South Exterior	Manual	8/18/2025 5:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	347	Building C South Exterior	Manual	8/18/2025 5:39:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	329	Building C West Exterior	Manual	8/18/2025 5:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	435	Building F Classroom F1	Manual	8/18/2025 5:39:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	444	Building F Classroom F10	Manual	8/18/2025 5:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	445	Building F Classroom F11	Manual	8/18/2025 5:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	446	Building F Classroom F12	Manual	8/18/2025 5:40:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	447	Building F Classroom F13	Manual	8/18/2025 5:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	436	Building F Classroom F2	Manual	8/18/2025 5:39:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	437	Building F Classroom F3	Manual	8/18/2025 5:39:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	438	Building F Classroom F4	Manual	8/18/2025 5:40:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	439	Building F Classroom F5	Manual	8/18/2025 5:40:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	440	Building F Classroom F6	Manual	8/18/2025 5:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	441	Building F Classroom F7	Manual	8/18/2025 5:40:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	442	Building F Classroom F8	Manual	8/18/2025 5:40:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	443	Building F Classroom F9	Manual	8/18/2025 5:40:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	448	Building F Hallway	Manual	8/18/2025 5:40:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	449	Building F Hallway	Manual	8/18/2025 5:40:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	430	Building F North Exterior	Manual	8/18/2025 5:39:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	431	Building F North Exterior	Manual	8/18/2025 5:39:47 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	432	Building F South Exterior	Manual	8/18/2025 5:39:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	433	Building F South Exterior	Manual	8/18/2025 5:39:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	434	Building F West Exterior	Manual	8/18/2025 5:39:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	532	Large Gym Large Gym	Manual	8/18/2025 5:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	533	Large Gym Large Gym	Manual	8/18/2025 5:40:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	534	Large Gym Large Gym	Manual	8/18/2025 5:40:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	535	Large Gym Large Gym	Manual	8/18/2025 5:40:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	528	Large Gym North Exterior	Manual	8/18/2025 5:40:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	529	Large Gym North Exterior	Manual	8/18/2025 5:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	530	Large Gym South Exterior	Manual	8/18/2025 5:40:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	531	Large Gym West Exterior	Manual	8/18/2025 5:40:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	651	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:35:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	652	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	662	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	661	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	660	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	659	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	658	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	657	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:37 PM
		Visual inspection	Passed (Manual)	
Visible	656	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:39 PM
		Visual inspection	Passed (Manual)	
Visible	655	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:41 PM
		Visual inspection	Passed (Manual)	
Visible	654	Locker Room Bldg Boys Locker Room	Manual	8/18/2025 5:36:42 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	653	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:44 PM
		Visual inspection	Passed (Manual)	
Visible	670	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:06 PM
		Visual inspection	Passed (Manual)	
Visible	669	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:08 PM
		Visual inspection	Passed (Manual)	
Visible	668	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:09 PM
		Visual inspection	Passed (Manual)	
Visible	667	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:11 PM
		Visual inspection	Passed (Manual)	
Visible	666	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:13 PM
		Visual inspection	Passed (Manual)	
Visible	665	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:14 PM
		Visual inspection	Passed (Manual)	
Visible	664	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:17 PM
		Visual inspection	Passed (Manual)	
Visible	663	Locker Room Bldg Girls Locker Room	Manual	8/18/2025 5:36:19 PM
		Visual inspection	Passed (Manual)	
Audible	650	Locker Room Bldg North Exterior	Manual	8/18/2025 5:36:48 PM
		Visual inspection	Passed (Manual)	
Audible	649	Locker Room Bldg North Exterior	Manual	8/18/2025 5:36:50 PM
		Visual inspection	Passed (Manual)	
Audible	648	Locker Room Bldg North Exterior	Manual	8/18/2025 5:36:52 PM
		Visual inspection	Passed (Manual)	
Audible	647	Locker Room Bldg North Exterior	Manual	8/18/2025 5:36:53 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	709	Portables AG Portable	Manual	8/18/2025 5:35:45 PM
		Visual inspection	Passed (Manual)	
Audible	706	Portables AG West Exterior	Manual	8/18/2025 5:35:56 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	707	Portables Room P1	Manual	8/18/2025 5:35:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	708	Portables Room P2	Manual	8/18/2025 5:35:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	574	Small Gym North Exterior	Manual	8/18/2025 5:40:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	586	Small Gym Restrooms	Manual	8/18/2025 5:36:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	585	Small Gym Restrooms	Manual	8/18/2025 5:36:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	578	Small Gym Small Gym	Manual	8/18/2025 5:40:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	579	Small Gym Small Gym	Manual	8/18/2025 5:40:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	580	Small Gym Small Gym	Manual	8/18/2025 5:40:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	582	Small Gym Small Gym	Manual	8/18/2025 5:37:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	581	Small Gym Small Gym	Manual	8/18/2025 5:37:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	575	Small Gym South Exterior	Manual	8/18/2025 5:40:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	576	Small Gym South Exterior	Manual	8/18/2025 5:40:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	584	Small Gym Stage Area	Manual	8/18/2025 5:37:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	583	Small Gym Stage Area	Manual	8/18/2025 5:37:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	587	Small Gym West Exterior	Manual	8/18/2025 5:36:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	577	Small Gym West Exterior	Manual	8/18/2025 5:40:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	689	Weight Room	Manual	8/18/2025 5:35:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	690	Weight Room	Manual	8/18/2025 5:35:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	688	Weight Room Bldg	Manual	8/18/2025 5:36:01 PM
		Visual inspection	Passed (Manual)	
Audible	687	Weight Room Bldg North Exterior	Manual	8/18/2025 5:36:03 PM
		Visual inspection	Passed (Manual)	
Audible	686	Weight Room Bldg North Exterior	Manual	8/18/2025 5:36:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Building	Manual	8/19/2025 6:14:59 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	146	Building A Room A7 Storage	Manual	8/19/2025 6:14:23 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	238	Building B Room B7 Storage W	Manual	8/20/2025 5:15:21 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	348	Building C Classroom C11 Strg	Manual	8/20/2025 6:08:40 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Building D Classroom D8	Manual	8/20/2025 6:08:51 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	450	Building F Hallway Storage	Manual	8/20/2025 4:31:48 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Cafeteria E/F Copy Rm Strg	Manual	8/20/2025 6:08:15 PM
		Visual inspection	Passed (Manual)	
Fire Alarm Panel		Head End Building	Manual	8/19/2025 6:15:04 PM
		Manufacturer	EST-3	
NAC Power Extender Panel	671	Locker Room Bldg Girls Office	Manual	8/20/2025 6:07:48 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	588	Small Gym Northwest Storage	Manual	8/20/2025 6:07:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	7-133	Admin Office	Manual	8/19/2025 5:26:02 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-381	Attic classroom F11	Manual	8/20/2025 5:52:19 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-381	Attic classroom F4	Manual	8/20/2025 5:52:22 PM
		Visual inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381	Attic classroom F5	Manual	8/20/2025 5:52:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003	Bldg H MDF FACP rm	Manual	8/19/2025 5:01:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-376 093	Building A Attic Classrm A8 Strg	Manual	8/20/2025 5:35:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 101	Building A Attic Classroom A1	Manual	8/20/2025 5:35:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 105	Building A Attic Classroom A10	Manual	8/20/2025 5:35:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 106	Building A Attic Classroom A11A	Manual	8/20/2025 5:35:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 097	Building A Attic Classroom A12	Manual	8/20/2025 5:35:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 102	Building A Attic Classroom A2	Manual	8/20/2025 5:35:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 103	Building A Attic Classroom A3	Manual	8/20/2025 5:35:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 104	Building A Attic Classroom A4	Manual	8/20/2025 5:35:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 094	Building A Attic Classroom A5	Manual	8/20/2025 5:35:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 095	Building A Attic Classroom A6	Manual	8/20/2025 5:35:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-376 090	Building A Attic Classroom A7	Manual	8/20/2025 5:35:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-376 092	Building A Attic Classroom A8	Manual	8/20/2025 5:35:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 096	Building A Attic Classroom A9	Manual	8/20/2025 5:35:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 098	Building A Attic Hallway	Manual	8/20/2025 5:35:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-378 099	Building A Attic Hallway	Manual	8/20/2025 5:35:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 100	Building A Attic Hallway	Manual	8/20/2025 5:35:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 115	Building A Attic Overhang	Manual	8/20/2025 4:31:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 116	Building A Attic Overhang	Manual	8/20/2025 4:31:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 113	Building A Attic Overhang	Manual	8/20/2025 4:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 114	Building A Attic Overhang	Manual	8/20/2025 4:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 111	Building A Attic Overhang	Manual	8/20/2025 4:31:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 112	Building A Attic Overhang	Manual	8/20/2025 4:31:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 109	Building A Attic Overhang	Manual	8/20/2025 4:31:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 107	Building A Attic Overhang	Manual	8/20/2025 4:31:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 108	Building A Attic Overhang	Manual	8/20/2025 4:31:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 110	Building A Attic Overhang	Manual	8/20/2025 4:31:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-376 091	Building A Attic Room A7 RR	Manual	8/20/2025 5:35:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-269 082	Building A Bldg A Hallway	Manual	8/19/2025 4:35:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-268 087	Building A Bldg A Hallway	Manual	8/19/2025 4:35:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-267 059	Building A Bldg A Hallway	Manual	8/19/2025 4:35:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-276	Building A Classroom A1	Manual	8/19/2025 4:44:17 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-277 052	Building A Classroom A1	Manual	8/19/2025 4:44:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-279 084	Building A Classroom A10	Manual	8/19/2025 4:44:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-278 083	Building A Classroom A10	Manual	8/19/2025 4:44:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-280 085	Building A Classroom A11A	Manual	8/19/2025 4:40:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-281 086	Building A Classroom A11B	Manual	8/19/2025 4:40:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-264 089	Building A Classroom A12	Manual	8/19/2025 4:35:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-265 088	Building A Classroom A12	Manual	8/19/2025 4:35:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-274 054	Building A Classroom A2	Manual	8/19/2025 4:44:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-275 053	Building A Classroom A2	Manual	8/19/2025 4:44:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-272 056	Building A Classroom A3	Manual	8/19/2025 4:44:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-273 055	Building A Classroom A3	Manual	8/19/2025 4:44:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-270 058	Building A Classroom A4	Manual	8/19/2025 4:44:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-271 057	Building A Classroom A4	Manual	8/19/2025 4:44:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-262 061	Building A Classroom A5	Manual	8/19/2025 4:34:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-261 060	Building A Classroom A5	Manual	8/19/2025 4:34:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-259 065	Building A Classroom A6	Manual	8/19/2025 4:34:44 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	4-260 064	Building A Classroom A6	Manual	8/19/2025 4:34:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-258 066	Building A Classroom A7	Manual	8/19/2025 4:34:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-255 067	Building A Classroom A7	Manual	8/19/2025 4:34:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-257 069	Building A Classroom A7	Manual	8/19/2025 4:34:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-256 068	Building A Classroom A7	Manual	8/19/2025 4:34:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-289 075	Building A Classroom A8	Manual	8/19/2025 4:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-288 074	Building A Classroom A8	Manual	8/19/2025 4:40:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-290 073	Building A Classroom A8	Manual	8/19/2025 4:44:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-291 072	Building A Classroom A8	Manual	8/19/2025 4:44:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-381 117	Building A Classroom A8A	Manual	8/19/2025 3:42:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-384 119	Building A Classroom A8A	Manual	8/19/2025 3:42:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-382 118	Building A Classroom A8A	Manual	8/19/2025 3:42:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-383 120	Building A Classroom A9	Manual	8/19/2025 3:42:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-284 078	Building A Classroom A9	Manual	8/19/2025 4:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-285 081	Building A Classroom A9	Manual	8/19/2025 4:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-282 079	Building A Classroom A9	Manual	8/19/2025 4:40:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-283 080	Building A Classroom A9	Manual	8/19/2025 4:40:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-266 062	Building A Room A5 Office 1	Manual	8/19/2025 4:35:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-263 063	Building A Room A5 Office 2	Manual	8/19/2025 4:35:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-254 070	Building A Room A7 Restroom	Manual	8/19/2025 4:34:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-253 071	Building A Room A7 Storage	Manual	8/19/2025 4:34:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-287 076	Building A Room A8A Storage	Manual	8/19/2025 4:40:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-286 077	Building A Room A8A Storage	Manual	8/19/2025 4:40:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-129 200	Building B Attic Classrm B5 Strg	Manual	8/20/2025 5:15:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-128 193	Building B Attic Classroom B1	Manual	8/20/2025 5:14:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-128 197	Building B Attic Classroom B10	Manual	8/20/2025 5:15:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-128 198	Building B Attic Classroom B11	Manual	8/20/2025 5:15:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-129 203	Building B Attic Classroom B12	Manual	8/20/2025 5:15:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-128	Building B Attic Classroom B2	Manual	8/20/2025 5:14:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-128 194	Building B Attic Classroom B2	Manual	8/20/2025 5:15:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-128 195	Building B Attic Classroom B3	Manual	8/20/2025 5:15:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-128 196	Building B Attic Classroom B4	Manual	8/20/2025 5:15:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	5-129 199	Building B Attic Classroom B5	Manual	8/20/2025 5:15:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-134 204	Building B Attic Classroom B6	Manual	8/20/2025 5:15:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-134 206	Building B Attic Classroom B7	Manual	8/20/2025 5:15:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-134 205	Building B Attic Classroom B7	Manual	8/20/2025 5:15:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-129 201	Building B Attic Classroom B8	Manual	8/20/2025 5:15:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-129 202	Building B Attic Classroom B9	Manual	8/20/2025 5:15:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-126 182	Building B Attic Hallway	Manual	8/20/2025 5:14:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-126 181	Building B Attic Hallway	Manual	8/20/2025 5:14:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-126	Building B Attic Hallway	Manual	8/20/2025 5:14:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-126 180	Building B Attic Hallway	Manual	8/20/2025 5:14:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-127 186	Building B Attic Overhang	Manual	8/20/2025 4:28:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-127 185	Building B Attic Overhang	Manual	8/20/2025 4:28:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-127 184	Building B Attic Overhang	Manual	8/20/2025 4:28:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-127 183	Building B Attic Overhang	Manual	8/20/2025 4:28:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-127 192	Building B Attic Overhang	Manual	8/20/2025 4:28:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-127 191	Building B Attic Overhang	Manual	8/20/2025 4:28:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	5-127 190	Building B Attic Overhang	Manual	8/20/2025 4:28:50 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	5-127 189	Building B Attic Overhang	Manual	8/20/2025 4:28:52 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	5-127 188	Building B Attic Overhang	Manual	8/20/2025 4:28:53 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	5-127 187	Building B Attic Overhang	Manual	8/20/2025 4:28:55 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-040 171	Building B B8 Mens Restroom	Manual	8/19/2025 4:04:20 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-009 152	Building B Bldg B Hallway	Manual	8/19/2025 3:57:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-008 148	Building B Bldg B Hallway	Manual	8/19/2025 3:57:17 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-007 149	Building B Bldg B Hallway	Manual	8/19/2025 3:57:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-029 157	Building B Classrm B5 Storage	Manual	8/19/2025 3:55:22 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-012	Building B Classroom B1	Manual	8/19/2025 3:51:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-011 174	Building B Classroom B10	Manual	8/19/2025 3:51:15 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-010 175	Building B Classroom B10	Manual	8/19/2025 3:51:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Duct	5-137 211	Building B Classroom B11	Manual	8/19/2025 3:42:36 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Duct	5-135 210	Building B Classroom B11	Manual	8/19/2025 3:42:38 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-022 176	Building B Classroom B11	Manual	8/19/2025 3:55:32 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Duct	5-136 212	Building B Classroom B12	Manual	8/20/2025 4:50:12 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	5-024 178	Building B Classroom B12	Manual	8/19/2025 3:55:33 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-023 177	Building B Classroom B12	Manual	8/19/2025 3:55:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-021 179	Building B Classroom B13	Manual	8/19/2025 3:55:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-014	Building B Classroom B2	Manual	8/19/2025 3:51:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-015	Building B Classroom B2	Manual	8/19/2025 3:51:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-017 147	Building B Classroom B3	Manual	8/19/2025 3:51:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-016	Building B Classroom B3	Manual	8/19/2025 3:51:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-019 150	Building B Classroom B4	Manual	8/19/2025 3:51:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-020 151	Building B Classroom B4	Manual	8/19/2025 3:55:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-028 156	Building B Classroom B5	Manual	8/19/2025 3:55:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-027 153	Building B Classroom B5	Manual	8/19/2025 3:55:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-026 154	Building B Classroom B5	Manual	8/19/2025 3:55:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-025 155	Building B Classroom B5	Manual	8/19/2025 3:55:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-030	Building B Classroom B5 Storage	Manual	8/19/2025 4:04:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-034 160	Building B Classroom B6	Manual	8/19/2025 4:04:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-033 159	Building B Classroom B6	Manual	8/19/2025 4:04:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-032 162	Building B Classroom B6	Manual	8/19/2025 4:04:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-031 161	Building B Classroom B6	Manual	8/19/2025 4:04:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-037 163	Building B Classroom B7	Manual	8/19/2025 4:04:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-038 166	Building B Classroom B7	Manual	8/19/2025 4:04:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-036 165	Building B Classroom B7	Manual	8/19/2025 4:04:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-035 164	Building B Classroom B7	Manual	8/19/2025 4:04:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-035	Building B Classroom B7 Storage S	Manual	8/19/2025 4:04:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-005 169	Building B Classroom B8	Manual	8/19/2025 3:57:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-004 170	Building B Classroom B8	Manual	8/19/2025 3:57:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-018 172	Building B Classroom B9	Manual	8/19/2025 3:51:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	5-132 209	Building B Room B5 Storage	Manual	8/19/2025 3:42:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	5-130 207	Building B Room B5 Storage	Manual	8/19/2025 3:42:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	5-131 208	Building B Room B5 Storage	Manual	8/19/2025 3:42:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-039 167	Building B Room B7 Storage S	Manual	8/19/2025 4:04:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-003 168	Building B Room B7 Storage W	Manual	8/19/2025 3:57:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-006 173	Building B Room B9 Storage	Manual	8/19/2025 3:57:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-298 290	Building C Art Room	Manual	8/18/2025 5:12:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	5-297 291	Building C Art Room Office	Manual	8/18/2025 5:11:52 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 296	Building C Attic Classroom C1	Manual	8/20/2025 5:29:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 295	Building C Attic Classroom C1	Manual	8/20/2025 5:30:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 301	Building C Attic Classroom C10	Manual	8/20/2025 5:29:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 300	Building C Attic Classroom C10	Manual	8/20/2025 5:30:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 302	Building C Attic Classroom C11	Manual	8/20/2025 5:29:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 303	Building C Attic Classroom C11	Manual	8/20/2025 5:30:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 297	Building C Attic Classroom C2	Manual	8/20/2025 5:29:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 298	Building C Attic Classroom C3	Manual	8/20/2025 5:29:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 299	Building C Attic Classroom C4	Manual	8/20/2025 5:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-377 304	Building C Attic Classroom C5	Manual	8/20/2025 5:30:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-377 305	Building C Attic Classroom C6	Manual	8/20/2025 5:30:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-377 306	Building C Attic Classroom C7	Manual	8/20/2025 5:30:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-377 307	Building C Attic Classroom C8	Manual	8/20/2025 5:30:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-377 309	Building C Attic Classroom C9	Manual	8/20/2025 5:30:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-377 308	Building C Attic Classroom C9	Manual	8/20/2025 5:30:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 321	Building C Attic Overhang	Manual	8/20/2025 4:29:39 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 320	Building C Attic Overhang	Manual	8/20/2025 4:29:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 319	Building C Attic Overhang	Manual	8/20/2025 4:29:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 318	Building C Attic Overhang	Manual	8/20/2025 4:29:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 317	Building C Attic Overhang	Manual	8/20/2025 4:29:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 310	Building C Attic Overhang	Manual	8/20/2025 4:29:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 316	Building C Attic Overhang	Manual	8/20/2025 4:29:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 315	Building C Attic Overhang	Manual	8/20/2025 4:29:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 314	Building C Attic Overhang	Manual	8/20/2025 4:29:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 313	Building C Attic Overhang	Manual	8/20/2025 4:29:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 312	Building C Attic Overhang	Manual	8/20/2025 4:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-380 311	Building C Attic Overhang	Manual	8/20/2025 4:29:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-274 264	Building C Classrm C5 Strg E	Manual	8/18/2025 5:19:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-273 263	Building C Classrm C5 Strg E	Manual	8/18/2025 5:19:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-272 265	Building C Classrm C5 Strg W	Manual	8/18/2025 5:19:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-305 240	Building C Classroom C1	Manual	8/18/2025 5:27:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-304 239	Building C Classroom C1	Manual	8/18/2025 5:27:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-307 242	Building C Classroom C1	Manual	8/18/2025 5:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-306 241	Building C Classroom C1	Manual	8/18/2025 5:27:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-303 243	Building C Classroom C1 Strg	Manual	8/18/2025 5:27:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-292 284	Building C Classroom C10	Manual	8/18/2025 5:11:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-293 285	Building C Classroom C10	Manual	8/18/2025 5:11:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-296 287	Building C Classroom C10	Manual	8/18/2025 5:11:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-295 286	Building C Classroom C10	Manual	8/18/2025 5:11:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-294 288	Building C Classroom C10 Strg	Manual	8/18/2025 5:12:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-299 294	Building C Classroom C11	Manual	8/18/2025 5:12:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-302 293	Building C Classroom C11	Manual	8/18/2025 5:27:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-301 292	Building C Classroom C11	Manual	8/18/2025 5:27:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-300 289	Building C Classroom C11 Strg	Manual	8/18/2025 5:27:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-258 247	Building C Classroom C2	Manual	8/18/2025 5:04:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-255 244	Building C Classroom C2	Manual	8/18/2025 5:04:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-256 245	Building C Classroom C2	Manual	8/18/2025 5:04:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-257 246	Building C Classroom C2	Manual	8/18/2025 5:04:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-254 248	Building C Classroom C2 Strg	Manual	8/18/2025 5:04:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-259 249	Building C Classroom C3	Manual	8/18/2025 5:04:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-261 251	Building C Classroom C3	Manual	8/18/2025 5:07:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-262 252	Building C Classroom C3	Manual	8/18/2025 5:08:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-260 250	Building C Classroom C3	Manual	8/18/2025 5:08:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-253 253	Building C Classroom C3 Strg	Manual	8/18/2025 5:04:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-265 256	Building C Classroom C4	Manual	8/18/2025 5:07:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-266 257	Building C Classroom C4	Manual	8/18/2025 5:07:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-263 254	Building C Classroom C4	Manual	8/18/2025 5:07:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-264 255	Building C Classroom C4	Manual	8/18/2025 5:07:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-267 258	Building C Classroom C4 Strg	Manual	8/18/2025 5:07:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-269 260	Building C Classroom C5	Manual	8/18/2025 5:07:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-268 259	Building C Classroom C5	Manual	8/18/2025 5:08:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-270 261	Building C Classroom C5	Manual	8/18/2025 5:12:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-271 262	Building C Classroom C5	Manual	8/18/2025 5:19:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-277 267	Building C Classroom C6	Manual	8/18/2025 5:19:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-275 269	Building C Classroom C6	Manual	8/18/2025 5:19:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-276 266	Building C Classroom C6	Manual	8/18/2025 5:19:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-278 268	Building C Classroom C6	Manual	8/18/2025 5:19:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-280 271	Building C Classroom C7	Manual	8/18/2025 5:19:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-279 270	Building C Classroom C7	Manual	8/18/2025 5:19:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-283 274	Building C Classroom C8	Manual	8/18/2025 5:19:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-282 273	Building C Classroom C8	Manual	8/18/2025 5:19:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-281 272	Building C Classroom C8	Manual	8/18/2025 5:19:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-284 275	Building C Classroom C8	Manual	8/18/2025 5:19:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-291 283	Building C Classroom C9	Manual	8/18/2025 5:11:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-290 281	Building C Classroom C9	Manual	8/18/2025 5:12:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-288 279	Building C Classroom C9	Manual	8/18/2025 5:19:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-286 277	Building C Classroom C9	Manual	8/18/2025 5:19:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-285 276	Building C Classroom C9	Manual	8/18/2025 5:19:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-287 278	Building C Classroom C9	Manual	8/18/2025 5:19:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-289 280	Building C Classroom C9	Manual	8/18/2025 5:19:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-308 282	Building C Classroom C9	Manual	8/18/2025 5:27:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	5-378 322	Building C Room C11 Kiln Room	Manual	8/20/2025 6:09:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-039 351	Building D Classroom D3	Manual	8/19/2025 5:13:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-028 355	Building D Classroom D5	Manual	8/19/2025 5:12:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-029 354	Building D Classroom D5	Manual	8/19/2025 5:27:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-033 357	Building D Classroom D5	Manual	8/19/2025 5:27:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-032 356	Building D Classroom D5	Manual	8/19/2025 5:27:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019	Building D Classroom D6	Manual	8/18/2025 4:59:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-027	Building D Classroom D6	Manual	8/19/2025 5:26:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-026 359	Building D Classroom D6	Manual	8/19/2025 5:26:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-020	Building D Classroom D6	Manual	8/19/2025 5:26:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-025	Building D Classroom D6 Low Strg SE	Manual	8/19/2025 5:13:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-018	Building D Classroom D6 Storage S	Manual	8/18/2025 4:59:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022	Building D Classroom D6 Storage SW	Manual	8/19/2025 5:26:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-023	Building D Classroom D6 Storage W	Manual	8/19/2025 5:13:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021	Building D Classroom D6 Storage W	Manual	8/19/2025 5:26:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-024	Building D Classroom D6 Upp Strg SE	Manual	8/19/2025 5:13:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-014	Building D Classroom D7	Manual	8/18/2025 4:59:24 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-013	Building D Classroom D7	Manual	8/18/2025 4:59:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-015	Building D Classroom D7	Manual	8/18/2025 4:59:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005	Building D Classroom D7 Storage	Manual	8/19/2025 5:13:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012	Building D Classroom D8	Manual	8/18/2025 4:59:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010	Building D Classroom D8	Manual	8/18/2025 4:59:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011	Building D Classroom D8	Manual	8/18/2025 4:59:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009	Building D Classroom D8	Manual	8/19/2025 5:26:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006	Building D Classroom D8 Storage	Manual	8/19/2025 5:12:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008	Building D Classroom D8 Storage	Manual	8/19/2025 5:12:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007	Building D Classroom D8 Storage	Manual	8/19/2025 5:13:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-034	Building D Girls RR	Manual	8/18/2025 4:59:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-036	Building D Men's RR	Manual	8/19/2025 5:13:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-035	Building D Men's RR	Manual	8/19/2025 5:13:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-046	Building D Room D1	Manual	9/11/2025 9:29:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-047	Building D Room D1	Manual	9/11/2025 9:30:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-050	Building D Room D1 Office	Manual	9/11/2025 9:30:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-045	Building D Room D1 Paint Rm	Manual	9/11/2025 9:30:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	4-132	Building D Room D1 Storage	Manual	8/20/2025 6:27:55 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-042	Building D Room D1 Storage E	Manual	9/11/2025 9:30:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-049	Building D Room D1 Storage W	Manual	9/11/2025 9:30:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-048	Building D Room D1 Wood Strg	Manual	9/11/2025 9:30:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-051	Building D Room D2	Manual	9/11/2025 9:30:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-052	Building D Room D2	Manual	9/11/2025 9:30:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-040 349	Building D Room D2 Storage N	Manual	8/19/2025 5:13:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-041 350	Building D Room D2 Storage S	Manual	8/19/2025 5:13:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-037	Building D Room D4	Manual	9/11/2025 9:30:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-038	Building D Room D4	Manual	9/11/2025 9:30:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-016 352	Building D Room D4 Storage C	Manual	8/18/2025 4:59:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 353	Building D Room D4 Storage E	Manual	8/18/2025 4:59:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-031 358	Building D Room D5 Storage S	Manual	8/19/2025 5:13:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-060	Building D Room D7	Manual	8/18/2025 4:59:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:29:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:29:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:29:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:30:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:30:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:30:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:30:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:30:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:30:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Building E Attic Overhang	Manual	8/20/2025 4:30:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377	Building E Attic Rm E1	Manual	8/20/2025 4:49:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377	Building E Attic Rm E1	Manual	8/20/2025 4:49:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376	Building E Attic Rm E10	Manual	8/20/2025 4:49:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378	Building E Attic Rm E11	Manual	8/20/2025 4:32:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376	Building E Attic Rm E2	Manual	8/20/2025 4:49:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376	Building E Attic Rm E3	Manual	8/20/2025 4:49:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376	Building E Attic Rm E4	Manual	8/20/2025 4:49:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378	Building E Attic Rm E5	Manual	8/20/2025 4:32:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378	Building E Attic Rm E6	Manual	8/20/2025 4:32:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-378	Building E Attic Rm E7	Manual	8/20/2025 4:32:54 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-378	Building E Attic Rm E8A	Manual	8/20/2025 4:32:51 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378	Building E Attic Rm E8B	Manual	8/20/2025 4:32:53 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-377	Building E Attic Rm E9	Manual	8/20/2025 4:49:34 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377	Building E Attic Rm E9 Strg	Manual	8/20/2025 4:49:32 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-275	Building E Hallway	Manual	8/18/2025 4:38:50 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-276	Building E Hallway	Manual	8/18/2025 4:39:02 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-277	Building E Hallway	Manual	8/18/2025 4:39:04 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-256	Building E Rm E1	Manual	8/18/2025 4:53:27 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-257	Building E Rm E1	Manual	8/18/2025 4:53:29 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-258	Building E Rm E1	Manual	8/18/2025 4:53:30 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-259	Building E Rm E1	Manual	8/18/2025 4:53:32 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-253	Building E Rm E1 Custodial	Manual	8/18/2025 4:36:42 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-268	Building E Rm E10	Manual	8/18/2025 4:43:16 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-269	Building E Rm E10	Manual	8/18/2025 4:43:18 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-281	Building E Rm E11	Manual	8/18/2025 4:42:51 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-280	Building E Rm E11	Manual	8/18/2025 4:42:53 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-263	Building E Rm E2	Manual	8/18/2025 4:43:04 PM
		Functional Inspection	Passed	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3-261	Building E Rm E2	Manual	8/18/2025 4:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262	Building E Rm E2	Manual	8/18/2025 4:43:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260	Building E Rm E2	Manual	8/18/2025 4:43:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-264	Building E Rm E3	Manual	8/18/2025 4:43:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-265	Building E Rm E3	Manual	8/18/2025 4:43:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266	Building E Rm E3	Manual	8/18/2025 4:43:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267	Building E Rm E3	Manual	8/18/2025 4:43:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278	Building E Rm E5	Manual	8/18/2025 4:38:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279	Building E Rm E5	Manual	8/18/2025 4:39:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-288	Building E Rm E6	Manual	8/18/2025 4:42:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289	Building E Rm E6	Manual	8/18/2025 4:42:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-286	Building E Rm E7	Manual	8/18/2025 4:42:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287	Building E Rm E7	Manual	8/18/2025 4:42:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285	Building E Rm E8A	Manual	8/18/2025 4:42:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284	Building E Rm E8A	Manual	8/18/2025 4:42:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283	Building E Rm E8B	Manual	8/18/2025 4:42:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-282	Building E Rm E8B	Manual	8/18/2025 4:42:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270	Building E Rm E9	Manual	8/18/2025 4:38:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-274	Building E Rm E9	Manual	8/18/2025 4:38:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-271	Building E Rm E9	Manual	8/18/2025 4:38:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-273	Building E Rm E9	Manual	8/18/2025 4:38:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-272	Building E Rm E9	Manual	8/18/2025 4:38:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-290	Building E Rm E9 Strg	Manual	8/19/2025 5:26:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-254	Building E Staff Men's RR	Manual	8/18/2025 4:25:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-255	Building E Staff Men's RR	Manual	8/18/2025 4:25:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 413	Building F Attic Classroom 10	Manual	8/20/2025 4:32:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 414	Building F Attic Classroom 13	Manual	8/20/2025 4:32:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 409	Building F Attic Classroom 6	Manual	8/20/2025 4:31:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 410	Building F Attic Classroom 7	Manual	8/20/2025 4:31:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 411	Building F Attic Classroom 8	Manual	8/20/2025 4:31:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 412	Building F Attic Classroom 9	Manual	8/20/2025 4:31:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 399	Building F Attic Classroom F1	Manual	8/20/2025 4:31:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-381 404	Building F Attic Classroom F11	Manual	8/20/2025 4:32:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-381 405	Building F Attic Classroom F12	Manual	8/20/2025 4:32:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 400	Building F Attic Classroom F2	Manual	8/20/2025 4:31:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-380 401	Building F Attic Classroom F3	Manual	8/20/2025 4:31:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 402	Building F Attic Classroom F4	Manual	8/20/2025 4:32:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 403	Building F Attic Classroom F5	Manual	8/20/2025 4:32:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 406	Building F Attic Hallway	Manual	8/20/2025 4:32:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 407	Building F Attic Hallway	Manual	8/20/2025 4:32:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 408	Building F Attic Hallway	Manual	8/20/2025 4:32:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 424	Building F Attic Overhang	Manual	8/20/2025 4:30:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 423	Building F Attic Overhang	Manual	8/20/2025 4:30:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 422	Building F Attic Overhang	Manual	8/20/2025 4:30:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 421	Building F Attic Overhang	Manual	8/20/2025 4:30:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 420	Building F Attic Overhang	Manual	8/20/2025 4:30:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 419	Building F Attic Overhang	Manual	8/20/2025 4:30:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 418	Building F Attic Overhang	Manual	8/20/2025 4:30:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 417	Building F Attic Overhang	Manual	8/20/2025 4:30:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 416	Building F Attic Overhang	Manual	8/20/2025 4:30:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 415	Building F Attic Overhang	Manual	8/20/2025 4:30:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-277 381	Building F Bldg F Hallway	Manual	8/18/2025 4:00:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 390	Building F Bldg F Hallway	Manual	8/18/2025 4:00:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 374	Building F Bldg F Hallway	Manual	8/18/2025 4:01:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 364	Building F Classrm F1A Storage	Manual	8/18/2025 4:09:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 365	Building F Classrm F1A Storage	Manual	8/18/2025 4:09:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-385 425	Building F Classroom F1	Manual	8/19/2025 3:42:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 361	Building F Classroom F1	Manual	8/18/2025 4:01:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 362	Building F Classroom F1	Manual	8/18/2025 4:02:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 363	Building F Classroom F1	Manual	8/18/2025 4:02:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 360	Building F Classroom F1	Manual	8/18/2025 4:02:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 389	Building F Classroom F10	Manual	8/18/2025 3:44:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 388	Building F Classroom F10	Manual	8/18/2025 3:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 391	Building F Classroom F11	Manual	8/18/2025 3:44:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 392	Building F Classroom F11	Manual	8/18/2025 3:44:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 393	Building F Classroom F11	Manual	8/18/2025 3:45:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 395	Building F Classroom F12	Manual	8/18/2025 3:45:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276	Building F Classroom F12	Manual	8/18/2025 3:46:04 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-286 397	Building F Classroom F13	Manual	8/18/2025 3:48:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-287 396	Building F Classroom F13	Manual	8/18/2025 3:48:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2-376 429	Building F Classroom F1A	Manual	8/19/2025 3:42:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2-379 428	Building F Classroom F1A	Manual	8/19/2025 3:42:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2-378 427	Building F Classroom F1A	Manual	8/19/2025 3:42:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2-377 426	Building F Classroom F1A	Manual	8/19/2025 3:42:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-263 366	Building F Classroom F2	Manual	8/18/2025 4:01:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-264 367	Building F Classroom F2	Manual	8/18/2025 4:01:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-265 369	Building F Classroom F3	Manual	8/18/2025 4:01:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-266 368	Building F Classroom F3	Manual	8/18/2025 4:01:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-270 373	Building F Classroom F4	Manual	8/18/2025 4:01:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-269 372	Building F Classroom F4	Manual	8/18/2025 4:01:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-272 375	Building F Classroom F5	Manual	8/18/2025 4:00:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-273 377	Building F Classroom F5	Manual	8/18/2025 4:00:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-274 378	Building F Classroom F5	Manual	8/18/2025 4:00:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-271 376	Building F Classroom F5	Manual	8/18/2025 4:00:52 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-289 379	Building F Classroom F6	Manual	8/18/2025 3:49:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-288 380	Building F Classroom F6	Manual	8/18/2025 3:49:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-291 383	Building F Classroom F7	Manual	8/18/2025 4:01:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-290 382	Building F Classroom F7	Manual	8/18/2025 4:01:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-284 384	Building F Classroom F8	Manual	8/18/2025 4:01:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-285 385	Building F Classroom F8	Manual	8/18/2025 4:01:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-283 386	Building F Classroom F9	Manual	8/18/2025 4:01:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-282 387	Building F Classroom F9	Manual	8/18/2025 4:01:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-253 398	Building F Hallway Storage	Manual	8/18/2025 3:42:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-268 371	Building F Rm F3 Girls Restrm	Manual	8/18/2025 4:01:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-267 370	Building F Rm F3 Girls Restrm	Manual	8/18/2025 4:01:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2M134	Building G	Manual	8/20/2025 6:09:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Supervisory - Control Valve	2M135	Building G	Manual	8/20/2025 5:36:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-011	Building G Collab G38	Manual	8/19/2025 5:02:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-056	Building G Conference G06	Manual	8/19/2025 4:54:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-070	Building G Conference G27	Manual	8/19/2025 5:02:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-068	Building G Controller G30	Manual	8/19/2025 4:53:16 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-058	Building G Counselor G10	Manual	8/19/2025 4:54:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059	Building G Counselor G11	Manual	8/19/2025 4:54:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060	Building G Counselor G12	Manual	8/19/2025 4:53:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057	Building G Counselor G9	Manual	8/19/2025 4:54:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028	Building G Custodial G36	Manual	8/19/2025 5:02:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053	Building G Fire Curtain	Manual	8/19/2025 4:54:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014	Building G Group Study G39	Manual	8/19/2025 5:02:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024	Building G Group Study G43	Manual	8/19/2025 5:02:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046	Building G Hall G01.1	Manual	8/19/2025 5:01:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034	Building G Hall G01.2	Manual	8/19/2025 5:01:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041	Building G Hall G01.2	Manual	8/19/2025 5:01:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047	Building G Hall G05.1	Manual	8/19/2025 5:02:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061	Building G Hall G05.3	Manual	8/19/2025 4:53:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039	Building G Hall G221	Manual	8/19/2025 5:02:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032	Building G Hall G34	Manual	8/19/2025 5:02:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031	Building G Hall G34	Manual	8/19/2025 5:02:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030	Building G Hall G34	Manual	8/19/2025 5:02:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033	Building G Hall G34	Manual	8/19/2025 5:02:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-040	Building G Hotel Conf G24	Manual	8/19/2025 5:02:15 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-005	Building G IDF Room G41	Manual	8/19/2025 5:02:39 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-022	Building G Library G42	Manual	8/19/2025 5:02:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-048	Building G Mailroom G20	Manual	8/19/2025 5:01:48 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-029	Building G Men's Restroom G37	Manual	8/19/2025 5:02:18 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-062	Building G Nurse Office G17	Manual	8/19/2025 4:53:20 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-038	Building G Office G31	Manual	8/19/2025 5:02:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-037	Building G Office G32	Manual	8/19/2025 5:02:10 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-036	Building G Office G33	Manual	8/19/2025 5:02:11 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-015	Building G Office G40	Manual	8/19/2025 5:02:36 PM
		Visual inspection	Passed (Manual)	
Supervisory - Control Valve	2M136	Building G OSY	Manual	8/20/2025 5:36:17 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-069	Building G Principle G28	Manual	8/19/2025 4:53:27 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-043	Building G Professional Development G21	Manual	8/19/2025 5:02:04 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-042	Building G Professional Development G21	Manual	8/19/2025 5:02:05 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-055	Building G Registrar G07	Manual	8/19/2025 4:54:46 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-064	Building G Restroom G15	Manual	8/19/2025 4:53:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-051	Building G Restroom G19	Manual	8/19/2025 4:54:38 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-052	Building G Restroom G20	Manual	8/19/2025 4:54:40 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-025	Building G Retail G44	Manual	8/19/2025 5:01:50 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-067	Building G Secretary G29	Manual	8/19/2025 4:53:29 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-049	Building G Staff Lounge G25	Manual	8/19/2025 5:02:07 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-050	Building G Storage G18	Manual	8/19/2025 4:54:44 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-065	Building G Trans Storage G14	Manual	8/19/2025 4:53:18 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-054	Building G Waiting Room G05	Manual	8/19/2025 4:54:48 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-035	Building G Waiting Room G22	Manual	8/19/2025 5:02:14 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-044	Building G Welcome Center G01	Manual	8/19/2025 5:01:56 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-045	Building G Welcome Center G01	Manual	8/19/2025 5:01:58 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-027	Building G Woman's Restroom G35	Manual	8/19/2025 5:02:20 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-129	Cafeteria A/B Attic Cafeteria	Manual	8/20/2025 5:28:10 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-129	Cafeteria A/B Attic Cafeteria	Manual	8/20/2025 5:28:12 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-129	Cafeteria A/B Attic Cafeteria	Manual	8/20/2025 5:28:13 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-129	Cafeteria A/B Attic Cafeteria	Manual	8/20/2025 5:28:14 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-129	Cafeteria A/B Attic Cafeteria	Manual	8/20/2025 5:28:16 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-129	Cafeteria A/B Attic Cafeteria	Manual	8/20/2025 5:28:18 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-129	Cafeteria A/B Attic Cafeteria	Manual	8/20/2025 5:28:19 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	8-393	Cafeteria A/B Attic Cafeteria N/E	Manual	8/19/2025 5:25:46 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	8-394	Cafeteria A/B Attic Cafeteria N/W	Manual	8/19/2025 5:25:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	8-396	Cafeteria A/B Attic Cafeteria S/E	Manual	8/19/2025 5:25:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-126	Cafeteria A/B Attic Conference	Manual	8/20/2025 5:28:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-126	Cafeteria A/B Attic Conference	Manual	8/20/2025 5:28:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-126	Cafeteria A/B Attic Conference	Manual	8/20/2025 5:28:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-127	Cafeteria A/B Attic Kitchen	Manual	8/20/2025 5:28:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-127	Cafeteria A/B Attic Kitchen	Manual	8/20/2025 5:28:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-127	Cafeteria A/B Attic Kitchen	Manual	8/20/2025 5:28:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-127	Cafeteria A/B Attic Kitchen	Manual	8/20/2025 5:28:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:30:58 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-130	Functional Inspection	Passed	
		Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:31:00 PM
Heat Detector - Restorable Spot	7-130	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-130	Cafeteria A/B Attic Overhang	Manual	8/20/2025 4:31:01 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-019	Functional Inspection	Passed	
		Cafeteria A/B Boys RR	Manual	8/18/2025 6:09:45 PM
Smoke Detector - General	7-019	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-031	Cafeteria A/B Cafeteria	Manual	8/18/2025 6:09:31 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-031	Functional Inspection	Passed	
		Cafeteria A/B Cafeteria	Manual	8/18/2025 6:09:32 PM
Smoke Detector - General	7-030	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-026	Cafeteria A/B Cafeteria	Manual	8/18/2025 6:11:54 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-026	Functional Inspection	Passed	
		Cafeteria A/B Cafeteria	Manual	8/18/2025 6:11:55 PM
Smoke Detector - General	7-029	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-028	Cafeteria A/B Cafeteria	Manual	8/18/2025 6:11:57 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-028	Functional Inspection	Passed	
		Cafeteria A/B Cafeteria	Manual	8/18/2025 6:11:58 PM
Smoke Detector - General	7-027	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	8-395	Cafeteria A/B Cafeteria S/W	Manual	8/19/2025 5:25:51 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-020	Functional Inspection	Passed	
		Cafeteria A/B Cafeteria Strg	Manual	8/18/2025 6:11:50 PM
Smoke Detector - General	7-020	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-006	Cafeteria A/B Conference Rm	Manual	8/18/2025 6:21:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-006	Functional Inspection	Passed	
		Cafeteria A/B Conference Rm	Manual	8/18/2025 6:21:05 PM
Smoke Detector - General	7-005	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-008	Cafeteria A/B Conference Rm	Manual	8/18/2025 6:21:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-008	Functional Inspection	Passed	
		Cafeteria A/B Conference Rm	Manual	8/18/2025 6:21:12 PM
Smoke Detector - General	7-007	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-025	Cafeteria A/B Girls RR	Manual	8/18/2025 6:11:49 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-017	Functional Inspection	Passed	
		Cafeteria A/B Kitchen	Manual	8/18/2025 6:09:54 PM
Heat Detector - Restorable Spot	7-017	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	7-024	Cafeteria A/B Kitchen	Manual	8/18/2025 6:12:01 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	7-021	Cafeteria A/B Kitchen	Manual	8/18/2025 6:12:02 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	7-023	Cafeteria A/B Kitchen	Manual	8/18/2025 6:12:04 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-005	Cafeteria A/B Kitchen N Strg	Manual	8/18/2025 6:21:10 PM
		Functional Inspection	Passed	
Smoke Detector - General	7-032	Cafeteria A/B Kitchen Office	Manual	8/18/2025 6:09:29 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-022	Cafeteria A/B Kitchen RR	Manual	8/18/2025 6:11:52 PM
		Functional Inspection	Passed	
Smoke Detector - General	7-018	Cafeteria A/B Kitchen S Strg	Manual	8/18/2025 6:09:50 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-014	Cafeteria A/B O/S Food Strg	Manual	8/18/2025 6:09:51 PM
		Functional Inspection	Passed	
Smoke Detector - General	7-011	Cafeteria A/B O/S S Strg	Manual	8/18/2025 6:09:44 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-012	Cafeteria A/B O/S S Strg	Manual	8/18/2025 6:09:53 PM
		Functional Inspection	Passed	
Smoke Detector - General	7-003	Cafeteria A/B Staff Closet	Manual	8/18/2025 6:21:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-009	Cafeteria A/B Staff Hall	Manual	8/18/2025 6:21:18 PM
		Functional Inspection	Passed	
Smoke Detector - General	7-013	Cafeteria A/B Staff Hall RR	Manual	8/18/2025 6:09:47 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-010	Cafeteria A/B Staff Hall RR	Manual	8/18/2025 6:09:48 PM
		Functional Inspection	Passed	
Smoke Detector - General	7-015	Cafeteria A/B Staff Rm	Manual	8/18/2025 6:09:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	7-016	Cafeteria A/B Staff Rm	Manual	8/18/2025 6:09:42 PM
		Functional Inspection	Passed	
Smoke Detector - General	3-006	Cafeteria E/F Attendance	Manual	8/18/2025 4:10:02 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-011	Cafeteria E/F Attendance	Manual	8/18/2025 4:10:12 PM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-007	Cafeteria E/F Attendance RR	Manual	8/18/2025 4:10:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-126	Cafeteria E/F Attic Attendance	Manual	8/20/2025 5:28:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-126	Cafeteria E/F Attic Boys RR	Manual	8/20/2025 5:28:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Cafeteria E/F Attic Cafeteria	Manual	8/20/2025 5:28:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Cafeteria E/F Attic Cafeteria	Manual	8/20/2025 5:28:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Cafeteria E/F Attic Cafeteria	Manual	8/20/2025 5:28:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Cafeteria E/F Attic Cafeteria	Manual	8/20/2025 5:28:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Cafeteria E/F Attic Cafeteria	Manual	8/20/2025 5:28:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Cafeteria E/F Attic Cafeteria	Manual	8/20/2025 5:28:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Cafeteria E/F Attic Cafeteria	Manual	8/20/2025 5:28:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-126	Cafeteria E/F Attic Kitchen Strg	Manual	8/20/2025 5:28:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128	Cafeteria E/F Attic Overhang	Manual	8/20/2025 4:30:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-126	Cafeteria E/F Attic ROP Rm	Manual	8/20/2025 5:28:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021	Cafeteria E/F Boys RR	Manual	8/18/2025 4:17:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022	Cafeteria E/F Boys RR Hall	Manual	8/18/2025 4:17:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-023	Cafeteria E/F Cafeteria	Manual	8/18/2025 4:17:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028	Cafeteria E/F Cafeteria	Manual	8/18/2025 4:17:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-027	Cafeteria E/F Cafeteria	Manual	8/18/2025 4:17:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026	Cafeteria E/F Cafeteria	Manual	8/18/2025 4:17:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-025	Cafeteria E/F Cafeteria	Manual	8/18/2025 4:17:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024	Cafeteria E/F Cafeteria	Manual	8/18/2025 4:17:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005	Cafeteria E/F Copy Rm	Manual	8/18/2025 4:09:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004	Cafeteria E/F Copy Rm Strg	Manual	8/18/2025 4:10:35 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3-014	Cafeteria E/F Custodial Office	Manual	8/18/2025 4:25:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-017	Cafeteria E/F Girls RR Hall	Manual	8/18/2025 4:25:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016	Cafeteria E/F Grils RR	Manual	8/18/2025 4:25:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-019	Cafeteria E/F Kitchen	Manual	8/18/2025 4:25:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-020	Cafeteria E/F Kitchen Hall	Manual	8/18/2025 4:10:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018	Cafeteria E/F Kitchen Strg	Manual	8/18/2025 4:25:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	8-392	Cafeteria E/F N	Manual	8/19/2025 5:25:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	8-391	Cafeteria E/F N/E	Manual	8/19/2025 5:25:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013	Cafeteria E/F Office	Manual	8/18/2025 4:13:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010	Cafeteria E/F Resource	Manual	8/18/2025 4:10:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009	Cafeteria E/F Resource Hall	Manual	8/18/2025 4:10:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-008	Cafeteria E/F Resource RR	Manual	8/18/2025 4:10:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012	Cafeteria E/F ROP Rm	Manual	8/18/2025 4:25:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	8-389	Cafeteria E/F S	Manual	8/19/2025 5:25:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	8-390	Cafeteria E/F S/E	Manual	8/19/2025 5:25:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003	Cafeteria E/F Staff Rm	Manual	8/18/2025 4:10:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015	Cafeteria E/F Staff Rm Strg	Manual	8/18/2025 4:13:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Classroom B Rm B1	Manual	8/19/2025 5:12:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-004	E/F Copy rm storage	Manual	8/18/2025 4:10:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	7-399	Large Gym Center	Manual	8/20/2025 6:06:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	7-393 524	Large Gym Center	Manual	8/20/2025 6:06:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	7-387 526	Large Gym North	Manual	8/20/2025 6:06:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	8-401 509	Large Gym Northwest	Manual	8/19/2025 5:26:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	7-385 527	Large Gym South	Manual	8/20/2025 6:06:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	8-403 511	Large Gym Southeast	Manual	8/19/2025 5:26:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	8-402 510	Large Gym Southwest	Manual	8/19/2025 5:26:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	8-404 512	Large Gym Southwest	Manual	8/19/2025 5:26:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	7-271	Large Gym Ticket Booth	Manual	8/19/2025 4:06:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	7-398 525	Large Gym West	Manual	8/20/2025 6:06:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	8-127 635	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	8-127 634	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	8-127 633	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	8-127 632	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	8-127 631	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	8-127 630	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:23 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-127 629	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-127 628	Locker Room Bldg Attic Boys Locker	Manual	8/20/2025 5:29:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 643	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:15:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 640	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:15:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 642	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:16:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 641	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:16:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 639	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:16:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 638	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:16:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 637	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:16:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-126 636	Locker Room Bldg Attic Girls Locker	Manual	8/19/2025 6:16:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-041 619	Locker Room Bldg Boys Locker	Manual	8/19/2025 4:23:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-033 616	Locker Room Bldg Boys Locker	Manual	8/20/2025 5:29:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-034 617	Locker Room Bldg Boys Locker	Manual	8/20/2025 5:29:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-032 615	Locker Room Bldg Boys Locker	Manual	8/20/2025 5:29:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-035 618	Locker Room Bldg Boys Locker	Manual	8/20/2025 5:29:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-026 590	Locker Room Bldg Boys Locker	Manual	8/19/2025 4:24:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	8-129 645	Locker Room Bldg Boys Locker East	Manual	8/20/2025 5:29:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-039 596	Locker Room Bldg Boys Locker East	Manual	8/19/2025 4:22:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-040 597	Locker Room Bldg Boys Locker East	Manual	8/19/2025 4:23:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-036 613	Locker Room Bldg Boys Locker Entry	Manual	8/20/2025 5:29:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-031 593	Locker Room Bldg Boys Locker Office	Manual	8/19/2025 4:22:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-024 614	Locker Room Bldg Boys Locker Restrmm	Manual	8/19/2025 4:24:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-042 600	Locker Room Bldg Boys Locker Strg NE	Manual	8/19/2025 4:23:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-038 599	Locker Room Bldg Boys Locker Strg SE	Manual	8/19/2025 4:22:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-037 598	Locker Room Bldg Boys Locker Strg SE	Manual	8/19/2025 4:22:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-027 591	Locker Room Bldg Boys Locker Strg SW	Manual	8/19/2025 4:24:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-023 592	Locker Room Bldg Boys Locker Strg W	Manual	8/19/2025 4:24:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-030 595	Locker Room Bldg Boys Locker Train Off	Manual	8/19/2025 4:22:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	8-128 644	Locker Room Bldg Boys Locker West	Manual	8/20/2025 5:29:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-028 620	Locker Room Bldg Boys Staff Lock RR	Manual	8/19/2025 4:24:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-029 594	Locker Room Bldg Boys Staff Lock RR	Manual	8/19/2025 4:24:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-025 589	Locker Room Bldg Custodial Storage	Manual	8/19/2025 4:24:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	8-008 603	Locker Room Bldg Girls Locker Entry	Manual	8/19/2025 4:30:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-019 624	Locker Room Bldg Girls Locker Room	Manual	8/19/2025 6:16:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-018 623	Locker Room Bldg Girls Locker Room	Manual	8/19/2025 6:16:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-017 622	Locker Room Bldg Girls Locker Room	Manual	8/19/2025 6:16:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-016 621	Locker Room Bldg Girls Locker Room	Manual	8/19/2025 6:16:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	8-130 646	Locker Room Bldg Girls Locker Room	Manual	8/19/2025 6:15:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-020 604	Locker Room Bldg Girls Locker Room	Manual	8/19/2025 4:24:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-021 625	Locker Room Bldg Girls Locker RR E	Manual	8/19/2025 4:24:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-010 626	Locker Room Bldg Girls Locker RR W	Manual	8/19/2025 6:16:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	8-006 627	Locker Room Bldg Girls Locker Staff RR	Manual	8/19/2025 6:15:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-022 608	Locker Room Bldg Girls Locker Strg E	Manual	9/11/2025 9:29:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-011 607	Locker Room Bldg Girls Locker Strg N	Manual	8/19/2025 4:31:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-007 609	Locker Room Bldg Girls Locker Strg S	Manual	8/19/2025 4:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-004 602	Locker Room Bldg Girls Office	Manual	8/19/2025 4:30:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-003 601	Locker Room Bldg Girls Office	Manual	8/19/2025 4:31:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-009 606	Locker Room Bldg Girls Restrmt Storage	Manual	8/19/2025 4:30:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	8-005 605	Locker Room Bldg Girls Staff Locker RR	Manual	8/19/2025 4:31:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-013 611	Locker Room Bldg Pool Storage	Manual	8/19/2025 4:30:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-014 612	Locker Room Bldg Pool Storage	Manual	8/19/2025 4:30:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	8-012 610	Locker Room Bldg Pool Storage	Manual	8/19/2025 4:31:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-056 695	Portables AG Portable	Manual	8/19/2025 5:29:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-057 696	Portables AG Portable	Manual	8/19/2025 5:29:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-131 705	Portables Attic AG Portable	Manual	8/20/2025 6:27:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-131 704	Portables Attic AG Portable	Manual	8/20/2025 6:27:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-131 703	Portables Attic AG Portable	Manual	8/20/2025 6:27:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-133	Reception G01	Manual	8/19/2025 5:26:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066	Secured Strg G13	Manual	8/19/2025 4:53:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-258 549	Small Gym Above Stage	Manual	8/19/2025 4:10:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-262 548	Small Gym Above Stage	Manual	8/19/2025 4:16:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-253 550	Small Gym Above Stage West	Manual	8/19/2025 4:13:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-255 551	Small Gym Above Stage West	Manual	8/19/2025 4:13:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-268 553	Small Gym Boys Restroom	Manual	8/19/2025 4:08:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	568	Small Gym East	Manual	8/20/2025 6:09:25 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	7-266 540	Small Gym Entry	Manual	8/19/2025 4:08:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	554	Small Gym Food Stand	Manual	8/19/2025 4:17:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	555	Small Gym Food Stand Storage	Manual	8/19/2025 4:17:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-267 552	Small Gym Girls Restroom	Manual	8/19/2025 4:08:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	539	Small Gym North	Manual	8/19/2025 5:26:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	536	Small Gym Northeast	Manual	8/19/2025 5:25:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	556	Small Gym Northwest Storage	Manual	8/19/2025 4:17:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	557	Small Gym ROTC Logistics Shed	Manual	8/20/2025 5:52:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	571	Small Gym South	Manual	9/11/2025 9:29:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	537	Small Gym Southeast	Manual	8/19/2025 5:25:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-257 543	Small Gym Stage	Manual	8/19/2025 4:09:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-260 542	Small Gym Stage	Manual	8/19/2025 4:14:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-261 545	Small Gym Stage	Manual	8/19/2025 4:16:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	541	Small Gym Stage	Manual	8/19/2025 4:17:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	544	Small Gym Stage	Manual	8/19/2025 4:17:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	7-264 547	Small Gym Stage Office	Manual	8/19/2025 4:11:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	546	Small Gym Stage Office	Manual	8/19/2025 4:17:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Mechanical, Electrosonic, or Pressure Waterflow Device	573	Small Gym Storage	Manual	8/20/2025 6:06:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	569	Small Gym Storage	Manual	8/19/2025 3:43:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	538	Small Gym West	Manual	8/19/2025 5:25:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	570	Small Gym West	Manual	8/20/2025 6:07:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	6-383 683	Weight Room Bldg HVAC FAU 1	Manual	8/20/2025 6:33:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	6-384 684	Weight Room Bldg HVAC FAU 2	Manual	8/20/2025 6:33:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	6-385 685	Weight Room Bldg HVAC FAU 3	Manual	8/20/2025 6:33:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-263 682	Weight Room Bldg IDF Closet	Manual	8/19/2025 5:29:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-264 681	Weight Room Bldg Storage	Manual	8/19/2025 5:29:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-267 674	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-265 672	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-266 673	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-269 676	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-268 675	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-270 677	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-271 678	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	6-273 680	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:50 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	6-272 679	Weight Room Bldg Weight Room	Manual	8/19/2025 5:29:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Skipped				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:28:57 PM
	Comment:	Not accessible		
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:10 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:13 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:15 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:18 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:20 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:23 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:25 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:28 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:30 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:33 PM
Heat Detector - Restorable Spot	4-130	Building D Attic Overhang	Manual	8/20/2025 4:29:36 PM
Heat Detector - Restorable Spot	4-129	Building D Attic Rm D1	Manual	8/20/2025 5:50:42 PM
Heat Detector - Restorable Spot	4-128	Building D Attic Rm D1 Strg	Manual	8/20/2025 5:50:45 PM
Heat Detector - Restorable Spot	4-129	Building D Attic Rm D2	Manual	8/20/2025 5:50:47 PM
Heat Detector - Restorable Spot	4-129	Building D Attic Rm D2	Manual	8/20/2025 5:50:50 PM
Heat Detector - Restorable Spot	4-128	Building D Attic Rm D2	Manual	8/20/2025 5:50:52 PM
Heat Detector - Restorable Spot	4-128	Building D Attic Rm D2	Manual	8/20/2025 5:50:55 PM
Heat Detector - Restorable Spot	4-127	Building D Attic Rm D4	Manual	8/20/2025 5:50:57 PM
Heat Detector - Restorable Spot	4-127	Building D Attic Rm D4 Strg	Manual	8/20/2025 5:50:35 PM
Heat Detector - Restorable Spot	4-126	Building D Attic Rm D5	Manual	8/20/2025 5:51:03 PM
Heat Detector - Restorable Spot	4-126	Building D Attic Rm D6	Manual	8/20/2025 5:51:01 PM
Heat Detector - Restorable Spot	4-126	Building D Attic Rm D6	Manual	8/20/2025 5:51:06 PM
Heat Detector - Restorable Spot	4-127	Building D Attic Rm D7	Manual	8/20/2025 5:50:38 PM
Smoke Detector - Duct	4-136	Building D Roof	Manual	8/19/2025 6:11:23 PM
Smoke Detector - Duct	4-135	Building D Roof	Manual	8/19/2025 6:11:29 PM
Smoke Detector - Duct	4-134	Building D Roof	Manual	8/19/2025 6:11:32 PM
Smoke Detector - Duct	3-381	Building E Roof	Manual	8/19/2025 6:11:17 PM
Smoke Detector - Duct	3-380	Building E Roof	Manual	8/19/2025 6:11:19 PM
Smoke Detector - Duct	3-382	Building E Roof	Manual	8/19/2025 6:11:52 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	7-131	Cafeteria A/B Roof	Manual	8/19/2025 6:11:12 PM
Smoke Detector - Duct	2-129	Cafeteria E/F - Roof	Manual	8/19/2025 6:10:59 PM
Smoke Detector - Duct	2-130	Cafeteria E/F - Roof	Manual	8/19/2025 6:11:01 PM
Heat Detector - Restorable Spot	7-388 514	Large Gym Attic Heat	Manual	8/20/2025 5:48:17 PM
Heat Detector - Restorable Spot	7-388 515	Large Gym Attic Heat	Manual	8/20/2025 5:48:20 PM
Heat Detector - Restorable Spot	7-388 516	Large Gym Attic Heat	Manual	8/20/2025 5:48:46 PM
Heat Detector - Restorable Spot	7-388 517	Large Gym Attic Heat	Manual	8/20/2025 5:48:49 PM
Heat Detector - Restorable Spot	7-388 518	Large Gym Attic Heat	Manual	8/20/2025 5:48:52 PM
Heat Detector - Restorable Spot	7-388 519	Large Gym Attic Heat	Manual	8/20/2025 5:49:04 PM
Heat Detector - Restorable Spot	7-388 520	Large Gym Attic Heat	Manual	8/20/2025 5:49:06 PM
Heat Detector - Restorable Spot	7-388 521	Large Gym Attic Heat	Manual	8/20/2025 5:49:09 PM
Heat Detector - Restorable Spot	7-388 522	Large Gym Attic Heat	Manual	8/20/2025 5:49:11 PM
Heat Detector - Restorable Spot	7-388	Large Gym Attic Heat	Manual	8/20/2025 5:49:42 PM
Heat Detector - Restorable Spot	7-388	Large Gym Attic Heat	Manual	8/20/2025 5:49:45 PM
Smoke Detector - Duct	7-400 523	Large Gym East	Manual	8/19/2025 6:11:04 PM
Heat Detector - Restorable Spot	558	Small Gym Attic Small Gym N	Manual	8/20/2025 5:49:14 PM
Heat Detector - Restorable Spot	559	Small Gym Attic Small Gym N	Manual	8/20/2025 5:49:16 PM
Heat Detector - Restorable Spot	560	Small Gym Attic Small Gym N	Manual	8/20/2025 5:49:19 PM
Heat Detector - Restorable Spot	561	Small Gym Attic Small Gym N	Manual	8/20/2025 5:49:22 PM
Heat Detector - Restorable Spot	562	Small Gym Attic Small Gym S	Manual	8/20/2025 5:49:25 PM
Heat Detector - Restorable Spot	563	Small Gym Attic Small Gym S	Manual	8/20/2025 5:49:28 PM
Heat Detector - Restorable Spot	564	Small Gym Attic Small Gym S	Manual	8/20/2025 5:49:31 PM
Heat Detector - Restorable Spot	565	Small Gym Attic Small Gym S	Manual	8/20/2025 5:49:34 PM
Heat Detector - Restorable Spot	566	Small Gym Attic Small Gym S	Manual	8/20/2025 5:49:36 PM
Heat Detector - Restorable Spot	567	Small Gym Attic Small Gym S	Manual	8/20/2025 5:49:39 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Projected Beam	572	Small Gym North	Manual	9/11/2025 9:29:56 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
[Other]	Gas Valve		Manual	8/19/2025 3:32:01 PM
[Other]	Automan		Manual	8/19/2025 3:32:03 PM
Range Suppression	Suppression System		Manual	8/19/2025 3:31:59 PM
Range Suppression Tank	3 Gallon Cylinder #2		Manual	8/19/2025 3:32:08 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Range Suppression Tank	3 Gallon Cylinder #1		Manual	8/19/2025 3:32:11 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
121	Building A North Exterior				
122	Building A North Exterior				
123	Building A East Exterior				
124	Building A East Exterior				
125	Building A South Exterior				
126	Building A South Exterior				
127	Building A West Exterior				
213	Building B North Exterior				
214	Building B North Exterior				
215	Building B East Exterior				
216	Building B East Exterior				
217	Building B South Exterior				
218	Building B South Exterior				
219	Building B South Exterior				
220	Building B West Exterior				
221	Building B West Exterior				
324	Building C North Exterior				
325	Building C North Exterior				
326	Building C East Exterior				
327	Building C South Exterior				
328	Building C South Exterior				
329	Building C West Exterior				
347	Building C South Exterior				
430	Building F North Exterior				
431	Building F North Exterior				
432	Building F South Exterior				
433	Building F South Exterior				
434	Building F West Exterior				
528	Large Gym North Exterior				
529	Large Gym North Exterior				
530	Large Gym South Exterior				
531	Large Gym West Exterior				
574	Small Gym North Exterior				
575	Small Gym South Exterior				
576	Small Gym South Exterior				
577	Small Gym West Exterior				
587	Small Gym West Exterior				
647	Locker Room Bldg North Exterior				
648	Locker Room Bldg North Exterior				
649	Locker Room Bldg North Exterior				
650	Locker Room Bldg North Exterior				
686	Weight Room Bldg North Exterior				
687	Weight Room Bldg North Exterior				
706	Portables AG West Exterior				
Audible And Visible					
128	Building A Classroom A1				
129	Building A Classroom A2				
130	Building A Classroom A3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
131	Building A Classroom A4				
132	Building A Classroom A5				
133	Building A Classroom A6				
134	Building A Classroom A7				
135	Building A Classroom A8				
136	Building A Classroom A9				
137	Building A Classroom A10				
138	Building A Classroom A11				
139	Building A Classroom A12				
140	Building A Classroom A13				
141	Building A Hallway				
222	Building B Classroom B1				
223	Building B Classroom B2				
224	Building B Classroom B3				
225	Building B Classroom B4				
226	Building B Classroom B5				
227	Building B Classroom B6				
228	Building B Classroom B7				
229	Building B Classroom B8				
230	Building B Classroom B9				
231	Building B Classroom B10				
232	Building B Classroom B11				
233	Building B Classroom B12				
234	Building B Hallway				
330	Building C Classroom C1				
331	Building C Classroom C2				
332	Building C Classroom C3				
333	Building C Classroom C4				
334	Building C Classroom C5				
335	Building C Classroom C6				
336	Building C Classroom C7				
337	Building C Classroom C8				
338	Building C Classroom C9				
339	Building C Classrm C9 Dark Rm				
340	Building C Classroom C10				
341	Building C Classroom C11				
435	Building F Classroom F1				
436	Building F Classroom F2				
437	Building F Classroom F3				
438	Building F Classroom F4				
439	Building F Classroom F5				
440	Building F Classroom F6				
441	Building F Classroom F7				
442	Building F Classroom F8				
443	Building F Classroom F9				
444	Building F Classroom F10				
445	Building F Classroom F11				
446	Building F Classroom F12				
447	Building F Classroom F13				
448	Building F Hallway				
532	Large Gym Large Gym				
533	Large Gym Large Gym				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
578	Small Gym Small Gym				
579	Small Gym Small Gym				
580	Small Gym Small Gym				
651	Locker Room Bldg Boys Locker Room				
652	Locker Room Bldg Boys Locker Room				
653	Locker Room Bldg Girls Locker Room				
688	Weight Room Bldg				
689	Weight Room				
707	Portables Room P1				
708	Portables Room P2				
709	Portables AG Portable				
Visible					
142	Building A Room A5 Office 1				
143	Building A Room A5 Office 2				
144	Building A Hallway				
145	Building A Womens Staff RR				
235	Building B B8 Mens Restroom				
236	Building B Room B9 Storage				
237	Building B Hallway				
342	Building C Kiln Room				
343	Building C Art Room				
344	Building C Art Room Office				
345	Building C Classroom C7				
346	Building C Classrm C9 Dark Rm				
449	Building F Hallway				
534	Large Gym Large Gym				
535	Large Gym Large Gym				
581	Small Gym Small Gym				
582	Small Gym Small Gym				
583	Small Gym Stage Area				
584	Small Gym Stage Area				
585	Small Gym Restrooms				
586	Small Gym Restrooms				
654	Locker Room Bldg Boys Locker Room				
655	Locker Room Bldg Boys Locker Room				
656	Locker Room Bldg Boys Locker Room				
657	Locker Room Bldg Boys Locker Room				
658	Locker Room Bldg Boys Locker Room				
659	Locker Room Bldg Boys Locker Room				
660	Locker Room Bldg Boys Locker Room				
661	Locker Room Bldg Boys Locker Room				
662	Locker Room Bldg Boys Locker Room				
663	Locker Room Bldg Girls Locker Room				
664	Locker Room Bldg Girls Locker Room				
665	Locker Room Bldg Girls Locker Room				
666	Locker Room Bldg Girls Locker Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
667	Locker Room Bldg Girls Locker Room				
668	Locker Room Bldg Girls Locker Room				
669	Locker Room Bldg Girls Locker Room				
670	Locker Room Bldg Girls Locker Room				
690	Weight Room				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
146	Building A Room A7 Storage				
238	Building B Room B7 Storage W				
348	Building C Classroom C11 Strg				
450	Building F Hallway Storage				
588	Small Gym Northwest Storage				
671	Locker Room Bldg Girls Office				
	Building D Classroom D8				
	Cafeteria E/F Copy Rm Strg				06/05/2019

Remote Annunciator

001	Admin Building				
-----	----------------	--	--	--	--

Fire Alarm Panel

	Head End Building	EST-3			06/30/2020
--	-------------------	-------	--	--	------------

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
4-277 052	Building A Classroom A1				
4-275 053	Building A Classroom A2				
4-274 054	Building A Classroom A2				
4-273 055	Building A Classroom A3				
4-272 056	Building A Classroom A3				
4-271 057	Building A Classroom A4				
4-270 058	Building A Classroom A4				
4-267 059	Building A Bldg A Hallway				
4-261 060	Building A Classroom A5				
4-262 061	Building A Classroom A5				
4-266 062	Building A Room A5 Office 1				
4-263 063	Building A Room A5 Office 2				
4-260 064	Building A Classroom A6				
4-259 065	Building A Classroom A6				
4-258 066	Building A Classroom A7				
4-255 067	Building A Classroom A7				
4-256 068	Building A Classroom A7				
4-257 069	Building A Classroom A7				
4-254 070	Building A Room A7 Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-253 071	Building A Room A7 Storage				
4-291 072	Building A Classroom A8				
4-290 073	Building A Classroom A8				
4-288 074	Building A Classroom A8				
4-289 075	Building A Classroom A8				
4-287 076	Building A Room A8A Storage				
4-286 077	Building A Room A8A Storage				
4-284 078	Building A Classroom A9				
4-282 079	Building A Classroom A9				
4-283 080	Building A Classroom A9				
4-285 081	Building A Classroom A9				
4-269 082	Building A Bldg A Hallway				
4-278 083	Building A Classroom A10				
4-279 084	Building A Classroom A10				
4-280 085	Building A Classroom A11A				
4-281 086	Building A Classroom A11B				
4-268 087	Building A Bldg A Hallway				
4-265 088	Building A Classroom A12				
4-264 089	Building A Classroom A12				
5-017 147	Building B Classroom B3				
5-008 148	Building B Bldg B Hallway				
5-007 149	Building B Bldg B Hallway				
5-019 150	Building B Classroom B4				
5-020 151	Building B Classroom B4				
5-009 152	Building B Bldg B Hallway				
5-027 153	Building B Classroom B5				
5-026 154	Building B Classroom B5				
5-025 155	Building B Classroom B5				
5-028 156	Building B Classroom B5				
5-029 157	Building B Classrm B5 Storage				
5-033 159	Building B Classroom B6				
5-034 160	Building B Classroom B6				
5-031 161	Building B Classroom B6				
5-032 162	Building B Classroom B6				
5-037 163	Building B Classroom B7				
5-035 164	Building B Classroom B7				
5-036 165	Building B Classroom B7				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-038 166	Building B Classroom B7				
5-039 167	Building B Room B7 Storage S				
5-003 168	Building B Room B7 Storage W				
5-005 169	Building B Classroom B8				
5-004 170	Building B Classroom B8				
5-040 171	Building B B8 Mens Restroom				
5-018 172	Building B Classroom B9				
5-006 173	Building B Room B9 Storage				
5-011 174	Building B Classroom B10				
5-010 175	Building B Classroom B10				
5-022 176	Building B Classroom B11				
5-023 177	Building B Classroom B12				
5-024 178	Building B Classroom B12				
5-021 179	Building B Classroom B13				
5-304 239	Building C Classroom C1				
5-305 240	Building C Classroom C1				
5-306 241	Building C Classroom C1				
5-307 242	Building C Classroom C1				
5-303 243	Building C Classroom C1 Strg				
5-255 244	Building C Classroom C2				
5-256 245	Building C Classroom C2				
5-257 246	Building C Classroom C2				
5-258 247	Building C Classroom C2				
5-254 248	Building C Classroom C2 Strg				
5-259 249	Building C Classroom C3				
5-260 250	Building C Classroom C3				
5-261 251	Building C Classroom C3				
5-262 252	Building C Classroom C3				
5-253 253	Building C Classroom C3 Strg				
5-263 254	Building C Classroom C4				
5-264 255	Building C Classroom C4				
5-265 256	Building C Classroom C4				
5-266 257	Building C Classroom C4				
5-267 258	Building C Classroom C4 Strg				
5-268 259	Building C Classroom C5				
5-269 260	Building C Classroom C5				
5-270 261	Building C Classroom C5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-271 262	Building C Classroom C5				
5-273 263	Building C Classrm C5 Strg E				
5-274 264	Building C Classrm C5 Strg E				
5-272 265	Building C Classrm C5 Strg W				
5-276 266	Building C Classroom C6				
5-277 267	Building C Classroom C6				
5-278 268	Building C Classroom C6				
5-275 269	Building C Classroom C6				
5-279 270	Building C Classroom C7				
5-280 271	Building C Classroom C7				
5-281 272	Building C Classroom C8				
5-282 273	Building C Classroom C8				
5-283 274	Building C Classroom C8				
5-284 275	Building C Classroom C8				
5-285 276	Building C Classroom C9				
5-286 277	Building C Classroom C9				
5-287 278	Building C Classroom C9				
5-288 279	Building C Classroom C9				
5-289 280	Building C Classroom C9				
5-290 281	Building C Classroom C9				
5-308 282	Building C Classroom C9				
5-291 283	Building C Classroom C9				
5-292 284	Building C Classroom C10				
5-293 285	Building C Classroom C10				
5-295 286	Building C Classroom C10				
5-296 287	Building C Classroom C10				
5-294 288	Building C Classroom C10 Strg				
5-300 289	Building C Classroom C11 Strg				
5-298 290	Building C Art Room				
5-297 291	Building C Art Room Office				
4-040 349	Building D Room D2 Storage N				
4-041 350	Building D Room D2 Storage S				
4-039 351	Building D Classroom D3				
4-016 352	Building D Room D4 Storage C				
4-017 353	Building D Room D4 Storage E				
4-029 354	Building D Classroom D5				
4-028 355	Building D Classroom D5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-032 356	Building D Classroom D5				
4-033 357	Building D Classroom D5				
4-031 358	Building D Room D5 Storage S				
4-026 359	Building D Classroom D6				
2-262 360	Building F Classroom F1				
2-259 361	Building F Classroom F1				
2-260 362	Building F Classroom F1				
2-261 363	Building F Classroom F1				
2-258 364	Building F Classrm F1A Storage				
2-257 365	Building F Classrm F1A Storage				
2-263 366	Building F Classroom F2				
2-264 367	Building F Classroom F2				
2-266 368	Building F Classroom F3				
2-265 369	Building F Classroom F3				
2-267 370	Building F Rm F3 Girls Restrm				
2-268 371	Building F Rm F3 Girls Restrm				
2-269 372	Building F Classroom F4				
2-270 373	Building F Classroom F4				
2-279 374	Building F Bldg F Hallway				
2-272 375	Building F Classroom F5				
2-271 376	Building F Classroom F5				
2-273 377	Building F Classroom F5				
2-274 378	Building F Classroom F5				
2-289 379	Building F Classroom F6				
2-288 380	Building F Classroom F6				
2-277 381	Building F Bldg F Hallway				
2-290 382	Building F Classroom F7				
2-291 383	Building F Classroom F7				
2-284 384	Building F Classroom F8				
2-285 385	Building F Classroom F8				
2-283 386	Building F Classroom F9				
2-282 387	Building F Classroom F9				
2-280 388	Building F Classroom F10				
2-281 389	Building F Classroom F10				
2-278 390	Building F Bldg F Hallway				
2-255 391	Building F Classroom F11				
2-256 392	Building F Classroom F11				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-254 393	Building F Classroom F11				
2-275 395	Building F Classroom F12				
2-287 396	Building F Classroom F13				
2-286 397	Building F Classroom F13				
2-253 398	Building F Hallway Storage				
7-266 540	Small Gym Entry				
541	Small Gym Stage				
7-260 542	Small Gym Stage				
7-257 543	Small Gym Stage				
544	Small Gym Stage				
7-261 545	Small Gym Stage				
546	Small Gym Stage Office				
7-264 547	Small Gym Stage Office				
7-262 548	Small Gym Above Stage				
7-258 549	Small Gym Above Stage				
7-253 550	Small Gym Above Stage West				
7-255 551	Small Gym Above Stage West				
7-267 552	Small Gym Girls Restroom				
7-268 553	Small Gym Boys Restroom				
554	Small Gym Food Stand				
555	Small Gym Food Stand Storage				
556	Small Gym Northwest Storage				
8-025 589	Locker Room Bldg Custodial Storage				
8-026 590	Locker Room Bldg Boys Locker				
8-027 591	Locker Room Bldg Boys Locker Strg SW				
8-023 592	Locker Room Bldg Boys Locker Strg W				
8-031 593	Locker Room Bldg Boys Locker Office				
8-029 594	Locker Room Bldg Boys Staff Lock RR				
8-030 595	Locker Room Bldg Boys Locker Train Off				
8-039 596	Locker Room Bldg Boys Locker East				
8-040 597	Locker Room Bldg Boys Locker East				
8-037 598	Locker Room Bldg Boys Locker Strg SE				
8-038 599	Locker Room Bldg Boys Locker Strg SE				
8-042 600	Locker Room Bldg Boys Locker Strg NE				
8-003 601	Locker Room Bldg Girls Office				
8-004 602	Locker Room Bldg Girls Office				
8-008 603	Locker Room Bldg Girls Locker Entry				
8-020 604	Locker Room Bldg Girls Locker Room				
8-005 605	Locker Room Bldg Girls Staff Locker RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
8-009 606	Locker Room Bldg Girls Restrm Storage				
8-011 607	Locker Room Bldg Girls Locker Strg N				
8-022 608	Locker Room Bldg Girls Locker Strg E				
8-007 609	Locker Room Bldg Girls Locker Strg S				
8-012 610	Locker Room Bldg Pool Storage				
8-013 611	Locker Room Bldg Pool Storage				
8-014 612	Locker Room Bldg Pool Storage				
6-265 672	Weight Room Bldg Weight Room				
6-266 673	Weight Room Bldg Weight Room				
6-267 674	Weight Room Bldg Weight Room				
6-268 675	Weight Room Bldg Weight Room				
6-269 676	Weight Room Bldg Weight Room				
6-270 677	Weight Room Bldg Weight Room				
6-271 678	Weight Room Bldg Weight Room				
6-272 679	Weight Room Bldg Weight Room				
6-273 680	Weight Room Bldg Weight Room				
6-264 681	Weight Room Bldg Storage				
6-263 682	Weight Room Bldg IDF Closet				
4-056 695	Portables AG Portable				
4-057 696	Portables AG Portable				
3-004	E/F Copy rm storage				05/20/2019
2-276	Building F Classroom F12				
4-276	Building A Classroom A1				
5-012	Building B Classroom B1				
	Classroom B Rm B1				06/05/2019
5-014	Building B Classroom B2				
5-015	Building B Classroom B2				
5-016	Building B Classroom B3				
5-030	Building B Classroom B5 Storage				
5-035	Building B Classroom B7 Storage S				
4-005	Building D Classroom D7 Storage				
4-006	Building D Classroom D8 Storage				
4-007	Building D Classroom D8 Storage				
4-008	Building D Classroom D8 Storage				
4-009	Building D Classroom D8				
4-010	Building D Classroom D8				
4-011	Building D Classroom D8				
4-012	Building D Classroom D8				
4-013	Building D Classroom D7				
4-014	Building D Classroom D7				
4-015	Building D Classroom D7				
4-018	Building D Classroom D6 Storage S				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-019	Building D Classroom D6				
4-020	Building D Classroom D6				
4-021	Building D Classroom D6 Storage W				
4-022	Building D Classroom D6 Storage SW				
4-023	Building D Classroom D6 Storage W				
4-024	Building D Classroom D6 Upp Strg SE				
4-025	Building D Classroom D6 Low Strg SE				
4-027	Building D Classroom D6				
4-034	Building D Girls RR				06/05/2019
4-035	Building D Men's RR				06/05/2019
4-036	Building D Men's RR				06/05/2019
4-060	Building D Room D7				
3-253	Building E Rm E1 Custodial				06/05/2019
3-254	Building E Staff Men's RR				06/05/2019
3-255	Building E Staff Men's RR				06/05/2019
3-256	Building E Rm E1				06/05/2019
3-257	Building E Rm E1				06/05/2019
3-258	Building E Rm E1				06/05/2019
3-259	Building E Rm E1				06/05/2019
3-260	Building E Rm E2				06/05/2019
3-261	Building E Rm E2				06/05/2019
3-262	Building E Rm E2				06/05/2019
3-263	Building E Rm E2				06/05/2019
3-264	Building E Rm E3				06/05/2019
3-265	Building E Rm E3				06/05/2019
3-266	Building E Rm E3				06/05/2019
3-267	Building E Rm E3				06/05/2019
3-268	Building E Rm E10				06/05/2019
3-269	Building E Rm E10				06/05/2019
3-270	Building E Rm E9				06/05/2019
3-271	Building E Rm E9				06/05/2019
3-272	Building E Rm E9				06/05/2019
3-273	Building E Rm E9				06/05/2019
3-274	Building E Rm E9				06/05/2019
3-275	Building E Hallway				06/05/2019
3-276	Building E Hallway				06/05/2019
3-277	Building E Hallway				06/05/2019
3-279	Building E Rm E5				06/05/2019
3-278	Building E Rm E5				06/05/2019
3-280	Building E Rm E11				06/05/2019
3-281	Building E Rm E11				06/05/2019
3-282	Building E Rm E8B				06/05/2019
3-283	Building E Rm E8B				06/05/2019
3-284	Building E Rm E8A				06/05/2019
3-285	Building E Rm E8A				06/05/2019
3-286	Building E Rm E7				06/05/2019
3-287	Building E Rm E7				06/05/2019
3-288	Building E Rm E6				06/05/2019
3-289	Building E Rm E6				06/05/2019
3-290	Building E Rm E9 Strg				06/05/2019

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
7-003	Cafeteria A/B Staff Closet				
7-005	Cafeteria A/B Kitchen N Strg				
7-005	Cafeteria A/B Conference Rm				
7-006	Cafeteria A/B Conference Rm				
7-007	Cafeteria A/B Conference Rm				
7-008	Cafeteria A/B Conference Rm				
7-009	Cafeteria A/B Staff Hall				
7-010	Cafeteria A/B Staff Hall RR				
7-011	Cafeteria A/B O/S S Strg				
7-012	Cafeteria A/B O/S S Strg				
7-013	Cafeteria A/B Staff Hall RR				
7-014	Cafeteria A/B O/S Food Strg				
7-015	Cafeteria A/B Staff Rm				
7-016	Cafeteria A/B Staff Rm				
7-018	Cafeteria A/B Kitchen S Strg				
7-019	Cafeteria A/B Boys RR				
7-020	Cafeteria A/B Cafeteria Strg				
7-022	Cafeteria A/B Kitchen RR				
7-025	Cafeteria A/B Girls RR				
7-026	Cafeteria A/B Cafeteria				
7-027	Cafeteria A/B Cafeteria				
7-028	Cafeteria A/B Cafeteria				
7-029	Cafeteria A/B Cafeteria				
7-030	Cafeteria A/B Cafeteria				
7-031	Cafeteria A/B Cafeteria				
7-032	Cafeteria A/B Kitchen Office				
3-003	Cafeteria E/F Staff Rm				06/05/2019
3-004	Cafeteria E/F Copy Rm Strg				06/05/2019
3-005	Cafeteria E/F Copy Rm				06/05/2019
3-006	Cafeteria E/F Attendance				06/05/2019
3-007	Cafeteria E/F Attendance RR				06/05/2019
3-008	Cafeteria E/F Resource RR				06/05/2019
3-009	Cafeteria E/F Resource Hall				06/05/2019
3-010	Cafeteria E/F Resource				06/05/2019
3-011	Cafeteria E/F Attendance				06/05/2019
3-012	Cafeteria E/F ROP Rm				06/05/2019
3-013	Cafeteria E/F Office				06/05/2019
3-014	Cafeteria E/F Custodial Office				06/05/2019
3-015	Cafeteria E/F Staff Rm Strg				06/05/2019
3-016	Cafeteria E/F Grils RR				06/05/2019
3-017	Cafeteria E/F Girls RR Hall				06/05/2019
3-018	Cafeteria E/F Kitchen Strg				06/05/2019
3-020	Cafeteria E/F Kitchen Hall				06/05/2019
3-021	Cafeteria E/F Boys RR				06/05/2019
3-022	Cafeteria E/F Boys RR Hall				06/05/2019
3-024	Cafeteria E/F Cafeteria				06/05/2019
3-025	Cafeteria E/F Cafeteria				06/05/2019
3-027	Cafeteria E/F Cafeteria				06/05/2019
3-026	Cafeteria E/F Cafeteria				06/05/2019
3-028	Cafeteria E/F Cafeteria				06/05/2019
7-271	Large Gym Ticket Booth				06/05/2019
2-032	Building G Hall G34				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-031	Building G Hall G34				
2-030	Building G Hall G34				
2-033	Building G Hall G34				
2-005	Building G IDF Room G41				
2-011	Building G Collab G38				
2-014	Building G Group Study G39				
2-015	Building G Office G40				
2-025	Building G Retail G44				
2-024	Building G Group Study G43				
2-022	Building G Library G42				
2-028	Building G Custodial G36				
2-069	Building G Principle G28				
2-027	Building G Woman's Restroom G35				
2-067	Building G Secretary G29				
2-070	Building G Conference G27				
2-029	Building G Men's Restroom G37				
2-068	Building G Controller G30				
2-039	Building G Hall G221				
2-040	Building G Hotel Conf G24				
2-065	Building G Trans Storage G14				
2-035	Building G Waiting Room G22				
2-037	Building G Office G32				
2-036	Building G Office G33				
2-060	Building G Counselor G12				
2-038	Building G Office G31				
2-059	Building G Counselor G11				
2-064	Building G Restroom G15				
2-061	Building G Hall G05.3				
2-058	Building G Counselor G10				
2-057	Building G Counselor G9				
2-062	Building G Nurse Office G17				
2-054	Building G Waiting Room G05				
2-047	Building G Hall G05.1				
2-048	Building G Mailroom G20				
2-049	Building G Staff Lounge G25				
2-034	Building G Hall G01.2				
2-041	Building G Hall G01.2				
2-042	Building G Professional Development G21				
2-043	Building G Professional Development G21				
2-044	Building G Welcome Center G01				
2-045	Building G Welcome Center G01				
2-046	Building G Hall G01.1				
2-051	Building G Restroom G19				
2-052	Building G Restroom G20				
2-050	Building G Storage G18				
2-056	Building G Conference G06				
2-055	Building G Registrar G07				
2-053	Building G Fire Curtain				
2-003	Bldg H MDF FACP rm				
2-066	Secured Strg G13				

Heat Detector - Restorable Spot

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-376 090	Building A Attic Classroom A7				
4-376 091	Building A Attic Room A7 RR				
4-376 092	Building A Attic Classroom A8				
4-376 093	Building A Attic Classrm A8 Strg				
4-377 094	Building A Attic Classroom A5				
4-377 095	Building A Attic Classroom A6				
4-377 096	Building A Attic Classroom A9				
4-377 097	Building A Attic Classroom A12				
4-378 098	Building A Attic Hallway				
4-378 099	Building A Attic Hallway				
4-378 100	Building A Attic Hallway				
4-379 101	Building A Attic Classroom A1				
4-379 102	Building A Attic Classroom A2				
4-379 103	Building A Attic Classroom A3				
4-379 104	Building A Attic Classroom A4				
4-379 105	Building A Attic Classroom A10				
4-379 106	Building A Attic Classroom A11A				
4-380 107	Building A Attic Overhang				
4-380 108	Building A Attic Overhang				
4-380 109	Building A Attic Overhang				
4-380 110	Building A Attic Overhang				
4-380 111	Building A Attic Overhang				
4-380 112	Building A Attic Overhang				
4-380 113	Building A Attic Overhang				
4-380 114	Building A Attic Overhang				
4-380 115	Building A Attic Overhang				
4-380 116	Building A Attic Overhang				
5-126 180	Building B Attic Hallway				
5-126 181	Building B Attic Hallway				
5-126 182	Building B Attic Hallway				
5-127 183	Building B Attic Overhang				
5-127 184	Building B Attic Overhang				
5-127 185	Building B Attic Overhang				
5-127 186	Building B Attic Overhang				
5-127 187	Building B Attic Overhang				
5-127 188	Building B Attic Overhang				
5-127 189	Building B Attic Overhang				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-127 190	Building B Attic Overhang				
5-127 191	Building B Attic Overhang				
5-127 192	Building B Attic Overhang				
5-128 193	Building B Attic Classroom B1				
5-128 194	Building B Attic Classroom B2				
5-128 195	Building B Attic Classroom B3				
5-128 196	Building B Attic Classroom B4				
5-128 197	Building B Attic Classroom B10				
5-128 198	Building B Attic Classroom B11				
5-129 199	Building B Attic Classroom B5				
5-129 200	Building B Attic Classrm B5 Strg				
5-129 201	Building B Attic Classroom B8				
5-129 202	Building B Attic Classroom B9				
5-129 203	Building B Attic Classroom B12				
5-134 204	Building B Attic Classroom B6				
5-134 205	Building B Attic Classroom B7				
5-134 206	Building B Attic Classroom B7				
5-301 292	Building C Classroom C11				
5-302 293	Building C Classroom C11				
5-299 294	Building C Classroom C11				
5-376 295	Building C Attic Classroom C1				
5-376 296	Building C Attic Classroom C1				
5-376 297	Building C Attic Classroom C2				
5-376 298	Building C Attic Classroom C3				
5-376 299	Building C Attic Classroom C4				
5-376 300	Building C Attic Classroom C10				
5-376 301	Building C Attic Classroom C10				
5-376 302	Building C Attic Classroom C11				
5-376 303	Building C Attic Classroom C11				
5-377 304	Building C Attic Classroom C5				
5-377 305	Building C Attic Classroom C6				
5-377 306	Building C Attic Classroom C7				
5-377 307	Building C Attic Classroom C8				
5-377 308	Building C Attic Classroom C9				
5-377 309	Building C Attic Classroom C9				
5-380 310	Building C Attic Overhang				
5-380 311	Building C Attic Overhang				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-380 312	Building C Attic Overhang				
5-380 313	Building C Attic Overhang				
5-380 314	Building C Attic Overhang				
5-380 315	Building C Attic Overhang				
5-380 316	Building C Attic Overhang				
5-380 317	Building C Attic Overhang				
5-380 318	Building C Attic Overhang				
5-380 319	Building C Attic Overhang				
5-380 320	Building C Attic Overhang				
5-380 321	Building C Attic Overhang				
2-380 399	Building F Attic Classroom F1				
2-380 400	Building F Attic Classroom F2				
2-380 401	Building F Attic Classroom F3				
2-381 402	Building F Attic Classroom F4				
2-381 403	Building F Attic Classroom F5				
2-381 404	Building F Attic Classroom F11				
2-381 405	Building F Attic Classroom F12				
2-382 406	Building F Attic Hallway				
2-382 407	Building F Attic Hallway				
2-382 408	Building F Attic Hallway				
2-383 409	Building F Attic Classroom 6				
2-383 410	Building F Attic Classroom 7				
2-383 411	Building F Attic Classroom 8				
2-383 412	Building F Attic Classroom 9				
2-383 413	Building F Attic Classroom 10				
2-383 414	Building F Attic Classroom 13				
2-384 415	Building F Attic Overhang				
2-384 416	Building F Attic Overhang				
2-384 417	Building F Attic Overhang				
2-384 418	Building F Attic Overhang				
2-384 419	Building F Attic Overhang				
2-384 420	Building F Attic Overhang				
2-384 421	Building F Attic Overhang				
2-384 422	Building F Attic Overhang				
2-384 423	Building F Attic Overhang				
2-384 424	Building F Attic Overhang				
7-388 514	Large Gym Attic Heat				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
7-388 515	Large Gym Attic Heat				
7-388 516	Large Gym Attic Heat				
7-388 517	Large Gym Attic Heat				
7-388 518	Large Gym Attic Heat				
7-388 519	Large Gym Attic Heat				
7-388 520	Large Gym Attic Heat				
7-388 521	Large Gym Attic Heat				
7-388 522	Large Gym Attic Heat				
557	Small Gym ROTC Logistics Shed				
558	Small Gym Attic Small Gym N				
559	Small Gym Attic Small Gym N				
560	Small Gym Attic Small Gym N				
561	Small Gym Attic Small Gym N				
562	Small Gym Attic Small Gym S				
563	Small Gym Attic Small Gym S				
564	Small Gym Attic Small Gym S				
565	Small Gym Attic Small Gym S				
566	Small Gym Attic Small Gym S				
567	Small Gym Attic Small Gym S				
8-036 613	Locker Room Bldg Boys Locker Entry				
8-024 614	Locker Room Bldg Boys Locker Restrm				
8-032 615	Locker Room Bldg Boys Locker				
8-033 616	Locker Room Bldg Boys Locker				
8-034 617	Locker Room Bldg Boys Locker				
8-035 618	Locker Room Bldg Boys Locker				
8-041 619	Locker Room Bldg Boys Locker				
8-028 620	Locker Room Bldg Boys Staff Lock RR				
8-016 621	Locker Room Bldg Girls Locker Room				
8-017 622	Locker Room Bldg Girls Locker Room				
8-018 623	Locker Room Bldg Girls Locker Room				
8-019 624	Locker Room Bldg Girls Locker Room				
8-021 625	Locker Room Bldg Girls Locker RR E				
8-010 626	Locker Room Bldg Girls Locker RR W				
8-006 627	Locker Room Bldg Girls Locker Staff RR				
8-127 628	Locker Room Bldg Attic Boys Locker				
8-127 629	Locker Room Bldg Attic Boys Locker				
8-127 630	Locker Room Bldg Attic Boys Locker				
8-127 631	Locker Room Bldg Attic Boys Locker				
8-127 632	Locker Room Bldg Attic Boys Locker				
8-127 633	Locker Room Bldg Attic Boys Locker				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
8-127 634	Locker Room Bldg Attic Boys Locker				
8-127 635	Locker Room Bldg Attic Boys Locker				
8-126 636	Locker Room Bldg Attic Girls Locker				
8-126 637	Locker Room Bldg Attic Girls Locker				
8-126 638	Locker Room Bldg Attic Girls Locker				
8-126 639	Locker Room Bldg Attic Girls Locker				
8-126 640	Locker Room Bldg Attic Girls Locker				
8-126 641	Locker Room Bldg Attic Girls Locker				
8-126 642	Locker Room Bldg Attic Girls Locker				
8-126 643	Locker Room Bldg Attic Girls Locker				
6-383 683	Weight Room Bldg HVAC FAU 1				
6-384 684	Weight Room Bldg HVAC FAU 2				
6-385 685	Weight Room Bldg HVAC FAU 3				
4-131 703	Portables Attic AG Portable				
4-131 704	Portables Attic AG Portable				
4-131 705	Portables Attic AG Portable				
2-381	Attic classroom F4				
2-381	Attic classroom F5				
2-381	Attic classroom F11				
5-128	Building B Attic Classroom B2				
5-126	Building B Attic Hallway				
4-037	Building D Room D4				
4-038	Building D Room D4				
4-042	Building D Room D1 Storage E				
4-045	Building D Room D1 Paint Rm				
4-046	Building D Room D1				
4-047	Building D Room D1				
4-048	Building D Room D1 Wood Strg				
4-049	Building D Room D1 Storage W				
4-050	Building D Room D1 Office				
4-051	Building D Room D2				
4-052	Building D Room D2				
4-126	Building D Attic Rm D5				
4-126	Building D Attic Rm D6				
4-126	Building D Attic Rm D6				
4-127	Building D Attic Rm D4				
4-127	Building D Attic Rm D4 Strg				
4-127	Building D Attic Rm D7				
4-128	Building D Attic Rm D2				
4-128	Building D Attic Rm D2				
4-129	Building D Attic Rm D2				
4-129	Building D Attic Rm D2				
4-128	Building D Attic Rm D1 Strg				
4-129	Building D Attic Rm D1				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
4-130	Building D Attic Overhang				
3-376	Building E Attic Rm E2				06/05/2019
3-376	Building E Attic Rm E3				06/05/2019
3-376	Building E Attic Rm E4				06/05/2019
3-376	Building E Attic Rm E10				06/05/2019
3-377	Building E Attic Rm E1				06/05/2019
3-377	Building E Attic Rm E1				06/05/2019
3-377	Building E Attic Rm E9				06/05/2019
3-377	Building E Attic Rm E9 Strg				06/05/2019
3-378	Building E Attic Rm E5				06/05/2019
3-378	Building E Attic Rm E6				06/05/2019
3-378	Building E Attic Rm E7				06/05/2019
3-378	Building E Attic Rm E8A				06/05/2019
3-378	Building E Attic Rm E8B				06/05/2019
3-378	Building E Attic Rm E11				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
3-379	Building E Attic Overhang				06/05/2019
7-017	Cafeteria A/B Kitchen				
7-021	Cafeteria A/B Kitchen				
7-023	Cafeteria A/B Kitchen				
7-024	Cafeteria A/B Kitchen				
7-126	Cafeteria A/B Attic Conference				
7-126	Cafeteria A/B Attic Conference				
7-126	Cafeteria A/B Attic Conference				
7-127	Cafeteria A/B Attic Kitchen				
7-129	Cafeteria A/B Attic Cafeteria				
7-129	Cafeteria A/B Attic Cafeteria				
7-129	Cafeteria A/B Attic Cafeteria				
7-129	Cafeteria A/B Attic Cafeteria				
7-129	Cafeteria A/B Attic Cafeteria				
7-129	Cafeteria A/B Attic Cafeteria				
7-129	Cafeteria A/B Attic Cafeteria				
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				
7-130	Cafeteria A/B Attic Overhang				
7-127	Cafeteria A/B Attic Kitchen				
7-127	Cafeteria A/B Attic Kitchen				
7-127	Cafeteria A/B Attic Kitchen				
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-019	Cafeteria E/F Kitchen				06/05/2019
3-023	Cafeteria E/F Cafeteria				06/05/2019
3-126	Cafeteria E/F Attic Attendance				06/05/2019
3-126	Cafeteria E/F Attic ROP Rm				06/05/2019
3-126	Cafeteria E/F Attic Kitchen Strg				06/05/2019
3-126	Cafeteria E/F Attic Boys RR				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-127	Cafeteria E/F Attic Cafeteria				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
3-128	Cafeteria E/F Attic Overhang				06/05/2019
7-388	Large Gym Attic Heat				
7-388	Large Gym Attic Heat				
Smoke Detector - Duct					
4-381 117	Building A Classroom A8A				
4-382 118	Building A Classroom A8A				
4-384 119	Building A Classroom A8A				
4-383 120	Building A Classroom A9				
5-130 207	Building B Room B5 Storage				
5-131 208	Building B Room B5 Storage				
5-132 209	Building B Room B5 Storage				
5-135 210	Building B Classroom B11				
5-137 211	Building B Classroom B11				
5-136 212	Building B Classroom B12				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-385 425	Building F Classroom F1				
2-377 426	Building F Classroom F1A				
2-378 427	Building F Classroom F1A				
2-379 428	Building F Classroom F1A				
2-376 429	Building F Classroom F1A				
7-400 523	Large Gym East				
7-393 524	Large Gym Center				
7-398 525	Large Gym West				
568	Small Gym East				
569	Small Gym Storage				
570	Small Gym West				
8-128 644	Locker Room Bldg Boys Locker West				
8-129 645	Locker Room Bldg Boys Locker East				
8-130 646	Locker Room Bldg Girls Locker Room				
2-129	Cafeteria E/F - Roof				
2-130	Cafeteria E/F - Roof				
4-134	Building D Roof				
4-135	Building D Roof				
4-136	Building D Roof				
3-380	Building E Roof				06/05/2019
3-381	Building E Roof				06/05/2019
3-382	Building E Roof				06/05/2019
7-131	Cafeteria A/B Roof				
7-399	Large Gym Center				
Mechanical, Electrosonic, or Pressure Waterflow Device					
5-378 322	Building C Room C11 Kiln Room				
573	Small Gym Storage				
4-132	Building D Room D1 Storage				
2M134	Building G				06/30/2020
Manual Pull Station					
8-401 509	Large Gym Northwest				
8-402 510	Large Gym Southwest				
8-403 511	Large Gym Southeast				
8-404 512	Large Gym Southwest				
536	Small Gym Northeast				
537	Small Gym Southeast				
538	Small Gym West				
539	Small Gym North				
8-396	Cafeteria A/B Attic Cafeteria S/E				
8-393	Cafeteria A/B Attic Cafeteria N/E				
8-394	Cafeteria A/B Attic Cafeteria N/W				
8-395	Cafeteria A/B Cafeteria S/W				
8-389	Cafeteria E/F S				06/05/2019
8-390	Cafeteria E/F S/E				06/05/2019
8-391	Cafeteria E/F N/E				06/05/2019
8-392	Cafeteria E/F N				06/05/2019

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-133	Reception G01				
7-133	Admin Office				
Smoke Detector - Projected Beam					
7-387 526	Large Gym North				
7-385 527	Large Gym South				
571	Small Gym South				
572	Small Gym North				
Supervisory - Control Valve					
2M135	Building G				06/30/2020
2M136	Building G OSY				06/30/2020

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression					
	Suppression System				07/29/2025
[Other]					
	Gas Valve				07/29/2025
	Automan				07/29/2025
Range Suppression Tank					
	3 Gallon Cylinder #1				07/29/2025
	3 Gallon Cylinder #2				07/29/2025