

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

LAUREL RUFF

5325 GARFIELD AVE
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, August 07, 2025

Test Session :05 Aug 2025 06:13 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	LAUREL RUFF	CONTACT
ADDRESS	5325 GARFIELD AVE	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	50	50(100%)	50(100%)	0(0%)
Fire Control Panel	6	6(100%)	2(33%)	4(67%)
Initiating Device	125	117(94%)	116(93%)	1(1%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, August 07, 2025

ACCEPTED BY 08/07/2025

Building Representative


TESTED BY 08/07/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Rooms 1-4 Bldg Rooms 3 4 RR Storage
MANUFACTURER		S/W VERSION	
MODEL		LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			
ADDRESS / SCAN ADDRESS		DESCRIPTION	Rooms 1-4 Bldg Rooms 3 4 RR Storage - Voice/EVAC Panel
MANUFACTURER	Fire-Lite	S/W VERSION	
MODEL	Fire Command 25/50X	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 6 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Fire Alarm Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage
	Created By:	Riley Goyet
	Creation Date:	12/13/2021
	Corrective Action:	Replace (2) 12V 55AH Duracell Ultra deep cell batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 55AH Duracell Ultra deep cell batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "Master"
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "B"
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Manual Pull Station	2-145 151	Pool Building Northwest Exit
	Created By:	Riley Goyet
	Creation Date:	08/05/2025
	Corrective Action:	Did not report to panel - make - FCI. Model - MS-2
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	013	Admin Building Nurses Office	Manual	8/5/2025 6:13:55 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	014	Admin Building Nurses Office	Manual	8/5/2025 6:13:56 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	015	Admin Building Nurses Restroom	Manual	8/5/2025 6:13:58 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	017	Admin Building Principals Office	Manual	8/5/2025 6:14:01 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	012	Admin Building Reception	Manual	8/5/2025 6:13:53 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	016	Admin Building Secretary Office	Manual	8/5/2025 6:13:59 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	127	Multi-Purpose Bldg Boys Restroom	Manual	8/5/2025 6:15:01 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	135	Multi-Purpose Bldg Boys Restroom	Manual	8/5/2025 6:15:14 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	136	Multi-Purpose Bldg Boys Restroom	Manual	8/5/2025 6:15:15 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	126	Multi-Purpose Bldg Girls Restroom	Manual	8/5/2025 6:15:00 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	133	Multi-Purpose Bldg Girls Restroom	Manual	8/5/2025 6:15:09 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	134	Multi-Purpose Bldg Girls Restroom	Manual	8/5/2025 6:15:12 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	130	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 6:15:06 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	131	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 6:15:07 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	137	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 6:15:16 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	128	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:15:03 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	129	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:15:04 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	125	Multi-Purpose Bldg Northeast Exterior	Manual	8/5/2025 6:14:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	132	Multi-Purpose Bldg Staff Break Room	Manual	8/5/2025 6:15:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	138	Multi-Purpose Bldg Staff Break Room	Manual	8/5/2025 6:15:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	140	Multi-Purpose Bldg Staff Mens Restroom	Manual	8/5/2025 6:15:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	139	Multi-Purpose Bldg Staff Womens RR	Manual	8/5/2025 6:15:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	169	Pool Building Pool Room	Manual	8/5/2025 6:15:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	170	Pool Building Pool Room	Manual	8/5/2025 6:15:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	171	Pool Building Pool Room	Manual	8/5/2025 6:15:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	172	Pool Building Pool Room	Manual	8/5/2025 6:15:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	173	Pool Building Pool Room	Manual	8/5/2025 6:15:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	174	Pool Building Pool Room	Manual	8/5/2025 6:15:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	175	Pool Building Pool Room	Manual	8/5/2025 6:15:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	042	Rooms 1-4 Bldg Room 1	Manual	8/5/2025 6:14:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	043	Rooms 1-4 Bldg Room 2	Manual	8/5/2025 6:14:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	044	Rooms 1-4 Bldg Room 3	Manual	8/5/2025 6:14:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	045	Rooms 1-4 Bldg Room 4	Manual	8/5/2025 6:14:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	047	Rooms 1-4 Bldg Rooms 1 2 Kitchen	Manual	8/5/2025 6:14:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	046	Rooms 1-4 Bldg Rooms 1 2 RR	Manual	8/5/2025 6:14:11 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible And Visible	049	Rooms 1-4 Bldg Rooms 3 4 Kitchen	Manual	8/5/2025 6:14:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	048	Rooms 1-4 Bldg Rooms 3 4 RR	Manual	8/5/2025 6:14:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	040	Rooms 1-4 Bldg South Exterior	Manual	8/5/2025 6:14:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	041	Rooms 1-4 Bldg West Exterior	Manual	8/5/2025 6:14:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	062	Rooms 5-7 Bldg Room 5	Manual	8/5/2025 6:14:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	063	Rooms 5-7 Bldg Room 6	Manual	8/5/2025 6:14:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	064	Rooms 5-7 Bldg Room 7	Manual	8/5/2025 6:14:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	090	Rooms 8-11 Bldg Room 10	Manual	8/5/2025 6:14:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	091	Rooms 8-11 Bldg Room 11	Manual	8/5/2025 6:14:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	088	Rooms 8-11 Bldg Room 8	Manual	8/5/2025 6:14:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	089	Rooms 8-11 Bldg Room 9	Manual	8/5/2025 6:14:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	093	Rooms 8-11 Bldg Rooms 10 11 RR	Manual	8/5/2025 6:14:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	092	Rooms 8-11 Bldg Rooms 8 9 Kitchen	Manual	8/5/2025 6:14:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	147	South Portable Main Room	Manual	8/5/2025 6:15:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	148	South Portable Restroom	Manual	8/5/2025 6:15:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Building Reception	Manual	8/5/2025 7:38:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage - Voice/EVAC Panel	Manual	8/5/2025 7:42:22 AM
		Manufacturer	Fire-Lite	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Model	Fire Command 25/50X	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Timer (s)	30_seconds	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage	Manual	8/5/2025 7:38:41 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "B"	Manual	8/5/2025 7:43:11 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "C"	Manual	8/5/2025 7:43:42 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "Master"	Manual	8/5/2025 7:42:01 AM
		Visual inspection	Failed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-037 008	Admin Building Conference Room	Manual	8/5/2025 6:44:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 004	Admin Building Nurses Office	Manual	8/5/2025 6:48:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 005	Admin Building Nurses Restroom	Manual	8/5/2025 6:49:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 007	Admin Building Office Storage	Manual	8/5/2025 6:45:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 009	Admin Building Principals Office	Manual	8/5/2025 6:47:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-126 002	Admin Building Reception	Manual	8/5/2025 10:05:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 003	Admin Building Reception	Manual	8/5/2025 9:41:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 010	Admin Building Secretary Office	Manual	8/5/2025 6:46:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 006	Admin Building Storage Workroom	Manual	8/5/2025 6:46:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Line	2.127	Electric Room	Manual	8/5/2025 7:50:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-102 100	Multi-Purpose Bldg Boys Restroom	Manual	8/5/2025 7:12:32 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 099	Multi-Purpose Bldg Boys Restroom	Manual	8/5/2025 7:11:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 098	Multi-Purpose Bldg Boys Restroom	Manual	8/5/2025 9:28:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 122	Multi-Purpose Bldg Custodian Closet	Manual	8/5/2025 6:54:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 101	Multi-Purpose Bldg Custodian Office	Manual	8/5/2025 7:03:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-081 121	Multi-Purpose Bldg Electrical Room	Manual	8/5/2025 9:52:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-103 097	Multi-Purpose Bldg Girls Restroom	Manual	8/5/2025 7:15:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 095	Multi-Purpose Bldg Girls Restroom	Manual	8/5/2025 7:15:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 096	Multi-Purpose Bldg Girls Restroom	Manual	8/5/2025 9:29:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-087 116	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 7:05:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-134 124	Multi-Purpose Bldg Kitchen	Manual	8/5/2025 10:00:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-086 115	Multi-Purpose Bldg Kitchen Entrance	Manual	8/5/2025 7:04:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 117	Multi-Purpose Bldg Kitchen Food Storage	Manual	8/5/2025 9:02:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 094	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:59:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 103	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:57:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 106	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:57:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 107	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:58:11 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-093 108	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:58:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 105	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:58:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 111	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:59:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 112	Multi-Purpose Bldg MP Room	Manual	8/5/2025 6:59:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 109	Multi-Purpose Bldg MP Room	Manual	8/5/2025 7:00:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 110	Multi-Purpose Bldg MP Room	Manual	8/5/2025 7:01:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 104	Multi-Purpose Bldg MP Room	Manual	8/5/2025 7:01:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 114	Multi-Purpose Bldg MP Room	Manual	8/5/2025 7:02:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104	Multi-Purpose Bldg MP Room	Manual	8/5/2025 7:15:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 113	Multi-Purpose Bldg MP Room	Manual	8/5/2025 8:59:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-135 123	Multi-Purpose Bldg MP Room Storage	Manual	8/5/2025 10:05:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 102	Multi-Purpose Bldg MP Room Storage	Manual	8/5/2025 7:02:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 118	Multi-Purpose Bldg Staff Break Room	Manual	8/5/2025 6:52:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 120	Multi-Purpose Bldg Staff Mens Restroom	Manual	8/5/2025 6:51:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 119	Multi-Purpose Bldg Staff Womens RR	Manual	8/5/2025 6:52:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 168	Pool Building Chemical Storage	Manual	8/5/2025 8:39:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-144 150	Pool Building East Exit	Manual	8/5/2025 8:11:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 152	Pool Building Pool Room	Manual	8/5/2025 8:16:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 153	Pool Building Pool Room	Manual	8/5/2025 8:17:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 154	Pool Building Pool Room	Manual	8/5/2025 8:20:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 155	Pool Building Pool Room	Manual	8/5/2025 8:20:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 156	Pool Building Pool Room	Manual	8/5/2025 8:24:31 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 157	Pool Building Pool Room	Manual	8/5/2025 8:26:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 158	Pool Building Pool Room	Manual	8/5/2025 8:27:29 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 159	Pool Building Pool Room	Manual	8/5/2025 8:28:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 160	Pool Building Pool Room	Manual	8/5/2025 8:29:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 161	Pool Building Pool Room	Manual	8/5/2025 8:31:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 162	Pool Building Pool Room	Manual	8/5/2025 8:32:46 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 163	Pool Building Pool Room	Manual	8/5/2025 8:34:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 164	Pool Building Pool Room	Manual	8/5/2025 8:37:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-143 149	Pool Building Southwest Exit	Manual	8/5/2025 8:10:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 167	Pool Building Southwest Storage	Manual	8/5/2025 8:39:29 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-136 038	Rooms 1-4 Bldg Attic Rooms 1 2 RR	Manual	8/5/2025 10:05:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-133 039	Rooms 1-4 Bldg Attic Rooms 3 4 RR	Manual	8/5/2025 10:05:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 019	Rooms 1-4 Bldg Room 1	Manual	8/5/2025 7:46:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 018	Rooms 1-4 Bldg Room 1	Manual	8/5/2025 7:46:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 021	Rooms 1-4 Bldg Room 1 Exterior Strg	Manual	8/5/2025 10:01:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 020	Rooms 1-4 Bldg Room 1 Interior Strg	Manual	8/5/2025 7:47:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 025	Rooms 1-4 Bldg Room 2	Manual	8/5/2025 7:42:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 026	Rooms 1-4 Bldg Room 2	Manual	8/5/2025 7:42:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 027	Rooms 1-4 Bldg Room 2 Closet	Manual	8/5/2025 7:44:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 028	Rooms 1-4 Bldg Room 3	Manual	8/5/2025 7:39:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 029	Rooms 1-4 Bldg Room 3	Manual	8/5/2025 7:39:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 030	Rooms 1-4 Bldg Room 3 Closet	Manual	8/5/2025 7:39:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 034	Rooms 1-4 Bldg Room 4	Manual	8/5/2025 7:35:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 035	Rooms 1-4 Bldg Room 4	Manual	8/5/2025 7:35:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 037	Rooms 1-4 Bldg Room 4 Exterior Strg	Manual	8/5/2025 9:34:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 036	Rooms 1-4 Bldg Room 4 Interior Strg	Manual	8/5/2025 7:36:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-023 024	Rooms 1-4 Bldg Rooms 1 2 Kitchen	Manual	8/5/2025 7:45:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 022	Rooms 1-4 Bldg Rooms 1 2 RR	Manual	8/5/2025 7:44:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 023	Rooms 1-4 Bldg Rooms 1 2 RR Strg	Manual	8/5/2025 7:48:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-010 033	Rooms 1-4 Bldg Rooms 3 4 Kitchen	Manual	8/5/2025 7:37:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 031	Rooms 1-4 Bldg Rooms 3 4 RR	Manual	8/5/2025 7:40:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 032	Rooms 1-4 Bldg Rooms 3 4 RR Storage	Manual	8/5/2025 7:40:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 050	Rooms 5-7 Bldg Room 5	Manual	8/5/2025 7:24:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 051	Rooms 5-7 Bldg Room 5	Manual	8/5/2025 7:24:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 053	Rooms 5-7 Bldg Room 5 Exterior Strg	Manual	8/5/2025 7:59:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 052	Rooms 5-7 Bldg Room 5 Interior Strg	Manual	8/5/2025 7:25:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 055	Rooms 5-7 Bldg Room 6	Manual	8/5/2025 7:22:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 054	Rooms 5-7 Bldg Room 6	Manual	8/5/2025 7:22:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 056	Rooms 5-7 Bldg Room 6 Storage	Manual	8/5/2025 7:23:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 057	Rooms 5-7 Bldg Room 6 Storage	Manual	8/5/2025 7:26:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 058	Rooms 5-7 Bldg Room 7	Manual	8/5/2025 7:18:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 059	Rooms 5-7 Bldg Room 7	Manual	8/5/2025 7:18:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-061 061	Rooms 5-7 Bldg Room 7 Exterior Strg	Manual	8/5/2025 8:01:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 060	Rooms 5-7 Bldg Room 7 Interior Strg	Manual	8/5/2025 7:20:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 080	Rooms 8-11 Bldg Rms 10 11 Off Strg	Manual	8/5/2025 6:35:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-139 087	Rooms 8-11 Bldg Rms 10 11 Office	Manual	8/5/2025 10:00:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 078	Rooms 8-11 Bldg Rms 10 11 Office	Manual	8/5/2025 6:35:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 079	Rooms 8-11 Bldg Rms 10 11 Office	Manual	8/5/2025 6:39:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 076	Rooms 8-11 Bldg Room 10	Manual	8/5/2025 6:32:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 075	Rooms 8-11 Bldg Room 10	Manual	8/5/2025 6:33:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 077	Rooms 8-11 Bldg Room 10 Storage	Manual	8/5/2025 9:58:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 082	Rooms 8-11 Bldg Room 11	Manual	8/5/2025 6:36:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 083	Rooms 8-11 Bldg Room 11	Manual	8/5/2025 6:36:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 085	Rooms 8-11 Bldg Room 11 Exterior Storage	Manual	8/5/2025 6:38:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 084	Rooms 8-11 Bldg Room 11 Interior Storage	Manual	8/5/2025 8:56:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 065	Rooms 8-11 Bldg Room 8	Manual	8/5/2025 6:21:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 066	Rooms 8-11 Bldg Room 8	Manual	8/5/2025 6:21:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 068	Rooms 8-11 Bldg Room 8 Exterior Storage	Manual	8/5/2025 8:04:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-060 067	Rooms 8-11 Bldg Room 8 Interior Storage	Manual	8/5/2025 6:27:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 072	Rooms 8-11 Bldg Room 9	Manual	8/5/2025 6:23:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 073	Rooms 8-11 Bldg Room 9	Manual	8/5/2025 6:23:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 074	Rooms 8-11 Bldg Room 9 Storage	Manual	8/5/2025 9:53:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 081	Rooms 8-11 Bldg Rooms 10 11 RR	Manual	8/5/2025 6:39:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-054 069	Rooms 8-11 Bldg Rooms 8 9 Kitchen	Manual	8/5/2025 6:25:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-055 070	Rooms 8-11 Bldg Rooms 8 9 Kitchen	Manual	8/5/2025 6:26:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-138 086	Rooms 8-11 Bldg Rooms 8 9 Kitchen	Manual	8/5/2025 10:05:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 071	Rooms 8-11 Bldg Rooms 8 9 Strg	Manual	8/5/2025 6:23:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-128 166	Pool Building Pool Room	Manual	8/5/2025 8:39:30 AM
Heat Detector - Restorable Spot	2-128 165	Pool Building Pool Room	Manual	8/5/2025 8:39:38 AM
Smoke Detector - General	2-038 143	South Portable Closet	Manual	8/5/2025 8:12:27 AM
Smoke Detector - General	2-029 144	South Portable Closet	Manual	8/5/2025 8:12:30 AM
	Comment:	Under construction		
Smoke Detector - General	2-039 145	South Portable Laundry	Manual	8/5/2025 8:12:46 AM
	Comment:	Under construction		
Heat Detector - Restorable Spot	2-028 146	South Portable Main Room	Manual	8/5/2025 8:13:07 AM
	Comment:	Under construction		
Smoke Detector - General	2-073 141	South Portable Office	Manual	8/5/2025 8:12:53 AM
	Comment:	Under construction		
Smoke Detector - General	2-074 142	South Portable Restroom	Manual	8/5/2025 8:13:01 AM
	Comment:	Under construction		

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-145 151	Pool Building Northwest Exit	Manual	8/5/2025 8:44:41 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
012	Admin Building Reception				
013	Admin Building Nurses Office				
014	Admin Building Nurses Office				
015	Admin Building Nurses Restroom				
016	Admin Building Secretary Office				
017	Admin Building Principals Office				
042	Rooms 1-4 Bldg Room 1				
043	Rooms 1-4 Bldg Room 2				
044	Rooms 1-4 Bldg Room 3				
045	Rooms 1-4 Bldg Room 4				
046	Rooms 1-4 Bldg Rooms 1 2 RR				
047	Rooms 1-4 Bldg Rooms 1 2 Kitchen				
048	Rooms 1-4 Bldg Rooms 3 4 RR				
049	Rooms 1-4 Bldg Rooms 3 4 Kitchen				
062	Rooms 5-7 Bldg Room 5				
063	Rooms 5-7 Bldg Room 6				
064	Rooms 5-7 Bldg Room 7				
088	Rooms 8-11 Bldg Room 8				
089	Rooms 8-11 Bldg Room 9				
090	Rooms 8-11 Bldg Room 10				
091	Rooms 8-11 Bldg Room 11				
092	Rooms 8-11 Bldg Rooms 8 9 Kitchen				
093	Rooms 8-11 Bldg Rooms 10 11 RR				
126	Multi-Purpose Bldg Girls Restroom				
127	Multi-Purpose Bldg Boys Restroom				
128	Multi-Purpose Bldg MP Room				
129	Multi-Purpose Bldg MP Room				
130	Multi-Purpose Bldg Kitchen				
131	Multi-Purpose Bldg Kitchen				
132	Multi-Purpose Bldg Staff Break Room				
133	Multi-Purpose Bldg Girls Restroom				
134	Multi-Purpose Bldg Girls Restroom				
135	Multi-Purpose Bldg Boys Restroom				
136	Multi-Purpose Bldg Boys Restroom				
137	Multi-Purpose Bldg Kitchen				
138	Multi-Purpose Bldg Staff Break Room				
139	Multi-Purpose Bldg Staff Womens RR				
140	Multi-Purpose Bldg Staff Mens Restroom				
147	South Portable Main Room				
148	South Portable Restroom				
169	Pool Building Pool Room				
170	Pool Building Pool Room				
171	Pool Building Pool Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
172	Pool Building Pool Room				
173	Pool Building Pool Room				
174	Pool Building Pool Room				
175	Pool Building Pool Room				
Audible					
040	Rooms 1-4 Bldg South Exterior				
041	Rooms 1-4 Bldg West Exterior				
125	Multi-Purpose Bldg Northeast Exterior				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Reception				
NAC Power Extender Panel					
	Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "Master"				
	Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "B"				
	Rooms 1-4 Bldg Rooms 3 4 RR Storage - P.E. "C"				
Fire Alarm Panel					
	Rooms 1-4 Bldg Rooms 3 4 RR Storage				
	Rooms 1-4 Bldg Rooms 3 4 RR Storage - Voice/EVAC Panel	Fire-Lite		Fire Command 25/50X	

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-126 002	Admin Building Reception				
2-142 094	Multi-Purpose Bldg MP Room				
2-143 149	Pool Building Southwest Exit				
2-144 150	Pool Building East Exit				
2-145 151	Pool Building Northwest Exit				
Smoke Detector - General					
2-033 003	Admin Building Reception				
2-030 004	Admin Building Nurses Office				
2-031 005	Admin Building Nurses Restroom				
2-032 006	Admin Building Storage Workroom				
2-035 007	Admin Building Office Storage				
2-037 008	Admin Building Conference Room				
2-036 009	Admin Building Principals Office				
2-034 010	Admin Building Secretary Office				
2-025 018	Rooms 1-4 Bldg Room 1				
2-024 019	Rooms 1-4 Bldg Room 1				
2-027 020	Rooms 1-4 Bldg Room 1 Interior Strg				
2-026 021	Rooms 1-4 Bldg Room 1 Exterior Strg				
2-017 022	Rooms 1-4 Bldg Rooms 1 2 RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-022 023	Rooms 1-4 Bldg Rooms 1 2 RR Strg				
2-016 025	Rooms 1-4 Bldg Room 2				
2-015 026	Rooms 1-4 Bldg Room 2				
2-013 027	Rooms 1-4 Bldg Room 2 Closet				
2-011 028	Rooms 1-4 Bldg Room 3				
2-012 029	Rooms 1-4 Bldg Room 3				
2-014 030	Rooms 1-4 Bldg Room 3 Closet				
2-006 031	Rooms 1-4 Bldg Rooms 3 4 RR				
2-001 032	Rooms 1-4 Bldg Rooms 3 4 RR Storage				
2-005 034	Rooms 1-4 Bldg Room 4				
2-004 035	Rooms 1-4 Bldg Room 4				
2-002 036	Rooms 1-4 Bldg Room 4 Interior Strg				
2-003 037	Rooms 1-4 Bldg Room 4 Exterior Strg				
2-071 050	Rooms 5-7 Bldg Room 5				
2-070 051	Rooms 5-7 Bldg Room 5				
2-069 052	Rooms 5-7 Bldg Room 5 Interior Strg				
2-072 053	Rooms 5-7 Bldg Room 5 Exterior Strg				
2-067 054	Rooms 5-7 Bldg Room 6				
2-066 055	Rooms 5-7 Bldg Room 6				
2-068 056	Rooms 5-7 Bldg Room 6 Storage				
2-065 057	Rooms 5-7 Bldg Room 6 Storage				
2-063 058	Rooms 5-7 Bldg Room 7				
2-062 059	Rooms 5-7 Bldg Room 7				
2-064 060	Rooms 5-7 Bldg Room 7 Interior Strg				
2-061 061	Rooms 5-7 Bldg Room 7 Exterior Strg				
2-057 065	Rooms 8-11 Bldg Room 8				
2-058 066	Rooms 8-11 Bldg Room 8				
2-060 067	Rooms 8-11 Bldg Room 8 Interior Storage				
2-059 068	Rooms 8-11 Bldg Room 8 Exterior Storage				
2-056 071	Rooms 8-11 Bldg Rooms 8 9 Strg				
2-053 072	Rooms 8-11 Bldg Room 9				
2-052 073	Rooms 8-11 Bldg Room 9				
2-050 074	Rooms 8-11 Bldg Room 9 Storage				
2-049 075	Rooms 8-11 Bldg Room 10				
2-048 076	Rooms 8-11 Bldg Room 10				
2-051 077	Rooms 8-11 Bldg Room 10 Storage				
2-045 078	Rooms 8-11 Bldg Rms 10 11 Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-046 079	Rooms 8-11 Bldg Rms 10 11 Office				
2-047 080	Rooms 8-11 Bldg Rms 10 11 Off Strg				
2-044 081	Rooms 8-11 Bldg Rooms 10 11 RR				
2-043 082	Rooms 8-11 Bldg Room 11				
2-042 083	Rooms 8-11 Bldg Room 11				
2-041 084	Rooms 8-11 Bldg Room 11 Interior Storage				
2-040 085	Rooms 8-11 Bldg Room 11 Exterior Storage				
2-100 095	Multi-Purpose Bldg Girls Restroom				
2-104 096	Multi-Purpose Bldg Girls Restroom				
2-101 098	Multi-Purpose Bldg Boys Restroom				
2-099 099	Multi-Purpose Bldg Boys Restroom				
2-098 101	Multi-Purpose Bldg Custodian Office				
2-097 102	Multi-Purpose Bldg MP Room Storage				
2-091 103	Multi-Purpose Bldg MP Room				
2-105 104	Multi-Purpose Bldg MP Room				
2-096 105	Multi-Purpose Bldg MP Room				
2-095 106	Multi-Purpose Bldg MP Room				
2-094 107	Multi-Purpose Bldg MP Room				
2-093 108	Multi-Purpose Bldg MP Room				
2-107 109	Multi-Purpose Bldg MP Room				
2-092 110	Multi-Purpose Bldg MP Room				
2-108 111	Multi-Purpose Bldg MP Room				
2-089 112	Multi-Purpose Bldg MP Room				
2-106 113	Multi-Purpose Bldg MP Room				
2-090 114	Multi-Purpose Bldg MP Room				
2-088 117	Multi-Purpose Bldg Kitchen Food Storage				
2-080 118	Multi-Purpose Bldg Staff Break Room				
2-082 119	Multi-Purpose Bldg Staff Womens RR				
2-083 120	Multi-Purpose Bldg Staff Mens Restroom				
2-085 122	Multi-Purpose Bldg Custodian Closet				
2-073 141	South Portable Office				
2-074 142	South Portable Restroom				
2-038 143	South Portable Closet				
2-029 144	South Portable Closet				
2-039 145	South Portable Laundry				
2-104	Multi-Purpose Bldg MP Room				12/13/2018
Heat Detector - Restorable Spot					
2-023 024	Rooms 1-4 Bldg Rooms 1 2 Kitchen				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-010 033	Rooms 1-4 Bldg Rooms 3 4 Kitchen				
2-054 069	Rooms 8-11 Bldg Rooms 8 9 Kitchen				
2-055 070	Rooms 8-11 Bldg Rooms 8 9 Kitchen				
2-103 097	Multi-Purpose Bldg Girls Restroom				
2-102 100	Multi-Purpose Bldg Boys Restroom				
2-086 115	Multi-Purpose Bldg Kitchen Entrance				
2-087 116	Multi-Purpose Bldg Kitchen				
2-081 121	Multi-Purpose Bldg Electrical Room				
2-028 146	South Portable Main Room				
2-128 152	Pool Building Pool Room				
2-128 153	Pool Building Pool Room				
2-128 154	Pool Building Pool Room				
2-128 155	Pool Building Pool Room				
2-128 156	Pool Building Pool Room				
2-128 157	Pool Building Pool Room				
2-128 158	Pool Building Pool Room				
2-128 159	Pool Building Pool Room				
2-128 160	Pool Building Pool Room				
2-128 161	Pool Building Pool Room				
2-128 162	Pool Building Pool Room				
2-128 163	Pool Building Pool Room				
2-128 164	Pool Building Pool Room				
2-128 165	Pool Building Pool Room				
2-128 166	Pool Building Pool Room				
2-128 167	Pool Building Southwest Storage				
2-128 168	Pool Building Chemical Storage				
Smoke Detector - Duct					
2-136 038	Rooms 1-4 Bldg Attic Rooms 1 2 RR				
2-133 039	Rooms 1-4 Bldg Attic Rooms 3 4 RR				
2-138 086	Rooms 8-11 Bldg Rooms 8 9 Kitchen				
2-139 087	Rooms 8-11 Bldg Rms 10 11 Office				
2-135 123	Multi-Purpose Bldg MP Room Storage				
2-134 124	Multi-Purpose Bldg Kitchen				
Heat Detector - Restorable Line					
2.127	Electric Room				12/13/2018