

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

ORANGE GROVE ADULT ED

4640 ORANGE GROVE AVE
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Friday, August 15, 2025

Test Session :13 Aug 2025 06:33 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	ORANGE GROVE ADULT ED	CONTACT
ADDRESS	4640 ORANGE GROVE AVE	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	44	44(100%)	43(98%)	1(2%)
Supervising Station Transmitting Equipment	1	1(100%)	1(100%)	0(0%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	128	125(98%)	125(98%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Friday, August 15, 2025

ACCEPTED BY 08/15/2025

Building Representative


TESTED BY 08/15/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Building C Room C1 Headend
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Monitoring Information

Building C Room C1 Headend			
TYPE	Digital Alarm Communicator Transmitter	INSTALL DATE	
MANUFACTURER	Bosch	TEST START	08/13/2025
MODEL	B9512G	TEST COMPLETE	08/15/2025
SERIAL NUMBER		Time to Transmit to Supervising Station	
MONITORING ORGANIZATION	Central Station / SJUSD Dispatch	ALARM SIGNAL	
MONITORING ORGANIZATION PHONE	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	ALARM RESTORE	
MONITORING ORGANIZATION EMAIL		TROUBLE SIGNAL	
MONITORING ORGANIZATION ACCOUNT NUMBER	Central Station # 881-8021	TROUBLE RESTORE	
MONITORING PHONE LINE 1		SUPERVISORY SIGNAL	
MONITORING PHONE LINE 2		SUPERVISORY RESTORE	
MONITORING RETRANSMISSION ENTITY			

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Audible And Visible	103	Building E Classroom E1
	Created By:	Riley Goyet
	Creation Date:	08/13/2025
	Corrective Action:	Does not work
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Building C Room C1 Headend
	Created By:	Riley Goyet
	Creation Date:	08/13/2025
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
NAC Power Extender Panel		Building D Classroom D4 - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	08/13/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	028	Building A Kitchen	Manual	8/13/2025 6:33:49 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	019	Building A Office A1	Manual	8/13/2025 6:34:12 AM
		Visual inspection	Passed (Manual)	
Visible	023	Building A Office A1A	Manual	8/13/2025 6:33:57 AM
		Functional Inspection	Passed	
Visible	024	Building A Office A2	Manual	8/13/2025 6:33:55 AM
		Visual inspection	Passed (Manual)	
Visible	025	Building A Office A2A	Manual	8/13/2025 6:33:54 AM
		Functional Inspection	Passed	
Visible	026	Building A Office A2B Restroom	Manual	8/13/2025 6:33:52 AM
		Visual inspection	Passed (Manual)	
Visible	027	Building A Restroom A5A	Manual	8/13/2025 6:33:51 AM
		Functional Inspection	Passed	
Audible And Visible	022	Building A Room A5	Manual	8/13/2025 6:34:08 AM
		Visual inspection	Passed (Manual)	
Audible	018	Building A South Exterior	Manual	8/13/2025 6:34:42 AM
		Functional Inspection	Passed	
Audible And Visible	020	Building A Teach Lounge A3	Manual	8/13/2025 6:34:11 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	021	Building A Work Room A4	Manual	8/13/2025 6:34:09 AM
		Functional Inspection	Passed	
Audible And Visible	056	Building B Kitchen	Manual	8/13/2025 6:34:37 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	055	Building B MP Room B3	Manual	8/13/2025 6:34:39 AM
		Functional Inspection	Passed	
Audible And Visible	054	Building B MP Room B3	Manual	8/13/2025 6:34:40 AM
		Visual inspection	Passed (Manual)	
Audible	052	Building B North Exterior	Manual	8/13/2025 6:34:56 AM
		Functional Inspection	Passed	
Audible	053	Building B West Exterior	Manual	8/13/2025 6:34:54 AM
		Visual inspection	Passed (Manual)	
Audible	062	Building C East Exterior	Manual	8/13/2025 6:34:52 AM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	063	Building C Staff RR C2	Manual	8/13/2025 6:34:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	064	Building C Unisex RR C3	Manual	8/13/2025 6:34:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	095	Building D Boys Restroom D5	Manual	8/13/2025 6:34:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	091	Building D Classroom D1	Manual	8/13/2025 6:34:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	092	Building D Classroom D2	Manual	8/13/2025 6:34:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	093	Building D Classroom D3	Manual	8/13/2025 6:34:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	094	Building D Classroom D4	Manual	8/13/2025 6:34:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	096	Building D Girls Restroom D7	Manual	8/13/2025 6:34:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	089	Building D North Exterior	Manual	8/13/2025 6:34:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	090	Building D West Exterior	Manual	8/13/2025 6:34:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	104	Building E Classroom E2	Manual	8/13/2025 6:34:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	126	Building F Classroom F1	Manual	8/13/2025 6:34:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	127	Building F Classroom F2	Manual	8/13/2025 6:34:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	128	Building F Classroom F3	Manual	8/13/2025 6:34:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	129	Building F Classroom F4	Manual	8/13/2025 6:34:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	125	Building F North Exterior	Manual	8/13/2025 6:34:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	160	Building G Boys Restroom G5	Manual	8/13/2025 6:34:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	156	Building G Classroom G1	Manual	8/13/2025 6:34:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	157	Building G Classroom G2	Manual	8/13/2025 6:34:19 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	158	Building G Classroom G3	Manual	8/13/2025 6:34:17 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	159	Building G Classroom G4	Manual	8/13/2025 6:34:15 AM
		Visual inspection	Passed (Manual)	
Visible	161	Building G Girls Restroom G7	Manual	8/13/2025 6:33:58 AM
		Visual inspection	Passed (Manual)	
Audible	154	Building G North Exterior	Manual	8/13/2025 6:34:46 AM
		Visual inspection	Passed (Manual)	
Audible	155	Building G South Exterior	Manual	8/13/2025 6:34:45 AM
		Visual inspection	Passed (Manual)	
Audible	171	Building K East Exterior	Manual	8/13/2025 6:34:43 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	172	Building K Room K1	Manual	8/13/2025 6:34:14 AM
		Visual inspection	Passed (Manual)	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	103	Building E Classroom E1	Manual	8/13/2025 8:29:06 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A Office A1 Reception	Manual	8/13/2025 8:08:19 AM
		Visual inspection	Passed (Manual)	
Fire Alarm Panel		Building C Room C1 Headend	Manual	8/13/2025 8:12:24 AM
		Manufacturer	EST	
		Model	3	
NAC Power Extender Panel		Building C Room C1 Headend - P.E. "B"	Manual	8/13/2025 8:13:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building C Room C1 Headend - P.E. "Master"	Manual	8/13/2025 8:13:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Classroom D4 - P.E. "C"	Manual	8/13/2025 8:19:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building G Classroom G4 - P.E. "D"	Manual	8/13/2025 8:21:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-018 016	Building A Kitchen	Manual	8/13/2025 7:49:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-130 002	Building A Office A1 Reception	Manual	8/13/2025 8:09:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-011 003	Building A Office A1 Reception	Manual	8/13/2025 8:09:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-009 004	Building A Office A1A	Manual	8/13/2025 8:10:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-010 005	Building A Office A1A Closet	Manual	8/13/2025 8:14:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-012 006	Building A Office A2	Manual	8/13/2025 8:10:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-013 007	Building A Office A2A	Manual	8/13/2025 8:10:31 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-014 008	Building A Office A2B Restroom	Manual	8/13/2025 8:11:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-017 015	Building A Restroom A5A	Manual	8/13/2025 8:14:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-022 014	Building A Room A5	Manual	8/13/2025 8:14:16 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-021 011	Building A Room A5	Manual	8/13/2025 8:14:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-020 013	Building A Room A5	Manual	8/13/2025 8:14:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-019 012	Building A Room A5	Manual	8/13/2025 8:14:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 017	Building A Room A5 Light Well	Manual	8/13/2025 7:42:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-015 009	Building A Teach Lounge A3	Manual	8/13/2025 8:11:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-016 010	Building A Work Room A4	Manual	8/13/2025 8:11:46 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-039 047	Building B Boiler Room B1	Manual	8/13/2025 8:10:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 050	Building B Cust Office Shed	Manual	8/13/2025 8:10:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-036 051	Building B Kitchen B2	Manual	8/13/2025 8:13:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-145 033	Building B Kitchen East Exit	Manual	8/13/2025 7:53:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-144 032	Building B Kitchen South Exit	Manual	8/13/2025 7:53:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 035	Building B MP Room B3	Manual	8/13/2025 7:00:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 036	Building B MP Room B3	Manual	8/13/2025 7:01:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 037	Building B MP Room B3	Manual	8/13/2025 7:02:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 045	Building B MP Room B3	Manual	8/13/2025 7:02:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 042	Building B MP Room B3	Manual	8/13/2025 7:08:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 043	Building B MP Room B3	Manual	8/13/2025 7:08:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 044	Building B MP Room B3	Manual	8/13/2025 7:09:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 038	Building B MP Room B3	Manual	8/13/2025 7:09:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 039	Building B MP Room B3	Manual	8/13/2025 7:10:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 040	Building B MP Room B3	Manual	8/13/2025 7:11:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 041	Building B MP Room B3	Manual	8/13/2025 7:11:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-025 034	Building B MP Room B3	Manual	8/13/2025 8:10:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 048	Building B MP Storage B3A	Manual	8/13/2025 7:14:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-146 030	Building B North Exit	Manual	8/13/2025 7:55:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-147 031	Building B South Exit	Manual	8/13/2025 7:54:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-148 029	Building B West Exit	Manual	8/13/2025 7:55:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 060	Building C Custodial C4	Manual	8/13/2025 8:14:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 061	Building C Room C1 Headend	Manual	8/13/2025 8:13:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 057	Building C Room C1 Headend	Manual	8/13/2025 8:14:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 058	Building C Staff RR C2	Manual	8/13/2025 8:14:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 059	Building C Unisex RR C3	Manual	8/13/2025 8:14:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 081	Building D Boys Restroom D5	Manual	8/13/2025 8:09:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 066	Building D Classroom D1	Manual	8/13/2025 7:18:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 067	Building D Classroom D1	Manual	8/13/2025 7:19:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 068	Building D Classroom D1	Manual	8/13/2025 7:20:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 065	Building D Classroom D1	Manual	8/13/2025 8:11:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 072	Building D Classroom D2	Manual	8/13/2025 7:23:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-055 071	Building D Classroom D2	Manual	8/13/2025 7:23:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 070	Building D Classroom D2	Manual	8/13/2025 8:11:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 069	Building D Classroom D2	Manual	8/13/2025 8:11:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 075	Building D Classroom D3	Manual	8/13/2025 7:27:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 076	Building D Classroom D3	Manual	8/13/2025 7:29:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 073	Building D Classroom D3	Manual	8/13/2025 7:29:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 074	Building D Classroom D3	Manual	8/13/2025 7:30:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 077	Building D Classroom D4	Manual	8/13/2025 7:31:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 080	Building D Classroom D4	Manual	8/13/2025 7:32:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 079	Building D Classroom D4	Manual	8/13/2025 8:11:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 078	Building D Classroom D4	Manual	8/13/2025 8:11:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-044 083	Building D Custodial Room D6	Manual	8/13/2025 7:49:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 082	Building D Girls Restroom D7	Manual	8/13/2025 7:35:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 085	Building D Room D1 Light Well	Manual	8/13/2025 7:06:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 086	Building D Room D2 Light Well	Manual	8/13/2025 7:04:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 087	Building D Room D3 Light Well	Manual	8/13/2025 7:02:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-133 088	Building D Room D4 Light Well	Manual	8/13/2025 7:00:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 101	Building E Attic Room E1	Manual	8/13/2025 7:09:45 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 102	Building E Attic Room E2	Manual	8/13/2025 7:09:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-082 097	Building E Classroom E1	Manual	8/13/2025 7:59:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-083 098	Building E Classroom E1	Manual	8/13/2025 7:59:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-081 099	Building E Classroom E2	Manual	8/13/2025 7:58:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-080 100	Building E Classroom E2	Manual	8/13/2025 7:58:32 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-075 108	Building F Classroom F1	Manual	8/13/2025 7:54:01 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-076 107	Building F Classroom F1	Manual	8/13/2025 7:55:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-078 106	Building F Classroom F1	Manual	8/13/2025 7:58:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-077 105	Building F Classroom F1	Manual	8/13/2025 7:58:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-073 112	Building F Classroom F2	Manual	8/13/2025 7:50:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-071 111	Building F Classroom F2	Manual	8/13/2025 7:52:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-072 109	Building F Classroom F2	Manual	8/13/2025 8:17:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-074 110	Building F Classroom F2	Manual	8/13/2025 8:17:50 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-068 115	Building F Classroom F3	Manual	8/13/2025 7:46:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-070 114	Building F Classroom F3	Manual	8/13/2025 7:47:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 113	Building F Classroom F3	Manual	8/13/2025 8:17:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 116	Building F Classroom F3	Manual	8/13/2025 8:17:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-064 120	Building F Classroom F4	Manual	8/13/2025 7:49:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 117	Building F Classroom F4	Manual	8/13/2025 7:41:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 118	Building F Classroom F4	Manual	8/13/2025 7:43:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 119	Building F Classroom F4	Manual	8/13/2025 7:44:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 121	Building F Room F1 Light Well	Manual	8/13/2025 7:19:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 122	Building F Room F2 Light Well	Manual	8/13/2025 7:20:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 123	Building F Room F3 Light Well	Manual	8/13/2025 7:22:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 124	Building F Room F4 Light Well	Manual	8/13/2025 7:23:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 146	Building G Boys Restroom G5	Manual	8/13/2025 8:08:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 131	Building G Classroom G1	Manual	8/13/2025 8:03:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 133	Building G Classroom G1	Manual	8/13/2025 8:04:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 132	Building G Classroom G1	Manual	8/13/2025 8:06:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 130	Building G Classroom G1	Manual	8/13/2025 8:08:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-264 137	Building G Classroom G2	Manual	8/13/2025 8:05:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 134	Building G Classroom G2	Manual	8/13/2025 8:05:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 136	Building G Classroom G2	Manual	8/13/2025 8:05:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 135	Building G Classroom G2	Manual	8/13/2025 8:06:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 138	Building G Classroom G3	Manual	8/13/2025 8:03:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 139	Building G Classroom G3	Manual	8/13/2025 8:03:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 140	Building G Classroom G3	Manual	8/13/2025 8:04:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 141	Building G Classroom G3	Manual	8/13/2025 8:04:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 142	Building G Classroom G4	Manual	8/13/2025 8:01:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 143	Building G Classroom G4	Manual	8/13/2025 8:02:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 144	Building G Classroom G4	Manual	8/13/2025 8:02:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 145	Building G Classroom G4	Manual	8/13/2025 8:02:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 147	Building G Custodial Room G6	Manual	8/13/2025 8:00:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 148	Building G Girls Restroom G7	Manual	8/13/2025 8:01:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 150	Building G Room G1 Light Well	Manual	8/13/2025 7:36:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 151	Building G Room G2 Light Well	Manual	8/13/2025 7:34:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-377 152	Building G Room G3 Light Well	Manual	8/13/2025 7:32:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 153	Building G Room G4 Light Well	Manual	8/13/2025 7:30:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-245 164	Building J - Storage Attic Heat	Manual	8/13/2025 7:48:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-245 163	Building J - Storage Attic Heat	Manual	8/13/2025 7:48:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-245 162	Building J - Storage Attic Heat	Manual	8/13/2025 7:48:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 165	Building K Room K1	Manual	8/13/2025 7:38:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 166	Building K Room K1	Manual	8/13/2025 7:38:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 167	Building K Room K1	Manual	8/13/2025 7:39:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 168	Building K Room K1	Manual	8/13/2025 7:40:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 170	Building K Room K1 Attic	Manual	8/13/2025 7:27:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142	Building K Room K1 Attic	Manual	8/13/2025 7:27:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 169	Building K Room K1A Office	Manual	8/13/2025 7:40:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 173	Misc Buildings Guard Shed	Manual	8/13/2025 8:10:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-037 049	Building B Kitchen Storage B2A	Manual	8/13/2025 8:10:39 AM
Heat Detector - Restorable Spot	2-043 084	Building D RR Chase Cust D6	Manual	8/13/2025 7:48:10 AM
Heat Detector - Restorable Spot	2-253 149	Building G RR Chase Cust G6	Manual	8/13/2025 7:48:13 AM

Supervising Station Transmitting Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
----------------	---------	-------------	--------	-----------

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Digital Alarm Communicator Transmitter		Building C Room C1 Headend	Manual	8/13/2025 8:13:47 AM
		Manufacturer	Bosch	
		Model	B9512G	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	Central Station # 881-8021	
		Monitoring Organization	Central Station / SJUSD Dispatch	
		Monitoring Organization Phone	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
052	Building B North Exterior				
053	Building B West Exterior				
062	Building C East Exterior				
089	Building D North Exterior				
090	Building D West Exterior				
125	Building F North Exterior				
154	Building G North Exterior				
155	Building G South Exterior				
171	Building K East Exterior				
018	Building A South Exterior				
Audible And Visible					
054	Building B MP Room B3				
055	Building B MP Room B3				
056	Building B Kitchen				
091	Building D Classroom D1				
092	Building D Classroom D2				
093	Building D Classroom D3				
094	Building D Classroom D4				
103	Building E Classroom E1				
104	Building E Classroom E2				
126	Building F Classroom F1				
127	Building F Classroom F2				
128	Building F Classroom F3				
129	Building F Classroom F4				
156	Building G Classroom G1				
157	Building G Classroom G2				
158	Building G Classroom G3				
159	Building G Classroom G4				
172	Building K Room K1				
019	Building A Office A1				
020	Building A Teach Lounge A3				
021	Building A Work Room A4				
022	Building A Room A5				
Visible					
063	Building C Staff RR C2				
064	Building C Unisex RR C3				
095	Building D Boys Restroom D5				
096	Building D Girls Restroom D7				
160	Building G Boys Restroom G5				
161	Building G Girls Restroom G7				
023	Building A Office A1A				
024	Building A Office A2				
025	Building A Office A2A				
026	Building A Office A2B Restroom				
027	Building A Restroom A5A				
028	Building A Kitchen				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Remote Annunciator			
001	Building A Office A1 Reception		
Fire Alarm Panel			
	Building C Room C1 Headend	EST	3
NAC Power Extender Panel			
	Building C Room C1 Headend - P.E. "Master"		
	Building C Room C1 Headend - P.E. "B"		
	Building D Classroom D4 - P.E. "C"		
	Building G Classroom G4 - P.E. "D"		

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Heat Detector - Restorable Spot					
2-036 051	Building B Kitchen B2				
2-003 061	Building C Room C1 Headend				
2-044 083	Building D Custodial Room D6				
2-043 084	Building D RR Chase Cust D6				
2-136 085	Building D Room D1 Light Well				
2-135 086	Building D Room D2 Light Well				
2-134 087	Building D Room D3 Light Well				
2-133 088	Building D Room D4 Light Well				
2-141 101	Building E Attic Room E1				
2-141 102	Building E Attic Room E2				
2-064 120	Building F Classroom F4				
2-140 121	Building F Room F1 Light Well				
2-139 122	Building F Room F2 Light Well				
2-138 123	Building F Room F3 Light Well				
2-137 124	Building F Room F4 Light Well				
2-253 149	Building G RR Chase Cust G6				
2-379 150	Building G Room G1 Light Well				
2-378 151	Building G Room G2 Light Well				
2-377 152	Building G Room G3 Light Well				
2-376 153	Building G Room G4 Light Well				
2-245 162	Building J - Storage Attic Heat				
2-245 163	Building J - Storage Attic Heat				
2-245 164	Building J - Storage Attic Heat				
2-142 170	Building K Room K1 Attic				
2-018 016	Building A Kitchen				
2-132 017	Building A Room A5 Light Well				
2-142	Building K Room K1 Attic				
Smoke Detector - General					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-002 057	Building C Room C1 Headend				
2-005 058	Building C Staff RR C2				
2-006 059	Building C Unisex RR C3				
2-007 060	Building C Custodial C4				
2-060 065	Building D Classroom D1				
2-061 066	Building D Classroom D1				
2-059 067	Building D Classroom D1				
2-058 068	Building D Classroom D1				
2-056 069	Building D Classroom D2				
2-057 070	Building D Classroom D2				
2-055 071	Building D Classroom D2				
2-054 072	Building D Classroom D2				
2-052 073	Building D Classroom D3				
2-053 074	Building D Classroom D3				
2-051 075	Building D Classroom D3				
2-050 076	Building D Classroom D3				
2-048 077	Building D Classroom D4				
2-049 078	Building D Classroom D4				
2-047 079	Building D Classroom D4				
2-046 080	Building D Classroom D4				
2-042 081	Building D Boys Restroom D5				
2-045 082	Building D Girls Restroom D7				
2-082 097	Building E Classroom E1				
2-083 098	Building E Classroom E1				
2-081 099	Building E Classroom E2				
2-080 100	Building E Classroom E2				
2-077 105	Building F Classroom F1				
2-078 106	Building F Classroom F1				
2-076 107	Building F Classroom F1				
2-075 108	Building F Classroom F1				
2-072 109	Building F Classroom F2				
2-074 110	Building F Classroom F2				
2-071 111	Building F Classroom F2				
2-073 112	Building F Classroom F2				
2-069 113	Building F Classroom F3				
2-070 114	Building F Classroom F3				
2-068 115	Building F Classroom F3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-067 116	Building F Classroom F3				
2-065 117	Building F Classroom F4				
2-066 118	Building F Classroom F4				
2-063 119	Building F Classroom F4				
2-270 130	Building G Classroom G1				
2-271 131	Building G Classroom G1				
2-268 132	Building G Classroom G1				
2-269 133	Building G Classroom G1				
2-266 134	Building G Classroom G2				
2-267 135	Building G Classroom G2				
2-265 136	Building G Classroom G2				
2-264 137	Building G Classroom G2				
2-262 138	Building G Classroom G3				
2-263 139	Building G Classroom G3				
2-261 140	Building G Classroom G3				
2-260 141	Building G Classroom G3				
2-258 142	Building G Classroom G4				
2-259 143	Building G Classroom G4				
2-257 144	Building G Classroom G4				
2-256 145	Building G Classroom G4				
2-252 146	Building G Boys Restroom G5				
2-254 147	Building G Custodial Room G6				
2-255 148	Building G Girls Restroom G7				
2-088 165	Building K Room K1				
2-089 166	Building K Room K1				
2-086 167	Building K Room K1				
2-087 168	Building K Room K1				
2-085 169	Building K Room K1A Office				
2-004 173	Misc Buildings Guard Shed				
2-011 003	Building A Office A1 Reception				
2-009 004	Building A Office A1A				
2-010 005	Building A Office A1A Closet				
2-012 006	Building A Office A2				
2-013 007	Building A Office A2A				
2-014 008	Building A Office A2B Restroom				
2-015 009	Building A Teach Lounge A3				
2-016 010	Building A Work Room A4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-021 011	Building A Room A5				
2-019 012	Building A Room A5				
2-020 013	Building A Room A5				
2-022 014	Building A Room A5				
2-017 015	Building A Restroom A5A				
2-025 034	Building B MP Room B3				
2-028 035	Building B MP Room B3				
2-031 036	Building B MP Room B3				
2-034 037	Building B MP Room B3				
2-035 038	Building B MP Room B3				
2-032 039	Building B MP Room B3				
2-029 040	Building B MP Room B3				
2-026 041	Building B MP Room B3				
2-024 042	Building B MP Room B3				
2-027 043	Building B MP Room B3				
2-030 044	Building B MP Room B3				
2-033 045	Building B MP Room B3				
2-039 047	Building B Boiler Room B1				
2-038 048	Building B MP Storage B3A				
2-037 049	Building B Kitchen Storage B2A				
2-091 050	Building B Cust Office Shed				
Manual Pull Station					
2-130 002	Building A Office A1 Reception				
2-148 029	Building B West Exit				
2-146 030	Building B North Exit				
2-147 031	Building B South Exit				
2-144 032	Building B Kitchen South Exit				
2-145 033	Building B Kitchen East Exit				
Supervising Station Transmitting Equipment					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Digital Alarm Communicator Transmitter					
	Building C Room C1 Headend	Bosch	B9512G		