

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

POCK CHARLES ELEMENTARY

6230 RUTLAND DR
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Friday, August 15, 2025

Test Session :13 Aug 2025 08:29 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	POCK CHARLES ELEMENTARY	CONTACT
ADDRESS	6230 RUTLAND DR	PHONE
CITY/STATE/ZIP	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	78	78(100%)	78(100%)	0(0%)
Fire Control Panel	7	7(100%)	7(100%)	0(0%)
Initiating Device	195	191(98%)	191(98%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Friday, August 15, 2025

ACCEPTED BY 08/15/2025

Building Representative


TESTED BY 08/15/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Rooms 1-9 Bldg Admin Electrical Rm
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel		Rooms 1-9 Bldg Admin Electrical Rm - P.E. "Master"
	Created By:	Riley Goyet
	Creation Date:	08/13/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Multi-Purpose Bldg Custodial Office - P.E. "B"
	Created By:	Riley Goyet
	Creation Date:	08/13/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Multi-Purpose Bldg Custodial Office - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	08/13/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	218	Kindergarten Bldg East Exterior	Manual	8/13/2025 9:05:56 AM
		Visual inspection	Passed (Manual)	
Audible	217	Kindergarten Bldg North Exterior	Manual	8/13/2025 9:05:58 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	219	Kindergarten Bldg Room K-A	Manual	8/13/2025 9:06:45 AM
		Functional Inspection	Passed	
Visible	221	Kindergarten Bldg Room K-A Restroom	Manual	8/13/2025 9:05:55 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	220	Kindergarten Bldg Room K-B	Manual	8/13/2025 9:06:44 AM
		Functional Inspection	Passed	
Visible	223	Kindergarten Bldg Room K-B Restroom	Manual	8/13/2025 9:05:52 AM
		Visual inspection	Passed (Manual)	
Visible	222	Kindergarten Bldg Room K-B Restroom	Manual	8/13/2025 9:05:54 AM
		Functional Inspection	Passed	
Audible And Visible	263	Multi-Purpose Bldg Custodial Office	Manual	8/13/2025 9:06:33 AM
		Visual inspection	Passed (Manual)	
Audible	254	Multi-Purpose Bldg East Exterior	Manual	8/13/2025 9:05:50 AM
		Functional Inspection	Passed	
Audible And Visible	260	Multi-Purpose Bldg Kitchen	Manual	8/13/2025 9:06:37 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	259	Multi-Purpose Bldg Kitchen	Manual	8/13/2025 9:06:39 AM
		Functional Inspection	Passed	
Audible And Visible	258	Multi-Purpose Bldg Kitchen Hall	Manual	8/13/2025 9:06:41 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	257	Multi-Purpose Bldg Kitchen Hall	Manual	8/13/2025 9:06:42 AM
		Functional Inspection	Passed	
Visible	265	Multi-Purpose Bldg MP Room	Manual	8/13/2025 9:05:44 AM
		Visual inspection	Passed (Manual)	
Visible	264	Multi-Purpose Bldg MP Room	Manual	8/13/2025 9:05:46 AM
		Functional Inspection	Passed	
Audible And Visible	261	Multi-Purpose Bldg Parent Resource Ctr	Manual	8/13/2025 9:06:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	266	Multi-Purpose Bldg Restroom Entry	Manual	8/13/2025 9:05:43 AM
		Visual inspection	Passed (Manual)	
Visible	268	Multi-Purpose Bldg Staff Restroom	Manual	8/13/2025 9:05:40 AM
		Visual inspection	Passed (Manual)	
Visible	267	Multi-Purpose Bldg Staff Restroom	Manual	8/13/2025 9:05:41 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	262	Multi-Purpose Bldg Stage	Manual	8/13/2025 9:06:34 AM
		Visual inspection	Passed (Manual)	
Visible	272	Multi-Purpose Bldg Stage	Manual	8/13/2025 9:05:33 AM
		Visual inspection	Passed (Manual)	
Visible	271	Multi-Purpose Bldg Stage	Manual	8/13/2025 9:05:35 AM
		Visual inspection	Passed (Manual)	
Visible	273	Multi-Purpose Bldg Stage Stair North	Manual	8/13/2025 9:05:31 AM
		Visual inspection	Passed (Manual)	
Visible	269	Multi-Purpose Bldg Stage Stair South	Manual	8/13/2025 9:05:38 AM
		Visual inspection	Passed (Manual)	
Visible	270	Multi-Purpose Bldg Stage Wheelchr lift	Manual	8/13/2025 9:05:37 AM
		Visual inspection	Passed (Manual)	
Audible	256	Multi-Purpose Bldg West Exterior	Manual	8/13/2025 9:05:48 AM
		Visual inspection	Passed (Manual)	
Audible	255	Multi-Purpose Bldg West Exterior	Manual	8/13/2025 9:05:49 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	198	Portables Classroom 19	Manual	8/13/2025 9:06:54 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	199	Portables Classroom 20	Manual	8/13/2025 9:06:52 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	200	Portables Classroom 21	Manual	8/13/2025 9:06:51 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	201	Portables Classroom 22	Manual	8/13/2025 9:06:50 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	202	Portables Classroom 23	Manual	8/13/2025 9:06:48 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	203	Portables Classroom 24	Manual	8/13/2025 9:06:47 AM
		Visual inspection	Passed (Manual)	
Audible	195	Portables East Exterior	Manual	8/13/2025 9:06:02 AM
		Visual inspection	Passed (Manual)	
Audible	194	Portables North Exterior	Manual	8/13/2025 9:06:04 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	197	Portables South Exterior	Manual	8/13/2025 9:05:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	196	Portables South Exterior	Manual	8/13/2025 9:06:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	160	Rooms 10-18 Bldg Boys RR by Library	Manual	8/13/2025 9:06:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	159	Rooms 10-18 Bldg Boys RR by Room 13	Manual	8/13/2025 9:06:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	149	Rooms 10-18 Bldg Classroom 10	Manual	8/13/2025 9:07:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	150	Rooms 10-18 Bldg Classroom 11	Manual	8/13/2025 9:07:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	151	Rooms 10-18 Bldg Classroom 12	Manual	8/13/2025 9:07:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	152	Rooms 10-18 Bldg Classroom 13	Manual	8/13/2025 9:07:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	153	Rooms 10-18 Bldg Classroom 14	Manual	8/13/2025 9:07:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	154	Rooms 10-18 Bldg Classroom 15	Manual	8/13/2025 9:07:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	155	Rooms 10-18 Bldg Classroom 16	Manual	8/13/2025 9:06:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	156	Rooms 10-18 Bldg Classroom 17	Manual	8/13/2025 9:06:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	157	Rooms 10-18 Bldg Classroom 18	Manual	8/13/2025 9:06:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	145	Rooms 10-18 Bldg East Exterior	Manual	8/13/2025 9:06:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	161	Rooms 10-18 Bldg Girls RR by Library	Manual	8/13/2025 9:06:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	158	Rooms 10-18 Bldg Girls RR by Room 14	Manual	8/13/2025 9:06:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	147	Rooms 10-18 Bldg Library	Manual	8/13/2025 9:07:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	148	Rooms 10-18 Bldg Library Storage	Manual	8/13/2025 9:07:09 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible	144	Rooms 10-18 Bldg North Exterior	Manual	8/13/2025 9:06:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	146	Rooms 10-18 Bldg West Exterior	Manual	8/13/2025 9:06:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	063	Rooms 1-9 Bldg Admin MDF Room	Manual	8/13/2025 9:07:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	078	Rooms 1-9 Bldg Admin Nurses Office	Manual	8/13/2025 9:06:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	076	Rooms 1-9 Bldg Admin Office	Manual	8/13/2025 9:06:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	077	Rooms 1-9 Bldg Admin Principals Off	Manual	8/13/2025 9:06:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	080	Rooms 1-9 Bldg Admin Restroom	Manual	8/13/2025 9:06:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	079	Rooms 1-9 Bldg Admin Storage Room	Manual	8/13/2025 9:06:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	081	Rooms 1-9 Bldg Boys RR by Room 5	Manual	8/13/2025 9:06:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	064	Rooms 1-9 Bldg Classroom 1	Manual	8/13/2025 9:07:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	065	Rooms 1-9 Bldg Classroom 2	Manual	8/13/2025 9:07:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	066	Rooms 1-9 Bldg Classroom 3	Manual	8/13/2025 9:07:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	067	Rooms 1-9 Bldg Classroom 4	Manual	8/13/2025 9:07:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	Rooms 1-9 Bldg Classroom 5	Manual	8/13/2025 9:07:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	069	Rooms 1-9 Bldg Classroom 6	Manual	8/13/2025 9:07:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	070	Rooms 1-9 Bldg Classroom 7	Manual	8/13/2025 9:07:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	Rooms 1-9 Bldg Classroom 8	Manual	8/13/2025 9:07:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	072	Rooms 1-9 Bldg Classroom 9	Manual	8/13/2025 9:07:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	082	Rooms 1-9 Bldg Girls RR by Room 6	Manual	8/13/2025 9:06:17 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	073	Rooms 1-9 Bldg Hall by Classroom 1	Manual	8/13/2025 9:07:16 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	074	Rooms 1-9 Bldg Hall by Classroom 3	Manual	8/13/2025 9:07:13 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	075	Rooms 1-9 Bldg Hall by Classroom 5	Manual	8/13/2025 9:07:12 AM
		Visual inspection	Passed (Manual)	
Audible	060	Rooms 1-9 Bldg North Exterior	Manual	8/13/2025 9:06:31 AM
		Visual inspection	Passed (Manual)	
Audible	061	Rooms 1-9 Bldg South Exterior	Manual	8/13/2025 9:06:29 AM
		Visual inspection	Passed (Manual)	
Audible	062	Rooms 1-9 Bldg West Exterior	Manual	8/13/2025 9:06:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Multi-Purpose Bldg Custodial Office - P.E. "B"	Manual	8/13/2025 11:23:32 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Multi-Purpose Bldg Custodial Office - P.E. "C"	Manual	8/13/2025 11:23:41 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Rooms 10-18 Bldg Storage by Room 10 - P.E. "E"	Manual	8/13/2025 11:23:50 AM
		Visual inspection	Passed (Manual)	
Fire Alarm Panel		Rooms 1-9 Bldg Admin Electrical Rm	Manual	8/13/2025 10:21:30 AM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 1-9 Bldg Admin Electrical Rm - P.E. "F"	Manual	8/13/2025 10:22:28 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Rooms 1-9 Bldg Admin Electrical Rm - P.E. "Master"	Manual	8/13/2025 10:22:26 AM
		Visual inspection	Passed (Manual)	
Remote Annunciator	001	Rooms 1-9 Bldg Admin Office	Manual	8/13/2025 10:21:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-376 215	Kindergarten Bldg HVAC Closet Rm K-A	Manual	8/13/2025 11:07:55 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 216	Kindergarten Bldg HVAC Closet Rm K-B	Manual	8/13/2025 11:07:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 208	Kindergarten Bldg Room K-A	Manual	8/13/2025 10:51:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 209	Kindergarten Bldg Room K-A	Manual	8/13/2025 10:52:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-184 205	Kindergarten Bldg Room K-A East	Manual	8/13/2025 10:39:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-253 212	Kindergarten Bldg Room K-A Restroom	Manual	8/13/2025 10:38:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-185 204	Kindergarten Bldg Room K-A West	Manual	8/13/2025 10:51:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 210	Kindergarten Bldg Room K-B	Manual	8/13/2025 10:47:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 211	Kindergarten Bldg Room K-B	Manual	8/13/2025 10:47:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-186 207	Kindergarten Bldg Room K-B East	Manual	8/13/2025 10:36:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-255 213	Kindergarten Bldg Room K-B Restroom	Manual	8/13/2025 10:37:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-254 214	Kindergarten Bldg Room K-B Restroom	Manual	8/13/2025 10:37:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-187 206	Kindergarten Bldg Room K-B West	Manual	8/13/2025 10:50:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 239	Multi-Purpose Bldg Custodial Office	Manual	8/13/2025 10:55:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-276 250	Multi-Purpose Bldg Kitchen	Manual	8/13/2025 10:25:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-179 229	Multi-Purpose Bldg Kitchen	Manual	8/13/2025 10:27:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 242	Multi-Purpose Bldg Kitchen Hall	Manual	8/13/2025 10:43:46 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-275 243	Multi-Purpose Bldg Kitchen Hall	Manual	8/13/2025 10:44:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-180 227	Multi-Purpose Bldg Kitchen Hall East	Manual	8/13/2025 10:43:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-181 226	Multi-Purpose Bldg Kitchen Hall West	Manual	8/13/2025 10:23:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-279 251	Multi-Purpose Bldg Kitchen Storage	Manual	8/13/2025 10:27:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 231	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:32:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 230	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:33:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 235	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:34:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 236	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:35:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 237	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:36:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 234	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:37:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 232	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:38:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 233	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:39:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 238	Multi-Purpose Bldg MP Room	Manual	8/13/2025 10:39:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-183 225	Multi-Purpose Bldg MP Room North	Manual	8/13/2025 10:42:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-182 224	Multi-Purpose Bldg MP Room West	Manual	8/13/2025 10:41:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-260 252	Multi-Purpose Bldg Outside Storage N	Manual	8/13/2025 11:07:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-273 253	Multi-Purpose Bldg Outside Storage S	Manual	8/13/2025 11:07:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-277 247	Multi-Purpose Bldg Parent Resource Ctr	Manual	8/13/2025 10:25:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-280 248	Multi-Purpose Bldg Restroom Entry	Manual	8/13/2025 10:28:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-278 249	Multi-Purpose Bldg Staff Restroom	Manual	8/13/2025 11:07:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 244	Multi-Purpose Bldg Staff Restroom	Manual	8/13/2025 10:55:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 241	Multi-Purpose Bldg Stage	Manual	8/13/2025 11:00:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 240	Multi-Purpose Bldg Stage	Manual	8/13/2025 11:00:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-259 245	Multi-Purpose Bldg Stage Stair North	Manual	8/13/2025 11:22:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-272 246	Multi-Purpose Bldg Stage Stair South	Manual	8/13/2025 11:22:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 178	Portables Attic Classroom 19	Manual	8/13/2025 9:50:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 179	Portables Attic Classroom 19	Manual	8/13/2025 9:50:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 180	Portables Attic Classroom 19	Manual	8/13/2025 9:50:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 182	Portables Attic Classroom 20	Manual	8/13/2025 9:46:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 183	Portables Attic Classroom 20	Manual	8/13/2025 9:46:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 181	Portables Attic Classroom 20	Manual	8/13/2025 9:46:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 184	Portables Attic Classroom 21	Manual	8/13/2025 9:41:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-377 185	Portables Attic Classroom 21	Manual	8/13/2025 9:41:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 186	Portables Attic Classroom 22	Manual	8/13/2025 9:36:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 187	Portables Attic Classroom 22	Manual	8/13/2025 9:36:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 188	Portables Attic Classroom 23	Manual	8/13/2025 9:34:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 189	Portables Attic Classroom 23	Manual	8/13/2025 9:34:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 190	Portables Attic Classroom 23	Manual	8/13/2025 9:34:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-281 176	Portables Classroom 19	Manual	8/13/2025 11:07:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-161 162	Portables Classroom 19	Manual	8/13/2025 9:47:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-290 177	Portables Classroom 20	Manual	8/13/2025 11:08:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-162 163	Portables Classroom 20	Manual	8/13/2025 9:44:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-163 164	Portables Classroom 21	Manual	8/13/2025 9:42:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 168	Portables Classroom 21	Manual	8/13/2025 10:09:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 169	Portables Classroom 21	Manual	8/13/2025 10:09:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-164 165	Portables Classroom 22	Manual	8/13/2025 9:30:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 170	Portables Classroom 22	Manual	8/13/2025 10:06:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 171	Portables Classroom 22	Manual	8/13/2025 10:07:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-165 166	Portables Classroom 23	Manual	8/13/2025 9:27:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 173	Portables Classroom 23	Manual	8/13/2025 10:04:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 172	Portables Classroom 23	Manual	8/13/2025 10:05:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-166 167	Portables Classroom 24	Manual	8/13/2025 9:26:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 174	Portables Classroom 24	Manual	8/13/2025 10:03:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 175	Portables Classroom 24	Manual	8/13/2025 10:04:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-042 132	Rooms 10-18 Bldg Boys RR by Library	Manual	8/13/2025 9:49:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-052 130	Rooms 10-18 Bldg Boys RR by Room 13	Manual	8/13/2025 10:02:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-045 104	Rooms 10-18 Bldg Classroom 10	Manual	8/13/2025 9:51:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-044 105	Rooms 10-18 Bldg Classroom 10	Manual	8/13/2025 9:52:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-149 085	Rooms 10-18 Bldg Classroom 10	Manual	8/13/2025 9:52:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-047 106	Rooms 10-18 Bldg Classroom 11	Manual	8/13/2025 9:53:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-046 107	Rooms 10-18 Bldg Classroom 11	Manual	8/13/2025 9:54:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-150 086	Rooms 10-18 Bldg Classroom 11	Manual	8/13/2025 9:54:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-049 108	Rooms 10-18 Bldg Classroom 12	Manual	8/13/2025 10:02:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-048 109	Rooms 10-18 Bldg Classroom 12	Manual	8/13/2025 10:02:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-151 087	Rooms 10-18 Bldg Classroom 12	Manual	8/13/2025 10:01:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-051 110	Rooms 10-18 Bldg Classroom 13	Manual	8/13/2025 10:02:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-050 111	Rooms 10-18 Bldg Classroom 13	Manual	8/13/2025 10:02:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-152 088	Rooms 10-18 Bldg Classroom 13	Manual	8/13/2025 10:02:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-067 112	Rooms 10-18 Bldg Classroom 14	Manual	8/13/2025 10:09:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-068 113	Rooms 10-18 Bldg Classroom 14	Manual	8/13/2025 10:09:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-154 090	Rooms 10-18 Bldg Classroom 14	Manual	8/13/2025 10:02:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-065 114	Rooms 10-18 Bldg Classroom 15	Manual	8/13/2025 10:11:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-066 115	Rooms 10-18 Bldg Classroom 15	Manual	8/13/2025 10:12:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-155 091	Rooms 10-18 Bldg Classroom 15	Manual	8/13/2025 10:12:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-063 116	Rooms 10-18 Bldg Classroom 16	Manual	8/13/2025 10:13:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-064 117	Rooms 10-18 Bldg Classroom 16	Manual	8/13/2025 10:13:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-156 092	Rooms 10-18 Bldg Classroom 16	Manual	8/13/2025 10:14:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-061 118	Rooms 10-18 Bldg Classroom 17	Manual	8/13/2025 10:15:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-062 119	Rooms 10-18 Bldg Classroom 17	Manual	8/13/2025 10:16:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157 093	Rooms 10-18 Bldg Classroom 17	Manual	8/13/2025 10:16:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-059 120	Rooms 10-18 Bldg Classroom 18	Manual	8/13/2025 10:19:15 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-060 121	Rooms 10-18 Bldg Classroom 18	Manual	8/13/2025 10:19:25 AM
		Functional Inspection	Passed	
Manual Pull Station	2-158 094	Rooms 10-18 Bldg Classroom 18	Manual	8/13/2025 10:18:32 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-053 129	Rooms 10-18 Bldg Cust Strg by Rm 13	Manual	8/13/2025 10:02:36 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-041 133	Rooms 10-18 Bldg Girls RR by Library	Manual	8/13/2025 10:23:04 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-070 127	Rooms 10-18 Bldg Girls RR by Room 14	Manual	8/13/2025 10:03:36 AM
		Functional Inspection	Passed	
Manual Pull Station	2-153 089	Rooms 10-18 Bldg Hall by Classroom 13	Manual	8/13/2025 10:02:47 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-054 126	Rooms 10-18 Bldg Hall by Classroom 14	Manual	8/13/2025 10:02:40 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-055 125	Rooms 10-18 Bldg Hall by Classroom 15	Manual	8/13/2025 10:21:01 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-056 124	Rooms 10-18 Bldg Hall by Classroom 16	Manual	8/13/2025 10:20:31 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-057 123	Rooms 10-18 Bldg Hall by Classroom 17	Manual	8/13/2025 10:20:10 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-058 122	Rooms 10-18 Bldg Hall by Classroom 18	Manual	8/13/2025 10:19:50 AM
		Functional Inspection	Passed	
Manual Pull Station	2-159 084	Rooms 10-18 Bldg Hall by Classroom 18	Manual	8/13/2025 9:50:38 AM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2-134 083	Rooms 10-18 Bldg Library	Manual	8/13/2025 10:30:38 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-034 096	Rooms 10-18 Bldg Library	Manual	8/13/2025 10:25:19 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-035 097	Rooms 10-18 Bldg Library	Manual	8/13/2025 10:27:06 AM
		Functional Inspection	Passed	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-037 098	Rooms 10-18 Bldg Library	Manual	8/13/2025 10:27:25 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-036 099	Rooms 10-18 Bldg Library	Manual	8/13/2025 10:28:31 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-039 102	Rooms 10-18 Bldg Library Storage	Manual	8/13/2025 11:05:20 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-038 101	Rooms 10-18 Bldg Library Storage	Manual	8/13/2025 11:05:24 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-040 103	Rooms 10-18 Bldg Library Storage	Manual	8/13/2025 11:05:25 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-131 134	Rooms 10-18 Bldg Outside HVAC Library	Manual	8/13/2025 11:22:42 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 135	Rooms 10-18 Bldg Outside HVAC Rm 10	Manual	8/13/2025 11:07:31 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-145 136	Rooms 10-18 Bldg Outside HVAC Rm 11	Manual	8/13/2025 11:22:30 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 137	Rooms 10-18 Bldg Outside HVAC Rm 12	Manual	8/13/2025 11:22:32 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-147 138	Rooms 10-18 Bldg Outside HVAC Rm 13	Manual	8/13/2025 11:22:33 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 139	Rooms 10-18 Bldg Outside HVAC Rm 14	Manual	8/13/2025 11:22:24 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-385 140	Rooms 10-18 Bldg Outside HVAC Rm 15	Manual	8/13/2025 11:22:26 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 141	Rooms 10-18 Bldg Outside HVAC Rm 16	Manual	8/13/2025 11:06:43 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-387 142	Rooms 10-18 Bldg Outside HVAC Rm 17	Manual	8/13/2025 11:22:28 AM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 143	Rooms 10-18 Bldg Outside HVAC Rm 18	Manual	8/13/2025 11:22:29 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-071 131	Rooms 10-18 Bldg P.E. Coach's Office	Manual	8/13/2025 11:07:52 AM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-160 095	Rooms 10-18 Bldg P.E. Coach's Office	Manual	8/13/2025 11:00:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-069 128	Rooms 10-18 Bldg PE Strg by Room 14	Manual	8/13/2025 11:07:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 100	Rooms 10-18 Bldg Storage by Room 10	Manual	8/13/2025 10:55:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032	Rooms 1-9 Bldg Admin	Manual	8/13/2025 9:31:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 020	Rooms 1-9 Bldg Admin Electrical Rm	Manual	8/13/2025 10:19:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-074 021	Rooms 1-9 Bldg Admin Hall	Manual	8/13/2025 9:16:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-073 023	Rooms 1-9 Bldg Admin MDF Room	Manual	8/13/2025 9:17:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-148 003	Rooms 1-9 Bldg Admin MDF Room	Manual	8/13/2025 9:19:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 018	Rooms 1-9 Bldg Admin Nurses Office	Manual	8/13/2025 10:19:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-126 002	Rooms 1-9 Bldg Admin Office	Manual	8/13/2025 10:21:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 016	Rooms 1-9 Bldg Admin Office	Manual	8/13/2025 10:19:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-135 004	Rooms 1-9 Bldg Admin Principals Off	Manual	8/13/2025 10:20:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 017	Rooms 1-9 Bldg Admin Principals Off	Manual	8/13/2025 10:18:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-031 022	Rooms 1-9 Bldg Admin Restroom	Manual	8/13/2025 9:15:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 019	Rooms 1-9 Bldg Admin Storage Room	Manual	8/13/2025 10:21:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-011 050	Rooms 1-9 Bldg Boys RR by Room 5	Manual	8/13/2025 11:07:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-001 024	Rooms 1-9 Bldg Classroom 1	Manual	8/13/2025 9:46:33 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-002 025	Rooms 1-9 Bldg Classroom 1	Manual	8/13/2025 9:46:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-167 006	Rooms 1-9 Bldg Classroom 1	Manual	8/13/2025 9:47:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 026	Rooms 1-9 Bldg Classroom 2	Manual	8/13/2025 9:22:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-004 027	Rooms 1-9 Bldg Classroom 2	Manual	8/13/2025 9:22:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-169 007	Rooms 1-9 Bldg Classroom 2	Manual	8/13/2025 9:42:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-005 028	Rooms 1-9 Bldg Classroom 3	Manual	8/13/2025 9:37:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-006 029	Rooms 1-9 Bldg Classroom 3	Manual	8/13/2025 9:38:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-170 008	Rooms 1-9 Bldg Classroom 3	Manual	8/13/2025 9:38:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-007 030	Rooms 1-9 Bldg Classroom 4	Manual	8/13/2025 9:30:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-008 031	Rooms 1-9 Bldg Classroom 4	Manual	8/13/2025 9:30:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-171 009	Rooms 1-9 Bldg Classroom 4	Manual	8/13/2025 9:34:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-009 032	Rooms 1-9 Bldg Classroom 5	Manual	8/13/2025 9:25:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-010 033	Rooms 1-9 Bldg Classroom 5	Manual	8/13/2025 9:26:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-172 010	Rooms 1-9 Bldg Classroom 5	Manual	8/13/2025 9:36:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-024 034	Rooms 1-9 Bldg Classroom 6	Manual	8/13/2025 9:27:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-025 035	Rooms 1-9 Bldg Classroom 6	Manual	8/13/2025 9:27:56 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Manual Pull Station	2-174 012	Rooms 1-9 Bldg Classroom 6	Manual	8/13/2025 9:35:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-022 036	Rooms 1-9 Bldg Classroom 7	Manual	8/13/2025 9:31:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-023 037	Rooms 1-9 Bldg Classroom 7	Manual	8/13/2025 9:31:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-175 013	Rooms 1-9 Bldg Classroom 7	Manual	8/13/2025 9:32:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-020 038	Rooms 1-9 Bldg Classroom 8	Manual	8/13/2025 9:39:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-021 039	Rooms 1-9 Bldg Classroom 8	Manual	8/13/2025 9:40:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-176 014	Rooms 1-9 Bldg Classroom 8	Manual	8/13/2025 9:41:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-018 040	Rooms 1-9 Bldg Classroom 9	Manual	8/13/2025 9:43:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-019 041	Rooms 1-9 Bldg Classroom 9	Manual	8/13/2025 9:44:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-177 015	Rooms 1-9 Bldg Classroom 9	Manual	8/13/2025 9:45:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-012 049	Rooms 1-9 Bldg Cust Strg by Rm 5	Manual	8/13/2025 11:07:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-027 047	Rooms 1-9 Bldg Girls RR by Room 6	Manual	8/13/2025 11:07:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-017 042	Rooms 1-9 Bldg Hall by Classroom 1	Manual	8/13/2025 9:21:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-168 005	Rooms 1-9 Bldg Hall by Classroom 1	Manual	8/13/2025 9:48:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-016 043	Rooms 1-9 Bldg Hall by Classroom 2	Manual	8/13/2025 9:21:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-015 044	Rooms 1-9 Bldg Hall by Classroom 3	Manual	8/13/2025 9:23:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-014 045	Rooms 1-9 Bldg Hall by Classroom 4	Manual	8/13/2025 9:24:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-013 046	Rooms 1-9 Bldg Hall by Classroom 5	Manual	8/13/2025 9:24:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-173 011	Rooms 1-9 Bldg Hall by Classroom 5	Manual	8/13/2025 9:28:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 051	Rooms 1-9 Bldg Outside HVAC Rm 1	Manual	8/13/2025 11:22:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 052	Rooms 1-9 Bldg Outside HVAC Rm 2	Manual	8/13/2025 11:22:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 053	Rooms 1-9 Bldg Outside HVAC Rm 3	Manual	8/13/2025 11:22:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 054	Rooms 1-9 Bldg Outside HVAC Rm 4	Manual	8/13/2025 11:22:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 055	Rooms 1-9 Bldg Outside HVAC Rm 5	Manual	8/13/2025 11:22:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 056	Rooms 1-9 Bldg Outside HVAC Rm 6	Manual	8/13/2025 11:22:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 057	Rooms 1-9 Bldg Outside HVAC Rm 7	Manual	8/13/2025 11:22:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 058	Rooms 1-9 Bldg Outside HVAC Rm 8	Manual	8/13/2025 11:22:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 059	Rooms 1-9 Bldg Outside HVAC Rm 9	Manual	8/13/2025 11:22:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-026 048	Rooms 1-9 Bldg PE Storage by Rm 6	Manual	8/13/2025 11:07:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-178 228	Multi-Purpose Bldg Parent Resource Ctr	Manual	8/13/2025 11:00:48 AM
Heat Detector - Restorable Spot	2-382 193	Portables Attic Classroom 24	Manual	8/13/2025 11:08:02 AM
Heat Detector - Restorable Spot	2-382 192	Portables Attic Classroom 24	Manual	8/13/2025 11:08:06 AM
Heat Detector - Restorable Spot	2-382 191	Portables Attic Classroom 24	Manual	8/13/2025 11:08:10 AM

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
060	Rooms 1-9 Bldg North Exterior				
061	Rooms 1-9 Bldg South Exterior				
062	Rooms 1-9 Bldg West Exterior				
144	Rooms 10-18 Bldg North Exterior				
145	Rooms 10-18 Bldg East Exterior				
146	Rooms 10-18 Bldg West Exterior				
194	Portables North Exterior				
195	Portables East Exterior				
196	Portables South Exterior				
197	Portables South Exterior				
217	Kindergarten Bldg North Exterior				
218	Kindergarten Bldg East Exterior				
254	Multi-Purpose Bldg East Exterior				
255	Multi-Purpose Bldg West Exterior				
256	Multi-Purpose Bldg West Exterior				
Audible And Visible					
063	Rooms 1-9 Bldg Admin MDF Room				
064	Rooms 1-9 Bldg Classroom 1				
065	Rooms 1-9 Bldg Classroom 2				
066	Rooms 1-9 Bldg Classroom 3				
067	Rooms 1-9 Bldg Classroom 4				
068	Rooms 1-9 Bldg Classroom 5				
069	Rooms 1-9 Bldg Classroom 6				
070	Rooms 1-9 Bldg Classroom 7				
071	Rooms 1-9 Bldg Classroom 8				
072	Rooms 1-9 Bldg Classroom 9				
073	Rooms 1-9 Bldg Hall by Classroom 1				
074	Rooms 1-9 Bldg Hall by Classroom 3				
075	Rooms 1-9 Bldg Hall by Classroom 5				
147	Rooms 10-18 Bldg Library				
148	Rooms 10-18 Bldg Library Storage				
149	Rooms 10-18 Bldg Classroom 10				
150	Rooms 10-18 Bldg Classroom 11				
151	Rooms 10-18 Bldg Classroom 12				
152	Rooms 10-18 Bldg Classroom 13				
153	Rooms 10-18 Bldg Classroom 14				
154	Rooms 10-18 Bldg Classroom 15				
155	Rooms 10-18 Bldg Classroom 16				
156	Rooms 10-18 Bldg Classroom 17				
157	Rooms 10-18 Bldg Classroom 18				
198	Portables Classroom 19				
199	Portables Classroom 20				
200	Portables Classroom 21				
201	Portables Classroom 22				
202	Portables Classroom 23				
203	Portables Classroom 24				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
219	Kindergarten Bldg Room K-A				
220	Kindergarten Bldg Room K-B				
257	Multi-Purpose Bldg Kitchen Hall				
258	Multi-Purpose Bldg Kitchen Hall				
259	Multi-Purpose Bldg Kitchen				
260	Multi-Purpose Bldg Kitchen				
261	Multi-Purpose Bldg Parent Resource Ctr				
262	Multi-Purpose Bldg Stage				
263	Multi-Purpose Bldg Custodial Office				
Visible					
076	Rooms 1-9 Bldg Admin Office				
077	Rooms 1-9 Bldg Admin Principals Off				
078	Rooms 1-9 Bldg Admin Nurses Office				
079	Rooms 1-9 Bldg Admin Storage Room				
080	Rooms 1-9 Bldg Admin Restroom				
081	Rooms 1-9 Bldg Boys RR by Room 5				
082	Rooms 1-9 Bldg Girls RR by Room 6				
158	Rooms 10-18 Bldg Girls RR by Room 14				
159	Rooms 10-18 Bldg Boys RR by Room 13				
160	Rooms 10-18 Bldg Boys RR by Library				
161	Rooms 10-18 Bldg Girls RR by Library				
221	Kindergarten Bldg Room K-A Restroom				
222	Kindergarten Bldg Room K-B Restroom				
223	Kindergarten Bldg Room K-B Restroom				
264	Multi-Purpose Bldg MP Room				
265	Multi-Purpose Bldg MP Room				
266	Multi-Purpose Bldg Restroom Entry				
267	Multi-Purpose Bldg Staff Restroom				
268	Multi-Purpose Bldg Staff Restroom				
269	Multi-Purpose Bldg Stage Stair South				
270	Multi-Purpose Bldg Stage Wheelchr lift				
271	Multi-Purpose Bldg Stage				
272	Multi-Purpose Bldg Stage				
273	Multi-Purpose Bldg Stage Stair North				

Fire Control Panel					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Rooms 1-9 Bldg Admin Office				
Fire Alarm Panel					
	Rooms 1-9 Bldg Admin Electrical Rm	EST		3	
NAC Power Extender Panel					
	Rooms 1-9 Bldg Admin Electrical Rm - P.E. "Master"				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Rooms 1-9 Bldg Admin Electrical Rm - P.E. "F"				
	Rooms 10-18 Bldg Storage by Room 10 - P.E. "E"				
	Multi-Purpose Bldg Custodial Office - P.E. "B"				
	Multi-Purpose Bldg Custodial Office - P.E. "C"				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-126 002	Rooms 1-9 Bldg Admin Office				
2-148 003	Rooms 1-9 Bldg Admin MDF Room				
2-135 004	Rooms 1-9 Bldg Admin Principals Off				
2-168 005	Rooms 1-9 Bldg Hall by Classroom 1				
2-167 006	Rooms 1-9 Bldg Classroom 1				
2-169 007	Rooms 1-9 Bldg Classroom 2				
2-170 008	Rooms 1-9 Bldg Classroom 3				
2-171 009	Rooms 1-9 Bldg Classroom 4				
2-172 010	Rooms 1-9 Bldg Classroom 5				
2-173 011	Rooms 1-9 Bldg Hall by Classroom 5				
2-174 012	Rooms 1-9 Bldg Classroom 6				
2-175 013	Rooms 1-9 Bldg Classroom 7				
2-176 014	Rooms 1-9 Bldg Classroom 8				
2-177 015	Rooms 1-9 Bldg Classroom 9				
2-134 083	Rooms 10-18 Bldg Library				
2-159 084	Rooms 10-18 Bldg Hall by Classroom 18				
2-149 085	Rooms 10-18 Bldg Classroom 10				
2-150 086	Rooms 10-18 Bldg Classroom 11				
2-151 087	Rooms 10-18 Bldg Classroom 12				
2-152 088	Rooms 10-18 Bldg Classroom 13				
2-153 089	Rooms 10-18 Bldg Hall by Classroom 13				
2-154 090	Rooms 10-18 Bldg Classroom 14				
2-155 091	Rooms 10-18 Bldg Classroom 15				
2-156 092	Rooms 10-18 Bldg Classroom 16				
2-157 093	Rooms 10-18 Bldg Classroom 17				
2-158 094	Rooms 10-18 Bldg Classroom 18				
2-160 095	Rooms 10-18 Bldg P.E. Coach's Office				
2-161 162	Portables Classroom 19				
2-162 163	Portables Classroom 20				
2-163 164	Portables Classroom 21				
2-164 165	Portables Classroom 22				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-165 166	Portables Classroom 23				
2-166 167	Portables Classroom 24				
2-185 204	Kindergarten Bldg Room K-A West				
2-184 205	Kindergarten Bldg Room K-A East				
2-187 206	Kindergarten Bldg Room K-B West				
2-186 207	Kindergarten Bldg Room K-B East				
2-182 224	Multi-Purpose Bldg MP Room West				
2-183 225	Multi-Purpose Bldg MP Room North				
2-181 226	Multi-Purpose Bldg Kitchen Hall West				
2-180 227	Multi-Purpose Bldg Kitchen Hall East				
2-178 228	Multi-Purpose Bldg Parent Resource Ctr				
2-179 229	Multi-Purpose Bldg Kitchen				
Smoke Detector - General					
2-029 016	Rooms 1-9 Bldg Admin Office				
2-028 017	Rooms 1-9 Bldg Admin Principals Off				
2-030 018	Rooms 1-9 Bldg Admin Nurses Office				
2-033 019	Rooms 1-9 Bldg Admin Storage Room				
2-072 020	Rooms 1-9 Bldg Admin Electrical Rm				
2-034 096	Rooms 10-18 Bldg Library				
2-035 097	Rooms 10-18 Bldg Library				
2-037 098	Rooms 10-18 Bldg Library				
2-036 099	Rooms 10-18 Bldg Library				
2-043 100	Rooms 10-18 Bldg Storage by Room 10				
2-288 168	Portables Classroom 21				
2-289 169	Portables Classroom 21				
2-282 170	Portables Classroom 22				
2-283 171	Portables Classroom 22				
2-287 172	Portables Classroom 23				
2-286 173	Portables Classroom 23				
2-284 174	Portables Classroom 24				
2-285 175	Portables Classroom 24				
2-252 208	Kindergarten Bldg Room K-A				
2-251 209	Kindergarten Bldg Room K-A				
2-256 210	Kindergarten Bldg Room K-B				
2-257 211	Kindergarten Bldg Room K-B				
2-263 230	Multi-Purpose Bldg MP Room				
2-268 231	Multi-Purpose Bldg MP Room				
2-271 232	Multi-Purpose Bldg MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-270 233	Multi-Purpose Bldg MP Room				
2-267 234	Multi-Purpose Bldg MP Room				
2-262 235	Multi-Purpose Bldg MP Room				
2-261 236	Multi-Purpose Bldg MP Room				
2-266 237	Multi-Purpose Bldg MP Room				
2-269 238	Multi-Purpose Bldg MP Room				
2-258 239	Multi-Purpose Bldg Custodial Office				
2-264 240	Multi-Purpose Bldg Stage				
2-265 241	Multi-Purpose Bldg Stage				
2-274 242	Multi-Purpose Bldg Kitchen Hall				
2-275 243	Multi-Purpose Bldg Kitchen Hall				
2-281 244	Multi-Purpose Bldg Staff Restroom				
2-032	Rooms 1-9 Bldg Admin				
Heat Detector - Restorable Spot					
2-074 021	Rooms 1-9 Bldg Admin Hall				
2-031 022	Rooms 1-9 Bldg Admin Restroom				
2-073 023	Rooms 1-9 Bldg Admin MDF Room				
2-001 024	Rooms 1-9 Bldg Classroom 1				
2-002 025	Rooms 1-9 Bldg Classroom 1				
2-003 026	Rooms 1-9 Bldg Classroom 2				
2-004 027	Rooms 1-9 Bldg Classroom 2				
2-005 028	Rooms 1-9 Bldg Classroom 3				
2-006 029	Rooms 1-9 Bldg Classroom 3				
2-007 030	Rooms 1-9 Bldg Classroom 4				
2-008 031	Rooms 1-9 Bldg Classroom 4				
2-009 032	Rooms 1-9 Bldg Classroom 5				
2-010 033	Rooms 1-9 Bldg Classroom 5				
2-024 034	Rooms 1-9 Bldg Classroom 6				
2-025 035	Rooms 1-9 Bldg Classroom 6				
2-022 036	Rooms 1-9 Bldg Classroom 7				
2-023 037	Rooms 1-9 Bldg Classroom 7				
2-020 038	Rooms 1-9 Bldg Classroom 8				
2-021 039	Rooms 1-9 Bldg Classroom 8				
2-018 040	Rooms 1-9 Bldg Classroom 9				
2-019 041	Rooms 1-9 Bldg Classroom 9				
2-017 042	Rooms 1-9 Bldg Hall by Classroom 1				
2-016 043	Rooms 1-9 Bldg Hall by Classroom 2				
2-015 044	Rooms 1-9 Bldg Hall by Classroom 3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-014 045	Rooms 1-9 Bldg Hall by Classroom 4				
2-013 046	Rooms 1-9 Bldg Hall by Classroom 5				
2-027 047	Rooms 1-9 Bldg Girls RR by Room 6				
2-026 048	Rooms 1-9 Bldg PE Storage by Rm 6				
2-012 049	Rooms 1-9 Bldg Cust Strg by Rm 5				
2-011 050	Rooms 1-9 Bldg Boys RR by Room 5				
2-130 051	Rooms 1-9 Bldg Outside HVAC Rm 1				
2-136 052	Rooms 1-9 Bldg Outside HVAC Rm 2				
2-137 053	Rooms 1-9 Bldg Outside HVAC Rm 3				
2-138 054	Rooms 1-9 Bldg Outside HVAC Rm 4				
2-139 055	Rooms 1-9 Bldg Outside HVAC Rm 5				
2-140 056	Rooms 1-9 Bldg Outside HVAC Rm 6				
2-141 057	Rooms 1-9 Bldg Outside HVAC Rm 7				
2-142 058	Rooms 1-9 Bldg Outside HVAC Rm 8				
2-143 059	Rooms 1-9 Bldg Outside HVAC Rm 9				
2-038 101	Rooms 10-18 Bldg Library Storage				
2-039 102	Rooms 10-18 Bldg Library Storage				
2-040 103	Rooms 10-18 Bldg Library Storage				
2-045 104	Rooms 10-18 Bldg Classroom 10				
2-044 105	Rooms 10-18 Bldg Classroom 10				
2-047 106	Rooms 10-18 Bldg Classroom 11				
2-046 107	Rooms 10-18 Bldg Classroom 11				
2-049 108	Rooms 10-18 Bldg Classroom 12				
2-048 109	Rooms 10-18 Bldg Classroom 12				
2-051 110	Rooms 10-18 Bldg Classroom 13				
2-050 111	Rooms 10-18 Bldg Classroom 13				
2-067 112	Rooms 10-18 Bldg Classroom 14				
2-068 113	Rooms 10-18 Bldg Classroom 14				
2-065 114	Rooms 10-18 Bldg Classroom 15				
2-066 115	Rooms 10-18 Bldg Classroom 15				
2-063 116	Rooms 10-18 Bldg Classroom 16				
2-064 117	Rooms 10-18 Bldg Classroom 16				
2-061 118	Rooms 10-18 Bldg Classroom 17				
2-062 119	Rooms 10-18 Bldg Classroom 17				
2-059 120	Rooms 10-18 Bldg Classroom 18				
2-060 121	Rooms 10-18 Bldg Classroom 18				
2-058 122	Rooms 10-18 Bldg Hall by Classroom 18				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-057 123	Rooms 10-18 Bldg Hall by Classroom 17				
2-056 124	Rooms 10-18 Bldg Hall by Classroom 16				
2-055 125	Rooms 10-18 Bldg Hall by Classroom 15				
2-054 126	Rooms 10-18 Bldg Hall by Classroom 14				
2-070 127	Rooms 10-18 Bldg Girls RR by Room 14				
2-069 128	Rooms 10-18 Bldg PE Strg by Room 14				
2-053 129	Rooms 10-18 Bldg Cust Strg by Rm 13				
2-052 130	Rooms 10-18 Bldg Boys RR by Room 13				
2-071 131	Rooms 10-18 Bldg P.E. Coach's Office				
2-042 132	Rooms 10-18 Bldg Boys RR by Library				
2-041 133	Rooms 10-18 Bldg Girls RR by Library				
2-131 134	Rooms 10-18 Bldg Outside HVAC Library				
2-144 135	Rooms 10-18 Bldg Outside HVAC Rm 10				
2-145 136	Rooms 10-18 Bldg Outside HVAC Rm 11				
2-146 137	Rooms 10-18 Bldg Outside HVAC Rm 12				
2-147 138	Rooms 10-18 Bldg Outside HVAC Rm 13				
2-384 139	Rooms 10-18 Bldg Outside HVAC Rm 14				
2-385 140	Rooms 10-18 Bldg Outside HVAC Rm 15				
2-386 141	Rooms 10-18 Bldg Outside HVAC Rm 16				
2-387 142	Rooms 10-18 Bldg Outside HVAC Rm 17				
2-388 143	Rooms 10-18 Bldg Outside HVAC Rm 18				
2-281 176	Portables Classroom 19				
2-290 177	Portables Classroom 20				
2-379 178	Portables Attic Classroom 19				
2-379 179	Portables Attic Classroom 19				
2-379 180	Portables Attic Classroom 19				
2-378 181	Portables Attic Classroom 20				
2-378 182	Portables Attic Classroom 20				
2-378 183	Portables Attic Classroom 20				
2-377 184	Portables Attic Classroom 21				
2-377 185	Portables Attic Classroom 21				
2-380 186	Portables Attic Classroom 22				
2-380 187	Portables Attic Classroom 22				
2-381 188	Portables Attic Classroom 23				
2-381 189	Portables Attic Classroom 23				
2-381 190	Portables Attic Classroom 23				
2-382 191	Portables Attic Classroom 24				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-382 192	Portables Attic Classroom 24				
2-382 193	Portables Attic Classroom 24				
2-253 212	Kindergarten Bldg Room K-A Restroom				
2-255 213	Kindergarten Bldg Room K-B Restroom				
2-254 214	Kindergarten Bldg Room K-B Restroom				
2-376 215	Kindergarten Bldg HVAC Closet Rm K-A				
2-376 216	Kindergarten Bldg HVAC Closet Rm K-B				
2-259 245	Multi-Purpose Bldg Stage Stair North				
2-272 246	Multi-Purpose Bldg Stage Stair South				
2-277 247	Multi-Purpose Bldg Parent Resource Ctr				
2-280 248	Multi-Purpose Bldg Restroom Entry				
2-278 249	Multi-Purpose Bldg Staff Restroom				
2-276 250	Multi-Purpose Bldg Kitchen				
2-279 251	Multi-Purpose Bldg Kitchen Storage				
2-260 252	Multi-Purpose Bldg Outside Storage N				
2-273 253	Multi-Purpose Bldg Outside Storage S				